g		GE Energy		Functional T	esting Sp	ecification		
	Parts & Repair Services Louisville, KY			LOU-GED-DS3800NATA				
	Test Procedure for an Attenuator board.							
	MENT REVISION STATUS	: Determined by the last ent	try in the "REV" and					
REV.		DESCRIPTION			GNATURE	REV. DATE		
Α	Initial release			J	. Hardin	5-31-2011		
В								
С								
Hard co	YRIGHT GENERAL ELECT pies are uncontrolled and are IETARY INFORMATION –		5 PROPRIETARY INF	FORMATION OF GENE	RAL ELECTRIC	COMPANY AND		
PREPA	ARED BY	ED TO OTHERS, EXCEPT WIT	TH THE WRITTEN PER PROPERTY OF THE PROPERTY OF		QUALITY AP	PROVAL		
J. Har DATE 5-31-2		DATE	DATE		Charlie We DATE 6/10/2011	ade		

LOU-GED-DS3800NATA REV. A	GE Energy Parts & Repair Services	Page 2 of 3
	Louisville, KY	

1. SCOPE

1.1 This is a functional testing procedure for a Card.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - 4.2.1.1 Wires broken, cracked, or loosely connected
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - 4.2.1.3 Components visually damaged
 - **4.2.1.4** Capacitors bloated or leaking
 - 4.2.1.5 Solder joints damaged or cold
 - 4.2.1.6 Circuit board burned or de-laminated
 - 4.2.1.7 Printed wire runs / Traces burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)

LOU-GED-DS3800NATA
REV. A

GE Energy
Parts & Repair Services
Louis ville, KY

Page 3 of 3

6. Testing Procedure

6.1 Test the following points, +/- 5%.

ТО	FROM	Value +/- 5%	TO	FROM	Value +/- 5%
JA1	JG4	1.5M	JD4	E21	500K
JA1	E6	500K	JD4	E20	750K
JA1	E5	750K	JD4	E19	1M
JA1	E4	1M	JD4	E18	1.25M
JA1	E3	1.25M	JD4	E17	1.5M
JA1	E2	1.5M	JE1	JG7	1.5M
JB2	JG3	1.5M	JE1	E26	500K
JB2	E11	500K	JE1	E25	750K
JB2	E10	750K	JE1	E24	1M
JB2	E9	1M	JE1	E23	1.25M
JB2	E8	1.25M	JE1	E22	1.5M
JB2	E7	1.5M	JF2	JG5	1.5M
JC3	JG6	1.5M	JF2	E31	500K
JC3	E16	500K	JF2	E30	750K
JC3	E15	750K	JF2	E29	1M
JC3	E14	1M	JF2	E28	1.25M
JC3	E13	1.25M	JF2	E27	1.5M
JC3	E12	1.5M	E1	JG9	0
JD4	JG8	1.5M	E1	JG2	0

6.2 ***TEST COMPLETE ***

7. NOTES

7.1 None at this time.

8. ATTACHMENTS

8.1 None at this time.