



GE Energy

Functional Testing Specification

Parts & Repair Services
Louisville, KY

LOU-UTS-IS200STTCH2A

Test Procedure for IS200STTCH2A card tested on the UTS Test System

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Paul Kelley	8/17/2012
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Paul Kelley	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 8/17/2012	DATE	DATE	DATE 8/17/2012

<p>LOU-UTS-IS200STTCH2A REV. A</p>	<p>g</p> <p>GE Energy Part & Repair Services Louisville, KY</p>	<p>Page 2 of 3</p>
-----------------------------------------------	-------------------------------------------------------------------------------------------	---------------------------

Test Procedure for IS200STTCH2A card tested on the UTS Test System

1. SCOPE

1.1 This is a functional testing procedure for the UTS3000 Tester

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires broken or cracked

4.2.1.2 Terminal strips / connectors broken or cracked

4.2.1.3 Loose wires

4.2.1.4 Components visually damaged

4.2.1.5 Capacitors leaking

4.2.1.6 Solder joints damaged or cold

4.2.1.7 Circuit board burned or de-laminated

4.2.1.8 Printed wire runs burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1	H188701	UTS3000 Tester
1	H188987	IS200STTC Fixture

<p>LOU-UTS-IS200STTCH2A REV. A</p>	<p>g</p> <p>GE Energy <i>Part & Repair Services Louisville, KY</i></p>	<p>Page 3 of 3</p>
-----------------------------------------------	--------------------------------------------------------------------------------------------------	---------------------------

6. TESTING PROCESS

6.1 Setup

6.1.1 As required by UTS3000 instructions.

6.2 Testing Procedure

6.2.1 Identify the test to be used on the UTS3000 by matching the model number with the ones on the system and follow the instructions given after execution.

6.3 *TEST COMPLETE*****

7. NOTES

7.1 None at this time.

8. Attachments

8.1 None at this time.