



GE Energy

## Functional Testing Specification

*Parts & Repair Services  
Louisville, KY*

**LOU-GED-531X129SNCADG1**

### Test Procedure for a snubber card

**DOCUMENT REVISION STATUS:** Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	J. Hardin	3/10/2010
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

<b>PREPARED BY</b> Jill Hardin	<b>REVIEWED BY</b>	<b>REVIEWED BY</b>	<b>QUALITY APPROVAL</b> Charlie Wade
<b>DATE</b> 3/10/2010	<b>DATE</b>	<b>DATE</b>	<b>DATE</b> 3/10/2010

<p>LOU-GED-531X129SNCADG1 REV. A</p>	<p><b>g</b></p> <p><b>GE Energy</b> Parts &amp; Repair Services Louisville, KY</p>	<p>Page 2 of 3</p>
--	--	--------------------

## 1. SCOPE

1.1 This is a functional testing procedure for a snubber card.

## 2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

## 3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Filename; 129snc.doc located in electronic folder.

## 4. ENGINEERING REQUIREMENTS

### 4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

### 4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

## 5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)

LOU-GED-531X129SNCADG1 REV. A	<div data-bbox="548 205 581 254" data-label="Image"></div> <div data-bbox="737 258 980 333" data-label="Text"> <p><b>GE Energy</b> Parts &amp; Repair Services Louisville, KY</p> </div>	Page 3 of 3
----------------------------------	--	-------------

## 6. TESTING PROCESS

### 6.1 Testing Procedure

- 6.1.1 Verify that C1, C2, C3 and C4 are .47uf 1000V capacitors (104X122AA244). Verify that they are securely tie-wrapped to the board.
- 6.1.2 Verify that R3, R4 and R5 are FS-205-5 NI (5%) or equivalent (104X123DA075) resistors.
- 6.1.3 Verify that R1 and R2 are 0.1 ohm 10% 20W NI or equivalent (104X123DA076) resistors. They can also consist of (3) .27-ohm PW5 resistors soldered in parallel.
- 6.1.4 Verify that D1, D2, D3, D4, D5, D6, D7 and D8 are SRP600K or equivalent (104X125AA159) diodes, that they are assembled per the top stamp and using an ohmmeter with a diode testing scale, verify that they are not shorted.
- 6.1.5 Verify that P1-T stab-on (104X161AC103) is present
- 6.1.6 Verify that wire jumpers J1 and J2 are present and correctly soldered
- 6.1.7 Verify that all four buss bar connectors (E2, C2, C1 and E1) (44B962815002) are present and correctly soldered.
- 6.1.8 Verify that all parts are mounted against the board
- 6.1.9 Verify that all parts are soldered to the board and that no bridges exist between the etchings.

### 6.2 \*\*\*TEST COMPLETE\*\*\*

## 7. NOTES

- 7.1 None at this time.

## 8. ATTACHMENTS

- 8.1 None at this time.