



GE Energy

Functional Testing Specification

*Parts & Repair Services
Louisville, KY*

LOU-GED-IS230STTC Rev. A

Test Procedure for an IS230STTCxxxx Thermocouple Assembly.

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	J. Francis	06/25/2018
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY J. Francis	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL
DATE 06/25/2018	DATE	DATE	DATE

<p>LOU-GED-IS230STTC Rev A</p>	<p style="text-align: center;">g</p> <p style="text-align: center;">GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 2 of 3</p>
--	---	---------------------------

1. SCOPE

1.1 This is a functional testing procedure for an **IS230STTCxxxx Thermocouple** assembly.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information.

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		TOFFEE Test System

<p>LOU-GED-IS230STTC Rev A</p>	<p style="text-align: center;">g</p> <p style="text-align: center;">GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 3 of 3</p>
--	---	---------------------------

6. TESTING PROCESS

6.1 Testing Procedure



Note: This procedure will be for an entire *IS230STCIHxA* assembly. The assembly will be broken down to individually test each sub-assembly separately using its assigned test. The test procedure will be listed for each sub-assembly.

6.1.1 Remove the **IS200STTC** cards and test using test procedure LOU-GED-IS200STTCH2-A, referring to Models Database for latest revision of test procedure.

6.1.2 Remove the **IS220PTCC** PAC Modules and test using test procedure LOU-TOFFEE-IS220PTCC-B, referring to Models Database for latest revision of test procedure.

6.2 ***TEST COMPLETE***

7. NOTES

7.1 None at this time.

8. ATTACHMENTS

8.1 None at this time.