| g | | GE Energy | Functi | onal Testing S _l | pecification | | |
|--|---------------------|-------------|-------------|-----------------------------|--------------|--|--|
| Parts & Repair Services Louisville, KY | | | | LOU-GED-DS3800NFCE | | | |
| Test Procedure for a DS3800NFCE Card | | | | | | | |
| DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column | | | | | | | |
| REV. | Initial Dalagae | DESCRIPTION | | SIGNATURE | REV. DATE | | |
| Α | Initial Release | | | J. Francis | 02/05/2010 | | |
| В | | | | | | | |
| С | | | | | | | |
| | | | | | | | |
| © COPYRIGHT GENERAL ELECTRIC COMPANY Hard copies are uncontrolled and are for reference only. PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY. | | | | | | | |
| James | RED BY s Francis | REVIEWED BY | REVIEWED BY | QUALITY A Charlie W | | | |
| 02/05/ | /2010 | DATE | DATE | DATE 2/8/2010 | | | |

g GE Energy Parts & Repair Services Louisville, KY LOU-GED-DS3800NFCE Page 2 of 38 REV. A

| | g | |
|--------------------|-------------------------|--------------|
| LOU-GED-DS3800NFCE | GE Energy | Page 3 of 38 |
| REV. A | Parts & Repair Services | |
| | Louisville, KY | |

1. SCOPE

1.1 This is a functional testing procedure for a DS3800NFCExxx.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- 4.2 Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - **4.2.1.1** Wires broken, cracked, or loosely connected
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - **4.2.1.3** Components visually damaged
 - 4.2.1.4 Capacitors bloated or leaking
 - 4.2.1.5 Solder joints damaged or cold
 - 4.2.1.6 Circuit board burned or de-laminated
 - 4.2.1.7 Printed wire runs / Traces burned or damaged

5. **EQUIPMENT REQUIRED**

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

| Qty | Reference # | Description |
|-----|----------------|------------------------------------|
| 2 | * | Fluke 85 DMM (or Equivalent) |
| 2 | * | Tenma Laboratory DC Power Supplies |
| 1 | H188853 | DS3800 Test Box |
| 2 | * | Rainbow Box |
| 1 | * | Tenma Function Generator |
| 1 | H188840 | DS3800DFCA Daughter Card |
| 1 | * | Tektronics TBS 2012B O-Scope |

^{*} Any equipment of same type will suffice.

GE Energy
Parts & Repair Services
Louisville, KY

LOU-GED-DS3800NFCE REV. A

6. TESTING PROCESS

6.1 Setup



Note: If any circuit fails during testing process, repair the malfunctioning circuit, retest, and then continue with test.

- **6.1.1** Remove existing proms from sockets U68 and U21.Verfiy both chips have correct checksum results. U68 checksum = 00028230, Device part # 82S181. U20 checksum = 00039C3B, Device part # 82S181. Replaced verified good proms into appropriate sockets.
- **6.1.2** Attach DS3800NFCE Unit Under Test (**UUT**) to DS3800NFCE Test Box, component side up.
- **6.1.3** Attach JA Cable to JA plug on UUT.
- **6.1.4** Connect +5 VDC to red connector on DS3800 Test Box.
- **6.1.5** Connect +5 VDC return to black power connector on DS3800 Test Box. For the remainder of this testing process, "black power connector on DS3800 Test Box" will be referred to as **(-) common**.
- **6.1.6** Connect +15 VDC to yellow power connector on DS3800 Test Box.
- **6.1.7** Connect +15 VDC return to black power connector on DS3800 Test Box.
- **6.1.8** Connect –15 VDC to green power connector on DS3800 Test Box.
- **6.1.9** Connect –15 VDC return to black power connector on DS3800 Test Box.
- **6.1.10** Connect 1st Rainbow Box to PBA connector on DS3800 Test Box.
- **6.1.11** Connect 2nd Rainbow Box to PBB connector on DS3800 Test Box.
- **6.1.12** Attach DS3800DFCA Daughter Card.
- **6.1.13** Adjust R85, R168, and R46 on the DS3800DFCA Daughter Card fully counterclockwise.
- **6.1.14** Adjust R49 on the DS3800DFCA Daughter Card Clockwise.
- **6.1.15** Adjust R155 on the DS3800NFCE Card fully clockwise.
- **6.1.16** Attach 6 12K Ohm 2 Watt resistors to the standoffs at the top of the Rainbow Box.
- **6.1.17** Connect pin 81 of Rainbow Box to the black post of first 12K Ohm resistor.
- **6.1.18** Connect pin 82 of Rainbow Box to the black post of second 12K Ohm resistor.
- 6.1.19 Connect pin 83 of Rainbow Box to the black post of third 12K Ohm resistor.
- **6.1.20** Connect pin 84 of Rainbow Box to the black post of fourth 12K Ohm resistor.
- **6.1.21** Connect pin 85 of Rainbow Box to the black post of fifth 12K Ohm resistor.
- **6.1.22** Connect pin 86 of Rainbow Box to the black post of sixth 12K Ohm resistor.
- **6.1.23** Connect all 6 red posts of the 12K Ohm resistors together in parallel.

LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 5 of 38

- **6.1.24** Connect + 28 VDC to the orange power connector on DS3800 Test Box.
- **6.1.25** Connect +28 VDC to the red posts of all 12K Ohm resistors.
- **6.1.26** Connect 28 VDC return to the black power connector on the DS3800 Test Box.
- **6.1.27** Jumper PB-4 to PB-8 and jumper PB-6 to PB-10.
- **6.1.28** Apply power to unit, watching lights as unit powers up. IMOK, SUP, and PLL lights should all come on, and PLL light should go out after approximately 1 second.
- 6.1.29 Set O-Scope for 2 V/Div and 10 mSec time/Div.
- **6.1.30** Apply 2 VRMS @ 60 Hz to PB-8 and PB-10 from the Function Generator.
- **6.1.31** Connect 1st channel of O-Scope to PB-70. Check for square wave of the same frequency as the input frequency at 4 Volts with approximately 50 % duty cycle as follows:




- 6.1.32
- **6.1.33** Apply 2 VRMS @ 55 Hz to PB-8 and PB-10 from the Function Generator.
- **6.1.34** Connect negative Multimeter lead to (-) common.
- 6.1.35 Connect positive Multimeter lead to TP11 (VCO). Set Multimeter to read DC Volts.
- **6.1.36** Adjust Potentiometer R184 to 2.5 VDC -/+ .1 VDC at TP11 (VCO). Apply Torque Seal to Pot R184 when complete.
- **6.1.37** Disconnect Multimeter positive lead from TP11 (VCO).

6.1.39

GE Energy Parts & Repair Services Louisville, KY


Page 6 of 38

6.1.38 Using 1st channel of O-Scope, check PA-61 for square wave approximately 4 V @ 330 Hz, to verify switching is occurring as follows:



g

6.1.40 Using 1st channel of O-Scope, check PB-20 for square wave approximately 4 V @ 165 Hz, to verify switching is occurring as follows:



6.1.43

GE Energy Parts & Repair Services Louisville, KY


Page 7 of 38

6.1.42 Using 1st channel of O-Scope, check PB-13 for square wave approximately 4 V @ 55 Hz, to verify switching is occurring as follows:



g

6.1.44 Using 1st channel of O-Scope, check PB-18 for square wave approximately 4 V @ 55 Hz, to verify switching is occurring as follows:




g

GE EnergyParts & Repair Services
Louisville, KY

Page 8 of 38

6.1.46 Using 1st channel of O-Scope, check PB-70 for square wave approximately 4 V @ 55 Hz, to verify switching is occurring as follows:




- 6.1.47
- **6.1.48** Using 1st channel of O-Scope, check PB-71 for square wave approximately 4 V @ 55 Hz, to verify switching is occurring as in step **6.1.47**.
- **6.1.49** Connect 1st channel of O-Scope to PB-72. Should display logic low.
- **6.1.50** Momentarily connect PA-76 to (-) common) while observing O-Scope display. When connected the O-Scope should display logic high, and when removed O-Scope should return to logic low.
- **6.1.51** Disconnect 1st channel of O-Scope from PA-71.
- **6.1.52** Disconnect 1st channel of O-Scope from PB-71 and connect to PB-59, should display logic high.
- **6.1.53** Connect right side of R188, located between U42 and U28, to (-) common. PLL light will come on and stay on as long as this connection is made. O-Scope should still be displaying logic high.
- **6.1.54** Connect PA-78 to (-) common. O-Scope should display logic low as long as this connection is made.
- **6.1.55** Disconnect PA-78 from (-) common and O-Scope should display logic high.
- 6.1.56 Disconnect right side of R188 from (-) common. PLL light should go out.
- **6.1.57** Disconnect 1st channel of O-Scope from PB-59.
- **6.1.58** Connect the following points to (-) common: PB-48, PB-58, PB-80, PB-78, PB-36, and PA-76.

g LOU-GED-DS3800NFCE Page 9 of 38 GE Energy REV. A Parts & Repair Services Louisville, KY

6.1.59 Connect 1st channel of O-Scope to PB-76. Set O-Scope for 2 V/Div and 250 nSec/Div. Look for a waveform of approximately 6 Vp-p at a frequency of 2.3 MHz as follows:



- 6.1.60
- 6.1.61 Connect left side of resistor R196, located behind 0V light, to (-) common. PLL light should come on and stay on as long as this connection is made.
- 6.1.62 Disconnect resistor R196. PLL light should go out after approximately 1 second.
- **6.1.63** Connect 1st channel of O-Scope to PB-67 and verify a logic low. Set 1st channel of O-Scope for 200 mV/Div and 2nd channel of O-Scope for 500 mV/Div and 5 mSec/Div.
- 6.1.64 Connect 1st channel of O-Scope PB-70 and 2nd channel of O-Scope, using probe, to U9 pin 6. Verify that channel 2 is twice the frequency as channel 1 as follows:



FCE

GE Energy
Parts & Repair Services
Louisville, KY

Page 10 of 38

LOU-GED-DS3800NFCE REV. A

- **6.1.66** Apply 2 VRMS @ 40 Hz to PB-8 and PB-10 from the Function Generator. PLL light should stay off.
- **6.1.67** Apply 2 VRMS @ 70 Hz to PB-8 and PB-10 from the Function Generator. PLL light should stay off.
- **6.1.68** Apply 2 VRMS @ 60 Hz to PB-8 and PB-10 from the Function Generator. PLL Light should be off.
- 6.1.69 Disconnect both channels of O-Scope.
- **6.1.70** Connect negative Multimeter lead to (-) common.
- 6.1.71 Connect positive Multimeter lead to TP11 (VCO). Set Multimeter to read DC Volts.
- **6.1.72** Apply 2 VRMS @ 40 Hz to PB-8 and PB-10 from the Function Generator. PLL Light should be off. Multimeter should read approximately 2.1 VDC.
- **6.1.73** Apply 2 VRMS @ 30 Hz to PB-8 and PB-10 from the Function Generator. PLL Light should be off. Multimeter should read approximately 1.9 VDC.
- **6.1.74** Apply 2 VRMS @ 15 Hz to PB-8 and PB-10 from the Function Generator. PLL Light should be on. Multimeter should read approximately 1.3 VDC. Note the frequency that the PLL light comes on.
- **6.1.75** Apply 2 VRMS @ 5 Hz to PB-8 and PB-10 from the Function Generator. PLL Light should be on. Multimeter should read 0 VDC.
- **6.1.76** For the next step, note the frequency that the PLL light goes out. The light should go out within 15 Hz of the frequency the light came on.
- **6.1.77** Apply 2 VRMS @ 40 Hz to PB-8 and PB-10 from the Function Generator. PLL Light should be off. Multimeter should read 2.2 VDC.
- **6.1.78** Apply 2 VRMS @ 60 Hz to PB-8 and PB-10 from the Function Generator. PLL Light should be off. Quickly adjust the input frequency from 40 to 70 Hz multiple times. The PLL light should stay of during this test.
- **6.1.79** Disconnect the following points from (-) common: PB-48, PB-58, PB-80, PB-78, PB-36, and PA-76.
- 6.1.80 Connect +8 VDC to PA-24.
- 6.1.81 Connect 8 VDC return to (-) common.
- **6.1.82** Connect PA-48 to (-) common.
- **6.1.83** Connect negative Multimeter lead to (-) common.
- 6.1.84 Connect positive Multimeter lead to TP9 (COS). Set Multimeter to read DC Volts.
- **6.1.85** Attach 16-pin chip clip to U21.

LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 11 of 38

- **6.1.86** Connect U21 pins 5 through 12 to (-) common.
- **6.1.87** Disconnect U21 pin 5 from (-) common and connect U21 pin 5 to +5 VDC red power connector on the DS3800 Test Box.
- **6.1.88** Adjust Potentiometer R155 so Multimeter to reads –0.4 VDC -/+ .025 VDC. Apply Torque Seal to Pot R155 when complete.
- **6.1.89** Disconnect U21 pin 12 from (-) common and connect to +5 VDC red power connector on the DS3800 Test Box. Multimeter should read -0.34 VDC -/+ .07 VDC.
- **6.1.90** Disconnect U21 pin 12 from + 5 VDC red power connector on the DS3800 Test Box and reconnect to (-) common.
- **6.1.91** Disconnect U21 pin 11from (-) common and connect to +5 VDC red power connector on the DS3800 Test Box. Multimeter should read –0.28 VDC -/+ .075 VDC.
- **6.1.92** Disconnect U21 pin 11 from +5 VDC red power connector on the DS3800 Test Box and reconnect to (-) common.
- **6.1.93** Disconnect U21 pin 10 from (-) common and connect to +5 VDC red power connector on the DS3800 Test Box. Multimeter should read -0.15 VDC -/+ .08 VDC.
- **6.1.94** Disconnect U21 pin 10 from +5 VDC red power connector on the DS3800 Test Box and reconnect to (-) common.
- **6.1.95** Disconnect U21 pin 9 from (-) common and connect to +5 VDC red power connector on the DS3800 Test Box. Multimeter should read +0.1 VDC -/+ .12 VDC.
- **6.1.96** Disconnect U21 pin 9 from +5 VDC red power connector on the DS3800 Test Box and reconnect to (-) common.
- **6.1.97** Disconnect U21 pin 8 from (-) common and connect to +5 VDC red power connector on the DS3800 Test Box. Multimeter should read +0.6 VDC -/+ .17 VDC.
- **6.1.98** Disconnect U21 pin 8 from +5 VDC red power connector on the DS3800 Test Box and reconnect to (-) common.
- **6.1.99** Disconnect U21 pin 7 from (-) common and connect to +5 VDC red power connector on the DS3800 Test Box. Multimeter should read +1.6 VDC -/+ .27 VDC.
- **6.1.100** Disconnect U21 pin 7 from +5 VDC red power connector on the DS3800 Test Box and reconnect to (-) common.
- **6.1.101** Disconnect U21 pin 6 from (-) common and connect to +5 VDC red power connector on the DS3800 Test Box. Multimeter should read +3.6 VDC -/+ .47 VDC.
- **6.1.102** Disconnect U21 pin 6 from +5 VDC red power connector on the DS3800 Test Box and reconnect to (-) common.

LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY


Page 12 of 38

- **6.1.103** Disconnect U21 pin 5 from +5 VDC red power connector on DS3800 Test Box and connect to (-) common. Multimeter should read –8.40 -/+ .87 VDC.
- 6.1.104 Disconnect PA-48 from (-) common.
- **6.1.105** Leave PA-24 connected to +8 VDC. Make sure the PLL light is still out.
- 6.1.106 Disconnect all pins of U21.
- **6.1.107** Connect U21 pin 5 to +5 VDC red power connector on the DS3800 Test Box.
- **6.1.108** Disconnect Multimeter positive lead from TP9 (COS) and connect to Diode CR13, located between U4 and U22, cathode. Should read less than .2 VDC.
- **6.1.109** Connect 1st channel of O-Scope to left side of resistor R34, located between U1 and U65, should display logic high.
- **6.1.110** Connect PA-16 to PA-24 (+ 8 VDC). The O-Scope should display logic low and Multimeter should read approximately +8 VDC as long as this connection is made.
- **6.1.111** Disconnect PA-16 from PA-24 and connect to (-) common. O-Scope should display logic high and Multimeter should read approximately 0 VDC.
- **6.1.112** Connect PA-6 to +5 VDC red connector on DS3800 Test Box. O-Scope should display logic high and Multimeter should read –5 VDC.
- **6.1.113** Disconnect Multimeter from Diode CR13 cathode.
- **6.1.114** Disconnect U21 pin 5 and remove chip clip.
- 6.1.115 Disconnect PA-6 from +5 VDC red connector on DS3800 Test Box.
- 6.1.116 Disconnect PA-16 and PA-48 from (-) common.
- **6.1.117** Connect PA-53, PA-76, and PB-36 to (-) common.
- **6.1.118** Disconnect 1st channel of O-Scope from resistor R34 and then connect to PB-40, should display logic high.
- **6.1.119** Momentarily connect PB-48 to (-) common. O-Scope display should toggle low as long as this connection is made.
- 6.1.120 Disconnect PB-48 from (-) common. O-Scope should display logic high.
- **6.1.121** Disconnect PA-76, PB-48, and PB-36 from (-) common.
- **6.1.122** Disconnect 1st channel of O-Scope from PB-40 and connect to PA-70. Set O-Scope for 2 V/Div and 1 mSec/Div, should display logic low.

GE Energy Parts & Repair Services Louisville, KY


Page 13 of 38

6.1.123 Connect PA-76 to (-) common. Should see 3 square waves as follows:



g


6.1.125 Connect PB-36 to (-) common. Square type waves should disappear as follows:




GE Energy
Parts & Repair Services
Louis ville, KY

Page 14 of 38

6.1.127 Connect PB-48 to (-) common. Should see 3 spikes as follows:




6.1.129 Disconnect PB-36 from (-) common. Should see 1 square wave as follows:



GE Energy Parts & Repair Services Louisville, KY

Page 15 of 38

6.1.131 Disconnect 1st channel of O-Scope from PA-70 and connect to PA-74. Should display 2 square waves as follows:



- 6.1.133 Disconnect PB-48, PA-53, and PA-76. Square type waves should disappear.
- **6.1.134** Disconnect 1st channel of O-Scope from PA-74.

- 6.1.135 Connect PA-18 to (-) common. Make sure the PLL light is out.
- **6.1.136** Connect Multimeter negative lead to (-) common.
- 6.1.137 Connect Multimeter positive lead to PA-12, should read 0 VDC -/+ .05 VDC.
- 6.1.138 Disconnect PA-18 from (-) common.
- **6.1.139** Apply +1.0 VDC -/+ .1 VDC to PA-18, meter should read -1.0 -/+ .09 VDC.
- **6.1.140** Disconnect PA-18.
- **6.1.141** Apply -1.0 VDC -/+ .1 VDC to PA-14, meter should read +1.0 -/+ .09 VDC.
- **6.1.142** Disconnect PA-14.
- **6.1.143** Disconnect Multimeter positive lead from PA-12.
- **6.1.144** Connect PA11 and PA13 to +5 VDC through 4.7 K Ohm pull-up resistors, each line should have it's own pull-up resistor.
- **6.1.145** Connect PA-10 to +5 VDC.
- 6.1.146 Connect PA-19 to +8 VDC.
- **6.1.147** Connect PA-18 to adjustable power supply. Set power supply output to + 13.5 VDC, IMOK light should go out.
- **6.1.148** Connect Multimeter positive lead to PA-20, should read more than +13.7 VDC.
- 6.1.149 Connect 1st channel of O-Scope to PA-13, should display logic low.

LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 16 of 38

- **6.1.150** Adjust Potentiometer R49 on daughter card counter clockwise to 13.2 VDC as read on Multimeter, 1st channel of O-Scope should display logic high.
- **6.1.151** Adjust Potentiometer R49 on daughter card fully clockwise. Multimeter should read more than +13.7 VDC and 1st channel of O-Scope should display logic low.
- **6.1.152** Set power supply output connected PA-18 to + 0 VDC, IMOK light should come back on.
- **6.1.153** Disconnect 1st channel of O-Scope from PA-13 and connect to PA-11, should display logic low.
- **6.1.154** Disconnect Multimeter positive lead from PA-20 and connect to PA-18.
- **6.1.155** Adjust Potentiometer R85 clockwise until PLL and 0V lights come on, and then adjust counter clockwise 1 full turn and PLL and 0 V lights should go out.
- **6.1.156** Make sure that the adjustable power supply connected to PA-18 is set power supply output to 0 VDC as read on Multimeter. Tolerance for input voltage on PA-18 is -/+ .01 VDC.
- 6.1.157 Connect PA-53 to (-) common.
- 6.1.158 Connect 2nd channel of O-Scope to PA-67.
- **6.1.159** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.160** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.161** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.162** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.163** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.164** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.165** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.166** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.167** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.

LOU-GED-DS3800NFCE

REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 17 of 38

- **6.1.168** Disconnect PA-53 from +5 VDC and reconnect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.169** Connect 1st channel of O-Scope to left side of resistor R57 (U4 pin 14 output).
- **6.1.170** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.171** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.172** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.173** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.174** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.175** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.176** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.177** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.178** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- **6.1.179** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.180** Connect 1st channel of O-Scope to PA-40.
- **6.1.181** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.182** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.183** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.184** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.185** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.

LOU-GED-DS3800NFCE

REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 18 of 38

- **6.1.186** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.187** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.188** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.189** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- **6.1.190** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.191** Connect 1st channel of O-Scope to PA-13.
- **6.1.192** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.193** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.194** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.195** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.196** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.197** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.198** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.199** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.200** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- **6.1.201** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.202** Connect 1st channel of O-Scope to PA-27.
- **6.1.203** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.

g LOU-GED-DS3800NFCE GE Energy Page 19 of 38 REV. A Parts & Repair Services Louisville, KY

- 6.1.204 Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- 6.1.205 Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- 6.1.206 Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- 6.1.207 Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- 6.1.208 Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- 6.1.209 Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- 6.1.210 Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- 6.1.211 Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- 6.1.212 Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.213** Connect 1st channel of O-Scope to left side of resistor R97, located near U52.
- 6.1.214 Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- 6.1.215 Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- 6.1.216 Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- 6.1.217 Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- 6.1.218 Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- 6.1.219 Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- 6.1.220 Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.

LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 20 of 38

- **6.1.221** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.222** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- **6.1.223** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- 6.1.224 Connect 1st channel of O-Scope to PA-22.
- **6.1.225** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.226** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.227** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.228** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.229** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.230** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.231** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.232** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.233** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- **6.1.234** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.235** Connect 1st channel of O-Scope to PA-66.
- **6.1.236** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.237** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.238** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.

LOU-GED-DS3800NFCE

REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 21 of 38

- **6.1.239** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.240** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.241** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.242** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.243** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.244** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- **6.1.245** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.246** Connect 1st channel of O-Scope to PA-65.
- **6.1.247** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.248** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.249** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.250** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.251** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.252** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.253** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.254** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.255** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.

LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 22 of 38

- **6.1.256** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- **6.1.257** Disconnect 2nd channel of O-Scope from PA-67.
- **6.1.258** Connect 1st channel of O-Scope to PA-67.
- **6.1.259** Adjust PA-18 input voltage to .05 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.260** Adjust PA-18 input voltage to .25 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.261** Adjust PA-18 input voltage to 1.5 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.262** Adjust PA-18 input voltage to 2.6 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.263** Adjust PA-18 input voltage to 4.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.264** Adjust PA-18 input voltage to 5.3 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic low.
- **6.1.265** Adjust PA-18 input voltage to 5.8 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.266** Adjust PA-18 input voltage to 14.0 VDC -/+ .01 VDC. 1st channel of O-Scope should display logic high.
- **6.1.267** Disconnect PA-53 from (-) common and connect to +5 VDC, 2nd channel of O-Scope should display logic low.
- **6.1.268** Disconnect PA-53 from +5 VDC, and connect to (-) common, 2nd channel of O-Scope should display logic high.
- 6.1.269 Disconnect PA-53, PA-67, PA-18, PA-10, PA-19, PA11, and PA-13.
- 6.1.270 Connect JA-29 to JA-32, and then connect these points to +5 VDC -/+ .1 VDC.
- **6.1.271** Connect Multimeter positive lead to right side of resistor R192, located near U3, should read 0 VDC -/+ .03 VDC.
- 6.1.272 Connect Multimeter positive lead to PA-80, should read 0 VDC -/+ .05 VDC.
- **6.1.273** Connect Multimeter positive lead to PA-64, should read more than + 4.8 VDC -/+ .01 VDC.
- **6.1.274** Disconnect +5 VDC from JA-29 and JA-32.
- **6.1.275** Disconnect JA-29 from JA-32.
- **6.1.276** Connect JA-32 to (-) common.

GE Energy
Parts & Repair Services
Louisville, KY

LOU-GED-DS3800NFCE REV. A

- **6.1.277** Connect JA-29 to positive of adjustable power supply set to O VDC.
- 6.1.278 Connect negative side of same adjustable power supply to TP17 (ACOM).
- **6.1.279** Apply + .35 VDC -/+ .002 VDC to JA-29.
- 6.1.280 Connect Multimeter positive lead to PA-80, should read + .231 VDC -/+ .05 VDC.
- **6.1.281** Connect Multimeter positive lead to right side of resistor R192, located near U3, should read .158 VDC -/+ .015 VDC.
- **6.1.282** Connect positive Multimeter lead to PA-64, should read more than + 4.8 VDC -/+ .1
- **6.1.283** Apply .35 VDC -/+ .002 VDC to JA-29.
- 6.1.284 Connect Multimeter positive lead to PA-80, should read .231 VDC -/+ .05 VDC.
- 6.1.285 Adjust Potentiometer R168 until output on PA-80 is -.231 VDC.
- **6.1.286** Connect Multimeter positive lead to right side of resistor R192, located near U3, should read + .158 VDC -/+ .015 VDC.
- **6.1.287** Connect positive Multimeter lead to PA-64, should read more than + 4.8 VDC -/+ .1 VDC.
- **6.1.288** Apply + 4.4 VDC -/+ .002 VDC to JA-29.
- 6.1.289 Connect Multimeter positive lead to PA-80, should read + 2.92 VDC -/+ .05 VDC.
- **6.1.290** Connect Multimeter positive lead to right side of resistor R192, located near U3, should read 2.92 VDC -/+ .015 VDC.
- **6.1.291** Connect positive Multimeter lead to PA-64, should read more than + 4.8 VDC -/+ .1 VDC.
- **6.1.292** Apply 4.4 VDC -/+ .002 VDC to JA-29.
- 6.1.293 Connect Multimeter positive lead to PA-80, should read -2.92 VDC -/+ .05 VDC.
- **6.1.294** Connect Multimeter positive lead to right side of resistor R192, located near U3, should read + 1.99 VDC -/+ .015 VDC.
- **6.1.295** Connect positive Multimeter lead to PA-64, should read more than + 4.8 VDC -/+ .1 VDC.
- 6.1.296 Apply + 15.5 VDC -/+ .002 VDC to JA-29, 0 V (CR50) light should come on.
- 6.1.297 Connect Multimeter positive lead to PA-80, should read + 10.3 VDC -/+ .1 VDC.
- **6.1.298** Connect Multimeter positive lead to right side of resistor R192, located near U3, should read 7.01 VDC -/+ .015 VDC.
- **6.1.299** Connect positive Multimeter lead to PA-64, should read .43 -/+ .1 VDC.
- 6.1.300 Apply 15.5 VDC -/+ .002 VDC to JA-29. 0 V (CR50) light should come on.
- 6.1.301 Connect Multimeter positive lead to PA-80, should read 10.3 VDC -/+ .1 VDC.

GE Energy
Parts & Repair Services
Louisville, KY

LOU-GED-DS3800NFCE REV. A

- **6.1.302** Connect Multimeter positive lead to right side of resistor R192, located near U3, should read + 7.01 VDC -/+ .015 VDC.
- 6.1.303 Connect positive Multimeter lead to PA-64, should read .43 -/+ .1 VDC.
- **6.1.304** Disconnect JA-29, JA-32, and Multimeter positive lead from right side of R192, located near U3. 0 V (CR50) light should go out.
- 6.1.305 Connect PA-76 to (-) common.
- **6.1.306** Connect PA-18 to positive of adjustable power supply set for 0 VDC.
- **6.1.307** Connect 1st channel of O-Scope to PB-54, should display logic high.
- **6.1.308** Momentarily push switch SW1 to the left, O-Scope should display logic low as long as switch is pushed to the left. When switch is released O-Scope should return to logic high.
- **6.1.309** Connect PB-57 to (-) common, O-Scope should display logic low.
- 6.1.310 Apply + 1 VDC to PA-18, O-Scope should display logic high.
- 6.1.311 Apply 0 VDC to PA-18, O-Scope should display logic low.
- 6.1.312 Connect left side of resistor R52, located between U32 and U27, and PB-57 to + 5 VDC.
- 6.1.313 SUP (CR4) light should be on.
- **6.1.314** Use 2nd channel of O-Scope to check logic levels on PB63 (should display logic low), PB68 (should display logic high), and PB-54 (should display logic high).
- **6.1.315** Disconnect left side of resistor R52 from + 5 VDC and connect left side of resistor R52, located between U32 and U27, to (-) common.
- **6.1.316** Use 2nd channel of O-Scope to check logic levels on PB63 (should display logic low), PB68 (should display logic high), and PB-54 (should display logic high).
- 6.1.317 Connect PA-76 to + 5 VDC.
- **6.1.318** SUP (CR4) light should be off.
- **6.1.319** Use 2nd channel of O-Scope to check logic levels on PB63 (should display logic high), PB68 (should display logic low), and PB-54 (should display logic low).
- **6.1.320** Connect 2nd channel of O-Scope to PB-66, should display logic high.
- **6.1.321** Push switch SW2 (TUNSU) to the left, O-Scope should display logic low as long as switch is pushed to the left.
- **6.1.322** Release switch SW2, O-Scope should display logic high.
- **6.1.323** Disconnect 2nd channel of O-Scope from PB-66.
- 6.1.324 Disconnect PA-76, PB-57, PA-18, and left side of resistor R52.
- **6.1.325** SUP (CR4) light should come on.
- 6.1.326 Connect JA-29 to (-) common.
- 6.1.327 Connect Function Generator to JA-29 and JA-32, set output to .7 Vrms at 60 Hz.

LOU-GED-DS3800NFCE

REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 25 of 38

- **6.1.328** Connect Multimeter positive lead, set for AC Volts, to right side of resistor R192, should read .317 Vrms -/+ .009 Vrms.
- 6.1.329 Connect Multimeter positive lead to PA-80, should read .465 Vrms -/+ .02 Vrms.
- **6.1.330** Connect Multimeter positive lead, set for DC Volts, to PA-64, should read + 5 VDC -/+ .1 VDC.
- 6.1.331 Disconnect Multimeter positive lead, JA29 and JA32.
- **6.1.332** Disconnect all connections made during tests.

6.2 Integrated Systems Tests

- 6.2.1 Connect +5 VDC to red connector on DS3800 Test Box.
- **6.2.2** Connect +5 VDC return to black power connector on DS3800 Test Box. For the remainder of this testing process, "black power connector on DS3800 Test Box" will be referred to as **(-) common**.
- 6.2.3 Connect +15 VDC to yellow power connector on DS3800 Test Box.
- **6.2.4** Connect +15 VDC return to black power connector on DS3800 Test Box.
- **6.2.5** Connect –15 VDC to green power connector on DS3800 Test Box.
- 6.2.6 Connect –15 VDC return to black power connector on DS3800 Test Box.
- **6.2.7** Connect 1st Rainbow Box to PBA connector on DS3800 Test Box.
- **6.2.8** Connect 2nd Rainbow Box to PBB connector on DS3800 Test Box.
- 6.2.9 Attach DS3800DFCA Daughter Card.
- 6.2.10 Adjust R85, R168, and R46 on the DS3800DFCA Daughter Card fully counterclockwise.
- **6.2.11** Adjust R49 on the DS3800DFCA Daughter Card Clockwise.
- **6.2.12** Adjust R155 on the DS3800NFCE Card fully clockwise.
- **6.2.13** Attach 6 12K Ohm 2 Watt resistors to the standoffs at the top of the Rainbow Box.
- **6.2.14** Connect pin 81 of Rainbow Box to the black post of first 12K Ohm resistor.
- **6.2.15** Connect pin 82 of Rainbow Box to the black post of second 12K Ohm resistor.
- **6.2.16** Connect pin 83 of Rainbow Box to the black post of third 12K Ohm resistor.
- **6.2.17** Connect pin 84 of Rainbow Box to the black post of fourth 12K Ohm resistor.
- **6.2.18** Connect pin 85 of Rainbow Box to the black post of fifth 12K Ohm resistor.
- **6.2.19** Connect pin 86 of Rainbow Box to the black post of sixth 12K Ohm resistor.
- **6.2.20** Connect all 6 red posts of the 12K Ohm resistors together in parallel.
- **6.2.21** Connect +28 VDC to the orange power connector on the DS3800 Test Box.
- **6.2.22** Connect +28 VDC to the red post of all 12K Ohm resistors.
- 6.2.23 Connect 28 VDC return to the black power connector on the DS3800 Test Box.
- **6.2.24** Jumper PB-4 to PB-8 and jumper PB-6 to PB-10.

Page 26 of 38

- **6.2.25** Make sure PA-48 is disconnected.
- 6.2.26 Connect PA-18 to ACOM reference point on UUT.

g


- **6.2.27** Connect PA-16 to + 5 VDC.
- **6.2.28** Connect PA-76, PB-48, PB-58, PB-80, and PB-36 to (-) common.
- 6.2.29 Connect O-Scope to PA-81 and set for 10 V/div at 2.5 mSec/div.
- **6.2.30** Apply 2 VRMS @ 60 Hz to PB-8 and PB-10 from the Function Generator.
- **6.2.31** Apply power to unit, watching lights as unit powers up. IMOK and PLL lights should come on, and PLL light should go out after approximately 1 second.
- **6.2.32** Using 1st channel of O-Scope connected to each of these connections, PA-81, PA-82, PA-83, PA-84, PA-85, PA86, should display an approximately +28 VDC signal as follows:



6.2.34 Connect PB-78 to (-) common.

6.2.33

6.2.35 Using O-Scope connected to each of these connections, PA-81, PA-82, PA-83, PA-84, PA-85, PA86, should display the following waveform:



6.2.37 Connect PB-62 to (-) common.


GE Energy Parts & Repair Services Louisville, KY

Page 27 of 38

6.2.38 Using O-Scope connected to each of these connections, PA-81, PA-82, PA-83, PA-84, PA-85, PA86, should display the following waveform:



- **6.2.39 6.2.40** Disconnect PB-62.
- 6.2.41 Connect PA-18 to +5 VDC.
- **6.2.42** Connect positive lead of adjustable DC power supply, set for 0 VDC, to PA-16.
- **6.2.43** Connect negative lead of same adjustable power supply to ACOM reference point on UUT.
- **6.2.44** Connect 1st channel of O-Scope to PA-81. Set 1st channel of O-Scope to 10 V/div, and 2nd channel to 2 V/div, and 2.5 mSec/div.
- **6.2.45** Connect 2nd channel of O-Scope to output of Function Generator, which should still be set for 2 Vrms at 60 Hz.
- **6.2.46** O-Scope should display the following:




6.2.49


GE Energy Parts & Repair Services Louisville, KY

Page 28 of 38

6.2.48 Adjust power supply connected to PA-16 to + 8 VDC, O-Scope should display the following (note pulse position has shifted 90 degrees):




- 6.2.50 Adjust power supply connected to PA-16 to 0 VDC, O-Scope should display as in step6.2.48 (note pulse position has shifted back 90 degrees).
- **6.2.51** Reverse polarity on adjustable power supply, set to 0 VDC.
- 6.2.52 Adjust power supply connected to PA-16 to 8 VDC, O-Scope should display as in6.2.50 (note pulse position has shifted 90 degrees).
- **6.2.53** Reverse polarity on adjustable power supply back to original, set to 0 VDC.
- **6.2.54** Connect 1st channel of O-Scope to PA-82, O-Scope should display the following:




GE Energy Parts & Repair Services Louisville, KY

Page 29 of 38

6.2.56 Adjust power supply connected to PA-16 to + 8 VDC, O-Scope should display the following (note pulse position has shifted 90 degrees):




- 6.2.57
- 6.2.58 Adjust power supply connected to PA-16 to 0 VDC, O-Scope should display as in step6.2.56 (note pulse position has shifted back 90 degrees).
- **6.2.59** Reverse polarity on adjustable power supply, set to 0 VDC.
- 6.2.60 Adjust power supply connected to PA-16 to 8 VDC, O-Scope should display as in6.2.58 (note pulse position has shifted 90 degrees).
- **6.2.61** Reverse polarity on adjustable power supply back to original, set to 0 VDC.
- **6.2.62** Connect 1st channel of O-Scope to PA-83, O-Scope should display the following:



GE Energy Parts & Repair Services Louisville, KY


Page 30 of 38

6.2.64 Adjust power supply connected to PA-16 to + 8 VDC, O-Scope should display the following (note pulse position has shifted 90 degrees):



g

- 6.2.66 Adjust power supply connected to PA-16 to 0 VDC, O-Scope should display as in step6.2.64 (note pulse position has shifted back 90 degrees).
- **6.2.67** Reverse polarity on adjustable power supply, set to 0 VDC.
- 6.2.68 Adjust power supply connected to PA-16 to 8 VDC, O-Scope should display as in6.2.66 (note pulse position has shifted 90 degrees).
- **6.2.69** Reverse polarity on adjustable power supply back to original, set to 0 VDC.
- **6.2.70** Connect 1st channel of O-Scope to PA-84, O-Scope should display the following:




6.2.65

6.2.73


GE Energy Parts & Repair Services Louisville, KY

Page 31 of 38

6.2.72 Adjust power supply connected to PA-16 to + 8 VDC, O-Scope should display the following (note pulse position has shifted 90 degrees):



- 6.2.74 Adjust power supply connected to PA-16 to 0 VDC, O-Scope should display as in step6.2.72 (note pulse position has shifted back 90 degrees).
- **6.2.75** Reverse polarity on adjustable power supply, set to 0 VDC.
- 6.2.76 Adjust power supply connected to PA-16 to 8 VDC, O-Scope should display as in6.2.74 (note pulse position has shifted 90 degrees).
- **6.2.77** Reverse polarity on adjustable power supply back to original, set to 0 VDC.
- **6.2.78** Connect 1st channel of O-Scope to PA-85, O-Scope should display the following:




6.2.81


GE EnergyParts & Repair Services
Louisville, KY

Page 32 of 38

6.2.80 Adjust power supply connected to PA-16 to + 8 VDC, O-Scope should display the following (note pulse position has shifted 90 degrees):



- 6.2.82 Adjust power supply connected to PA-16 to 0 VDC, O-Scope should display as in step6.2.80 (note pulse position has shifted back 90 degrees).
- **6.2.83** Reverse polarity on adjustable power supply, set to 0 VDC.
- 6.2.84 Adjust power supply connected to PA-16 to 8 VDC, O-Scope should display as in6.2.82 (note pulse position has shifted 90 degrees).
- **6.2.85** Reverse polarity on adjustable power supply back to original, set to 0 VDC.
- **6.2.86** Connect 1st channel of O-Scope to PA-86, O-Scope should display the following:




LOU-GED-DS3800NFCE
REV. A

GE Energy
Page 33 of 38

Page 33 of 38

Louis ville, KY

6.2.88 Adjust power supply connected to PA-16 to + 8 VDC, O-Scope should display the following (note pulse position has shifted 90 degrees):



- 6.2.90 Adjust power supply connected to PA-16 to 0 VDC, O-Scope should display as in step6.2.88 (note pulse position has shifted back 90 degrees).
- **6.2.91** Reverse polarity on adjustable power supply, set to 0 VDC.
- **6.2.92** Adjust power supply connected to PA-16 to 8 VDC, O-Scope should display as in **6.2.90** (note pulse position has shifted 90 degrees).
- **6.2.93** Reverse polarity on adjustable power supply back to original, set to 0 VDC.
- 6.2.94 Disconnect 1st channel of O-Scope from PA-86 and connect to TP9 (COS) on UUT.
- **6.2.95** Connect + 8 VDC to PA-24.

6.2.89


- **6.2.96** Connect Multimeter positive lead to Anode (left) side of CR10, located between U4 and U22.
- **6.2.97** Connect Multimeter negative lead to (-) common (connection should already have been made previously in testing process).

LOU-GED-DS3800NFCE
REV. A


GE Energy
Parts & Repair Services
Louisville, KY

Page 34 of 38

6.2.98 Adjust power supply connected to PA-16 to 0 VDC, as measured on Multimeter, O-Scope should display the following wave form:



6.2.100 Adjust power supply connected to PA-16 to + 5 VDC, as measured on Multimeter, O-Scope should display the following wave form:




LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 35 of 38

6.2.102 Adjust power supply connected to PA-16 to + 8.1 VDC, as measured on Multimeter, O-Scope should display the following wave form:




- **6.2.104** Adjust power supply connected to PA-16 to + 12 VDC, as measured on Multimeter, IMOK (CR49) light should go out at approximately + 11.5 VDC.
- **6.2.105** Adjust power supply connected to PA-16 to 0 VDC, as measured on Multimeter, IMOK (CR49) light should turn on at approximately + 11.5 VDC.
- **6.2.106** Adjust power supply connected to PA-16 to 12 VDC, as measured on Multimeter, IMOK (CR49) light should go out at approximately 11.5 VDC.
- **6.2.107** Adjust power supply connected to PA-16 to 0 VDC, as measured on Multimeter, IMOK (CR49) light should turn on at approximately 11.5 VDC.
- **6.2.108** Disconnect 1st channel of O-Scope from TP9 (COS).
- **6.2.109** Disconnect Multimeter positive lead from Anode (left) side of CR10 and connect to PB-50. Should be reading less than + .8 VDC (logic low).
- **6.2.110** Connect PB-62 to (-) common.


GE Energy Parts & Repair Services Louisville, KY

Page 36 of 38

6.2.111 Using 1st channel of O-Scope, check PA-81, PA-82, PA-83, PA-84, PA-85, and PA-86 to verify that each connection has the following wave form:



- 6.2.113 The next step in this procedure is to check that only one set of outputs will produce firing pulses, while the other 2 sets of outputs will be latched high and will not produce any firing pulses. The sets are arranged as follows; PA-81 and PA84, PA-82 and PA-85; PA-83 and PA-86. Example, if PA-82 is producing firing pulses, PA-85 should also produce firing pulses, while all others will not produce firing pulses and are latched high at + 28 VDC.
- 6.2.114 Disconnect PB-36.
- **6.2.115** Using 1st channel of O-Scope, check connections PA-81 through PA-86. 1 set of outputs (as described in step 6.2.114) will produce all firing pulses with the following wave form:




LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 37 of 38

6.2.117 Using 1st channel of O-Scope, verify that the other two sets of outputs do not produce any firing pulses and are latched high with the following wave form:



- 6.2.119 Reconnect PB-36.
- **6.2.120** Using 1st channel of O-Scope verify that all outputs, PA-81 through PA-86, should now be producing firing pulses as shown in step **6.2.113**.

6.3 Continuity Tests

- **6.3.1** Remove all cable connections from both rainbow boxes and unplug JA Cable from JA plug on UUT.
- **6.3.2** Using Multimeter set for Ohm's, check for continuity between PA-55 and PA-57.
- **6.3.3** Using Multimeter set for Ohm's, check for continuity between PA-49, PB-49, JA-1, and JA-2.
- **6.3.4** Using Multimeter set for Ohm's, check for continuity between JA-30, JA-31, JA-33, TP12 (ACOM), PA-9, PB-9, and TP17 (ACOM).
- **6.3.5** Using Multimeter set for Ohm's, check for continuity between JA-3, JA-5, JA-7, JA-9, JA-11, JA-13, and JA-25.
- **6.3.6** Using Multimeter set for Ohm's, check for continuity between TP1 (CFB) and right side of resistor R301, located near TP17 (ACOM).
- **6.3.7** Using Multimeter set for Ohm's, check for continuity between TP8 (PIA) and PA-18.
- **6.3.8** Using Multimeter set for Ohm's, check for continuity between TP3 (TIA) and PA-14.
- **6.3.9** Using Multimeter set for Ohm's, check for continuity between TP2 (TREG) and PA-06.
- **6.3.10** Using Multimeter set for Ohm's, check for continuity between TP5 (CLP) and PA-10.
- **6.3.11** Using Multimeter set for Ohm's, check for continuity between TP13 (VFB) and PA-80.
- 6.3.12 Using Multimeter set for Ohm's, check for continuity between TP4 (SUP) and PA-20.

LOU-GED-DS3800NFCE
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 38 of 38

- 6.3.13 Using Multimeter set for Ohm's, check for continuity between TP14 (INF) and PB-40.
- **6.3.14** Using Multimeter set for Ohm's, check for continuity between PA-50 and PA-60.
- **6.3.15** Using Multimeter set for Ohm's, check for continuity between PA-5 and PB-5.
- 6.3.16 Using Multimeter set for Ohm's, check for continuity between PA-7 and PB-7.
- **6.3.17** Using Multimeter set for Ohm's, check for continuity between PA1, PA43, PA-79, PB-1, PB-43, PB-79, TP18 (DCOM), and TP6 (DCOM).
- **6.3.18** Using Multimeter set for Ohm's, check for continuity between PA-3, PA-45, PA-77, PB3, PB-45, and PB77.
- 6.3.19 Using Multimeter set for Ohm's, check for continuity between TP10 (HVNY) and JA-29.
- 6.3.20 Using Multimeter set for Ohm's, check for continuity between TP15 (INL) and PB-59.
- **6.3.21** Using Multimeter set for Ohm's, check for continuity between TP16 (ZCD) and PB-70.
- 6.3.22 Remove UUT from DS3800NFCE Test Box.
- 6.3.23 Remove DS3800DFCA Daughter Card from UUT.

7. NOTES

7.1 None at this time?

8. ATTACHMENTS

8.1 None at this time?