g		GE Energy	,	Functional [*]	Testing Spe	ecification
	Parts & Repa Louisville, K	ir Services '		LOU-0	SED-DS3800X	TFH
	Test Procedure for a DS3800XTFH					
	MENT REVISION STATUS	: Determined by the last e	ntry in the "REV" a			
REV.	Initial values	DESCRIPTION			SIGNATURE	REV. DATE
Α	Initial release			St	eve Pharris	08/10/2011
В						
С						
Hard co						
PREPA	ARED BY Pharris	REVIEWED BY	REVIEWE		QUALITY APP	PROVAL
DATE 08/10	/2011	DATE	DATE		DATE 8/25/2011	<i></i>

	g	
LOU-GED-DS3800XTFH	GE Energy	Page 2 of 8
REV. A	Parts & Repair Services	
	Louisville, KY	

1. SCOPE

1.1 This is a functional testing procedure for a DS3800XTFH.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - 4.2.1.1 Wires broken, cracked, or loosely connected
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - 4.2.1.3 Components visually damaged
 - **4.2.1.4** Capacitors bloated or leaking
 - 4.2.1.5 Solder joints damaged or cold
 - 4.2.1.6 Circuit board burned or de-laminated
 - 4.2.1.7 Printed wire runs / Traces burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)

GE Energy
Parts & Repair Services
Louisville, KY

LOU-GED-DS3800XTFH REV. A

6. Testing Process

- 6.1 Setup
 - **6.1.1** Set all potentiometers fully CCW
 - 6.1.2 Install all jumpers
 - **6.1.3** Remove any components from saddle clamps

6.2 Testing Procedure

- **6.2.1** Verify less than 2 ohms between the following points
 - JA1-JB6
 - JA2-JB1
 - JA2-JB2
 - JA2-JB3
 - JA3-JB8
 - JA4-JB7
 - JA5-JB4
 - JA6-JB9
 - JA6-JB10
 - JA7-JE1
 - JA7-JE2
 - JA7-JE3

 - JA8-JE4
 - JA9-JE7
 - JA10-JE6
 - JA11-JE9
 - JA11-JE10
 - JA12-JE8
 - JA13-JD1
 - JA13-JD2
 - JA13-JD3
 - JA14-JD6
 - JA13-JD7
 - JA13-JD9
 - JA13-JD10
 - JA16-JD8

	g	
LOU-GED-DS3800XTFH	GE Energy	Page 4 of 8
REV. A	Parts & Repair Services	
	Louisville, KY	

JA17-JG4

JA18-JD4

JA19-JG6

JA20-JG1

JA20-JG2

0, 120 002

JA20-JG3

JA21-JG8

JA22-JG7

JA23-JF6

JA24-JG9

JA24-JG10

JA25-JF8

JA26-JF1

JA26-JF2

JA26-JF3

JA27-JF4

JA28-JF7

JA28-JF9

JA28-JF10

JA29-JC1

JA29-JC2

JA29-JC3

JA30-JC4

JA31-JC7

JA32-JC6

JA33-JC9

JA33-JC10

JA34-JC8

JR1-JS1

JR2-JS4

JR3-JS6

JR4-JS5

JR5-JS7

JR6-JS10

LOU-GED-DS3800XTFH REV. A		Pa	E Energy rts & Repair Services uisville, KY		Page 5 of 8
	JT1-JU1				
	JT2-JU4				
	JT3-JU6				
	JT4-JU5				
	JT5-JU7				
	JT6-JU0				
6.2.2	Set DMM to dio	de			
6.2.3	Connect negative	e from meter to JA	15		
6.2.4	Verify proper di	ode voltage drop at	the following points		
	JA5				
	JB5				
	JC5				
	JD5				
	JE5				
	JF5				
6.2.5	Reverse the me	ter leads and repea	t step 6.2.4 this time veri	fying meter r	eads open
6.2.6	Connect negative	e from meter to JH	15		
6.2.7	Verify proper di	ode voltage drop at	the following points		
	JJ5				
	JK5				
	JL5				
	JM5				
	JN5				
	JP5				
6.2.8	Reverse the me	ter leads and repea	t step 6.2.7 this time veri	fying meter r	eads open
6.2.9	Measure resista	nce between the fo	lowing points and verify	all measurem	nents are
	between 17.9K	ohms and 18.5K oh	ms		
	JB4-JB5				

JC4-JC5 JD4-JD5 JE4-JE5 JF4-JF5 JG4-JG5 JJ4-JJ5

g **GE Energy** LOU-GED-DS3800XTFH Page 6 of 8 REV. A Parts & Repair Services Louisville, KY

JK4-JK5

JL4-JL5

JM4-JM5

JN4-JN5

JP4-JP5

- 6.2.10 Connect DMM across JR1 and JR2
- **6.2.11** Verify meter reads between 6 and 7 ohms
- **6.2.12** Remove BJ1 (As you remove these jumpers leave them off until told to replace them)
- **6.2.13** Verify meter reads between 8 and 9 ohms
- **6.2.14** Remove BJ2
- **6.2.15** Verify meter reads between 10 and 11 ohms
- **6.2.16** Remove BJ3
- **6.2.17** Verify meter reads between 13 and 14 ohms
- **6.2.18** Move meter to JR3 and JR4
- **6.2.19** Verify meter reads between 6 and 7 ohms
- **6.2.20** Remove BJ4
- **6.2.21** Verify meter reads between 8 and 9 ohms
- **6.2.22** Remove BJ5
- **6.2.23** Verify meter reads between 10 and 11 ohms
- **6.2.24** Remove BJ6
- **6.2.25** Verify meter reads between 13 and 14 ohms
- 6.2.26 Move meter to JR5 and JR6
- **6.2.27** Verify meter reads between 6 and 7 ohms
- **6.2.28** Remove BJ7
- **6.2.29** Verify meter reads between 8 and 9 ohms
- **6.2.30** Remove BJ8
- **6.2.31** Verify meter reads between 10 and 11 ohms
- 6.2.32 Remove BJ9
- **6.2.33** Verify meter reads between 13 and 14 ohms
- **6.2.34** Move meter to JT1 and JT2
- **6.2.35** Verify meter reads between 6 and 7 ohms
- 6.2.36 Remove BJ10
- **6.2.37** Verify meter reads between 8 and 9 ohms
- 6.2.38 Remove BJ11

g

LOU-GED-DS3800XTFH REV. A

GE Energy Parts & Repair Services Louisville, KY

Page 7 of 8

6.2.39	Verify meter reads between 10 and 11 ohms
6.2.40	Remove BJ12
6.2.41	Verify meter reads between 13 and 14 ohms
6.2.42	Move meter to JT3 and JT4
6.2.43	Verify meter reads between 6 and 7 ohms
6.2.44	Remove BJ13
6.2.45	Verify meter reads between 8 and 9 ohms
6.2.46	Remove BJ14
6.2.47	Verify meter reads between 10 and 11 ohms
6.2.48	Remove BJ15
6.2.49	Verify meter reads between 13 and 14 ohms
6.2.50	Move meter to JT5 and JT6
6.2.51	Verify meter reads between 6 and 7 ohms
6.2.52	Remove BJ16
6.2.53	Verify meter reads between 8 and 9 ohms
6.2.54	Remove BJ17
6.2.55	Verify meter reads between 10 and 11 ohms
6.2.56	Remove BJ18
6.2.57	Verify meter reads between 13 and 14 ohms
6.2.58	Turn all pots fully CW
6.2.59	Verify the following points measure between 20 and 22 ohms
	JR1-JR2
	JR3-JR4
	JR5-JR6
	JT1-JT2
	JT3-JT4
	JT5-JT6
6.2.60	Replace all jumpers
6.2.61	Connect DMM across TC37 and TC38
6.2.62	Verify DMM reads 8 ohms
6.2.63	Connect a jumper wire across R67 saddle clamps
6.2.64	Verify DMM reads less than 2 ohms
6.2.65	Connect DMM across TC39 and TC40

6.2.66 Verify DMM reads 8 ohms

LOU-GED-DS3800XTFH
REV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 8 of 8

- 6.2.67 Connect a jumper wire across R68 saddle clamps
- **6.2.68** Verify DMM reads less than 2 ohms
- 6.2.69 Connect DMM across TC41 and TC42
- 6.2.70 Verify DMM reads 8 ohms
- 6.2.71 Connect a jumper wire across R69 saddle clamps
- **6.2.72** Verify DMM reads less than 2 ohms
- 6.2.73 Connect DMM across TC43 and TC44
- 6.2.74 Verify DMM reads 8 ohms
- **6.2.75** Connect a jumper wire across R70 saddle clamps
- 6.2.76 Verify DMM reads less than 2 ohms
- 6.2.77 Connect DMM across TC45 and TC46
- 6.2.78 Verify DMM reads 8 ohms
- **6.2.79** Connect a jumper wire across R71 saddle clamps
- **6.2.80** Verify DMM reads less than 2 ohms
- 6.2.81 Connect DMM across TC47 and TC48
- **6.2.82** Verify DMM reads 8 ohms
- **6.2.83** Connect a jumper wire across R72 saddle clamps
- **6.2.84** Verify DMM reads less than 2 ohms
- **6.2.85** If any resistors were removed from the saddle clamps before testing verify they are proper resistance according to resistor body
- 6.2.86 Reinstall any saddle clamped resistors

6.3 ***TEST COMPLETE ***

7. Notes

7.1 None at this time.

8. Attachments

8.1 None at this time.