g		GE Energy Services	Functional Testing Specification
	Parts & Repair Services Louisville. KY		LOU-GED-DS3800NHVA

## **Test Procedure for a High Voltage Card**

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column						
REV.	DESCRIPTION	SIGNATURE	REV. DATE			
A	Added information pertaining to DS3800NHVA	D. Laemmle	9/29/03			
В	Separated the NHVA into its own test procedure	D. Laemmle	10/31/2008			

### © COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY R. Duvall	REVIEWED BY D. Laemmle	REVIEWED BY	QUALITY APPROVAL Charlie Wade
<b>DATE</b> 07/19/02	DATE 10/14/02	DATE	<b>DATE</b> 11/3/2008

g

### LOU-GED-DS3800NHVA REV. B

GE Energy Parts & Repair Services Louisville, KY Page 2 of 7

### Functional test procedure for High Voltage Card

### 1. SCOPE

1.1 This is a functional testing procedure for a High Voltage Card

## 2. STANDARDS OF QUALITY

**2.1** Refer to the current revision of the IPC-A-610 standard for workmanship standards.

### 3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
  - 3.1.1 UUT documentation folder

## 4. ENGINEERING REQUIREMENTS

- **4.1** Equipment Cleaning
  - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.
- **4.2** Equipment Inspection
  - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
    - **4.2.1.1** Wires broken or cracked
    - **4.2.1.2** Terminal strips / connectors broken or cracked
    - **4.2.1.3** Loose wires
    - **4.2.1.4** Components visually damaged
    - **4.2.1.5** Capacitors leaking
    - **4.2.1.6** Solder joints damaged or cold
    - **4.2.1.7** Circuit board burned or de-laminated
    - **4.2.1.8** Printed wire runs burned or damaged

g

## LOU-GED-DS3800NHVA REV. B

GE Energy Parts & Repair Services Louisville, KY Page 3 of 7

# 5. EQUIPMENT REQUIRED

**5.1** The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 85 DMM (or Equivalent)
1		O-Scope
1		115 VAC line cord
1		28 VDC Power Supply
1		SCR Firing Box
1		Digital Thermometer (only cards with temperature
		sensor ckt)

GE Energy Parts & Repair Services Louisville, KY Page 4 of 7

# 6. TESTING PROCESS

# 6.1 Attenuator Resistor Test (Voltage) NHVA

**6.1.1** To test the attenuator resistors, 10.000VDC+/- 1 mv is input with the polarity indicated and the output is read from output pin listed to JT (COM).

IN (+)	IN (-)	Output	Nom. Voltage	Max. Range
JD2-1	JD2-6	JB-1	+31.9 mv	+31.7 to +32.2 mv
		JA-27	+31.9 mv	+31.7 to +32.2 mv
		JB-6	-63.8 mv	-63.4 to -64.2 mv
JD2-6	JD2-11	JB-6	+63.8 mv	+ 63.4 to +64.2 mv
		JB-17	-31.9 mv	-31.7 to -32.2 mv
		JA-28	-31.9 mv	-31.7 to -32.2 mv
JD2-11	JD2-1	JB-1	-47.9 mv	-47.5 to -48.2 mv
		JA-27	-47.9 mv	-47.5 to -48.2 mv
		JB-17	+47.9 mv	+47.5 to +48.2 mv
		JA-28	+47.9 mv	+47.5 to +48.2 mv
JD1-1	JD1-7	JB-10	+47.8 mv	+47.5 to + 48.1 mv
		JA-32	+47.8 mv	+47.5 to +48.1 mv
		JB-13	-47.8 mv	-47.5 to -48.2 mv
		JA-29	-47.8 mv	-47.5 to -48.1 mv

# **6.2 CT INPUT TEST: (NHVA)**

- 6.2.1 Connect a 28-ohm 2W resistor across the daughter board terminals 1A and ACOM. Connect a scope across the resistor. Apply an isolated 6.3VAC (USE AN ISOLATION TRANSFORMER WITH THE VARIAC) to JC-1-JC-6. See a full wave waveform of only positive peaks approx. 7.7volts high.
- **6.2.2** Move the AC input to JC-2 JC-3 and see the same waveform.
- **6.2.3** Move the AC input to JC-4 JC-5 and see the same waveform. Disconnect the input, resistor and scope.

## **6.3** CT CLAMP TEST: (NHVA)

**6.3.1** Apply +28V through a 180 ohm 2 watt resistor to JA34 (+) and JA30 (-). The voltage at JA34 (+) to JA30 (com) must be 16V +/- 2V.

## 6.4 Neon Lamp Test

**6.4.1** Connect the AC line cord per table 2 and apply power to check each neon. Neon glows dimly on 120 VAC.

DS3800NHVA	Point A	Point B	Neon
Circuit # 1	JL-2	JE-2	P1
Circuit # 2	JM-2	JF-3	P2
Circuit # 3	JN-4	JG-4	P3
Circuit # 4	JP-2	JH-1	N1
Circuit # 5	JR-1	JJ-3	N2
Circuit # 6	JS-7	JK-3	N3

Table 2

# 6.5 Firing Circuit & LED Test

- **6.5.1** For the specific model being tested, use the information in table 3 to apply a non-isolated negative pulse from the SCR Firing box to each circuit and verify with the scope a controllable pulse train output on each circuit. (Reference Figure 1). See notes 1&2 for amplitude.
- **6.5.2** Using the information in table 3, probe each of the circuits positive input with the power supply common and verify that the LED for each circuit illuminates to full brightness.

DS3800NHVA	SCR Box COM	SCR	Scope +	Scope	28 VDC +	Notes
		Box NEG		-		
Circuit # 1	JA-3	JA-22	JL-3	JL-2	JA-1	1,2
Circuit # 2	JA-3	JA-4	JE-1	JE-2	JA-1	1,2
Circuit # 3	JA-3	JA-24	JM-1	JM-2	JA-1	1,2
Circuit # 4	JA-3	JA-6	JF-1	JF-3	JA-1	1,2
Circuit # 5	JA-3	JA-26	JN-5	JN-4	JA-1	1,2
Circuit # 6	JA-3	JA-8	JG-3	JG-4	JA-1	1,2
Circuit # 7	JA-3	JA-16	JP-3	JP-2	JA-1	1,2
Circuit # 8	JA-3	JA-10	JH-2	JH-1	JA-1	1,2
Circuit # 9	JA-3	JA-18	JR-2	JR-1	JA-1	1,2
Circuit # 10	JA-3	JA-12	JJ-1	JJ-3	JA-1	1,2
Circuit # 11	JA-3	JA-20	JS-8	JS-7	JA-1	1,2
Circuit # 12	JA-3	JA-14	JK-2	JK-3	JA-1	1,2

**TABLE** 

3

Note 1: NHVA amplitude is 17 volts. Note 2: 28 VDC COM to SCR Box COM

**6.6** \*\*\*TEST COMPLETE \*\*\*

### 7. NOTES


Output voltages (Waveforms) of gate circuits are measured with output unloaded.

g

GE Energy Parts & Repair Services Louisville, KY Page 7 of 7

# 8. Oscilloscope Verification Examples:





DS3800NHVK 17V Peak 5V/Div .5ms/Div