

<div>g</div> <div>GE Energy</div>		Functional Testing Specification	
Parts & Repair Services Louisville, KY		LOU-GED-948D818G5	
Test Procedure for a 948D818G5			
DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column			
REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release Transferred from paper copy to an electronic format, and added Brunswick specific adjustments.	G. Chandler	1/14/2012
B	Clarified steps 7.2.8, 7.2.9 , 7.2.10, & 7.2.11	G. Chandler	1/18/2012
C	Added 4 steps to Brunswick data sheet	G. Chandler	3/23/2012
© COPYRIGHT GENERAL ELECTRIC COMPANY Hard copies are uncontrolled and are for reference only. PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.			
PREPARED BY G. Chandler	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 1/14/2012	DATE	DATE	DATE 1/14/2012

LOU-GED-948D818G5 REV. C	g GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 2 of 7
---	---	--------------------

1. SCOPE

1.1 This is a functional testing procedure for a Turbine Control board

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein.
Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
2		30VDC Power Supplies
1		Fluke 85 meter or equivalent
1		Op Amp Card

<p>LOU-GED-948D818G5 REV. C</p>	<p>g</p> <p>GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 3 of 7</p>
---	--	---------------------------

6. Modifications/Upgrades

6.1 Check Orange Book for any modifications or upgrades.

7. Testing Process

7.1 Setup

7.1.1 Notes highlighted in "Blue" were hand written on test instruction P3K-AL-0025.

7.1.1.1 Power, -22VDC to Pin-21 and ground to Pin-19

7.2 Testing Procedure

7.2.1 Turn on power.

7.2.2 Before start of test note voltages at TP4 _____ and TP5 _____ and write down.

7.2.3 Adjust Pot R4 and R3 clock-wise.

7.2.4 TP4 = -8.3VDC +/- 0.45VDC. Pin 32 is the same voltage as TP4. Run R3 CCW monitoring the voltage at TP4, should be a smooth change to 0VDC. Return R3 clock-wise.

7.2.5 TP5 = -8.3VDC +/- 0.45VDC. Run R4 CCW monitoring the voltage at TP5, should be a smooth change to 0VDC.

7.2.6 Set pot R4 CCW, set pot R3 for -5.0VDC at TP4, and short Pin-25 to common. "Do this on". Read Pin-20, about -1.7V

7.2.7 Remove common from Pin-25 and place at Pin-36. Read Pin-20 about -1.43VDC.

7.2.8 Remove common from Pin-36 and place at Pin-3. The voltage should measure between -2.38V and -2.47V at Pin-20.

7.2.9 Remove common from Pin-3 and place at Pin-18. The voltage should measure between -1.63V and -2.36V at Pin-20.

7.2.10 Set pot R3 full CCW. Set pot R4 for -5.0VDC at TP5. Read Pin-20 about -2.34VDC

7.2.11 Set TP4 (R3) and TP5 (R4) to step 7.2.2.

7.2.12 Disconnect all leads to test kit.

Using a sinewave generator put a 10 Hz signal into Pin-36 (use Pin-19 as common). Set voltage at C2 and R13 junction for 2.00VRMS. Raise the frequency until the voltage at C2/R13 junction = 1.41VRMS. The frequency should be about 36 to 45 Hz.

7.2.13 If card is for Brunswick go to appendix A, otherwise continue to next step.

7.3 Post Testing Burn-in **Required** ☒ Yes ☐ No



Note: 100 hour burn is required for most Turbine Control Boards

7.4 ***TEST COMPLETE***

8. Attachments

8.1 Appendix A - Brunswick specific setup adjustment.

8.2 Brunswick Drawing (Figure 1)




Figure 1

<p>LOU-GED-948D818G5 REV. C</p>	<p>g</p> <p>GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 5 of 7</p>
---	--	---------------------------

Appendix A (Brunswick Specific Test adjustment for 948D818G0005)

1. Testing Process

1.1 Setup

- 1.1.1 Set pots R3 and R4 CCW.
- 1.1.2 Adjust pot R1 for 386K ohms between Pin-1 and Pin-20.
- 1.1.3 Adjust pot R2 for 183.5K ohms between Pin-18 and Pin-20.
- 1.1.4 Install Op/Amp card
 - 1.1.4.1 Pin-20 to Op/Amp input pin 27
 - 1.1.4.2 Pin-1 to Op/Amp output pin 41
- 1.1.5 Ground Pin-18 (TP2), Pin-25 (TP3) and Pin-36 (TP6)
- 1.1.6 Install an Op Amp card Pin-20 to the input & Pin-1 to the output of the Op Amp.
- 1.1.7 Ground Pin-18, Pin-25, and Pin-36.

1.2 Testing Procedure

- 1.2.1 Apply power to card under test and to Op Amp card.
- 1.2.2 Adjust Op/Amp R3 for 0.000 at Pin-3 (TP1)
- 1.2.3 Remove Ground and apply +0.2V at Pin-36 (TP6) and trim R1 for -3.86V +/- 50mV at Pin-3 (TP1).
 - 1.2.3.1 Ground Pin-36.
- 1.2.4 Remove ground and apply 5.000V to Pin-18 (TP2) and adjust R4 for 0.0V +/- 50mV at Pin-3 (TP1).
- 1.2.5 Remove voltage and ground Pin-18 (TP2).
- 1.2.6 Remove ground and apply 0.545V at Pin-36 (TP6) and trim R4 for 0.0V +/- 50mV at Pin-3 (TP1).
- 1.2.7 Remove voltage and ground Pin-36 (TP6).
- 1.2.8 Remove ground and apply +5.000V to Pin-18 (TP2) and trim R2 for 0.0V +/- 50mV at Pin-3 (TP1)
- 1.2.9 Turn R3 CW.
- 1.2.10 Apply a "+" voltage to Pin-36 (TP6) until Pin-3 = 0V +/- 50mV.
- 1.2.11 The voltage at Pin-36 (TP6) must be >+4.5V.
- 1.2.12 Adjust voltage at Pin-36 (TP6) to +4.455V and adjust R3 for 0V +/- 50mV on Pin-3 (TP1).
- 1.2.13 Remove voltage and ground Pin-18 (TP2).
- 1.2.14 Increase voltage at Pin-36 (TP6) until Pin-3 (TP1) = 0V +/- 50mV.
- 1.2.15 The voltage on Pin-36 (TP6) should = +5.000V +/-0.01V.

<p>LOU-GED-948D818G5 REV. C</p>	<p>g</p> <p>GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 6 of 7</p>
---	--	---------------------------

1.2.16 Ground pin 32 (TP4).

1.2.17 Decrease applied voltage to Pin-36 (TP6) until Pin-3 (TP1) is 0.0V +/- 50mV.


1.2.18 Verify voltage to Pin-36 (TP6) is +0.545V +/- 10mV.

1.2.19 Remove voltage and ground Pin-36 (TP6).

1.2.20 Apply “+” voltage to pin 25 (TP3) until pin 3 (TP1) is 0.0V +/- 50mV.

1.2.21 Verify voltage to pin 25 (TP3) is +0.82V +/- 20mV.

1.3 *End of Adjustment*****

LOU-GED-948D818G5 REV. C	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 7 of 7
---	--	--------------------

Job # _____

Serial # _____

Burn-in Start _____

Date _____

Data Sheet for 948D818G0005

Burn-in Stop _____

Test Procedure P3K-AL-0025

Technician _____

Test Procedure Step	Nominal	Lower Limit	Pre-Burn in Results	Post Burn in Results	Upper Limit	Pot Values If applicable CW CCW		Pass/Fail
7.2.4	-8.3V	-7.85V			-8.75V	R3		
7.2.4	0V	0V			0V		R3	
7.2.5	-8.3V	-7.85V			-8.75V	R4		
7.2.5	0V	0V			0V		R4	
7.2.6	-1.7V	About			About			
7.2.7	-1.43V	About			About			
7.2.8	-2.43V	-2.38V			-2.47V			
7.2.9	-1.94V	-1.63V			-2.36V			
7.2.10	-2.34V	About			About			
7.2.12	41Hz	36 Hz			45 Hz			

Brunswick plant specific alignment results (Appendix A)

Test Procedure Step	Nominal	Lower Limit	Pre-Burn in Results	Post Burn in Results	Upper Limit	Pot Values If applicable CW CCW		Pass/Fail
1.1.2	R1							
1.1.3	R2							
1.2.3	-3.86V	-3.81V			-3.91V			
1.2.4	0V	-.05V			+.05V			
1.2.6	0V	-.05V			+.05V			
1.2.8	0V	-.05V			+.05V			
1.2.11	> +4.5V	+4.5V						
1.2.12	0V	-.05V			+.05V			
1.2.15	+5V	+4.99V			+5.01V			
1.2.17	0V	-.05V			+.05V			
1.2.18	+0.545V	+0.535V			+0.555V			
1.2.21	+0.82V	+0.80V			+0.84V			