g		GE Energy		Functional T	esting Spe	ecification	
Parts & Repair Services Louisville, KY				LOU-GED-DS3800XTFS			
Test Procedure for a DS380XTFS card							
DOCUI	MENT REVISION STATUS:	Determined by the last entry in t	he "REV" a	nd "DATE" column			
REV.		DESCRIPTION			GNATURE	REV. DATE	
Α	Initial release			J.	Wychulis	8/9/2010	
В							
С							
Hard co	YRIGHT GENERAL ELECTF pies are uncontrolled and are f	for reference only.					
MAY N	PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY. PREPARED BY REVIEWED BY REVIEWED BY QUALITY APPROVAL						
	Wychulis	2475			Charlie Wa	de	
DATE 8/9/20	010	DATE	DATE		DATE 8/10/2010		

	g	
LOU-GED-DS3800XTFS	GE Energy	Page 2 of 3
REV. A	Parts & Repair Services	
	Louisville, KY	

1. SCOPE

1.1 This is a functional testing procedure for a DS3800XTFS Card.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - 4.2.1.1 Wires broken, cracked, or loosely connected
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - 4.2.1.3 Components visually damaged
 - **4.2.1.4** Capacitors bloated or leaking
 - 4.2.1.5 Solder joints damaged or cold
 - 4.2.1.6 Circuit board burned or de-laminated
 - 4.2.1.7 Printed wire runs / Traces burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		28VDC Power Supply

GE Energy
Parts & Repair Services
Louisville, KY

LOU-GED-DS3800XTFS REV. A

6. TESTING PROCESS

- 6.1 Setup
 - 6.1.1 28VDC (+-.005) power supply to JA2 and JB2(+) and JA1,JB1 are COM
- 6.2 Testing Procedure
 - **6.2.1** Turn on power
 - 6.2.2 All lights are on
 - 6.2.3 Check for 28 VDC (+- .01) at TB1,7,8,9,4,5,6 with respect TP PCOM
- **6.3** ***TEST COMPLETE ***

7. NOTES

7.1 None at this time

8. Attachments

8.1 None at this time