g	GE	Energy	Functional Testing Specification
	Parts & Repair Services Louisville, KY		LOU-GED-DS200PTBAG1A

Test Procedure for a DS200PTBAG1A card

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column				
REV.	DESCRIPTION	SIGNATURE	REV. DATE	
Α	Initial release	Jill Hardin	08/18/2010	
В	Corrected steps and amended table for easier use	S. Pharris	11/30/2010	
С	Added step 6.1.2, on burn-in requirements, none needed.	C. Wade	12/17/2013	
D	In section 6.1.1 added comments (Red) to four steps	S. Cash	8/26/2014	

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Jill Hardin	REVIEWED BY S. Pharris	REVIEWED BY S. Cash	QUALITY APPROVAL Charlie Wade
DATE	DATE	DATE	DATE
8/18/2010	11/30/2010	8/26/2014	8/18/2010

LOU-GED-DS200PTBAG1A
REV. D

GE Energy
Parts & Repair Services
Louis ville, KY

Page 2 of 6

1. SCOPE

1.1 This is a functional testing procedure for a terminal board.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - 4.2.1.1 Wires broken, cracked, or loosely connected
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - 4.2.1.3 Components visually damaged
 - **4.2.1.4** Capacitors bloated or leaking
 - 4.2.1.5 Solder joints damaged or cold
 - 4.2.1.6 Circuit board burned or de-laminated
 - 4.2.1.7 Printed wire runs / Traces burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)

	g	
LOU-GED-DS200PTBAG1A	GE Energy	Page 3 of 6
REV. D	Parts & Repair Services	
	Louis ville, KY	

6. <u>TESTING PROCESS</u>

6.1 Testing Procedure

6.1.1 Please check the following points. For those reading at "0" ohm, tolerance will be +- 1 ohm. All other readings will be +- 5%.

ТО	Reading in Ohms	Notes
JU-1	0	
JJR-1	0	
JJS-1	0	
JJT-1	0	
JJR-2	0	
JJS-2	0	
JJT-2	0	
JU-2	0	
JU-3	0	
JJR-3	0	
JJS-3	0	
JJT-3	0	
JJR-4	0	
JJS-4	0	
JJT-4	0	
JU-4	0	
JU-5	0	
JJR-5	0	
JJS-5	0	
JJT-5	0	
JJR-6	0	
JJS-6	0	
JJT-6	0	
JU-6	0	
JU-7	0	
JJR-7	0	
JJS-7	0	
JJT-7	0	
JJR-8	0	
JJS-8	0	
JJT-8	0	
JU-8	0	
	JU-1 JJR-1 JJR-1 JJS-1 JJT-1 JJR-2 JJS-2 JJT-2 JU-2 JU-3 JJR-3 JJR-3 JJS-3 JJT-3 JJR-4 JJS-4 JJS-4 JJS-6 JJT-5 JJR-6 JJT-6 JJR-6 JJT-6 JU-7 JJR-7 JJR-7 JJR-7 JJR-8 JJS-8 JJT-8	JU-1 0 JJR-1 0 JJR-1 0 JJS-1 0 JJT-1 0 JJR-2 0 JJS-2 0 JJS-2 0 JU-2 0 JU-3 0 JJR-3 0 JJR-3 0 JJR-3 0 JJR-4 0 JJS-4 0 JJS-4 0 JU-5 0 JJR-5 0 JJR-5 0 JJR-6 0 JJR-6 0 JJR-6 0 JJR-6 0 JU-7 0 JJR-7 0 JJR-7 0 JJR-8 0 JJS-8 0 JJS-8 0 JJS-8 0 JJS-8 0 JJS-8 0 JJT-8 0

LOU-GED-DS200PTBAG1A REV. D

g

GE Energy Parts & Repair Services Louisville, KY

Page 4 of 6

FROM	то	Reading in Ohms	Notes
TB-9	JU-9	0	
TB-10	JU-10	0	
TB-9	TB-10	0	Is an open will only be different if MOV's shorted
TB-11	JU-11	0	unicient ii iiio v 3 shorted
TB-12	JU-12	0	
10 12	00 12	Ü	Is an open will only be
TB-11	TB-12	0	different if MOV's shorted
TB-13	JVA-1	2.7K	
TB-14	JU-19	3.3K	
TB-15	JVA-2	2.7K	
TB-16	JU-20	3.3K	
TB-17	JVA-3	2.7K	
TB-18	JU-21	3.3K	
JU-13	JU-19	1.5K	
JU-13	JU-20	1.5K	
JU-13	JU-21	1.5K	
TB-19	JVA-4	2.7K	
TB-20	JU-22	3.3K	
TB-21	JVA-5	2.7K	
TB-22	JU-23	3.3K	
TB-23	JVA-6	2.7K	
TB-24	JU-24	3.3K	
JU-13	JU-22	1.5K	
JU-13	JU-23	1.5K	
JU-13	JU-24	1.5K	
JU-13	JU-25	1.5K	
JU-13	JU-26	1.5K	
TB-25	JVA-7	2.7K	
TB-26	JU-25	3.3K	
TB-27	JVA-8	2.7K	
TB-28	JU-26	3.3K	
TB-29	JV-1	155 ohms	
TB-30	JV-2	155 ohms	
TB-31	JV-3	155 ohms	
TB-32	JV-4	155 ohms	
TB-33	JV-5	155 ohms	
TB-34	JV-6	155 ohms	
TB-35	JN-4	0	

LOU-GED-DS200PTBAG1A REV. D

g

GE Energy Parts & Repair Services Louisville, KY

Page 5 of 6

From	ТО	Reading in Ohms	Notes
TB-36	JN-5	0	
TB-37	JM-6	0	
TB-38	JM-3	0	
TB-38	TB-39	0	Remove is an external jumper on schematic-open
TB-39	TB-40	0	Jumper on soficinatio open
TB-41	JN-6	Diode Drop	Negative lead on TB-41
TB-38	TB-41	Diode Drop	Positive lead on TB-41
TB-42	JM-11	0	1 001470 1044 011 12 11
TB-43	JN-1	0	
TB-44	TB-45	0	
TB-46	TB-47	0	
TB-48	JN-2	0	
TB-49	JN-2	0	
TB-48	TB-49	0	
TB-50	TB-51	0	
TB-52	TB-53	0	
TB-54	TB-55	0	
TB-56	JN-3	0	
JU-15	JN-7	0	
JU-16	JN-8	0	
JU-14	JN-9	0	
TB-57	JM-1	0	
TB-58	TB-59	0	
TB-58	JM-4	0	
TB-59	JM-4	0	
TB-60	JM-5	0	
TB-61	TB-70	0	
TB-61	JM-2	0	
TB-62	TB-63	0	
TB-62	TB-71	0	
TB-63	TB-71	0	
TB-62	JM-7	0	
TB-63	JM-7	0	
TB-64	JM-8	0	
TB-65	JM-9	0	
TB-66	JM-10	0	
TB-67	TB-62	0	
TB-67	TB-63	0	
TB-67	TB-69	0	

LOU-GED-DS200PTBAG1A
REV. D

GE Energy
Parts & Repair Services
Louisville, KY

Page 6 of 6

FROM	ТО	Reading in Ohms	Notes
TB-68	JM-12	0	
TB-70	JM-2	0	
TB-61	TB-70	0	
TB-72	JN-10	0	
TB-73	TB-74	1.45M	
TB-73	JV-7	0	
TB-74	JV-8	0	
TB-75	TB-76	1.45M	
TB-75	JV-9	0	
TB-76	JV-10	0	
TB-77	TB-78	1.45M	
TB-77	JV-11	0	
TB-78	JV-12	0	
JU-18	JN-12	0	
JU-17	JN-11	0	

- **6.1.2** For all normal repairs; card does not have any active components so unit does not require any burn-in.
- 6.1.3 ***TEST COMPLETE ***

7. NOTES

7.1 None at this time.

8. ATTACHMENTS

8.1 None at this time.