GENERAL (%) ELECTRIC

P3K-AL-0461-A01
CONT ON SHEET 2 SH NO. 1

REVISIONS

TO COR AT ALCOHOL

TITLE

T CONTENDE (MORE O)

P3K-AL-0461-A01

CONT ON SHEET 2 SH NO.

MSV POSITION CONTROL (MSV-2)

CIRCUIT BOARD ASSEMBLY 118D1307 G1, G2 1F1-A101

FIRST MADE FOR EHC MARK II

A. BOARD CONTENTS

- 1. 2 regulated power supplies
- 2. Normalizing amplifier (IC1)
- 3. Summing amplifier (IC2)
- 4. Meter amplifier (IC3)

+ 22 to pri 47

B. POWER SUPPLIES

- 1. $V_{TP1} = 15.7 \pm 1 \text{ VDC}$
- 2. $V_{TP2} = -15.7 + 1 \text{ VDC}$
- 3. I pin 37 = ma DC
- 4. I pin 41 = ma DC

ACTIVE FOR all Groups
BY ______DATE ____//__/

C. NORMALIZING AMPLIFIER (IC1)

1. Null Adjust (VR51)

Ground TP9 Insure that adjusting VR51 runs V_{TP7} through zero.

 Amplifier Gains - Steady State Null ICl, then

 $-0.062 < V_{\mathrm{TP7}}/V_{\mathrm{TP9}} < -0.059$; (0 $\leq V_{\mathrm{TP9}} \leq$ 10 VDC, VR9 CCW)

+LYDE TRY ROOM THY

 $-1.2 < V_{\mathrm{TP}7}/V_{\mathrm{TP}9} < -0.95;$ (0 $\leq V_{\mathrm{TP}9} < 10 \mathrm{VDC}$, VR9 CW)

3. Saturation Protection (CR5, CR6, IC1)

|Vpin 2 - Vpin 3 | < 0.6 VDC; |VTP9| > 0

4. Transient State

Null IC1 Set $VR9 V_{TP7}/V_{TP9} = -1.00$

Apply +2 VDC step input to TP9 Verify VTP7 by Figure 1.

273-2 273-12-273-710 273-138 273-221

273-227

PRINTS TO

37 OKACLR SEP 2 6 1977

185UED SEP 2 6 1977

Steam Turbine
Schenectady, N.Y.

DIV OR P 3K-AL-

P3K-AL-0461-A01

SH NO. I. CODE IDENT HO.

PRINTED IN U.S.A.

+

REV NO.

+

+

TITLE

MSV POSITION CONTROL (MSV-2)

CIRCUIT BOARD ASSEMBLY 118D1307 G1, G2 1F1-A101

P3K-AL-0461-A01

CONT ON SHEET 3 SH NO. 2

FIRST MADE FOR EHC MARK II

REVISIONS

2

D. METER AMPLIFIER (IC3)

- 1. $V_{TP53} = -22 \text{ VDC}$, (VR10 CW) -6.85 $< V_{TP53} < -5.8 \text{ VDC}$, (VR10 CCW)
- 2. Null Adjust (VR50)

Ground TP5 Insure that VR50 adjust runs $\ensuremath{\text{V}_{\text{TP4}}}$ through zero

- 3. $V_{TP4}/V_{TP5} = 1.00$; (IC3 nulled, -10 $\leq V_{TP5} \leq 0$ VDC)
- 4. Attach milliammeter pin 24 to ground

Apply -10 VDC to TP5 THEN

1.5 < I $_{\rm meter}$ < 1.6 ma DC, (VR5 CW)

 $0.82 < I_{\rm meter} < 0.92$ ma DC, (VR5 CCW)

Remove -100 From TP5.

3.98

E. SUMMING AMPLIFIER (IC2)

- 1. Voltage ranges
 - a. $V_{TP60} = 0V$, (VR4 CCW) -6.0 $< V_{TP60} < -5.0$ VDC, (VR4 CW)
 - b. $11.8 < V_{TP61} < 12.5 \text{ VDC}$, (VR1 CW) $8.30 < V_{TP61} < 8.55 \text{ VDC}$, (VR1 CCW)
 - c. $-10.9 < V_{TP10} < -10.5 VDC$
 - d. TP63 grounded: $1.94 < V_{TP10} < 2.02$ VDC
- 2. Limit Circuits
 - a. TP58 TP59 shorted:

 $V_{TP3} = 2.5 \pm 0.5 \text{ VDC (soft limit)}$

b. Short removed:

 $V_{TP3} = 0.3 \pm 0.1 \text{ VDC (hard limit)}$

PRINTS TO

SEP 26 1977.

Steam Turbine

DIV OR

P3K-AL-0461-A01

Schenectady, N.Y.

LOCATION CONT ON SHEET

SH NO. Z

FF-803-WA (2-75) PRINTED IN U.S.A. CODE IDENT NO

FF-803-WA (2-76) PRINTED IN U.S.A.

--

--

CODE IDENT NO

CONT ON SHEET

P3K-AL-0461-A01

REV C

TITLE

MSV POSITION CONTROL (MSV-2) CIRCUIT BOARD ASSEMBLY 118D1307 G1, G2 1F1-A101

EHC MARK II

CONT ON SHEET 5 SH NO. FIRST MADE FOR

REVISIONS

SUMMING AMPLIFIER (IC2) (continued)

- 4. TP52 - TP57 shorted TP58 - TP59 shorted TP5, TP61, TP65, TP63, TP62, TP56 grounded ρ_1 ρ_{33} ρ_{33} ρ_{34} ρ_{35} ρ_{35}
 - TP52 TP57 shorted TP58 - TP59 shorted
 - TP52 TP57 shorted TP58 - TP59 shorted TP5, TP61, TP65, TP66, TP56 grounded P33 P38 $-0.205 < V_{TP3}/V_{TP7} < -0.194$ (VR9 CW, $-10 < V_{TP9} < 0$ VDC)
- 5. Amplifier Gains transients
 - TP52 TP57 shorted TP58 - TP59 shorted TP5, TP61, TP65, TP66, TP62 grounded P6 P33 Pin38 Pin38 Verify $V(t)_{TP3}$ $(V(t)_{TP56})$; $V(t)_{TP56}$ = 1 u(t)According to Figure 2.
 - TP52-TP57 shorted TP58 - TP59 shorted TP5, TP61, TP65, TP66, TP7, TP56 grounded Verify $V(t)_{TP3}$ $(V(t)_{TP62});$ $V(t)_{TP62}^{f_{in}} \stackrel{3}{\sim} = 1 \text{ u(t)}$ According to Figure 3
 - TP52 TP57 shorted c. TP58 - TP59 shorted TP5, TP61, TP65, TP10, TP62, TP56 grounded Verify $V(t)_{TP3}$ $(V(t)_{TP66});$ $V(t)_{TP66}^{\rho_{10}}$ = 1 u(t) According to Figure 3.

APPROVALS

PRINTS TO

R, SEP 26 1977 SEP 26 1977

Steam Turbine

DIV OR

P3K-AL-0461-A01

LOCATION CONT ON SHEET

SH NO.

FF-803-WA (2-75) PRINTED IN U.S.A.

+

+

Schenectady, N.Y.

CODE IDENT NO

REVISIONS

CONT ON SHEET TITLE MSV POSITION CONTROL (MSV-2) P3K-AL-0461-A01 CIRCUIT BOARD ASSEMBLY 118D1307 G1, G2 1F1-A101 CONT ON SHEET 6. FIRST MADE FOR EHC MARK II

SUMMING AMPLIFIER (IC2) (continued)

(continued)

- d. TP52 TP57 shorted TP58 - TP59 shorted TP5, TP61, TP66, TP62, TP56 grounded $(V(t)_{TP65}); V(t)_{TP65}^{h/33} = 1 u(t)$ Verify V(t)_{TP3} According to Figure 3.
- e. TP52 TP57 shorted TP58 - TP59 shorted TP61, TP65, TP66, TP62, TP56 grounded $V(t)_{TP3}$ $(V(t)_{TP5})$, $V(t) \frac{h}{TP5} = 1 u(t)$ Verify According to Figure 3.

PRINTS TO

SEP 26 1977

Steam Turbine


APPROVALS


DIV OR

P3K-AL-0461-A01

+

CODE IDENT NO.





FF-803-WA 12-741 PRINTED IN U.S.A. A

CODE TOENT