CONT ON SHEET TITLE TEST INSTRUCTIONS TO THUD POS. IND. (ASSEMBLY DRAWING 11709105 G1) P3K-AL-0426-A01 FIRST MADE FOR ENC MARK CONT ON SHEET SH NO.

SCOPE

REVISIONS

This instruction outlines the test specifications for circuit board 1TM1-A001 (Reference Drawing 117D9105).

CIRCUIT DESCRIPTION II.

The Thrust Bearing Wear Detector Position Indicator Demodulator is an electronic circuit which transforms the output of an LVDT into a DC current suitable for driving a milliammeter.

The circuit operates as follows: The LVDT secondary output voltages are first individually amplitude demodulated and then electronically summed to produce a DC voltage which is proportional to the magnitude of the LVDT differential output voltage, and polarized to indicate the direction of LVDT core position. Extensive filtration is then applied to eliminate 400 HZ ripple from the DC voltage.

In the circuit, Amplitude Demodulation is performed by two half wave rectifier stages, IC1 and IC2. One stage, IC1, produces a positive half wave rectified wave form while the other, IC2, produces a negative one, as illustrated in figure 1.

The operational amplifiers which perform the half wave rectification. operate in two distinct states. When diodes CR6 and CR8 are conducting (CR5 and CR7 cut off), the half wave rectifier output votlages are determined by the feedback resistance (R_{F} = R_9 = R_{10}), the input resistance (R_{I} = R_3 = R_4 = R5 = R6) and the input capacitance ($\overline{C} = C5 = C6$):

$$\frac{E_{OUT}}{E_{IN}} (PEAK) = \frac{R_F}{2R_I} \left[\frac{1 + R_I C S}{2} \right] = 1.327 \angle -45^{\circ} \text{ at 400 HZ}$$

During the "off" state, when diodes CR5 and CR7 are conducting (CR6 and CR8 cut off), resistors R11 and R12 are used to clamp the output voltages at zero volts.

The outputs of the two half wave rectifiers are then filtered, to extract their DC components (1 time their peak value), and electronically added to

a variable offset bias, established by VR1, R13, R14 and R17, which compensates for LVDT mechanical offsets of upto \pm 0.3 inches. The filtration and signal summing is done with a single operation amplifier, IC3.

The output of the summer and filter stage, IC3, is then scaled and filtered to produce a low ripple, calibrated DC voltage suitable for high resolution measurements. Two stages of range adjustment facilitate calibration to within \pm 0.001 volts over the \pm 10 volt range. One range adjustment is a voltage divider consisting of R20 and VR2. The second range adjustment is a variable gain operational amplifier, TC4, which also

APPROVALS

273-2 273-12 273-71° 273-138 273-221

273-227 PRINTS TO

R, SEP 21 1977 SEP 22 1971

DIV OR Steam Turbine Schenectady, N.Y. LOCATION CONT ON SHEET

P3K-AL-0426-A01

CODE IDENT NO

Schenectady, N.Y.

LOCATION CONT ON SHEET

2

CODE IDENT NO

22 1977

+

REV O		TITLE		CONT ON SHEE	•	но. 3
P3K-AL-0426	-A01	9 .	JCTIONS TO TBWD POS. DRAWING 117D9105 G1)		Т	
CONT ON SHEET 4	зн но. 3	FIRST MADE FO	R EHC MARK II			
						REVISION
III. CIRCUIT	SPECIFICATIO	NS (continue	d)			
D. (co	ntinued)					
<i>D</i> : (CO	Lineay			•	•	
2.	Voltage Divi	der Network	for Zero Adjust (R1	3, R14, R17, VR1	L, TP5).	
	VR1 POSITION		VOLTAGE AT TP5	/		
	CCW CW		$-3.414 \pm 1.389 \text{ VD}$ $3.414 \pm 1.389 \text{ VD}$			
3.	Positive Halaces, CR5, CR6, TP3		fier Stage (IC1, R3	, R4, R7, R9, R1	12, C6,	
	a. Transfer	Function				
	$\frac{\text{TP50}}{\text{TP3}} =$	$\frac{-G1}{1 + T_1 S}$				*000***********************************
	Noise Sur	pression La	1.877 ± 0.038 Volts g Time Constant (T1) g Break Point (F1)	$= 402 \pm 24$ use	i c Stages	
	b. AC to DC $\frac{\text{TP50}}{\text{TP3}} = 0$		2 VDC/VRMS at 400 H2	Z	n di subini	
	c. Saturation	on Limits (T	P50)	·		
	±11.5 VD	C (minimum)				
4.	Negative Half CR7, CR8, TP4		fier Stage (IC2, R5	, R6, R8, R10, R	11, C5,	
	a. Transfer	Function		·		
	$\frac{\text{TP51}}{\text{TP4}} =$	-G2 1 + T ₂ S				
	Noise Sup	pression La	1.877 ± 0.038 Volts/ g Time Constant (T2) g Break Point (F2) =	= 402 + 24 use	c	
		Conversion	,			
	$\frac{\text{TP51}}{\text{TP4}} =$	-0.598 <u>+</u> 0.0	012 VDC/VRMS at 400	нZ		
	c. Saturatio	n Limits (T	251)			-
	-	C (minimum)				PRINTS T
	SEP 21 1977	APPROVALS	Steam Turbine	DIV OR P3K-AL	-0426-A01	1,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
ISSUED SEP 2	2 2 1977		Schenectady, N.Y.	LOCATION CONT ON SHEE		NO. 3
PE-803-WA (2-74) PRINTED IN U.S.A.	pa.		1			CODE IDENT !

+

+

ISSUED SEP 21 1977

Steam Turbine

APPROVALS

DIV OR


P3K-AL-0426-A01

Schenectady, N.Y. LOCATION CONT ON SHEET 6

SEP 22 1977

+

CODE IDENT !



1	• *		·····		I	L JIMMAL I	7720 1301	_
1.1	REY ()	TITLE		<u> </u>	,	CONT ON SHEET	51	4 но8
	NO. C/	TEST INSTE	RUCTIONS	TO TBWD I	POS. IND.	1TM-A001	,	
1	p3K-AL-0426-A01	(ASSEMBLY	DRAWING	117D9105	G1)			
	CONT ON SHEET SH NO. 8	FIRST MADE FO	R EHC	MARK II				
		· ·						REVISION
	•							
	·							
		_	4					
+		, R:S.	200-		ከ A ጥ ዩ	8-26-	- 24	
•	SPECIFICATION PREPARED B	R.S. Gord			DAIL			-
İ	·	EHC DESIG	GN ENGINE	ERING				ŀ
	·		•		•			-
				•				
		1						
	(a) c	P 41			ከለጥፑ	9-12	-ファ	
ļ	APPROVED BY P.C. Callan	MANACER		 	DALL			
	P.C. Callan	- PEMAGER					*	
	EHC DESIGN E	NGINEERING						
1.3	EHC DESIGN E	NGINEERING						
'>	EHC DESIGN E	NGINEERING						
' >>	EHC DESIGN E	NGINEERING	en e					
¹ >>	EHC DESIGN E	NGINEERING	en e					
· >>	EHC DESIGN E	NGINEERING	a, i e e e e e e e e e e e e e e e e e e					
**	EHC DESIGN E	NGINEERING	an est Torono					
'	EHC DESIGN E	NGINEERING	en de Parties					
¹ →						90	22	
1		Delet	J. G.		DATI	9-9-	27	
***	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	J. C.		DATI	9-9-	27	
'	TEST PROCEDURE REVIEWED BY	Deberto	L		DATI	<u>9-9-</u>	27	
· · · · · · · · · · · · · · · · · · ·	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	J. C.		DATI	. <u>9</u> -9-	27	
· · >>	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	La		DATI	. <u>9-9</u> -	27	
' ≫	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	J. C.		DATI	. <u>9-9-</u>	27	
' <i>≫</i>	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	La		DATI	9-9-	27	
' ≫	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	J. C.		DATI	9-9-	27	
' <i>≫</i>	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	L		DATI	9-9-	27	
' ≫	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	La		DATI	9-9-	27	
' <i>≫</i>	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	J.C.		DATI	9-9-	27	
' <i>≫</i>	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	Le		DATI	9-9-	27	
· > -	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	J. Co.		DATI	9-9-	27	
' >>	TEST PROCEDURE REVIEWED BY R. Debertoli	Deberto	La		DATI	9-9-	27	ODJA!
· >>	TEST PROCEDURE REVIEWED BY R. Debertoli	De beit	La		DATI	9-9-	27	PRINT
+	TEST PROCEDURE REVIEWED BY R. Debertoli EHC TEST ENG	Deberto		Turbine	DIV O	R	<i>27</i> L-0426-A	
+	TEST PROCEDURE REVIEWED BY R. Debertoli EHC TEST ENG	De beit	Steam	Turbine ctady, N	ÖİV Ö	R	L-0426-A	PRINT