

**g**

GE Energy

**Functional Testing Specification***Parts & Repair Services  
Louisville, KY***LOU-ATE1-DS200PTCT****Test procedure for a card tested on the ATE1 System****DOCUMENT REVISION STATUS:** Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Eric Rouse	10/25/2001
B	Transferred procedure from a general group to a specific single document. Also added asset numbers to section 5.	P. Kelley	6/24/2010

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

<b>PREPARED BY</b> E. Rouse	<b>REVIEWED BY</b> P. Kelley	<b>REVIEWED BY</b>	<b>QUALITY APPROVAL</b> <i>Charlie Wade</i>
<b>DATE</b> 10/25/2001	<b>DATE</b> 6/24/2010	<b>DATE</b>	<b>DATE</b> 6/25/2010

LOU-ATE1-DS200EXPSG REV. B	g  <b>GE Energy</b> Parts & Repair Services Louisville, KY	Page 2 of 3
-------------------------------	--	-------------

## Functional test procedure for an ATE tested item.

### 1. SCOPE

1.1 This is a functional testing procedure for a DS200PTCT card on ATE1.

### 2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

### 3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

### 4. ENGINEERING REQUIREMENTS

#### 4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

#### 4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires broken or cracked

4.2.1.2 Terminal strips / connectors broken or cracked

4.2.1.3 Loose wires

4.2.1.4 Components visually damaged

4.2.1.5 Capacitors leaking

4.2.1.6 Solder joints damaged or cold

4.2.1.7 Circuit board burned or de-laminated

4.2.1.8 Printed wire runs burned or damaged

### 5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1	H033779	ATE1
1	H188591	Test Fixture for DS200PTCTG
1	None	Banana to banana plug connector wire
1	None	AC power cord

<p><b>LOU-ATE1-DS200EXPSG REV. B</b></p>	<p><b>g</b></p> <p><b>GE Energy</b> <i>Parts &amp; Repair Services</i> <i>Louisville, KY</i></p>	<p><b>Page 3 of 3</b></p>
--	--	---------------------------

## 6. TESTING PROCESS

### 6.1 Setup

**6.1.1** As required by ATE instructions

### 6.2 Testing Procedure

**6.2.1** Identify the test to be used on the ATE by matching the model number with the ones on the system and follow the instructions given after execution.

**6.3 \*\*\*TEST COMPLETE \*\*\***

## 7. NOTES

**7.1** Changes to the electronic ATE test are recorded in the [Software Control Database](#)