



GE Energy

## Functional Testing Specification

*Parts & Repair Services  
Louisville, KY*

**LOU-GED-TOFFEE**

### Test Procedure for cards tested on the Toffee System

**DOCUMENT REVISION STATUS:** Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	E Rouse	02/23/2010
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

<b>PREPARED BY</b> Eric Rouse	<b>REVIEWED BY</b>	<b>REVIEWED BY</b>	<b>QUALITY APPROVAL</b> <i>Charlie Wade</i>
<b>DATE</b> 02/23/2010	<b>DATE</b>	<b>DATE</b>	<b>DATE</b> 02/23/2010

<p><b>LOU-GED-TOFFEE REV. A</b></p>	<p><b>g</b></p> <p><b>GE Energy</b> Part &amp; Repair Services Louisville, KY</p>	<p><b>Page 2 of 3</b></p>
---	---	---------------------------

## Functional test procedure for equipment tested on the Toffee Test system

### 1. SCOPE

- 1.1 This is a functional testing procedure for the Toffee Test System for testing various circuit boards. A list of those circuit boards can be found on the Toffee Test System.

### 2. STANDARDS OF QUALITY

- 2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

### 3. APPLICABLE DOCUMENTS

- 3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

### 4. ENGINEERING REQUIREMENTS

- 4.1 Equipment Cleaning
- 4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- 4.2 Equipment Inspection
- 4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
- 4.2.1.1 Wires broken or cracked
  - 4.2.1.2 Terminal strips / connectors broken or cracked
  - 4.2.1.3 Loose wires
  - 4.2.1.4 Components visually damaged
  - 4.2.1.5 Capacitors leaking
  - 4.2.1.6 Solder joints damaged or cold
  - 4.2.1.7 Circuit board burned or de-laminated
  - 4.2.1.8 Printed wire runs burned or damaged

### 5. EQUIPMENT REQUIRED

- 5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1	H188818	Toffee Test System #14
1	As required	Toffee test fixture for specific model number

<p><b>LOU-GED-TOFFEE REV. A</b></p>	<p><b>g</b></p> <p><b>GE Energy</b> <i>Part &amp; Repair Services Louisville, KY</i></p>	<p><b>Page 3 of 3</b></p>
---	--	---------------------------

## 6. TESTING PROCESS

### 6.1 Setup

6.1.1 Install fixture onto TOFFEE test System.

6.1.2 Install Unit Under Test into proper test fixture.

### 6.2 Testing Procedure

6.2.1 Load appropriate test program and follow instructions on screen.

6.3 **\*\*\*TEST COMPLETE \*\*\***

## 7. NOTES

7.1 None at this time

## 8. ATTACHEMENTS

8.1 Picture of the Toffee Test System

