g		GE Energy		Functional T	esting Spe	cification		
Parts & Repair Services Louisville, KY				LOU-UTS-DS3800NGRD				
Test Procedure for cards tested on the UTS-3000 Tester								
DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column								
REV.		DESCRIPTION		SI	GNATURE	REV. DATE		
Α	Initial release on the	UTS System		Ste	ve Pharris	5/26/2011		
В								
С								
© COP	YRIGHT GENERAL ELECTI	RIC COMPANY						
Hard copies are uncontrolled and are for reference only.  PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.								
	ARED BY Pharris	REVIEWED BY Eric Rouse	REVIEWE	D BY	QUALITY APP			
			DATE		Charlie Was	re		
<b>DATE</b> 5/26/2	2011	<b>DATE</b> 5/26/2011	DATE		<b>DATE</b> 5/26/2011			

LOU-UTS-DS3800NGRD
REV. A

GE Energy
Part & Repair Services
Louisville, KY

Page 2 of 3

Functional test procedure for a DS3800NGRD card tested on the UTS Test System.

### 1. SCOPE

1.1 This is a functional testing procedure for the UTS3000 Tester. This fixture will test the DS3800NGRD card.

## 2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

## 3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
  - **3.1.1** Check board's electronic folder for more information

### 4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
  - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- 4.2 Equipment Inspection
  - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
    - 4.2.1.1 Wires broken or cracked
    - 4.2.1.2 Terminal strips / connectors broken or cracked
    - **4.2.1.3** Loose wires
    - 4.2.1.4 Components visually damaged
    - 4.2.1.5 Capacitors leaking
    - 4.2.1.6 Solder joints damaged or cold
    - 4.2.1.7 Circuit board burned or de-laminated
    - 4.2.1.8 Printed wire runs burned or damaged

### 5. EQUIPMENT REQUIRED

**5.1** The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description	
1		UTS3000 Tester	
1	H188981	DS3800NGRC Fixture	

GE Energy
Part & Repair Services
Louisville, KY

## LOU-UTS-DS3800NGRD REV. A

# 6. TESTING PROCESS

- 6.1 Setup
  - **6.1.1** Install test fixture H188981.
  - **6.1.2** As required by UTS3000 instructions.
- 6.2 Testing Procedure
  - **6.2.1** Identify the test to be used on the UTS3000 by matching the model number with the ones on the system and follow the instructions given after execution.
- 6.3 \*\*\*TEST COMPLETE \*\*\*
- 7. NOTES
  - 7.1 None at this time.
- 8. Attachments
  - **8.1** None at this time.