


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-10

Sample Type & Sample Depth from top : SPT & 0.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	17	22.39
2	21	22.33
3	23	21.08
4	32	19.89

TEST RESULTS

Liquid Limit (w_L)	: 21.00 %
Plastic Limit (w_P)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-10

Sample Type & Sample Depth from top : SPT & 3.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	15	17.99
2	17	18.29
3	26	16.50
4	32	14.46

TEST RESULTS

Liquid Limit (w_L)	: 16.10 %
Plastic Limit (w_P)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-10

Sample Type & Sample Depth from top : SPT & 13.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	16	19.74
2	19	19.94
3	20	19.50
4	32	18.18

TEST RESULTS

Liquid Limit (w_L)	: 18.90 %
Plastic Limit (w_P)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.