


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-13

Sample Type & Sample Depth from top : UDS & 1.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	17	36.32
2	22	34.20
3	26	32.54
4	28	33.40

TEST RESULTS

Liquid Limit (w_L)	: 33.50 %
Plastic Limit (w_P)	: 15.40 %
Plasticity Index (PI)	: 18.10 %

Remarks / Note:


- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.

LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-13

Sample Type & Sample Depth from top : UDS & 4.50 m



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	15	34.84
2	17	34.57
3	19	34.95
4	30	30.71

TEST RESULTS

Liquid Limit (w_L)	: 32.20 %
Plastic Limit (w_P)	: 14.70 %
Plasticity Index (PI)	: 17.50 %

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-13

Sample Type & Sample Depth from top : SPT & 6.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	17	24.92
2	21	24.24
3	25	24.00
4	28	22.87

TEST RESULTS

Liquid Limit (w_L)	: 23.60 %
Plastic Limit (w_P)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-13

Sample Type & Sample Depth from top : SPT & 10.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	15	24.44
2	19	24.30
3	25	22.59
4	31	20.56

TEST RESULTS

Liquid Limit (w_l)	: 22.20 %
Plastic Limit (w_p)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-13

Sample Type & Sample Depth from top : SPT & 13.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	15	21.30
2	18	20.18
3	20	20.62
4	27	19.19

TEST RESULTS

Liquid Limit (w_L)	: 19.50 %
Plastic Limit (w_P)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.