


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-14

Sample Type & Sample Depth from top : UDS & 1.50 m



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	17	35.92
2	21	35.63
3	26	34.01
4	29	32.68

TEST RESULTS

Liquid Limit (w_L)	: 34.00 %
Plastic Limit (w_P)	: 16.00 %
Plasticity Index (PI)	: 18.00 %

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-14

Sample Type & Sample Depth from top : UDS & 4.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	18	37.77
2	19	36.18
3	22	35.31
4	31	33.90

TEST RESULTS

Liquid Limit (w_L)	: 35.00 %
Plastic Limit (w_P)	: 15.40 %
Plasticity Index (PI)	: 19.60 %

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-14

Sample Type & Sample Depth from top : SPT & 6.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	16	37.95
2	22	34.64
3	24	35.58
4	32	33.37

TEST RESULTS

Liquid Limit (w_L)	: 34.80 %
Plastic Limit (w_P)	: 14.90 %
Plasticity Index (PI)	: 19.90 %

Remarks / Note:


- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.

LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-14

Sample Type & Sample Depth from top : UDS & 7.50 m



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	18	35.32
2	22	34.27
3	23	34.71
4	29	32.66

TEST RESULTS

Liquid Limit (w_l)	: 33.70 %
Plastic Limit (w_p)	: 15.00 %
Plasticity Index (PI)	: 18.70 %

Remarks / Note:


- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.

LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-14

Sample Type & Sample Depth from top : SPT & 10.50 m



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	15	32.62
2	19	32.65
3	26	30.53
4	30	28.88

TEST RESULTS

Liquid Limit (w_L)	: 30.40 %
Plastic Limit (w_P)	: 15.50 %
Plasticity Index (PI)	: 14.90 %

Remarks / Note:


- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.

LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-14

Sample Type & Sample Depth from top : SPT & 13.50 m



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	16	32.55
2	19	30.54
3	24	29.62
4	31	29.14

TEST RESULTS

Liquid Limit (w_L)	: 29.80 %
Plastic Limit (w_P)	: 14.60 %
Plasticity Index (PI)	: 15.20 %

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : CBH-14

Sample Type & Sample Depth from top : SPT & 15.00 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	16	31.07
2	22	27.99
3	26	28.47
4	28	27.13

TEST RESULTS

Liquid Limit (w_L)	: 28.00 %
Plastic Limit (w_P)	: 14.60 %
Plasticity Index (PI)	: 13.40 %

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.