


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : **SBH-05**
Sample Type & Sample Depth from top : **SPT & 3.50 m**

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	15	12.70
2	18	12.11
3	22	11.22
4	27	11.20

TEST RESULTS

Liquid Limit (w_L)	: 11.20 %
Plastic Limit (w_P)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : SBH-05

Sample Type & Sample Depth from top : UDS & 4.50 m

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	18	36.09
2	21	35.12
3	22	35.58
4	29	34.22

TEST RESULTS

Liquid Limit (w_L)	: 34.80 %
Plastic Limit (w_P)	: 16.50 %
Plasticity Index (PI)	: 18.30 %

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.


LIQUID LIMIT DETERMINATION - FLOW CURVE

Test Method: IS 2720 (Part 5)

Borehole ID : **SBH-05**

Sample Type & Sample Depth from top : **SPT & 10.00 m**

FLOW CURVE



LIQUID LIMIT TEST OBSERVATIONS

Trial No.	Number of Blows (N)	Moisture Content, w (%)
1	16	20.32
2	22	17.66
3	24	18.38
4	27	17.15

TEST RESULTS

Liquid Limit (w_L)	: 17.60 %
Plastic Limit (w_P)	: —
Plasticity Index (PI)	: —

Remarks / Note:

- Flow curve plotted as per IS 2720 (Part 5) using semi-logarithmic scale.
- Liquid Limit reported at 25 blows from the best fit line.