HMI–01 LABVIEW SCADA SCREEN WIREFRAME CONCEPTUAL FRONT PANEL DESIGN SEE DWG 015 / SHEET 1 OF 3, SHEET 2 OF 3, AND SHEET 3 OF 3

A. HMI TREND / PRODUCTION SCREEN

HMI–01
TREND / PRODUCTION

MAIN | AUTO | MANUAL | ALARM | TREND | SETTINGS

LIVE TREND — SEE DWG 015 / SHEET 3 OF 3

- PROCESS / VIBRATION
- PROXIMITY
- MOTOR SPEED

X–AXIS TIME Y–AXIS ENGINEERING VALUE

TREND CHANNEL SELECT

X	PROCESS / VIBRATION
X	PROXIMITY
X	MOTOR SPEED
	TEST POSITION
	DIGITAL I/O STATUS

PRODUCTION SUMMARY

TOTAL CYCLE COUNT 00001234	CURRENT BATCH COUNT 00000024
GOOD COUNT 00001198	LAST CYCLE TIME 00:01:42
REJECT COUNT 00000036	AVERAGE CYCLE TIME 00:01:38

TREND TIME RANGE

LIVE | 1 MIN | 10 MIN | 1 HOUR | CUSTOM

FROM YYYY–MM–DD HH:MM
TO YYYY–MM–DD HH:MM

APPLY RANGE

CURRENT PRODUCTION STATUS

CURRENT MODE AUTO	SEQUENCE STATE S10 READY / IDLE	
CURRENT RESULT PASS	LAST COMPLETED TIME YYYY–MM–DD HH:MM	LAST COMPLETED PART PART–00001234

B. HMI SETTINGS / USER ACCESS SCREEN

HMI–01
SETTINGS / USER ACCESS

MAIN | AUTO | MANUAL | ALARM | TREND | SETTINGS

CURRENT USER

USER NAME OPERATOR_01	ACCESS LEVEL OPERATOR
LOGIN TIME YYYY–MM–DD HH:MM	

USER COMMAND

LOGIN | LOGOUT

SETPOINT EDITING REQUIRES ENGINEER ACCESS.

CHANGE PASSWORD

USER ACCESS SHALL NOT BYPASS PLC SAFETY INTERLOCKS.

SYSTEM SETTINGS STATUS

SETPOINT EDIT ENABLE LOCKED	DATA LOGGING ENABLED
TIME SYNCHRONIZATION OK	HMI CONFIGURATION REV A

C. HMI COMMUNICATION / DIAGNOSTIC SCREEN

HMI–01
COMMUNICATION / DIAGNOSTIC

MAIN | AUTO | MANUAL | ALARM | TREND | SETTINGS

COMMUNICATION STATUS

DEVICE	PROTOCOL	LINK STATUS	LAST UPDATE	ERROR COUNT
PLC–01	MODBUS TCP / ETHERNET	CONNECTED	YYYY–MM–DD HH:MM:SS	0000
MCU–01	MODBUS RTU / SERIAL	CONNECTED	YYYY–MM–DD HH:MM:SS	0000

COMMUNICATION DETAIL

PLC POLL RATE	MCU POLL RATE	LAST PLC RESPONSE	LAST MCU RESPONSE	COMMUNICATION FAULT STATUS
XXX ms	XXX ms	YYYY–MM–DD HH:MM:SS	YYYY–MM–DD HH:MM:SS	NORMAL

TREND, PRODUCTION, HISTORY, AND COMMUNICATION DATA SHALL BE RECORDED BY HMI–01 EVENT / DATA LOGGING FUNCTION.

HMI REQUESTS SHALL BE VALIDATED BY PLC–01.
HMI–01 SHALL NOT DIRECTLY WRITE PLC OUTPUTS P20~P29 OR REPLACE HARDWIRED SAFETY FUNCTION.

HMI TAG / DATA LOGGING / COMMUNICATION MAP:
SEE DWG 015 / SHEET 3 OF 3.

DIAGNOSTIC COMMAND

REFRESH STATUS

COMMUNICATION DIAGNOSTIC COMMANDS SHALL NOT WRITE PLC OUTPUTS.

PLC–01 SAFETY FUNCTION SHALL REMAIN HARDWIRED AND INDEPENDENT OF HMI COMMUNICATION.

DIAGNOSTIC COMMAND PANEL SHOWN OUTSIDE SCREEN FRAME FOR DRAWING CLARITY.
PANEL SHALL BE LOCATED IN THE LOWER AREA OF THE HMI COMMUNICATION / DIAGNOSTIC SCREEN.

NO.	DATE	REVISION
A	2026–09–18	INITIAL RELEASE

DWG TITLE
EDS Wafer Map Linked Package
Final Test and Multi–Bin Sorting Cell

SCADA HMI TREND / PRODUCTION / SETTINGS / COMMUNICATION SCREEN

DRAWN BY J. H. KO
DATE 2026–09–18
DWG NO 016
SHEET NO 3 OF 25