AC ZONE

Isolation /protection
PLC AC supply

CONTROL POWER

PS-01 /24V branches
Power and signal separation

CONTROLLERS

PLC-01 LS /PLC-02 FX
Safety device separate
Exact footprints required

INTERFACES

Relays /suppression
Communications
Keep wiring accessible

TERMINAL /PE ZONE

TB-AC /TB-24C /TB-24S /TB-DI /TB-DO /TB-COM /PE
Physical terminal counts, pitch and conductor sizes to select.
No fixed enclosure600×800 dimensions asserted.

PLANNED TERMINAL GROUP SUMMARY	
Group	Purpose
TB-AC	L/N body/SMPS branches
TB-24C	Maintained controls/indicators
TB-24S	Safety-controlled actuators
TB-DI	Field sensors and pushbuttons
TB-DO	Load signal/return pairs
TB-COM	Only selected real interfaces
PE	Protective conductors

LAYOUT RELEASE CHECKS

Choose enclosure/IP/thermal load.
Check door device depth and terminal clearance.
Separate power /motor /signal routes.
Confirm rail/mounting and bend radii.
Label wires and both cable ends.
PB-04: planned manual safety reset, separate from process RESET; see drawing 019.
Add dimensions only after component footprints are known.

Panel layout is functional NTS, not a fabrication template. Actual clearance, duct width, ventilation and protective bonding are open design inputs.

NO.	DATE	REVISION
R0	2026-10-22	CONCEPT / NOT FOR CONSTRUCTION

DWG. TITLE

SEMICON SORTER PROJECT
Final Test and Multi-Bin Sorting Cell

PLANNED PANEL ZONE AND TERMINAL GROUPS

DRAWN BY	DATE
J. H. KO	2026-10-14

DWG. NO

021

SHEET NO

1 OF 1