LP - 708 - IDN

LAPORAN UJI
TEST REPORT

No:QI-26/02/0002

KLIEN
CLIENT : Mr Ram Ranaje

NAMA SAMPEL
NAME OF SAMPLE : ALTERNATING CURRENT LAMPHOLDERS

MEREK
TRADE MARK : {BrandLogo}

JENIS SMPEL
TYPE OF SAMPLE : CONNECTOR PLUG AND CONNECTOR BOX

KATEGORY
TEST CATEGORY : Uji Jenis (Type Test)

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

LAPORAN PENGUJIAN
TEST REPORT

Tanggal penerimaan sampel *Sample receiving date*	: 02 February 2026	No. order kerja *Work order no.*	:
Tanggal pelaksanaan uji *Test performing date*	: 02 February 2026	No. laporan uji *Test report no.*	: QI-26/02/0002

Nama klien *Client´s name*	: Mr Ram Ranaje
Alamat *Address*	: xyz,abc, fdw, vadodara, 391101, INDIA
No. Referensi *Reference no.*	: 2026000825

Nama sampel pengujian Name of test sample	: ALTERNATING CURRENT LAMPHOLDERS
Marek Trade mark	: yugh
Jenis sampel Type of sample	: CONNECTOR PLUG AND CONNECTOR BOX
Peringkat Rating	: 16A 250V~
Metode uji Test method	: SNI IEC 60669-1: 2013
Laboratorium penguji Test laboratory	: PT. Qualis Indonesia

Pernyataan umum/General statement
- Sampel yang diserahkan tidak diambil oleh laboratorium/The submitted samples are not drawn by the laboratory
- Laporan pengujian hanya berlaku untuk objek yang diuji/The test report applies only to the object tested

Uji Listrik *(Electrical test)*
Lulus *(Pass)*

Uji Fisik *(Physical test)*
Lulus (Pass)

Uji Mekanik (Mechanical test)
Lulus (Pass)

Berdasarkan evaluasi hasil uji dan standar uji perangkat tersebut di atas
Based on the evaluation of the test results and the test standards mentioned above

MEMENUHI
COMPLY

Approved and digitally signed on behalf of
PT. Qualis Indonesia

Dokumen ini diterbitkan secara elektronik dan tidak diperlukan tanda tangan basah.
This document is electronically generated and bears no signature.

Silahkan memindai kode QR untuk verifikasi keaslian dokumen.
Please scan QR code to verify document originality.

Yana Diana
Laboratory Manager

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

PT. Qualis Indonesia || Testing, Certification, Inspection, Calibration

Head Office & Laboratory
Jl. Pajajaran No. 17, Gandasari, Kec. Jatiuwung, Tangerang 15137 – INDONESIA
T:(021) 5565 2583/86 || F:(021) 5565 2489 || www.qualis-indonesia.com

Marketing Office
Artha Gading Niaga Blok H No. 1-2, Kelapa Gading, Jakarta Utara 14240 – INDONESIA
T:(021) 4585 0885 || F:(021) 4585 0661 || www.qualis-indonesia.com

Deskripsi objek pengujian:
Description of the test object:

Nama klien & alamat	: **Mr Ram Ranaje**
Client´s name & Address	: xyz,abc, fdw, vadodara, 391101, INDIA
Nama perusahaan & alamat	: **ASRT PVT LTD**
Company name & address	: xyz,abc, fdw, vadodara, 391101, INDIA
Nama pabrik & alamat	: **ASE PVT LTD**
Factory name & address	: Halol GIDC
Merek	: yugh
Trade mark	
Jenis sampel	: CONNECTOR PLUG AND CONNECTOR BOX
Type of sample	
Peringkat	: 16A 250V~
Rating	
Jumlah sampel	: 2
Number of samples	
Jumlah kutub	
Bukaan kontak (gap)	
Tingkat proteksi terhadap efek bahaya karena masuknya benda asing padat	
Tingkat proteksi terhadap efek bahaya karena masuknya air	
Metode pergerakan sakelar	
Metode pemasangan sakelar	
Jenis terminal	
Metode instalasi sakelar	

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

Test sample photo:

{images}

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

Testing/measuring equipment:

No.	Nama Alat/Equipment name
1.	Magnifying glass
2.	Water, Petroleum Spirit, Soft cotton cloth
3.	Digital caliper
4.	Space gauge
5.	Contact sequence tester
6.	IEC 61032 Probe B
7.	IEC 61032 Probe 11
8.	Voltage droop tester
9.	Torque driver
10.	Conductor damage tester
11.	Pull & push gauge
12.	High temperature test chamber
13.	Constant temperature & humidity machine
14.	High voltage insulation Hi tester
15.	High voltage tester
16.	Temperature recorder
17.	Temperature rising tester
18.	Endurance tester
19.	AC single phase load
20.	Impact tester
21.	Withdrawal tester
22.	Plug compression tester
23.	High-precision circulator exact oven
24.	Ball pressure device
25.	Stopwatch
26.	Optical magnifier (Lupe)
27.	Glow wire tester

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

Test summary:

{TestSummary}

Test case decision description:

Pass (L)	: Meet the requirements
Failed (TL)	: Does not meet the requirements
Not Applicable (TB)	: Testing was not performed on the test specimen
/	: Test result decision was not implemented
-	: Test data information only

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

Test results:

Clause	Test requirements	Test Results	Decision
8	**MARKING**		**PASSED**
8.1	**The switches are marked with:**		
	Current (A) or fluorescent load rating (AX) or a combination of both if two different ratings	10AX	L
	Voltage (V)	250V	L
	Supply nature symbol	~	L
8.3	**Switch markings are placed on the main part:**		
	Markings must be clearly visible and easy to read.	Fulfil	L
	Markings should not be placed on parts that cannot be removed without the use of tools	Fulfil	L
8.4	Terminals for connection of line conductors (supply conductors): shall be identified unless the method of connection is unimportant, is selfevident or is stated on the wiring diagram	COM1, COM2, L11, L12, L21, L22	L
	Indications should not be placed on screws or other easily removable parts	Fulfil	L
	Terminals for connecting conductors that do not form part of the primary function of the switch:		
	Switch terminal identification can be accomplished by		
8.9	The marking must be durable and easy to read. Test: The marking is rubbed for 15 seconds with a piece of cloth moistened with water and then for another 15 seconds with a piece of cloth moistened with petroleum spirit.	Fulfil	L
25	**RESISTANCE TO RUST**		**PASSED**
	Metal parts, including covers and cases, must be adequately protected against rust.	The terminal metal part is resistant against rust	L

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

	After testing, the surface of the test specimen must not show any signs of rust.	The metal part of the terminal is not rusty	L

********** End of the Test Report**********

The results relate only to the items tested. This report shall not be reproduced except in full.
Do not copy this report without written consent from authorized personnel of PT Qualis Indonesia.

Please be informed that this report is issued under the following conditions:
Harap diketahui bahwa laporan ini diterbitkan dengan ketentuan sebagai berikut:

1. Test/calibration result in the form of official report will be issued immediately after testing/calibration has been completed. Hasil pengujian/kalibrasi dalam bentuk laporan resmi akan diterbitkan segera setelah pengujian/kalibrasi selesai dilakukan.
2. Unless otherwise specified by the Client, this report shall only contain technical evaluation results conducted by PT QUALIS INDONESIA. In the event of a requirement to submit analysis, interpretation of the results, opinions and/or professional recommendations expressed thereupon, then these shall be indicated PT QUALIS INDONESIA in writing and additional fee, if applicable, borne by the Client.
   Laporan ini hanya berisi hasil evaluasi teknis yang dilakukan oleh PT QUALIS INDONESIA kecuali diminta sebaliknya oleh Klien. Dalam hal diperlukannya penyampaian analisis, interpretasi terhadap hasil, pendapat dan/atau rekomendasi profesional, maka semua perlu disampaikan secara tertulis kepada PT QUALIS INDONESIA dan jika ada biaya tambahan maka akan dibebankan kepada Klien.
3. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that PT QUALIS INDONESIA approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that PT QUALIS INDONESIA in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
   Laporan ini berlaku untuk sampel produk/peralatan tertentu yang diajukan pada saat pengujian/kalibrasi. Segala hasil tidak dapat digunakan untuk menunjukkan atau menyiratkan bahwa hasil evaluasi sampel berlaku untuk barang serupa lainnya. Selain itu, hasil tersebut tidak dapat digunakan untuk menunjukkan atau menyiratkan bahwa PT QUALIS INDONESIA menyetujui, merekomendasikan atau mengesahkan pabrikan, pemasok atau pengguna produk/peralatan tersebut, atau bahwa PT QUALIS INDONESIA dalam bentuk apapun "menjamin" kinerja produk/peralatan untuk seterusnya. Kecuali dinyatakan lain dalam laporan ini, tidak ada pengujian yang dilakukan untuk menentukan efek jangka panjang penggunaan produk/peralatan yang dimaksud.
4. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. PT QUALIS INDONESIA therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any other information supplied.
   Sampel yang dicantumkan dalam laporan ini diserahkan/disediakan/diproduksi oleh Klien. Oleh karena itu, PT QUALIS INDONESIA tidak bertanggung jawab atas keakuratan informasi tentang nama merek, nomor model, asal-usul pembuatan, pengiriman atau informasi lainnya apapun yang diberikan.
5. Additional copies of the report are available to the Client at an additional fee. No third party can obtain a copy of this report through PT QUALIS INDONESIA, unless the Client has authorized PT QUALIS INDONESIA in writing to do so.
   Salinan tambahan dari laporan ini tersedia untuk Klien dengan biaya tambahan. Tidak ada pihak ketiga yang dapat memperoleh salinan laporan ini melalui PT QUALIS INDONESIA, kecuali Klien telah memberi kuasa kepada PT QUALIS INDONESIA secara tertulis untuk melakukannya.
6. PT QUALIS INDONESIA may at its sole discretion add to or amend the conditions of the report at the time of report issuance. Such report and additions or amendments shall be binding on the Client.
   Atas kebijakannya sendiri, PT QUALIS INDONESIA dapat menambah atau mengubah ketentuan laporan pada saat penerbitan laporan. Laporan dan penambahan atau amandemen tersebut bersifat mengikat untuk Klien.
7. All copyright in the report shall remain with PT QUALIS INDONESIA and the Client shall, upon payment of PT QUALIS INDONESIA's fees for the carrying out of the tests/calibrations, be granted the permission to use or publish the report to the third parties subject to the terms and conditions herein, provided that PT QUALIS INDONESIA is always at its absolute discretion entitled to impose such terms and conditions on the report as it sees relevant.
   Seluruh hak cipta atas laporan tetap menjadi milik PT QUALIS INDONESIA dan setelah pembayaran biaya pelaksanaan pengujian/kalibrasi kepada PT QUALIS INDONESIA, Klien akan diberikan ijin untuk menggunakan atau mempublikasikan laporan kepada pihak ketiga dengan syarat dan ketentuan sebagaimana yang tertera dalam laporan ini, dengan catatan bahwa atas pertimbangan mutlaknya, PT QUALIS INDONESIA berhak memberlakukan syarat dan ketentuan yang dimaksud pada laporan yang dianggap relevan.
8. Nothing in this report shall be interpreted to mean that PT QUALIS INDONESIA has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
   Tidak ada hal apapun dalam laporan ini yang dapat ditafsirkan bahwa PT QUALIS INDONESIA telah memverifikasi atau memberikan pengesahan atau tanda dari otoritas atau badan pengujian lain yang mungkin ditemukan pada sampel tersebut.
9. This report shall not be reproduced in parts and no reference shall be made by the Client to PT QUALIS INDONESIA, or to the report or results furnished by PT QUALIS INDONESIA in any advertisements or sales promotion.
   Laporan ini tidak diperkenankan untuk dicetak ulang secara sebagian dan Klien tidak diperkenankan untuk membuat referensi terhadap PT QUALIS INDONESIA dalam iklan atau promosi penjualan, atau terhadap laporan atau hasil yang diterbitkan oleh PT QUALIS INDONESIA