Test category	Type Test		
Type	KBN426_16S_WE_G3; LNA426_16SP_WE; LNA32_2_WE	**Test Method**	SNI IEC 60669-1: 2013
Ranking	16A 250V~	**Job Order No.**	WO/25110092
Test Date	14/11/2025	**Request No.**	R/25110092
Room Temp.	24	**Sample code**	A
Humidity	59	**Test Equipment No.**	QE/14/PH/56

Clause	Test requirements	Check up result	Decision
8	**MARKING**		**PASSED**
8.1	**The completeness must be marked as follows:**		
	rated current; (A)	16A	L
	rated voltage; (V)	250V	L
	supply nature symbol;	~	TB
	name of the manufacturer or responsible vendor, trademark or identification mark;	-	TB
	reference type, possibly catalog number;	SNI IEC 60884-1 / KBN426_16S_WE_G 3	L
	the first characteristic number for the degree of protection against access to hazardous parts and against the harmful effects of the ingress of solid foreign objects;	-	TB
	the second characteristic number for the degree of protection against the harmful effects of water ingress;	-	TB
	Sockets with screwless terminals shall be marked with the following:		**PASSED**
	proper marking, indicating the length of the insulation to be stripped;	-	TB
	indication of suitability to accept only rigid conductors	-	TB
8.2	Symbol which used must like which required in the standard	Fulfil	L
	The marking for the nature of the supply must be placed next to the marking for the rated current and rated voltage.	Fulfil	TL
8.3	**For fixed socket outlets, the following markings must be placed on the main body:**		
	rated current, rated voltage and nature of supply;	16A 250V~	L
	any of the names, trademarks or identification marks of the manufacturer or responsible vendor;		
	the length of insulation to be stripped before inserting the conductor into the screwless terminal, if any;	-	TB
	type reference in the form of a catalog number		
	Parts such as cover plates that are necessary for safety purposes and intended to be sold separately, must be marked with the name of the manufacturer or responsible vendor, trademark or identification mark and type reference.	-	TB
	The protection level code, if applicable, should be marked so that it is easily visible when the contact box is installed and wired for normal use	-	TB
8.4	Plugs and portable socket-outlets the marking specified in 8.1, in addition to the type reference, shall be readily visible when the accessories are wired and assembled.	-	TB
	Portable plugs and socket-outlets for class II equipment shall not be marked with the symbol for class II construction.	-	TB
8.5	Terminals intended exclusively for the neutral conductor shall be indicated by the letter N.		

	The earthing terminal for the connection of protective conductors shall be indicated by an earthing symbol.		
	This marking should not be placed on screws or other easily removable parts.		
8.5	**Terminals for connecting conductors that do not form part of the socket-outlet:**		
	must be clearly identified unless the intent is self-evident, or		
	indicated in the wiring diagram that must be fixed to the equipment		
-	**Complete terminal identification can be obtained by:**		
	marking with graphic symbols in accordance with IEC 60174-2 or color and/or letter-number systems, or		
	marking with physical dimensions or relative location.		
8.6	For surface mount boxes which are an integral part of a contact box having an IP code higher than IP20, the IP code must be marked on the outside of the enclosure so that it is easily visible when the contact box is installed and wired as in normal use.		
8.7	The IP code must be indicated by the marking or in the manufacturer's catalogue or instruction sheet where the position or by special provisions the stated degree of protection of the fixed socket-outlet of the submerged or semi-submerged type is confirmed to be higher than IPX0.		
8.8	The marking must be durable and easy to read. Test: The marking is rubbed for 15 seconds with a piece of cloth moistened with water and then for another 15 seconds with a piece of cloth moistened with petroleum spirit.		TB

Test case decision description:

- Testing meets requirements : Pass (L)
- Testing does not meet requirements : Not Passed (TL)
- Testing does not apply to test objects : Not applicable (TB)

PT Qualis Indonesia	Witnessed by		
	Name	Company	Signature
Tested by:			

Checked by:			