Test category	Type Test		
Type	LNA426_16SP_WE, KBN426_16S_WE_G3	**Test Method**	SNI IEC 60884-1: 2014
Ranking	16A 250V~	**Job Order No.**	WO/25110097
Test Date	21/11/2025	**Request No.**	R/25110097
Room Temp.	24	**Sample code**	A
Humidity	57	**Test Equipment No.**	QE/14/PH/56

Clause	Test requirements	Check up result			Decision
19	**TEMPERATURE RISE**				**PASSED**
	The fittings shall be constructed so as to satisfy the temperature rise test.				L
	Non-rewireable accessories are tested upon delivery.				L
	Flexible cable type; number of conductors and nominal cross-sectional area (mm2)	-			TB
	Rewireable equipment is installed with PVC insulated conductors having nominal cross-sectional areas as shown in table 15				TB
	Complete rated current; (A)	16A			L
	Nominal cross-sectional area; (mm^2)	2.5mm^2			L
	Conductor type; (rigid solid/rigid stranded)	Solid stiff			L
	Terminal screws or nuts are tightened to a torque equivalent to two-thirds of that specified in 12.2.8; (Nm)	0.8Nm			L
	The contact box is tested using a brass pin having the specified minimum dimensions	The socket is tested usingthe appropriate socket.standard requirements			TL
	The test current is applied for 1 hour; (A)	22A			L
	The temperature rise should not exceed 45 K (K)	A	B	C	ABC
		< 45	< 45	< 45	
	Phase contact (K)	22.4	19.2	18.5	L
	Neutral contact (K)	21.4	18.9	18.3	L
	Earth contact (K)	17.5	16.4	13.3	L
	For the purposes of test 25.3, the temperature rise of the external parts of the insulating material need not hold the current-carrying parts and the earthing circuit parts in position (K)	-	-	-	TB
	Plugs with side earthing contacts and springloaded earthing contacts are tested using a fixed socket-outlet that meets this standard	-			TB
	The temperature rise should not exceed 45 K (K)	A	B	C	ABC
		< 45	< 45	< 45	
	Phase contact (K)	-	-	-	TB
	Neutral contact (K)	-	-	-	TB
	Earth contact (K)	-	-	-	TB
	For the purposes of test 25.3, the temperature rise of the external parts of the insulating material need not hold the current-carrying parts and the earthing circuit parts	-	-	-	TB

	in position (K)		

Test case decision description:

- Testing meets requirements : Pass (L)
- Testing does not meet requirements : Not Passed (TL)
- Testing does not apply to test objects : Not applicable (TB)

PT Qualis Indonesia	Witnessed by		
	Name	Company	Signature
Tested by:			
Checked by:			