

# Simultaneous Sensor and Actuator Placement for Contaminant Detection and Mitigation in Water Distribution Networks

Suhas Gundimeda<sup>a</sup>, Venkata Reddy Palleti<sup>a</sup>, Shankar Narasimhan<sup>a</sup>

<sup>a</sup>*Department of Chemical Engineering, Indian Institute of Technology Madras, Chennai 600036, India*

---

## Abstract

Water Distribution Networks (WDNs) are considered to be part of the critical infrastructure of any city. WDNs are often exposed to either accidental or intentional contamination. Therefore, it is very important to protect the public from such kinds of incidents. These contaminants can be detected by deploying sensors in the work. Once the sensors detect the presence of a contamination, it is also necessary to take appropriate actions in order to mitigate the effects of contaminations. Therefore, in this paper, we propose an optimal simultaneous sensor and actuator placement for contamination detection and mitigation in WDNs. A multi-objective mixed integer linear optimization formulation is proposed to obtain the optimal sensor and actuator placement. The proposed method is demonstrated on the real urban water distribution system.

*Keywords:* Water distribution networks, observable sensor network, actuator network, contamination detection and mitigation.

---

## 1. Introduction

Water Distribution Networks (WDNs) are networks of pipes, tanks, pumps, valves, and other components that are used to distribute water from sources, like reservoirs, to consumers. The topology of the network, number of consumer nodes, loading conditions, hydraulic elements etc make the control of a water distribution system a difficult

task and makes it highly vulnerable to contamination (Kessler et al., 1998). WDNs are often susceptible to either accidental or intentional contamination. Accidental contamination occurs due to system deficiencies (e.g, cross connections, pipeline breakage) and intentional contamination occurs as a result of deliberate acts of chemical or biological intrusions. Introduction of chemical or biological agents in WDN can damage public health. After 9/11 attacks in United States, the concern over possible terrorist attacks on WDN has increased and can be considered as the most serious threat to WDNs (Ostfeld et al., 2008). Hence, it is very important to detect such kinds of attacks as quickly as possible and it is also necessary to take appropriate actions to mitigate the effects of a contamination event. Suggested detection and response methods are varied, and one such is the placing of online sensors and actuators (or shut-off valves) for detection and containment of contaminants. The sensors can be used to detect the contaminants, and the actuators are useful to shut down the network to prevent further spread of contaminants. Therefore, in this paper we propose a methodology to obtain an optimal sensor and actuator placement for contaminant detection and mitigation of the contamination effects.

The problems of contaminant detection in WDNs and appropriate response to a contamination event have been addressed in literature. Numerous procedures are available in the literature for the contamination detection problem. However, very few studies are available with respect to the problem of response to contamination events. Several optimization algorithms have been proposed for the problem of sensor placement for contamination detection in WDNs. Single objective optimization problems(Kessler et al., 1998; Lee and Deininger, 1992; Berry et al., 2005; Kumar et al., 1997) are solved by considering objectives for maximizing the demand coverage, maximizing the likelihood detection and minimizing the elapsed time between the injection and detection of contaminants. Further, multi-objective optimization problems (Ostfeld et al., 2008; Rico-Ramirez et al., 2007; Preis and Ostfeld, 2008;

Watson et al., 2004) have been solved by considering objectives for minimizing the time of detection, minimizing the contaminated volume consumed prior to detection, population at risk etc. The problem of contamination source identification based on deployed sensor measurements have been reported (Mann et al., 2012; Laird et al., 2005). Sensor placement algorithm using the principle that there must exist a unique non-zero set of sensors for each of the vulnerable nodes was developed by Palleti et al. (2016). In this paper, the graph abstraction of water distribution networks with vulnerable nodes representing multiple real nodes and used sets of affected nodes to find a viable sensor placement.

Although, design of a sensor network to detect and identify intentional contamination of a WDN is important, it is also necessary to consider the potential action that one can take to mitigate the effect of the contaminant. Once the sensor network detects the presence of a contaminant, U.S. Environmental Protection Agency’s (USEPA) response protocol toolbox (USEPA, 2004a) provides recommendations for implementation of specific responses to minimize the effect of contamination event. This protocol includes the detection, source identification followed by consequence management strategies. Various researchers have developed methodologies related to the detection and source identification problems as described earlier. Once a contaminant has been detected, water utilities must evaluate the response to the contamination so that potential impact to the public can be minimized. These consequence management strategies may include: (1) public notification, (2) isolation and containment of a contaminant through valve operations (USEPA, 2004a), (3) flushing the contamination system, and (4) combinations of isolation, notification, and flushing (USEPA, 2004b). Very few studies are available with respect to the mitigating actions that would be taken after detecting the presence of contaminant in the WDN (Poulin et al., 2008, 2010; Preis and Ostfeld, 2008; Guidorzi et al., 2009; Alfonso et al., 2010) . Heuristic procedures are proposed for isolating a contaminated area

through the simultaneous closure of a number of valves in the system, assuming an unlimited number of response teams and subsequent removal of the contaminant by unidirectional flushing Poulin et al. (2008, 2010) . Preis and Ostfeld (2008) proposed a multi-objective approach with the aim of minimizing the number of operations to be performed and to reduce the consumption of contaminated water by consumers for a given specific contamination event. Such an approach is useful only when complete knowledge of the contaminant history is known (in terms of intrusion location, duration and quantity of contaminant injected). Similarly, multi-objective procedures were proposed to identify the minimum number of operations that minimize the contaminated water consumption (Guidorzi et al., 2009; Alfonso et al., 2010). These approaches (Guidorzi et al., 2009; Alfonso et al., 2010) have not considered the characteristics of the contamination event (i.e, location, duration and quantity of contaminant introduced). Later, the problem of optimal scheduling of device activation in order to minimize the consumption of contaminated water after the detection of a contaminant has been studied by Alvisi et al. (2012).

The previous studies focused on operational strategies to be implemented in the event of a contaminant detection assuming that valves are already present in the network. The design problem of optimal valve placement to minimize the effects of contamination events has not been reported in the literature. But recently, Palleti et al. (2018) proposed a methodology for design of actuator network for a given sensor network to mitigate contamination effects in WDNs. In their work, shut-off valves are placed on optimal number of pipes so that it is possible to shutdown the network to prevent the uncontaminated part of the network from the contaminated network. Further, they design the actuator network assuming that the sensor network design has already been carried out and locations of sensors are known a priori. It means that the sensor and actuator network designs are carried out independently and they are decoupled. In contrast to this work, in this paper, we obtain a sensor and actu-

ator placement simultaneously for detection and mitigation of contamination effects. Therefore, in this work we propose a multi- objective mixed integer linear optimization formulation is proposed to determine the simultaneous optimal sensor and actuator network. Also, we hypothesize that simultaneous sensor and actuator planning can be achieved and is more efficient than iterative non-linear optimization sequentially solving the two placement problems, i.e. these are not independent problems, and these can be formulated as an integer linear program and solved.

The current work assumes both of these objectives are binary, i.e. no time delay in detection and accurate sensing.

## 2. Problem Description

The water distribution network is represented as a deterministic weighted directed graph,  $G(V, E)$ , where  $E$  represents the edges or connections, and  $V$  represents the vertices or nodes. Nodes are used to represent sources, such as reservoirs or tanks from where water is supplied, as well as demand points where water is consumed and taken out of the network. All the junctions of pipes, such as those from pipes dividing or combining are also regarded as nodes. Pipes, valves, pumps, and other connections are represented as edges in the graph. A typical city's WDN has several hundred nodes and edges. Intentional contamination generally only occurs at sources - tanks, reservoirs, fire hydrants. Unintentional contamination can typically occur at any point in the WDN. In this work, we develop techniques that can be used for the general case, where any set of nodes in the network can be contaminated. These potential sites of intrusion are referred to as vulnerable nodes.

### 2.1. Assumptions

- We are given complete information about the network - (sparse) adjacency matrix, set of nodes vulnerable to contamination, set of nodes which should be

prevented from contamination (demand nodes).

- Each affected node and sensor satisfies all conditions for sensors to identify the presence of contaminant, such as concentration of contaminants, flow rate, sensitivity of sensor, etc.
- This identification of contaminant is instant, binary and without error - neither false positives or false negatives.
- There is no time delay in communication, processing and actuation to stop spread.

All of the vulnerable nodes are infected (not necessarily at the same time) - case 1.  
A subset of vulnerable nodes are contaminated - this required a modified solution - case 2.

## *2.2. Requirements of a solution*

A distribution of sensors on nodes and actuators on edges such that an attack on a subset of vulnerable nodes can be identified and the network shut down.

Three scenarios with different and progressive requirements of a solution are explored in this work, with the differences in formalism illustrated with an example network.

## **3. Base problem: Formulating as Mixed Integer Linear Program (MILP)**

A binary integer optimization problem is presented:

$$\begin{aligned}
\text{PROBLEM I: } & \min(\sum x_i + \sum z_i) \\
& \text{s.t. } \mathbf{A}p \leq \mathbf{b} \\
& \mathbf{A}_{eq}p = \mathbf{b}_{eq}
\end{aligned} \tag{1}$$

Where,  $p = \begin{bmatrix} \mathbf{x} & \mathbf{y} & \mathbf{z} \end{bmatrix}^T$

$\mathbf{x} \equiv [x_i]$  is 1 if there exists a sensor at  $i^{th}$  node, 0 otherwise.

$\mathbf{y} \equiv [y_i]$  is 1 if  $i^{th}$  node is in the demands side of the actuators, 0 otherwise.

$\mathbf{z} \equiv [z_i]$  is 1 if there exists an actuator at  $i^{th}$  edge, 0 otherwise.

Hence the vector  $\begin{bmatrix} \mathbf{x} & \mathbf{y} & \mathbf{z} \end{bmatrix}$  is of length  $2 * N + E$ .

$$\mathbf{A} = \begin{bmatrix} \mathbf{A}_1 & \mathbf{0} \\ \mathbf{0} & \mathbf{A}_2 \end{bmatrix}, \mathbf{A}_{eq} = \begin{bmatrix} \mathbf{A}_{eq1} & \mathbf{0} \\ \mathbf{0} & \mathbf{A}_{eq2} \end{bmatrix}, \mathbf{b} = \begin{bmatrix} b_1 \\ b_2 \end{bmatrix}, \mathbf{b}_{eq} = \begin{bmatrix} b_{eq1} \\ b_{eq2} \end{bmatrix}.$$

$\mathbf{A}_1$  is a matrix of vulnerable nodes versus affected nodes, with  $A_{1ij} = -1$  if  $i^{th}$  vulnerable node affects the  $j^{th}$  node in graph.

$$\mathbf{A}_2 = \begin{bmatrix} \mathbf{J} & \mathbf{I}_{E \times E} \end{bmatrix} \text{ where } \mathbf{J} \text{ is the incidence matrix.}$$

$$b_1 = \begin{bmatrix} \cdot \\ \cdot \\ \cdot \\ -1 \\ \cdot \\ \cdot \\ \cdot \end{bmatrix}, b_2 = [\mathbf{0}].$$

This links the partitioning variables  $\mathbf{y}$  to the variables in the cost function,  $\mathbf{z}$ .

$$\mathbf{A}_{eq1} = b_{eq1} = \mathbf{0}$$

$\mathbf{A}_{eq2}$ ,  $b_{eq2}$  provide bounds to force the decision variables to the constraints of the specific scenario, for example, that the demand nodes should be in the second partition and that the vulnerable nodes should be in the first.

## 4. Scenarios

### 4.1. Scenario of vacuum pipes

#### 4.1.1. Key assumptions

- Shutting down the network effectively stops the contaminant beyond the actuator as well.
- Finite amount of contaminant is allowed reach the demand nodes

In this simpler scenario, there are no additional constraints on the actuator placement problem beyond that of actuator edges being a min-cut of the entire graph. That is, the removal of the pipes in the water distribution network corresponding to the set of actuator edges must partition the network into two - one with all the vulnerable nodes, and one with all the demand nodes. We assert that the sensor and actuator placement problems are independent. As long as the sensor network detects the contaminant before it reaches the demand nodes and the actuation happens immediately, no demand node is compromised. But without additional constraints, this is not guaranteed viz. the formulation presented here minimizes the number of sensor nodes even at the cost of late (post-compromise) detection.

#### 4.1.2. Illustrative artificial network example

Consider the graph represented by 1, with demand node 6 and vulnerable nodes 1 and 2.

This scenario is the same as the base case. The specific matrix defining this example are as follows.

$$A_1 = \begin{bmatrix} -1 & -1 & -1 & -1 & -1 & -1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & -1 & -1 & -1 & -1 & -1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \end{bmatrix}$$






Figure 1: A graph with 6 nodes and 9 edges

$$b_1 = \begin{bmatrix} -1 \\ -1 \end{bmatrix}$$

$$A_{eq1} = b_{eq1} = \mathbf{0}$$

The following maps the actuator placement problem to one of classification into source or demand partition.

$$A_2 = \begin{bmatrix} J & I_{E \times E} \end{bmatrix} = \begin{bmatrix} -1 & 1 & 0 & 0 & 0 & 0 & -1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ -1 & 0 & 1 & 0 & 0 & 0 & 0 & -1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & -1 & 1 & 0 & 0 & 0 & 0 & 0 & -1 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & -1 & 0 & 1 & 0 & 0 & 0 & 0 & 0 & -1 & 0 & 0 & 0 & 0 & 0 \\ 0 & -1 & 0 & 0 & 1 & 0 & 0 & 0 & 0 & 0 & -1 & 0 & 0 & 0 & 0 \\ 0 & 0 & -1 & 1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & -1 & 0 & 0 & 0 \\ 0 & 0 & -1 & 0 & 1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & -1 & 0 & 0 \\ 0 & 0 & 0 & -1 & 0 & 1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & -1 & 0 \\ 0 & 0 & 0 & 0 & -1 & 1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & -1 \end{bmatrix}$$

where  $J$  is the incidence matrix.

$b_2 = [\mathbf{O}]$ . This links the partitioning variables  $\mathbf{y}$  to the variables in the cost function,  $\mathbf{z}$ . An edge between two different partitions causes the cost function to assume the presence of an edge as well, that is, increase the corresponding binary variable to 1. This increases cost function by 1.

$A_{eq2}$ ,  $b_{eq2}$  provide bounds to force the decision variables to reality, i.e. the demand nodes being in the second partition and the vulnerable nodes being in the first.

This is the same as the base case, no other constraints are enforced.

$$A_{eq2} = \begin{bmatrix} 1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & 1 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 \end{bmatrix}; b_{eq2} = \begin{bmatrix} 0 \\ 0 \\ 1 \end{bmatrix}$$

#### 4.1.3. Results and verification

Actuator edges are verified to be a min-cut of the network. At least one sensor node is verified to exist downstream of every vulnerable node.

### 4.2. Scenario of simultaneous attack

#### 4.2.1. Key assumptions

- The contaminant must be contained in the vulnerable side of actuator network.
- Contamination attacks occur on all vulnerable nodes at once.

This case is not trivial as the positions of the sensors must be used as input, that is, the time-dependent total spread of each contaminant must be on the contained at time of actuation.

#### 4.2.2. Formulation

Formulating as binary integer optimization problem:

$$\begin{aligned}
& \min (\sum x_i + \sum z_i) \\
& \text{sub} \\
& \mathbf{A} \begin{bmatrix} \mathbf{x} \\ \mathbf{y} \\ \mathbf{z} \\ a \\ \mathbf{w} \end{bmatrix} \leq \mathbf{b} \\
& \mathbf{A}_{\text{eq}} \begin{bmatrix} \mathbf{x} \\ \mathbf{y} \\ \mathbf{z} \\ a \\ \mathbf{w} \end{bmatrix} = \mathbf{b}_{\text{eq}}
\end{aligned}$$

Where  $\mathbf{x} \equiv [x_i]$  is 1 if there exists a sensor at  $i^{th}$  node, 0 otherwise.

$\mathbf{y} \equiv [y_i]$  is 1 if  $i^{th}$  node is in the demands side of the actuators, 0 otherwise.

$\mathbf{z} \equiv [z_i]$  is 1 if there exists an actuator at  $i^{th}$  edge, 0 otherwise.

$a$  is a decision variable which stores the maximum distance the set of sensors are to the set of vulnerable nodes.

$\mathbf{w} \equiv [w_i]$  is 1 if  $i^{th}$  node is in the demands side of the actuators, a large number ( $M$ ) otherwise.

$M$  is a large number.

Hence the vector  $\begin{bmatrix} \mathbf{x} & \mathbf{y} & \mathbf{z} & a & \mathbf{w} \end{bmatrix}$  is of length  $3 * N + E + 1$ .

$$\mathbf{A} = \begin{bmatrix} A_1 & \mathbf{0} & \mathbf{0} \\ \mathbf{0} & A_2 & \mathbf{0} \\ & A_3 & \end{bmatrix}, \mathbf{A}_{\text{eq}} = \begin{bmatrix} A_{eq1} & \mathbf{0} & \mathbf{0} \\ \mathbf{0} & A_{eq2} & \mathbf{0} \\ \mathbf{0} & A_{eq3} & \end{bmatrix}, \mathbf{b} = \begin{bmatrix} b_1 \\ b_2 \\ b_3 \end{bmatrix}, \mathbf{b}_{\text{eq}} = \begin{bmatrix} b_{eq1} \\ b_{eq2} \\ b_{eq3} \end{bmatrix}.$$

$A_1$  is a matrix of vulnerable nodes vs. affected nodes, with  $A_{1ij} = -1$  if  $i^{th}$  vulnerable node affects the  $j^{th}$  node in graph.

$$b_1 = \begin{bmatrix} \cdot \\ \cdot \\ \cdot \\ -1 \\ \cdot \\ \cdot \\ \cdot \end{bmatrix}$$

$$A_{eq1} = b_{eq1} = [\mathbf{O}]$$

$$A_2 = \begin{bmatrix} J & I_{E \times E} \end{bmatrix} \text{ where } J \text{ is the incidence matrix.}$$

$b_2 = [\mathbf{O}]$ . This links the partitioning variables  $\mathbf{y}$  to the variables in the cost function,  $\mathbf{z}$ .

$A_{eq2}, b_{eq2}$  provide bounds to force the decision variables to reality, viz. the demand nodes being in the second partition and the vulnerable nodes being in the first.

We use shortest path lengths from all the vulnerable nodes (simulating an attack on all of them) to all the nodes in the graph to model “farther away in time”. Let this vector be  $\mathbf{S}$ . The first set of constraints of  $A_3$  is this vector of shortest paths multiplied with each column of  $\mathbf{I} \times \mathbf{x}$ , storing the maximum distance of that particular sensor configuration in  $a$ . The actuators need to be at least that much distance away from the set of vulnerable nodes.

This can be implemented in two ways: constraining the actuators to be placed after a particular distance, or constraining the demand partition to start after a particular distance. Since generally speaking  $N < E$  in a lot of real world networks, we show the node implementation.

We transform the  $\mathbf{y}$  vector to  $\mathbf{w}$ , where  $M$  denotes the sensor partition and 1 implies the demand partition. Then we construct constraints for actuator placement

for the  $i^{th}$  node as follows:  $\begin{bmatrix} \dots & 0 & -(M + \mathbf{S}) & 0 & \dots \end{bmatrix} \mathbf{w}_i + [a + \frac{a}{M}] \leq \begin{bmatrix} -M \end{bmatrix}$ . This completes the formulation.

#### 4.2.3. Illustrative artificial network example

Consider the same network in Figure 1, with the two vulnerable nodes (1, 2) and one demand node (6).

The additional constraints introduced in this case are  $\mathbf{S}_i \mathbf{x}_i - a \leq 0$  for each node  $i$ . This becomes

$$\begin{bmatrix} 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 1 & 0 & 0 & 0 \\ 0 & 0 & 0 & 1 & 0 & 0 \\ 0 & 0 & 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 0 & 0 & 2 \end{bmatrix} \mathbf{x} - \begin{bmatrix} a \\ a \\ a \\ a \\ a \\ a \end{bmatrix} \leq \begin{bmatrix} 0 \\ 0 \\ 0 \\ 0 \\ 0 \\ 0 \end{bmatrix}$$

The constraints for ensuring desired partitioning are:

$$\begin{bmatrix} -(M) & 0 & 0 & 0 & 0 & 0 \\ 0 & -(M) & 0 & 0 & 0 & 0 \\ 0 & 0 & -(M+1) & 0 & 0 & 0 \\ 0 & 0 & 0 & -(M+1) & 0 & 0 \\ 0 & 0 & 0 & 0 & -(M+1) & 0 \\ 0 & 0 & 0 & 0 & 0 & -(M+2) \end{bmatrix} \mathbf{w} + \begin{bmatrix} a + \frac{a}{M} \\ a + \frac{a}{M} \\ a + \frac{a}{M} \\ a + \frac{a}{M} \\ a + \frac{a}{M} \\ a + \frac{a}{M} \end{bmatrix} \leq \begin{bmatrix} -M \\ -M \\ -M \\ -M \\ -M \\ -M \end{bmatrix}$$

This ensures that  $\mathbf{S}_i$  is greater than  $a$  for all nodes  $i$ .

#### 4.2.4. Results and verification

The network is verified to have no paths from vulnerable to demand after removing edges. The distance to detection in this design is 0 units.

### 4.3. Scenario of independent attacks

#### 4.3.1. Key assumptions

- Vulnerable nodes may be attacked independently, at different time points or not at all.

#### 4.3.2. Solution formulation

Formulating as mixed integer linear optimization problem:

$$\begin{aligned}
 & \min \quad (\sum x_i + \sum z_i) \\
 & \text{sub} \\
 & \mathbf{A} \begin{bmatrix} \mathbf{x} \\ \mathbf{y} \\ \mathbf{z} \\ \mathbf{d} \\ \mathbf{w} \\ \mathbf{v} \end{bmatrix} \leq \mathbf{b} \\
 & \mathbf{A}_{\text{eq}} \begin{bmatrix} \mathbf{x} \\ \mathbf{y} \\ \mathbf{z} \\ \mathbf{d} \\ \mathbf{w} \\ \mathbf{v} \end{bmatrix} = \mathbf{b}_{\text{eq}}
 \end{aligned}$$

Where  $\mathbf{x} \equiv [x_i]$  is a decision variable vector whose components are 1 if there exists a sensor at  $i^{th}$  node, 0 otherwise.

$\mathbf{y} \equiv [y_i]$  is a decision variable vector whose components are 1 if  $i^{th}$  node is in the demands side of the actuators(demand partition), 0 otherwise (source partition).

$\mathbf{z} \equiv [z_i]$  is a decision variable vector whose components are 1 if there exists an actuator at  $i^{th}$  edge, 0 otherwise.

$\mathbf{d} \equiv [d_i]$  is a decision variable vector whose components store  $M$ —the “distance to detection” for a particular vulnerable node.

$\mathbf{w} \equiv [w_i]$  is 1 if  $i^{th}$  node is in the demand partition, a large number ( $M$ ) otherwise.

$\mathbf{v} \equiv [v_{ji}]$  is 1 if the  $j^{th}$  vulnerable node’s distance to detection is inequal to the distance to the  $i^{th}$  (sensor4.3.2) node.

$M$  is a large number greater in order than the distances in the network.

Hence the decision vector  $\begin{bmatrix} \mathbf{x} & y & z & a & w & \mathbf{v} \end{bmatrix}$  is of length  $3*N + E + V + N*V$ , where  $V$  is the number of vulnerable nodes,  $N$  is the number of nodes,  $E$  is the number of edges.

$$A = \begin{bmatrix} A_1 & \mathbf{0} & \mathbf{0} \\ \mathbf{0} & A_2 & \mathbf{0} \\ & A_3 & \end{bmatrix}, A_{eq} = \begin{bmatrix} A_{eq1} & \mathbf{0} & \mathbf{0} \\ \mathbf{0} & A_{eq2} & \mathbf{0} \\ & A_{eq3} & \end{bmatrix}, b = \begin{bmatrix} b_1 \\ b_2 \\ b_3 \end{bmatrix}, b_{eq} = \begin{bmatrix} b_{eq1} \\ b_{eq2} \\ b_{eq3} \end{bmatrix}.$$

$A_1$  is a matrix of vulnerable nodes vs. affected nodes, with  $A_{1ij} = -1$  if  $i^{th}$  vulnerable node affects the  $j^{th}$  node in graph.

$$b_1 = \begin{bmatrix} \cdot \\ \cdot \\ \cdot \\ -1 \\ \cdot \\ \cdot \\ \cdot \end{bmatrix}$$

$$A_{eq1} = b_{eq1} = [\mathbf{0}]$$

To link the partitioning variables  $\mathbf{y}$  to the variables in the cost function,  $\mathbf{z}$ :

$$A_2 = \begin{bmatrix} J & I_{E \times E} \end{bmatrix} \text{ where } J \text{ is the incidence matrix.}$$

$b_2 = [\mathbf{0}]$ . The presence of an edge from source to demand forces the corresponding

$\mathbf{z}_i$  to switch to one, indicating the presence of an actuator on that edge.

$A_{eq2}, b_{eq2}$  provide bounds to force the decision variables to reality, viz. the demand nodes necessarily being in the demand partition and the vulnerable nodes being in the source. We might also include constraints to consider a few steps after vulnerable node to be necessarily in the source partition, as done in Palleti et al. (2018).

We use the shortest distances from each of the vulnerable nodes to all other nodes in the graph to model time to contamination. We're assuming the actual times are linear functions of distance. Let this matrix be  $\mathbf{D}$ . The first set of constraints of  $A_3$  is one for each entry in  $M - \mathbf{D}$  matrix, each of which is multiplied with  $\mathbf{x}$ . Each constraint is balanced by  $-d_j$ , where  $j$  is the vulnerable node under consideration in that constraint.  $b_3 = [\mathbf{0}]$ .

Now,  $d_j$  is greater than or equal to  $M - D_{ij}$ . We add constraints to force equality to the distance to the closest sensor:  $D_{ij} + d_j - Mv_{ij} \leq M$  for all sensors. More constraints for making sure non-sensor nodes don't use positive  $v_{ij}$ :  $-x_i + v_i \leq 0$ . For ensuring at least one equality of  $D_{ij}$  and  $d_j$ , per  $j$ :  $A_{1j}\mathbf{x} - A_j\mathbf{v}_j \leq -1$ .

The actuators need to be at least  $M - d_j$  distance away from the each of the vulnerable nodes. This can be implemented in two ways: constraining the actuators to be placed after a particular distance, or constraining the demand partition to start after a particular distance. Since generally speaking  $N < E$  in a lot of networks, we show the node implementation.

Transform the  $\mathbf{y}$  vector to  $\mathbf{w}$ , where  $w_i = M$  denotes the sensor partition and  $w_i = 1$  implies the node is in demand partition. Construct constraints for actuator placement for the  $i^{th}$  node as follows:  $\begin{bmatrix} \dots & 0 & -(M + D_{ij} - 1) & 0 & \dots \end{bmatrix} [\mathbf{w}] + \begin{bmatrix} -1 \end{bmatrix} d_j \leq \begin{bmatrix} -2 * M \end{bmatrix}$ . This ensures that when  $\mathbf{w}_i$  is 1, the constraint is activated and only satisfied if the corresponding  $\mathbf{D}_{ij} > \mathbf{d}_j$ . When  $\mathbf{w}_i$  is  $M$ , the constraint is always satisfied as  $M^2$  is several orders of magnitude greater than  $2 * M$ .



#### 4.3.3. Illustrative artificial network example

Consider the same network in Figure 1, with the two vulnerable nodes (1, 2) and one demand node (6).

The additional constraints over case 2 introduced in this case are:

$$\begin{aligned}
 & \begin{bmatrix} M-0 & 0 & 0 & 0 & 0 & 0 \\ 0 & M-1 & 0 & 0 & 0 & 0 \\ 0 & 0 & M-1 & 0 & 0 & 0 \\ 0 & 0 & 0 & M-2 & 0 & 0 \\ 0 & 0 & 0 & 0 & M-2 & 0 \\ 0 & 0 & 0 & 0 & 0 & M-3 \end{bmatrix} \mathbf{x} - \begin{bmatrix} d_1 \\ d_1 \\ d_1 \\ d_1 \\ d_1 \\ d_1 \end{bmatrix} \leq \begin{bmatrix} 0 \\ 0 \\ 0 \\ 0 \\ 0 \\ 0 \end{bmatrix} \\
 & \begin{bmatrix} M-M & 0 & 0 & 0 & 0 & 0 \\ 0 & M-0 & 0 & 0 & 0 & 0 \\ 0 & 0 & M-1 & 0 & 0 & 0 \\ 0 & 0 & 0 & M-1 & 0 & 0 \\ 0 & 0 & 0 & 0 & M-1 & 0 \\ 0 & 0 & 0 & 0 & 0 & M-2 \end{bmatrix} \mathbf{x} - \begin{bmatrix} d_2 \\ d_2 \\ d_2 \\ d_2 \\ d_2 \\ d_2 \end{bmatrix} \leq \begin{bmatrix} 0 \\ 0 \\ 0 \\ 0 \\ 0 \\ 0 \end{bmatrix}
 \end{aligned}$$

This gets us variables storing  $M-d_i$ , the value after subtracting the minimum distance to sensor from the large number for each vulnerable node.

Constraints for ensuring the conditions around  $d_j$ 's:

$$\begin{bmatrix} 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 1 & 0 & 0 & 0 & 0 \\ 0 & 0 & 1 & 0 & 0 & 0 \\ 0 & 0 & 0 & 2 & 0 & 0 \\ 0 & 0 & 0 & 0 & 2 & 0 \\ 0 & 0 & 0 & 0 & 0 & 3 \end{bmatrix} \mathbf{x} + \begin{bmatrix} d_1 \\ d_1 \\ d_1 \\ d_1 \\ d_1 \\ d_1 \end{bmatrix} - M \begin{bmatrix} v_{11} \\ v_{12} \\ v_{13} \\ v_{14} \\ v_{15} \\ v_{16} \end{bmatrix} \leq M \begin{bmatrix} 1 \\ 1 \\ 1 \\ 1 \\ 1 \\ 1 \end{bmatrix}$$

$$\begin{bmatrix} M & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 1 & 0 & 0 & 0 \\ 0 & 0 & 0 & 1 & 0 & 0 \\ 0 & 0 & 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 0 & 0 & 2 \end{bmatrix} \mathbf{x} + \begin{bmatrix} d_2 \\ d_2 \\ d_2 \\ d_2 \\ d_2 \\ d_2 \end{bmatrix} - M \begin{bmatrix} v_{21} \\ v_{22} \\ v_{23} \\ v_{24} \\ v_{25} \\ v_{26} \end{bmatrix} \leq M \begin{bmatrix} 1 \\ 1 \\ 1 \\ 1 \\ 1 \\ 1 \end{bmatrix}$$

For  $v_i$ 's are 1 only when  $i$  is a sensor:  $-x_i + v_i \leq 0$ . At least one equality constraint being satisfied:

$$\begin{bmatrix} -1 & -1 & -1 & -1 & -1 & -1 \\ 0 & -1 & -1 & -1 & -1 & -1 \end{bmatrix} \mathbf{x} - \begin{bmatrix} 1 & 1 & 1 & 1 & 1 & 1 \\ 0 & 1 & 1 & 1 & 1 & 1 \end{bmatrix} \begin{bmatrix} \mathbf{v}_1 \\ \mathbf{v}_2 \end{bmatrix} \leq \begin{bmatrix} -1 \\ -1 \end{bmatrix}$$

The constraints for ensuring desired partitioning are:

$$\begin{aligned}
& -1 \times \begin{bmatrix} M+0-1 & 0 & 0 & 0 & 0 & 0 \\ 0 & M+1-1 & 0 & 0 & 0 & 0 \\ 0 & 0 & M+1-1 & 0 & 0 & 0 \\ 0 & 0 & 0 & M+2-1 & 0 & 0 \\ 0 & 0 & 0 & 0 & M+2-1 & 0 \\ 0 & 0 & 0 & 0 & 0 & M+3-1 \end{bmatrix} \mathbf{w} - \begin{bmatrix} d_1 \\ d_1 \\ d_1 \\ d_1 \\ d_1 \\ d_1 \end{bmatrix} \leq \\
& \begin{bmatrix} -2M \\ -2M \\ -2M \\ -2M \\ -2M \\ -2M \end{bmatrix} \\
& -1 \times \begin{bmatrix} M+M-1 & 0 & 0 & 0 & 0 & 0 \\ 0 & M+0-1 & 0 & 0 & 0 & 0 \\ 0 & 0 & M+1-1 & 0 & 0 & 0 \\ 0 & 0 & 0 & M+1-1 & 0 & 0 \\ 0 & 0 & 0 & 0 & M+1-1 & 0 \\ 0 & 0 & 0 & 0 & 0 & M+2-1 \end{bmatrix} \mathbf{w} - \begin{bmatrix} d_2 \\ d_2 \\ d_2 \\ d_2 \\ d_2 \\ d_2 \end{bmatrix} \leq \\
& \begin{bmatrix} -2M \\ -2M \\ -2M \\ -2M \\ -2M \\ -2M \end{bmatrix}
\end{aligned}$$

#### 4.3.4. Results and verification

The network is verified to have no paths from vulnerable to demand after removing edges. The distance to detection is always lesser than the distance to the first actuators.

### 5. Case study network

The algorithms for each scenario were tested on a benchmark abstraction of an urban WDN - one based on Bangalore city, India. It has 3 reservoirs and 6 pumps,




Figure 2: Layout of bangalore network, where nodes 1, 2, 3 are reservoirs and the six others shown are pumps

all of which are considered vulnerable nodes. 24 demand nodes are presented in the network. The network consists of 116 pipes, 29 control valves, 3 on-off valves and 7

pumps. The primary purpose of the network is to supply the water to all demand nodes.

The network is assumed to be static, and the hydraulic results at 00:00 hours after EPANET simulation are considered for this work. All of the results are produced using no more data than the directed connectivity results. All pipes are assumed to be of length 1.

### 5.1. Results

#### 5.1.1. Scenario of vacuum pipes




Figure 3: Graph abstraction with vulnerable nodes in red and sensors in blue.

It takes three sensors to detect contaminant with no other requirements.

This is the same as Palleti et al. (2016).

The closing of network requires 12 actuators: on edges 1, 4, 30, 37, 39, 47, 49, 50, 64, 81, 149, 154.

Vulnerable Nodes	Sensor Nodes
1	41, 70, 85
2	41, 85
3	70
19	41
32	70
37	41
39	41
53	85
66	70

Table 1: Vulnerable nodes and their corresponding sensor nodes

#### 5.1.2. Scenario of simultaneous attack

Vulnerable Nodes	Time to sense	Sensor nodes	Actuator edges
1,2,3,19,32,37,39,53,66	0	19,39,53,66	1,13,27,30,38,39,40,44, 51,52,68,72,80,87,90,103,150,149
1,2,3	0	1,2,3	1,4,68
131,20	0	131	27, 30, 37

Table 2: The distance to detection for different sets of vulnerable nodes

In the previous work Palleti et al. (2018), the number of actuators suggested was 19 viz. 2, 12, 16, 24, 30, 38, 40, 48, 51, 52, 67, 71, 76, 86, 79, 89, 108, 110, 127 with 3 sensors (at nodes 40, 54, 67) and the same 9 vulnerable nodes.

#### 5.1.3. Scenario of independent attacks

In the previous work Palleti et al. (2018), the similar task was partial shutdown of WDN. The number of actuators suggested was 20 viz. 2, 12, 16, 24, 30, 38, 40,

Vulnerable Nodes	Time to sense	Sensor nodes	Actuator edges
1 2 3 19 32 37 39 53 66	0 0 0 0 0 0 0 0 0	1 2 3 19 32 37 39 53 66	1 4 40 48 51 52 68 150 151 152 153 149
1 2 3	0 0 0	1,2,3	1,4,68
1 2 3 19 32 37 39 53 66 <sup>1</sup>	0 4 1 0 1 0 0 1 0	1 7 19 33 37 39 54 57 66	2 8 12 30 38 40 48 51 52 67 69 77 78 89 103 108 110

Table 3: The distance to detection for different sets of vulnerable nodes

48, 51, 52, 67, 71, 76, 86, 79, 89, 108, 110, 127, 112 with 3 sensors (at nodes 40, 54, 67) and the same 9 vulnerable nodes. The nodes directly downstream of vulnerable are taken as source nodes. Here for task 4, we get a solution with 26 cardinality: 17 actuators, 9 sensors. The previous work does not require that no demand node be compromised though.

## 6. Validation of Palleti et al. (2018)

The results of the scenario explored in Palleti et al. (2018) are presented in Figure 8

## 7. Conclusions and future work

For a given WDN, we presented ways to arrive at a sensor and actuator placement strategy. This sensor and actuator network design is useful for water authorities to detect contaminants and isolate the contaminated area in the event of an attack on the WDN. We proposed a multi-objective linear programming formulation that gives the optimal sensor and actuator cardinality.

The formulation can reproduce the results of Palleti et al. (2018) after relaxing the full requirements to partial, viz. to prevent further contamination of demand nodes.

A performance benchmark of the simultaneous framework and the sequential non-linear optimization solution would be an illuminating exercise.

This formulation introduces an  $O(NV)$  blowup in the number of decision variables, but there exist techniques to solve such specifically constrained variables much faster. An implementation using such techniques would be useful for assessing real performance.

Integration of an implementation of these algorithms with existing open-source toolboxes for sensor and actuator placement is a possible future action, which makes the techniques presented here much more accessible.

## 8. REFERENCES

- Alfonso, L., Jonoski, A., Solomatine, D., 2010. Multiobjective optimization of operational responses for contaminant flushing in water distribution networks. *Journal of Water Resources Planning and Management* 136 (1), 48–58.
- Alvisi, S., Franchini, M., Gavanelli, M., Nonato, M., 2012. Near-optimal scheduling of device activation in water distribution systems to reduce the impact of a contamination event. *Journal of Hydroinformatics* 14 (2), 345–365.
- Berry, J., Fleischer, L., Hart, W., Phillips, C., Watson, J., 2005. Sensor placement in municipal water networks. *Journal of Water Resources Planning and Management* 131 (3), 237–243.
- Guidorzi, M., Franchini, M., Alvisi, S., 2009. A multi-objective approach for detecting and responding to accidental and intentional contamination events in water distribution systems. *Urban water journal* 6 (2), 115–135.
- Kessler, A., Ostfeld, A., Sinai, G., 1998. Detecting accidental contaminations in mu-



- municipal water networks. *Journal of Water Resources Planning and Management* 124 (4), 192–198.
- Kumar, A., Kansal, M., Arora, G., 1997. Identification of monitoring stations in water distribution system. *Journal of Environmental Engineering* 123 (8), 746–752.
- Laird, C., Biegler, L., van Bloemen Waanders, B., Bartlett, R., 2005. Contamination source determination for water networks. *Journal of Water Resources Planning and Management* 131 (2), 125–134.
- Lee, B., Deininger, R., 1992. Optimal locations of monitoring stations in water distribution system. *Journal of Environmental Engineering* 118 (1), 4–16.
- Mann, A. V., McKenna, S. A., Hart, W. E., Laird, C. D., 2012. Real-time inversion in large-scale water networks using discrete measurements. *Computers & Chemical Engineering* 37, 143–151.
- Ostfeld, A., Uber, J., Salomons, E., Berry, J., Hart, W., Phillips, C., Watson, J., Dorini, G., Jonkergouw, P., Kapelan, Z., di Pierro, F., Khu, S., Savic, D., Eliades, D., Polycarpou, M., Ghimire, S., Barkdoll, B., Gueli, R., Huang, J., McBean, E., James, W., Krause, A., Leskovec, J., Isovitsch, S., Xu, J., Guestrin, C., VanBriesen, J., Small, M., Fischbeck, P., Preis, A., Propato, M., Piller, O., Trachtman, G., Wu, Z., Walski, T., 2008. The battle of the water sensor networks (bwsn): A design challenge for engineers and algorithms. *Journal of Water Resources Planning and Management* 134 (6), 556–568.
- Palleti, V. R., Kurian, V., Narasimhan, S., Rengaswamy, R., Jan. 2018. Actuator network design to mitigate contamination effects in Water Distribution Networks. *Computers & Chemical Engineering* 108, 194–205.

URL <http://www.sciencedirect.com/science/article/pii/S0098135417303083>

- Palleti, V. R., Narasimhan, S., Rengaswamy, R., Teja, R., Bhallamudi, S. M., 2016. Sensor network design for contaminant detection and identification in water distribution networks. *Computers and Chemical Engineering* 87, 246 – 256.
- Poulin, A., Mailhot, A., Grondin, P., Delorme, L., Periche, N., Villeneuve, J., 2008. Heuristic approach for operational response to drinking water contamination. *Journal of Water Resources Planning and Management* 134 (5), 457–465.
- Poulin, A., Mailhot, A., Periche, N., Delorme, L., Villeneuve, J., 2010. Planning unidirectional flushing operations as a response to drinking water distribution system contamination. *Journal of Water Resources Planning and Management* 136 (6), 647–657.
- Preis, A., Ostfeld, A., 2008. Multiobjective contaminant response modeling for water distribution systems security. *Journal of Hydroinformatics* 10 (4), 267–274.
- Rico-Ramirez, V., Frausto-Hernandez, S., Diwekar, U. M., Hernandez-Castro, S., 2007. Water networks security: A two-stage mixed-integer stochastic program for sensor placement under uncertainty. *Computers & chemical engineering* 31 (5), 565–573.
- USEPA, 2004a. Response protocol toolbox: Planning for and responding to drinking water contamination threats and incidents-module 5:public health response guide. Tech. rep., Report EPA 817-03-005 interim Final-April 2004, Washington, D.C.
- USEPA, 2004b. Response protocol toolbox: Planning for and responding to drinking water contamination threats and incidents-module 6:public health response guide. Tech. rep., Report EPA 817-03-006 interim Final-April 2004, Washington, D.C.

Watson, J.-P., Greenberg, H. J., Hart, W. E., 2004. A multiple-objective analysis of sensor placement optimization in water networks. In: Proceedings of the World Water and Environment Resources Congress, American Society of Civil Engineers. pp. 1–10.




Figure 4: Results of independent placement case




Figure 5: Scenario where all possible vulnerable nodes are always attacked simultaneously




Figure 6: Sensor and actuator placement strategy for 9 vulnerable nodes




Figure 7: Sensor and actuator placement strategy for 9 vulnerable nodes and instant downstream contamination




Figure 8: Validation of Palleti et al. (2018), case of allowing demand nodes to be compromised  
The cardinality is 21, the same as presented in the earlier work.