Certificate of Compliance

Certificate: 1245094 (31928M361)

Master Contract: 152724 (Alt. 75088)

Project: 80114474

Date Issued: January 27, 2022

Issued to: **Rockwell Automation, Inc.**
1201 South Second St.
Milwaukee Wisconsin 53204
United States

The products listed below are eligible to bear the CSA Mark shown

Issued by: Lizon Deschamps
Lizon Deschamps

PRODUCTS

CLASS 3211 04 - INDUSTRIAL CONTROL EQUIPMENT Motor Controllers - Magnetic
CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Sockets, Models 700-HN121 Ser B and 700-HN122 Ser B:

Electrical Ratings:

Model	Number of contact poles	Coil terminal	Contact terminal
700-HN121 Ser B	1	1A, 250V	10A, 250V
700-HN122 Ser B	2	1A, 250V	6A, 250V

Notes:

1. Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by CSA Group.
2. The sockets were evaluated/tested at 70 deg C surrounding air temperature at the request of the submittor.
3. The sockets were evaluated/tested for wiring No. 18 - 16 AWG, solid and/or stranded, CU with its installation instructions.

© 2018 CSA Group. All rights reserved.

Certificate: 1245094 (31928M361) **Master Contract:** 152724 (Alt. 75088)
Project: 80114474 **Date Issued:** January 27, 2022

APPLICABLE REQUIREMENTS

CSA C22.2 No. 14-18 - Industrial Control Equipment
UL Std. 508(18th Ed.) - Industrial Control Equipment

CLASS 3211 04 - INDUSTRIAL CONTROL EQUIPMENT Motor Controllers - Magnetic
CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Relays, Types 800Z-N10, -N11, and -N12, open, with dust cover or plastic seal, silver cadmium oxide or silver indium oxide contacts, rated 2-pole, 8A, 250V ac or 30V dc, 1/6 hp, 125V ac, 1/4 hp, 125 or 250V ac and 1/3 hp, 125 or 250V ac, 330VA, 250V ac, 530VA, 20-265V ac, 60VA, 4.5-30V dc, 4 FLA, 30V dc, (Ag Cd only); B300/R300 at 85°C (AgIno Contacts).

- Relays, Type 700-HK with suffixes, open type, with dust cover, coils 3 through 240V ac and 3 through 110V dc. Max ratings as follows:
  I. 700-HK, Single Pole, Single Contact

  a. Contact material/Suffix: AgCdO/Blank

Rating	Tested Ambient	No of Operations Tested
30V ac, 10, resistive	Standard	100,000
250V ac, 10A	Standard	6, 000
250V ac, 10A	Standard	100,000
250V ac, 10, resistive	60°C	30,000
277Vac, 5A	Standard	6,000
250V ac, 5A	84°C	100,000
277V ac, 10A	Standard	6, 000
120V ac, 3A (360W) tungsten	Standard	25,000
TV-3 (N.O. contacts)	Standard	25,000
125V ac, 1/4Hp	Standard	1,000
250V ac, 1/2Hp	Standard	1, 000
277V ac, 1/2Hp	Standard	1,000
120V ac, 1/3Hp	84°C	30,000
125V ac, 1/3Hp	70°C	30,000
120V ac, 250VA pilot duty	84°C	30,000
B300	60°C	30, 000
250V ac, 1.8 FLA, 18 LRA	60°C	30,000
250V ac, 10A	70°C	100,000
250V ac, 8A	60°C	30,000

© 2018 CSA Group. All rights reserved.

b. Contact material/Suffix: AgSnIn/-ASI

Rating	Tested Ambient	No of Operations Tested
35V ac, 10A, resistive	Standard	30,000
30V ac, 10A, resistive	Standard	100,000
250V ac, 10A	Standard	6,000
250V ac, 10A	Standard	100,000
277V ac, 5A	Standard	6,000
120V ac, 5A (600W) tungsten	Standard	25,000
TV-5 (N.O. contacts)	Standard	25,000
TV-8 (N.O. contacts)	Standard	25,000
125V ac, 1/4Hp	Standard	1,000
250V ac, 1/2Hp	Standard	1,000
277V ac, 1/2Hp	Standard	1,000
TV-3 (N.C. contacts)	Standard	25,000

c. Contact material/Suffix: AgCdO/-E

Rating	Tested Ambient	No of Operations Tested
35V dc, 10A resistive	Standard	30,000
30V dc 16A resistive	Standard	6,000
250V ac, 10A	Standard	6,000
250V ac, 16A	Standard	6,000
125V ac, 15A	70°C	30,000
277V ac, 20A	70°C	30,000
240V ac, 20A	70°C	30,000
120V ac, 3A (360W) tungsten	Standard	25,000
TV3 (N.O. Contacts)	Standard	25,000
240V ac, 1Hp	Standard	1,000
120V ac, 1/2Hp	Standard	1,000
120V ac, 1/3Hp	Standard	1,000
250V ac, 1/2Hp	Standard	1,000
240V ac, 3A, pilot duty	65°C	30,000
120V ac, 5FLA, 20LRA (N.O.)	75°C	30,000
120V ac, 10.5FLA, 63LRA (N.O.)	70°C	30,000
250V ac, 2FLA, 12 LRA	60°C	30,000

© 2018 CSA Group. All rights reserved.

d. Contact material/Suffix: AgSnIn/-E and -ASI

Rating	Tested Ambient	No of Operations Tested
30V ac, 10 resistive	Standard	6,000
30V dc, 16A resistive	Standard	6,000
250V ac, 10A	Standard	6,000
250V ac, 16A	Standard	6,000
125V ac, 15A	70°C	30,000
277V ac, 20A	70°C	30,000
240V ac, 20A	70°C	30,000
120V ac, 5A (600W) tungsten	Standard	25,000
TV-3	Standard	25,000
TV-8 (N.O.)	Standard	25,000
125V ac, 10FLA, 60LRA (N.O.)	74°C	100,000
125V ac, 500VA pilot duty (N.O.)	74°C	100,000

e. Contact material/Suffix: AgSnO/-E and -AS

Rating	Tested Ambient	No of Operations Tested
30V dc, 16A resistive (N.O.)	Standard	6,000
250V ac, 16A (N.O.)	Standard	6,000

f. Contact material/Suffix: AgSnO/-AS

Rating	Tested Ambient	No of Operations Tested
30V dc, 10A resistive	Standard	100,000
250V ac, 8A resistive	60°C	30,000
250V ac, 10A	70°C	100,000
277V ac, 10A	Standard	6,000
250V ac, 5A	84°C	100,000
120V ac, 3A, (360W) tungsten	Standard	25,000
TV-3 (N.O.)	Standard	25,000
120V ac, 1/4Hp	Standard	1,000
250V ac, 1/2Hp	Standard	1,000
277V ac, 1/2Hp	Standard	1,000
125V ac, 1/3Hp	84°C	30,000
120V ac, 250VA, pilot duty	84°C	30,000
B300, pilot duty	Standard	6,000
250V ac, 2FLA, 12LRA	60°C	30,000

© 2018 CSA Group. All rights reserved.

II. 700-HK, Single Pole, Twin Contact

a. Contact material/Suffix: AgCdO/Z

Rating	Tested Ambient	No of Operations Tested
30V dc, 5A resistive	Standard	6,000
250V dc, 5A resistive	Standard	6,000

b. Contact material/Suffix: Crossbar Au Clad/3

Rating	Tested Ambient	No of Operations Tested
30V dc, 1A resistive	Standard	6,000
250V dc, 1A resistive	Standard	6,000

III. 700-HK, Double Pole, Single Contact

a. Contact material/Suffix: Ag or AgNi/Blank

Rating	Tested Ambient	No of Operations Tested
30V dc, 5A resistive	Standard	100,000
250V ac, 5A resistive	Standard	100,000
120V ac, 5A	Standard	6,000
250V ac, 5A	Standard	6,000
120V ac, 3A, (360W) tungsten	Standard	25,000
120V ac, 1/10Hp	Standard	1,000
125V ac, 1/10Hp	Standard	1,000
250V ac, 1/10Hp	Standard	1,000
240V ac, 1/4Hp	Standard	1,000
120V ac, 1/6Hp	Standard	1,000
240V ac, 1/3Hp	Standard	1,000
265V ac, 1/6Hp	Standard	30,000
265V ac, 1/3Hp	Standard	30,000

b. Contact material/Suffix: AgCdO/Blank

Rating	Tested Ambient	No of Operations Tested
30V dc, 5A resistive	Standard	100,000
250V ac, 5A resistive	Standard	100,000
30V dc, 10A resistive	Standard	50,000
120V ac, 5A	Standard	6,000
250V ac, 5A	Standard	6,000

© 2018 CSA Group. All rights reserved.

250V ac, 5A	84°C	100,000
125V ac, 5A	70°C	30,000
277V ac, 10A	Standard	100,000
TV-3 (N.O.)	Standard	25,000
125V ac, 1/10HP	Standard	1,000
250V ac, 1/10Hp	Standard	1,000
250V ac, 1/10Hp	Standard	1,000
240V ac, 1/4Hp	Standard	1,000
120V ac, 1/6Hp	Standard	1,000
240V ac, 1/3Hp	Standard	1,000
265V ac, 1/6Hp	Standard	30,000
265V ac, 1/3Hp	Standard	30,000
120V ac, 250VA pilot duty	84°C	30,000
B300	Standard	6,000

c. Contact material/Suffix: AgSnIn/-ASI

Rating	Tested Ambient	No of Operations Tested
30V dc, 5A resistive	Standard	100,000
240V ac, 5A resistive	Standard	100,000
120V dc, 5A	Standard	6,000
120V ac, 5A	Standard	6,000
250V ac, 5A	Standard	6,000
250V ac, 5A	84°C	100,000
TV-3 (N.O.)	Standard	25,000
120V ac, 1/10HP	Standard	1,000
125V ac, 1/10Hp	Standard	1,000
250V ac, 1/10Hp	Standard	1,000
240V ac, 1/4Hp	Standard	1,000
120V ac, 1/6Hp	Standard	1,000
240V ac, 1/3Hp	Standard	1,000
265V ac, 1/6Hp	Standard	30,000
265V ac, 1/3Hp	Standard	30,000

Notes:

1. Suffix letters and numbers added to type designation to form catalogue numbers, and indicate numbers of poles, contact arrangement, dust cover, terminal type, contact material, insulation class, etc.

© 2018 CSA Group. All rights reserved.

2. Open type relays are Certified for use only as components in equipment where the suitability of the combination is to be determined by CSA International.

- Relays, Types 700-HK36, 700-HK32 with suffixes, open, with dust cover or plastic seal, max contact ratings for single contacts and silver cadmium oxide contacts or silver indium oxide contacts; 1/3 hp, 125V ac; 1/2 hp, 250V ac; for silver indium oxide contacts; 1 6A, 250V ac; 1 6A, 30V dc; for silver cadmium oxide contacts; 16A, 250V ac; 1 6A, 30V dc, max contact ratings for single contacts and silver cadmium oxide contacts or silver indium oxide contacts; 1/10 hp, l25V ac; 1/10 hp, 250V ac, 1/3 and 1/6 hp at 265V ac; for single contacts and twin contacts (without crossbar); 5A, 250V ac; 5A, 30V dc; for dpst (N.O.), twin contacts with crossbar, 1 A, 250V ac/30V dc; devices provided with cover or devices provided with flux tight and standard type characteristics; 5A, 250V ac; 5A, 30V dc; coils 3 through 240V ac and 3 through 110V dc. B300 ratings.

- Relays, Type 700-HK36, 700-HK32 with suffixes, N.O. and N.C., silver cadmium oxide contacts, silver indium oxide contacts, silver contacts, 2-pole, 1/10 hp, 125/250V ac, 1/6 hp max, 120V ac, 1/3 hp max, 240V ac, 1/3 hp* max, 265V ac; with silver cadmium oxide or silver indium oxide contacts, 1-pole, 1/4 hp, l25V ac, 1/3 hp, 125V ac* (70C ambient); 1/2 hp, 250/277V ac; silver cadmium oxide single contact 1/2 hp, 120V ac, 1 hp, 240V ac; (silver indium oxide single contacts) 14 FLA, 72 LRA, 125V ac. B300 ratings.

Notes:

1. Suffix letters or numbers are added to type designation to indicate number of poles, type of construction and marketing features.
2. Except relays, Types 700-HK36, 700-HK32 (1 pole and same polarity only), the above relays are Certified for use only in equipment where the short circuit capacity of the circuit in which they are connected is limited by fuses having ratings not exceeding the rating of the relay.
3. Open-type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 0.6	-	Flammability Testing of Polymeric Materials
CAN/C SA-C22.2 No. 1-98	-	Radio, Television and Electronic Apparatus
CANICSA-C2.2 No. 14-95	-	Industrial Control Equipment

© 2018 CSA Group. All rights reserved.

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown without an indicator for Canada only (indicating that products have been manufactured to the requirements of Canadian Standards).

Company's name, and/or CSA file number 152724, Alt. 75088 or File 31928M361, type designation, electrical ratings, serial number or date coding, the CSA Mark appear in a permanent manner on each unit, and any other information as specified in the Certification Report.

© 2018 CSA Group. All rights reserved.