




HEILONGJIANG WANGYUNFENG WIND POWER PROJECT



Document Prepared By China Classification Society Certification Co., Ltd.

Project Title	Heilongjiang Wangyunfeng Wind Power Project
Version	02
Report ID	0104020322031(011)

Report Title	Heilongjiang Wangyunfeng Wind Power Project
Client	Longyuan (Beijing) Carbon Asset Management Technology Co., Ltd.

Pages	35
Date of Issue	31/10/2022 report issued
Prepared By	China Classification Society Certification Co., Ltd. (CCSC)
Contact	40, Dong Huang Cheng Gen Nan Jie, Beijing, 100006, P.R. China, Tel: + 86 10 5631 3492 Email: ccscbj_yf@c.ccs.org.cn www.ccs-c.com.cn
Approved By	Mr. HUANG Shiyuan, Chairman of the Board 
Work Carried Out By	Team Leader: Sun Chunlin Team Member: Zhong Tingting, Tian Ye, Yang Yuwei Technical Reviewer: Meng Cuiling, Piao Lijing

Summary:

China Classification Society Certification Co., Ltd. (CCSC), commissioned by Longyuan (Beijing) Carbon Asset Management Technology Co., Ltd., has performed the third periodic verification of Heilongjiang Wangyunfeng Wind Power Project (hereafter referred to as "the project") covering the monitoring period from 01/01/2019 - 19/01/2020, on the basis of requirements of Verified Carbon Standard (VCS) Version 4.

The project involves the construction and operation of 49.3MW wind power project on Damahe Forest Farm, Luobei County, Hegang City, Heilongjiang Province of China, consisting of 58 sets of wind turbines with capacities of 850kW each. The project is expected to supply 120,069 MWh of electricity per year to Northeast China Power Grid (NECPG) and displaces the equivalent power generated by the existing power plants and likely capacity additions within the given grid.

The project has been registered as a VCS project (VCS Project ID: 1051) under VCS Standard Version 3 using approved CDM methodology ACM0002 (version 12.1.0) "Consolidated baseline methodology for grid-connected electricity generation from renewable sources", with the first renewable crediting period from 20/01/2010 to 19/01/2020. The VCS monitoring report of this monitoring period has been reviewed against the relevant criteria and decisions by the VERRA Board, including the approved baseline and monitoring methodology ACM0002 (version 12.1.0).

The verification process includes three phases:

- 1) Desk review of documents;
- 2) On-site visit and follow-up interviews;
- 3) Issuance of the final verification report and opinion.

CCSC appointed a qualified verification team in accordance with internal procedures to perform the verification. During the verification, 1 Clarification Request (CL), no Corrective Action Requests (CARs) and no forward request (FAR) were raised.

As a result of this verification, the verification team confirms that:

- All operations of the project are implemented and installed as planned and described in the validated Project Description;
- The registered monitoring plan is in accordance with the applied approved CDM methodology, i.e., ACM0002 (version 12.1.0) "Consolidated baseline methodology for grid-connected electricity generation from renewable sources";
- The implementation of monitoring follows the registered monitoring plan;
- The monitoring system is in place and functional;
- The installed equipment for measuring parameters required for calculating emission reductions are calibrated appropriately.

Based on the information observed and evaluated, the verification team confirms that the emission reductions are correctly calculated in the MR (version 03 dated 28/10/2022).

In conclusion, it is CCSC's opinion that the project activity "Heilongjiang Wangyunfeng Wind Power Project", as described in the MR (version 03 dated 28/10/2022), meets all relevant requirements for VCS and all relevant host Party criteria. Hence, CCSC is able to certify that the emission reductions from the project during the monitoring period from 01/01/2019 to 19/01/2020 amount to 121,014 tCO₂e and requests issuance of the equivalent VCUs.

CONTENTS

1	Introduction	6
1.1	Objective	6
1.2	Scope and Criteria	6
1.3	Level of Assurance	7
1.4	Summary Description of the Project	7
2	Verification Process	8
2.1	Method and Criteria	8
2.2	Document Review	8
2.3	Interviews	9
2.4	Site Inspections	11
2.5	Resolution of Findings	11
2.6	Forward Action Requests	12
2.7	Eligibility for Validation Activities	12
3	Validation Findings	12
3.1	Participation under Other GHG Programs	12
3.2	Methodology Deviations	12
3.3	Project Description Deviations	13
3.4	Grouped Project	13
4	Verification Findings	13
4.1	Project Implementation Status	13
4.2	Safeguards	23
4.3	AFOLU-Specific Safeguards	23
4.4	Accuracy of GHG Emission Reduction and Removal Calculations	23
4.5	Quality of Evidence to Determine GHG Emission Reductions and Removals	27
4.6	Non-Permanence Risk Analysis	28
5	Verification conclusion	29
	APPENDIX A: ABBREVIATIONS	31
	APPENDIX B: REFERENCE	32

APPENDIX C: RESOLUTION OF CLARIFICATION REQUESTS AND CORRECTIVE ACTION REQUESTS AND FORWARD ACTION REQUESTS	34
--	-----------

1 INTRODUCTION

1.1 Objective

Longyuan (Beijing) Carbon Asset Management Technology Co., Ltd., has commissioned CCSC to verify and provide a verification statement of the emission reductions of the Heilongjiang Wangyunfeng Wind Power Project (hereafter referred to as "the project"), which is located on Damahe Forest Farm, Luobei County, Hegang City, Heilongjiang Province of China for the monitoring period from 01/01/2019 to 19/01/2020, based on requirement of VCS Standard (version 4.3) /11/ as well as criteria to provide for consistent project operations, monitoring and reporting.

CCSC as the validation/verification body (VVB) of the project has been accredited as a DOE by UNFCCC and meets the competence requirements as set out in ISO 14065:2020.

Verification of emission reductions from a project activity is the independent review and ex post determination by VVB of the monitored reductions in GHG emissions during the reported monitoring period. The objectives of verification are to:

- a) Ensure that the project activity has been implemented and operated as per the VCS project description (VCS-PD) /3/ and that all physical features (technology, project equipment, and monitoring and metering equipment) of the project are in place;
- b) Ensure that the monitoring report and other supporting documents provided are complete in accordance with the latest applicable version of Registration and Issuance Process /15/ and in accordance with the additional requirements stated by the VERRA;
- c) Ensure that actual monitoring systems and procedures comply with the monitoring systems and procedures described in the monitoring plan and the approved methodology /12/;
- d) Evaluate the data recorded and stored as per the monitoring methodology /12/.

1.2 Scope and Criteria

The verification scope encompasses an independent and objective review and ex-post determination of the monitored reductions in GHG emissions by the CCSC. The verification scope covers the relevant documents (e.g. the VCS-PD /3/, the monitoring plan, the VCS monitoring report (VCS-MR) /1/, the emission reduction calculation spreadsheet /2/, supporting documents available to the verifier and information collected through performing interviews and during the on-site assessment, VERRA's requirements publicly available, relevant rules, including the host country legislation, etc.) to be independently reviewed, the project geographical locations to be visited on-site, the related project local stakeholders to be interviewed with, and processes that are necessary to acquire objective evidence for the evaluation of the project compliance to the VCS requirements and associated interpretations.

The above verification activities are conducted according to the VERRA's requirements. In doing so, the principles of accuracy and completeness, relevance, reliability and credibility were followed.

The verification is not meant to provide any consulting service towards the PPs. However, stated requests for clarifications and/or corrective actions may provide input for improvement of the project.

1.3 Level of Assurance

CCSC has undertaken a reasonable assurance engagement in accordance with VCS Standard (version 4.3) /11/. It requires a reasonable level of assurance in verification that GHG assertions are free of material errors, omissions and misrepresentations. The verification conclusion is based on the VCS-PD /3/, VCS-MR /1/, and supporting evidences made available to the verifier and information collected through performing interviews and during the on-site inspection.

1.4 Summary Description of the Project

The project developed by Hegang Longyuan Wind Power Co., Ltd. is located on Damahe Forest Farm, Luobei County, Hegang City, Heilongjiang Province of China. The central geographical coordinates are north latitude 47°54'34", and east longitude 130°39'56". The project is to utilize wind resources for electricity generation through the construction of a windpower plant with the installation of 58 sets of wind turbines with capacities of 850kW each, which amount to a total installed capacity of 49.3MW. The project started construction on 04/06/2009. The first wind turbine started operation on 20/01/2010 and all wind turbines started operation on 12/04/2010. The expected operation period of the project is 20 years.

The electricity generated from the project is supplied to Northeast China Power Grid (NECPG), where geographic and system boundaries can be clearly identified and information on the grid and calculation of baseline emissions is published and public available according to Notification on Determining Baseline Emission Factor of China's Grid dated on 02/07/2009/17/.

By exporting expected annual electricity of 120,069 MWh, the project achieves greenhouse gas (GHG) emissions reductions by displacing equivalent electricity from fossil fuel-based power plants connected to NECPG, which is dominated by thermal power plants.

The project was registered as a CDM project on 31/01/2012 (UNFCCC registration reference number of 5711), issued 72,155 tCO₂e during the 1st CDM monitoring period from 31/01/2012 - 31/12/2012.

According to the VERRA website, the project also has registered as a VCS project (VCS ID 1051), issued 195,043 tCO₂e during the 1st VCS monitoring period from 20/01/2010 to 30/01/2012. The current verification has been finalized for the monitoring period from 01/01/2019 to 19/01/2020.

During the monitoring period from 01/01/2019 to 19/01/2020, the total GHG emission reductions generated by the project are 121,014 tCO₂e.

2 VERIFICATION PROCESS

2.1 Method and Criteria

The overall verification, from Contract Review to Verification Report & Opinion, was conducted using CCSC internal procedures.

CCSC verified the project against the requirements set in VCS/11//13//14//15/, and other relevant VCS requirements.

The following sections outline each step in more detail.

2.2 Document Review

A desk review of the registered VCS-PD /3/, the registered validation report /5/, the previous verification reports /6//7//8/, the applied monitoring methodology /12/, the VCS monitoring report (VCS-MR) /1/ and supporting documents was conducted by the verification team. The aim of the desk review of the documentation was to verify the completeness of the data and the information presented, to carry out the compliance check of the VCS-MR /1/ with respect to the monitoring plan and the applied methodology /12/.

Particular attention was given to the quality of the metering equipment including calibration requirements /18//19/, the monitored data and its evidence, and the emission reduction calculation. The evaluation of data management and the quality assurance and quality control system in the context of their influence on the generation and reporting of emission reductions was also conducted.

Appendix B of this report contains a complete list of all documents and proofs reviewed by the verification team.

2.3 Interviews

On 13/07/2022, CCSC performed an on-site assessment at the physical site of the project.

The verification team verified that the actual implementation of the project was in compliance with that described in the VCS-PD /3/, VCS-MR /1/. This included the review of the project operation based on the evidence of on-site observation and presented documents.

During the on-site assessment, the verification team has interviewed with key personnel from the project owner (the project participant) , the consultancy, and local stakeholders.

The assessment content and topics/the persons interviewed at the on-site assessment were provided in the below table.

Date: 13/07/2022	
Interview topics	Interviewed Organizations and persons
--The status of VCS project implementation. -- Any changes of the VCS project. -- The project on-site inspection -- The evidences of construction status and operation of key equipment, parameters monitoring and data processing activities, monitor equipment and calibration. -- Monitoring data. -- Quality Management; organizational structure, responsibilities and competencies; Internal QA/QC Management procedures and document control. -- Compliance with National Laws and Regulations.	Hegang Longyuan Wind Power Co., Ltd. Liu Jiyuan, Operation and control staff Feng Yanbing, Maintenance Staff
-- The impact of the project activity. -- The complaint by local stakeholders. -- The stakeholder consultation during the operation of the project activity.	Wang Wenhua, Hegang Ecology and Environment Protection Bureau Yu Jinfeng, local resident of Xingdong Village, Luobei Town Song Baohua, local resident of Damahe Forest Farm, Luobei Town

Date: 13/07/2022	
Interview topics	Interviewed Organizations and persons
-- Preparation of Monitoring Report. -- Compliance of the monitoring plan with the monitoring methodology. -- Compliance of monitoring with the monitoring plan -- Assessment of data and calculation of GHG emission reductions.	Longyuan (Beijing) Carbon Asset Management Technology Co., Ltd., Mr. Xue Qiang, Project Manager

2.4 Site Inspections

The on-site assessment involved following activities,

An assessment of the implementation and operation of the project activity as per the VCS-PD /3/;

A review of information flows for generating, aggregating and reporting the monitoring parameters;

Interviews with relevant personnel to confirm that the operational and data collection procedures are implemented in accordance with the approved monitoring plan;

A cross-check between information provided in the monitoring report /1/ and data from other sources such as operational records or similar data sources;

A check of the monitoring equipment including calibration performance and observations of monitoring practices against the requirements of the VCS-PD /3/ and the selected methodology /12/;

A review of calculations and assumptions made in determining the GHG data and emission reductions;

An identification of quality control and quality assurance procedures in place to prevent or identify and correct any errors or omissions in the reported monitoring parameters.

2.5 Resolution of Findings

During the verification of a project activity, to identify issues that need to be further elaborated upon, researched or added to in order to confirm that the project activity meets the VERRA's requirements and can achieve credible emission reductions, the verification team will issue a Corrective Action Request (CAR), a Clarification Request (CL) or a Forward Action Request (FAR) depending on different situations.

The objective of this phase of the verification is to resolve issues related to the monitoring, implementation and operations of the registered project activity that could impair the capacity of the registered project activity to achieve emission reductions or influence the monitoring and reporting of emission reductions prior to CCSC's positive conclusion on the GHG emission reduction calculation.

Findings established during the verification can either be seen as a non-fulfilment of criteria ensuring the proper implementation of a project or where a risk to deliver high quality emission reductions is identified.

A Corrective Action Request (CAR) will be raised if one of the following occurs:

- a) Non-compliance with the monitoring plan or methodology are found in monitoring and reporting and has not been sufficiently documented by the project participants, or if the evidence provided to prove conformity is insufficient;
- b) Modifications to the implementation, operation and monitoring of the registered project activity has not been sufficiently documented by the project participants;
- c) Mistakes have been made in applying assumptions, data or calculations of emission reductions that will impact the quantity of emission reductions;
- d) Issues identified in a FAR during validation to be verified during verification or previous verification(s) have not been resolved by the project participants.

A Clarification Request (CL) will be raised if information is insufficient or not clear enough to determine whether the applicable VCS requirements have been met.

A Forward Action Request (FAR) will be raised, for actions if the monitoring and reporting require attention and/or adjustment for the next verification period.

There are 1 Clarification Request (CL) has been raised during the current verification.

2.6 Forward Action Requests

No Forward Action Requests were raised during the current verification.

2.7 Eligibility for Validation Activities

The VVB of "China Classification Society Certification Co., Ltd." commissioned by the project participant is one of eligible VVBs listed on the VERRA website (<https://verra.org/project/vcs-program/validation-verification/>), and it holds the accreditation for validation/verification for the sectoral scope: "1. Energy (renewable/non-renewable)", to which the project activity belongs. Therefore, CCSC is eligible for the validation/verification of the project activity.

3 VALIDATION FINDINGS

3.1 Participation under Other GHG Programs

The project was validated by Bureau Veritas Certification Holding SAS on 04/01/2012 under CDM scheme for registration /5/. CCSC only performed verification activities on this monitoring period for the project according to the VCS Program Guide.

3.2 Methodology Deviations

No deviation from the methodology is needed to be submitted.

3.3 Project Description Deviations

As per registered VCS PD /3/, the VCS crediting period was determined as from 20/01/2010 to 30/01/2012. The project is registered under VCS Standard Version 3 and completed validation before 19/03/2020. As per Appendix 3 of VCS Standard version 4.3, registered projects and projects that complete validation on or before 19/03/2020 remain eligible to apply the crediting period requirements under VCS Version 3. Thus, it remains eligible to apply the crediting period requirements under VCS Version 3 which shall be a maximum of ten years and may be renewed at most twice. Considering 3*7 years CDM crediting period and 20 years operation time, it is reasonable that the total VCS crediting period was determined from 20/01/2010 to 19/01/2030, of which the first VCS crediting period is from 20/01/2010~19/01/2020 and the second VCS crediting period is from 20/01/2020~19/01/2030.

As per para 3.8.9-3 of VCS Standard version 4.3, "The updated project description shall be validated in accordance with the VCS Program rules. In addition, the project shall be validated against the (current) scope of the VCS. Such validation report shall be issued after the end of the (previous) project crediting period but within two years after the end of the (previous) project crediting period.". Since the project did not conduct the validation of crediting period renewal within the two years after the end of the first VCS crediting period, the VCS crediting period of the first crediting period of the project ends on 19/01/2020.

According to the information collected during on-site visit and the relevant evidence provided by project owner, CCSC can confirm that the deviation does not impact the applicability of the methodology, additionality or the appropriateness of the baseline scenario, and the project remains in compliance with the applied methodology, the deviation has been appropriately described and justified in the monitoring report and will be described in all subsequent monitoring reports, and the project remains in compliance with the VCS Program rules.

3.4 Grouped Project

Not applicable as the project activity is not grouped project.

4 VERIFICATION FINDINGS

4.1 Project Implementation Status

4.1.1 Project Implementation in accordance with the VCS PD

The project has been registered as VCS project activity with the Project ID 1051 (<https://registry.terra.org/app/projectDetail/VCS/1051>). The first crediting period is proposed for 10 years starting on 20/01/2010. This monitoring period is from 01/01/2019 to 19/01/2020, which is compliance with the crediting period and continued with the previous monitoring period. This monitoring period is verified in accordance with the VCS Standard version 4.3 /11/. The project started construction on 04/06/2009. The first wind turbine started operation on 20/01/2010 and all wind turbines started operation on 12/04/2010, and the start date of the project is 20/01/2010.

The project is to utilize wind resources for electricity generation through the construction of a wind power plant with the installation of 58 sets of wind turbines with capacities of 850kW each, which amount to a total installed capacity of 49.3MW on Damahe Forest Farm, Luobei County, Hegang City, Heilongjiang Province, P.R.China. The electricity generated from the project is sold to Northeast China Power Grid (NECPG). Through the on-site visit, the power generating technology, installed capacity, technical specifications of wind turbine and generator, and power delivering systems indicated in the VCS PD are in place and the project has been operated as per the VCS PD /3/. The verification team confirms the project has been implemented as per the registered VCS PD /3/. During this monitoring period, the monitoring of this project activity was in compliance with the registered VCS PD.

The major technical specifications of the project /25/ have been verified during the site visit and listed in the table below and the verification team confirmed they are consistent with the registered PD /3/.

Table 4-1 The main technical parameters of wind turbines and generators

Parameters	Data	
Rated wind speed (m/s)	13	
Unit capacity	850kW	
Type	G58-850	G52-850
Diameter of rotor (m)	58	52
Cut-in wind speed (m/s)	3	
Cut-out wind speed (m/s)	21	
Survival wind speed (m/s)	37.5	
Swept area (m ²)	2642/2214	
Lifetime	20 year	
Generator	Doubly fed asynchronous	

	generator
--	-----------

According to the registered PD /3/ and the emission reductions calculation spreadsheet /2/, quantity of net electricity generation supplied by the project plant/unit to the grid is 117,718.920 MWh during this monitoring period (01/01/2019~19/01/2020), and total 384 days). All the data and the calculated process in the emission reductions calculation spreadsheet /2/ have been checked by the verification team and it is correctly and in accordance with both the monthly reading records /20/ and Electricity Sales and Purchase Receipts /10/. Therefore, the verification team confirmed there are no changes of the project from the validated PD /3/ that cause increase of emission reductions.

By checking UNFCCC website (<https://cdm.unfccc.int/Projects/DB/BVQI1327230197.63/view>), it is confirmed by CCSC that the project has been registered as CDM project activity on 31/01/2012 with reference No. 5711. GHG emission reductions have been issued as CERs from 31/01/2012 - 31/12/2012 under CDM scheme. There are no CDM issuance during this monitoring period. Furthermore, CCSC checked public information from the REC Mechanism database of China, Chinese Emission Trading System, Chinese Certified Emission Reduction Mechanism, Gold Standard Registry and interviewed with project owner during site visit, it is confirmed that except CDM and VCS scheme, the project has not been participated or been rejected under any other GHG programs since validation or previous verification.

Furthermore, as per “Notice on Strengthening Enterprise Greenhouse Gas Emission Report Management” /21/ issued by Ministry of Ecology and Environment of P.R.China, China has a national emissions trading scheme only cover the high-emission industries, including thermal power generation, petrochemical, chemical, building materials, iron and steel, non-ferrous, paper, aviation and other key emission industries that emitted at least 26,000 tons of CO₂e/year. By checking “List of key emissions in the national carbon emissions transaction quota management in 2019-2020” /22/ issued by Ministry of Ecology and Environment of P.R.China, the project owner is not included in the mandatory emission control scheme and thus no emission cap was enforced for the project activity.

Therefore, the verification team confirmed that the project only applies CERs and VCU under CDM and VCS, and no rejection from CDM and VCS occurs, there are no other forms of environmental credits applied or issued for the project activity, the emission reduction resulted from the project during this monitoring period would only apply for VCUs.

By checking China's National Plan on Implementation of the 2030 Agenda for Sustainable Development/16/ and 17 SDGs defined by UNDP, and interviewing with stakeholders during site visit, CCSC confirmed that the project would contribute to sustainable development in as below:

- **SDG 13:** Reducing greenhouse gas emissions compared to a business-as-usual scenario. During this monitoring period, the emission reductions achieved were 121,014tCO₂e. By

checking UNFCCC website (<https://cdm.unfccc.int/Projects/DB/BVQI1327230197.63/view>) and VERRA website (<https://registry.terra.org/app/projectDetail/VCS/1051>), it is confirmed that the cumulative Contributions Over Project Lifetime were 833,206tCO₂e achieved emission reductions.

- **SDG 7:** Providing clean and renewable energy source and displacing the power generation of fossil fuel power plants, reducing pollution emissions caused by coal burning significantly, thus mitigating the air pollution and its adverse impacts on human health, promoting sustainable economic development in local area. During this monitoring period, the renewable energy supplied to NECPG was 117,718.920MWh. By checking UNFCCC website (<https://cdm.unfccc.int/Projects/DB/BVQI1327230197.63/view>) and VERRA website (<https://registry.terra.org/app/projectDetail/VCS/1051>), it is confirmed that the cumulative Contributions Over Project Lifetime was 810,518.212MWh renewable energy supplied to NECPG.

- **SDG 8:** Providing direct and indirect employment opportunities during construction and operation period, which promotes sustained, inclusive and sustainable economic growth, full and productive employment and decent work for local residents. By checking staff roaster /24/, it is confirmed that since operation of the project activity, 12 long term working opportunities are provided.

In Table 1 of the Monitoring Report (version 01 dated 12/07/2022), the “Current Project Contributions” of SDG target 7.2 and 13.0 were the same as that of “Contributions Over Project Lifetime”. Hence, **CL-1** was raised requesting PP to clarify the reason. In the updated MR, the “Current Project Contributions” of SDG target 7.2 and 13.0 has been updated which is the same as SDG target achieved during this monitoring period and confirmed by CCSC to be correct. Therefore, **CL-1** was closed.

In conclusion, according to the information collected during site visit and the relevant evidence provided by project owner, CCSC can confirm that:

- a) No project design change occurred during this monitoring period and the project was implemented in accordance the registered VCS-PD /3/;
- b) The project contributes to sustainable development including: creating job opportunities in the project area, displacing part of the electricity generated by coal-fired power plants, and generating emission reductions;
- c) The GHG emission reductions or removals generated by the project have not included in an emissions trading program or any other mechanism that includes GHG allowance trading;
- d) The project has not sought or received another form of GHG-related environmental credit, including renewable energy certificates, during this monitoring period. None of the credits will be claimed in the same period;

- e) The GHG emission reductions generated by the project during this monitoring period (01/01/2019~19/01/2020) will be only claimed under VCS program as VCUs for the project to avoid double counting.

4.1.2 Compliance of monitoring with the monitoring plan

The verification team has assessed the implementation of monitoring by the project owner against the registered monitoring plan. A short summary on the verification of every parameter listed in the monitoring plan and used for emission reduction calculation is provided below:

Monitoring Parameter Requirement	Assessment/ Observation by the VVB
Data / Parameter: (as in the monitoring plan of PD):	$EG_{\text{facility},y}$ Quantity of net electricity generation supplied by the project plant/unit to the grid in year y (MWh)
Measuring frequency:	Continuously measurement
Reporting frequency:	Daily recorded and monthly aggregated
Is measuring and reporting frequency in accordance with the monitoring plan and monitoring methodology? (Yes / No)	Yes
Type of monitoring equipment:	Calculated via equation: $EG_{\text{facility},y} = EG_{\text{export},y} - EG_{\text{import},y}$ $EG_{\text{export},y}$ and $EG_{\text{import},y}$ are measured by electricity meter main meter M1 and backup meter M2.
Is accuracy of the monitoring equipment as stated in the PD? If the PD does not specify the accuracy of the monitoring equipment, does the monitoring equipment represent good monitoring practise?	Yes. Accuracy level of monitoring meters is 0.5S as described in the registered VCS PD /3/. For details see Table 4-2.
Calibration frequency /interval:	Annually as per relevant sectoral standards in China
Is the calibration interval in line with the monitoring plan of the PD? If the PD does not specify the frequency of calibration, does the selected frequency represent good monitoring practise?	Yes

Company performing the calibration:	See Table 4-2
Did calibration confirm proper functioning of monitoring equipment? (Yes / No):	Yes
Is(are) calibration(s) valid for the whole reporting period?	Yes. For details see Table 4-2.
If applicable, has the reported data been cross-checked with other available data?	Yes, the reported data has been cross-checked with Electricity Sales and Purchase Receipts in line with registered VCS PD /3/.
How were the values in the monitoring report verified?	The verification details have been reported in Section 4.4 of this report.
Does the data management (from monitoring equipment to emission reduction calculation) ensure correct transfer of data and reporting of emission reductions and are necessary QA/QC processes in place?	Yes.
In case only partial data are available because activity levels or non-activity parameters have not been monitored in accordance with the registered monitoring plan, has the most conservative assumption theoretically possible been applied or has a request for deviation been approved?	Not applicable.
Data / Parameter: (as in the monitoring plan of PD):	$EG_{\text{export},y}$ Electricity exported to the grid by the project (MWh)
Measuring frequency:	Continuously measurement
Reporting frequency:	Daily recorded and monthly aggregated
Is measuring and reporting frequency in accordance with the monitoring plan and monitoring methodology? (Yes / No)	Yes
Type of monitoring equipment:	Electricity meters
Is accuracy of the monitoring equipment as stated in the PD? If the PD does not specify the accuracy of the monitoring equipment, does the	Yes. Accuracy level of monitoring meters is 0.5S as described in the registered VCS PD /3/. For details see Table 4-2.

monitoring equipment represent good monitoring practise?	
Calibration frequency /interval:	Annually as per relevant sectoral standards in China
Is the calibration interval in line with the monitoring plan of the PD? If the PD does not specify the frequency of calibration, does the selected frequency represent good monitoring practise?	Yes
Company performing the calibration:	See Table 4-2
Did calibration confirm proper functioning of monitoring equipment? (Yes / No):	Yes
Is(are) calibration(s) valid for the whole reporting period?	Yes. For details see Table 4-2.
If applicable, has the reported data been cross-checked with other available data?	Yes, the reported data has been cross-checked with Electricity Sales Receipts in line with registered VCS PD /3/.
How were the values in the monitoring report verified?	The verification details have been reported in Section 4.4 of this report.
Does the data management (from monitoring equipment to emission reduction calculation) ensure correct transfer of data and reporting of emission reductions and are necessary QA/QC processes in place?	Yes.
In case only partial data are available because activity levels or non-activity parameters have not been monitored in accordance with the registered monitoring plan, has the most conservative assumption theoretically possible been applied or has a request for deviation been approved?	Not applicable.
Data / Parameter: (as in the monitoring plan of PD):	EG _{import,y} Electricity utilized by the project (MWh)
Measuring frequency:	Continuously measurement

Reporting frequency:	Daily recorded and monthly aggregated
Is measuring and reporting frequency in accordance with the monitoring plan and monitoring methodology? (Yes / No)	Yes
Type of monitoring equipment:	Electricity meters
Is accuracy of the monitoring equipment as stated in the PD? If the PD does not specify the accuracy of the monitoring equipment, does the monitoring equipment represent good monitoring practise?	Yes. Accuracy level of monitoring meters is 0.2S which is in compliance with described in the registered CDM-PDD /3/. For details see Table 4-2.
Calibration frequency /interval:	Annually as per relevant sectoral standards in China
Is the calibration interval in line with the monitoring plan of the PD? If the PD does not specify the frequency of calibration, does the selected frequency represent good monitoring practise?	Yes
Company performing the calibration:	See Table 4-2
Did calibration confirm proper functioning of monitoring equipment? (Yes / No):	Yes
Is(are) calibration(s) valid for the whole reporting period?	Yes. For details see Table 4-2.
If applicable, has the reported data been cross-checked with other available data?	Yes, the reported data has been cross-checked with Electricity Sales Receipts in line with registered VCS PD /3/.
How were the values in the monitoring report verified?	The verification details have been reported in Section 4.4 of this report.
Does the data management (from monitoring equipment to emission reduction calculation) ensure correct transfer of data and reporting of emission reductions and are necessary QA/QC processes in place?	Yes.
In case only partial data are available because activity levels or non-activity	Not applicable.

parameters have not been monitored in accordance with the registered monitoring plan, has the most conservative assumption theoretically possible been applied or has a request for deviation been approved?

According to the applied methodology ACM0002 (version 12.1.0) "Consolidated baseline methodology for grid-connected electricity generation from renewable sources", Quantity of net electricity generation supplied by the project plant/unit to the grid in year y ($EG_{\text{facility},y}$) is calculated as the difference of Electricity exported to the grid by the project ($EG_{\text{export},y}$) and Electricity utilized by the project ($EG_{\text{import},y}$), which is used for the calculation of baseline emission.

Furthermore, the verification team has verified that the accuracy of measure of the monitoring equipment was set according to the requirements and all calibration procedures were carried out according to the registered VCS PD and manufacturer specifications. The calibration information of the monitoring meters /10//23//26/ in this monitoring period has been listed in Table 4-2 below. The monitoring equipment has been installed in the project in line with the registered VCS PD. 2 meters (M1 and M2) are installed respectively at outlet of the main transformer and the inlet of the main transformer at the on-site 110 kV substation. The meters measure Electricity exported to the grid by the project and Electricity utilized by the project. During this monitoring period, the meters are working well.

In summary, the verification team is able to verify that the accuracy the monitoring equipment was set according to the registered VCS PD /3/ and relevant sectoral standard of China.

Table 4-2 Verified calibration information of monitoring meters

Meter	Type	Serial number	Accuracy	Frequency	Calibration date	Valid until	Calibration Entity
M1	DTSD719	42005250 40909208 867	0.5S	Annually	30/04/2018 28/04/2019	29/04/2019 27/04/2020	Hegang Metrological Verification Institution /23/
M2	DTSD719	42002220 40909208 865	0.5S	Annually	30/04/2018 28/04/2019	29/04/2019 27/04/2020	

The verification team confirmed that there is no proposed or actual change to monitoring plan of registered VCS PD during this monitoring period. All required equipments and procedures are available and implemented in an appropriate manner. All necessary monitoring instruments are installed. All required instruments including standby and operating procedures for the same have been implemented in an appropriate manner. The

project is completely operational and the same has been confirmed on-site. Neither mistakes nor malfunction on meters have been observed during this monitoring period.

4.2 Safeguards

4.2.1 No Net Harm

By checking the EIA summary and conclusion provided in the registered VCS PD, it is confirmed that wind power is green power and the impact caused by wind power on the surrounding ecosystem and residents, wastewater, solid waste and atmosphere etc. is very little, there would be no net harm caused due to the project activity. Besides, the EIA of the project are approved by the government.

Also, no potential environment or social economic matter was found during on-site assessment. The project is renewable energy project and thus no net harm observed in air or water quality on-site.

4.2.2 Local Stakeholder Consultation

As per the registered VCS PD (version 01 dated 21/12/2012), the local stakeholder's consultation was done through a stakeholders' conference on 06/05/2009. 10 stakeholder representatives respectively from local Development and Reform Bureau, local Environmental Protection Bureau, local Power Grid Corporation and local residents participated the meeting. No negative comments was received.

Besides, the local stakeholder's consultation was done through distributing a one-page questionnaire, which was designed to be easily filled in. 40 copies of questionnaire were distributed, and 40 pieces of reply were received. The respondents are representative in terms of age, occupation and education, so their attitude towards the impacts of the project can therefore be seen as a comprehensive reflection of the attitudes of the residents possibly affected by the project.

The survey showed that the local people supported and agreed with the construction of the project. They believe that the project would have a positive impact on the local economic development and their living conditions, without having negative impacts on the environment and the ecosystem.

Communications with Local stakeholders was being carried out at periodic intervals. There are no negative comments received for the project.

All such conclusion has been verified through on-site assessment and check registered VCS PD.

4.3 AFOLU-Specific Safeguards

The project is not AFOLU project, and thus this section is not applicable for the project.

4.4 Accuracy of GHG Emission Reduction and Removal Calculations

4.4.1 Parameters and information flow

The parameters required by the monitoring plan and the way CCSC has verified the information flow (from data generation, aggregation, to recording, calculation and reporting for these parameters including the values) in the monitoring report are described below:

Parameters monitored ex-post:

$$EG_{\text{facility},y} = EG_{\text{export},y} - EG_{\text{import},y}$$

Where:

- 1) **$EG_{\text{facility},y}$: Quantity of net electricity generation supplied by the project plant/unit to the grid in year y (MWh);**
- 2) **$EG_{\text{export},y}$ is Electricity exported to the grid by the project (MWh);**
- 3) **$EG_{\text{import},y}$ is Electricity utilized by the project (MWh);**

According to the VCS-MR /1/ of the project and the registered VCS PD /3/, the Electricity exported to the grid by the project ($EG_{\text{export},y}$) and Electricity utilized by the project ($EG_{\text{import},y}$) are both continuously monitored through the meter which is both agreed by the grid company and the project owner. The Quantity of net electricity generation supplied by the project plant/unit to the grid in year y is the difference of Electricity exported to the grid by the project and Electricity utilized by the project, i.e. $EG_{\text{facility},y} = EG_{\text{export},y} - EG_{\text{import},y}$. The daily and monthly monitoring records of the project have been verified during on-site assessment.

The verification team has cross-checked $EG_{\text{facility},y}$, $EG_{\text{export},y}$, and $EG_{\text{import},y}$ in the emission reductions calculation spreadsheet /2/ with Electricity Sales and Purchase Receipts /9/ of the project from the grid company. By the on-site assessment, the values in emission reductions calculation spreadsheet /2/ is in line with Electricity Sales and Purchase Receipts /9/ during this period.

Parameter determined ex-ante:

EF_y : Combined margin CO2 emission factor for grid connected power generation in the year y.

According to the registered PD /3/, the $EF_{\text{grid,CM},y}$ is ex-ante determined as 1.0280 tCO₂/MWh for Northeast China Power Grid over the first crediting period. The emission factors used in this monitoring report have been verified against the registered VCS-PD /3/ and found them to be consistent.

4.4.2 Assessment Data and Calculation

It was verified that the project is a newly built wind power plant. Therefore, the project emission of the project is zero under ACM0002 (version 12.1.0) /12/ ($PE_y=0$).

The project is a new wind power plant. Therefore, no leakage needs to be considered for the project activity according to the methodology /12/. ($LE_y=0$).

Since the project emission and the leakage emission has been justified as zero under ACM0002 (version 12.1.0) /12/, the calculation of the emission reductions simply involves the calculation of the baseline emissions.

Formula 1:

$$ER_y = BE_y - 0 - 0 = EG_{\text{facility},y} \times EF_y \quad (1)$$

Where:

ER_y : Emission reductions in year y (tCO_2/yr)

BE_y : The baseline emissions (tCO_2/yr)

$EG_{\text{facility},y}$: Quantity of net electricity generation supplied by the project plant/unit to the grid in year y (MWh)

EF_y : Combined margin CO_2 emission factor for grid connected power generation in the year y (tCO_2/MWh)

Quantity of net electricity generation supplied by the project plant/unit to the grid in year y ($EG_{\text{facility},y}$) is calculated as the difference of Electricity exported to the grid by the project ($EG_{\text{export},y}$) and Electricity utilized by the project ($EG_{\text{import},y}$), as follow:

$$\text{Formula 2: } EG_{\text{facility},y} = EG_{\text{export},y} - EG_{\text{import},y} \quad (2)$$

Following the approach described in section 4.4.1 above, $EG_{\text{export},y}$ and $EG_{\text{import},y}$ were verified as below:

Table 4-4 The verified $EG_{\text{export},y}$ of the project (Unit: MWh)

Period	$EG_{\text{export},y}$ (MWh)		
	Values from meter readings from Main Meter (M1)	Values from Electricity Sales Receipts	Conservative Value
	A	B	C=Min (A, B)
01/01/2019-31/01/2019	11,238.480	11,238.480	11,238.480
01/02/2019-28/02/2019	11,197.560	11,197.560	11,197.560
01/03/2019-31/03/2019	7,788.000	7,788.000	7,788.000
01/04/2019-30/04/2019	6,737.280	6,737.280	6,737.280
01/05/2019-31/05/2019	7,502.880	7,502.880	7,502.880
01/06/2019-30/06/2019	5,177.040	5,177.040	5,177.040
01/07/2019-31/07/2019	3,594.360	3,594.360	3,594.360
01/08/2019-31/08/2019	5,738.040	5,738.040	5,738.040
01/09/2019-30/09/2019	8,655.240	8,655.240	8,655.240

01/10/2019-31/10/2019	9,346.920	9,346.920	9,346.920
01/11/2019-30/11/2019	16,267.680	16,267.680	16,267.680
01/12/2019-31/12/2019	15,015.000	15,015.000	15,015.000
Subtotal	108,258.480	108,258.480	108,258.480
01/01/2020-19/01/2020	9,699.360	9,699.360	9,699.360
Subtotal	9,699.360	9,699.360	9,699.360
Total	117,957.840	117,957.840	117,957.840

Table 4-5 The verified $EG_{import,y}$ of the project (Unit: MWh)

Period	$EG_{import,y}$ (MWh)		Conservative Value
	Values from meter readings Meter (M1)	Values from Electricity Purchase Receipts	
	D	E	F=Max(D,E)
01/01/2019-31/01/2019	7.920	7.920	7.920
01/02/2019-28/02/2019	14.520	14.520	14.520
01/03/2019-31/03/2019	23.760	23.760	23.760
01/04/2019-30/04/2019	13.200	13.200	13.200
01/05/2019-31/05/2019	13.200	13.200	13.200
01/06/2019-30/06/2019	34.320	34.320	34.320
01/07/2019-31/07/2019	35.640	35.640	35.640
01/08/2019-31/08/2019	29.040	29.040	29.040
01/09/2019-30/09/2019	15.840	15.840	15.840
01/10/2019-31/10/2019	13.200	13.200	13.200
01/11/2019-30/11/2019	6.600	6.600	6.600
01/12/2019-31/12/2019	31.680	31.680	31.680
Subtotal	238.920	238.920	238.920
01/01/2020-19/01/2020	0.000	0.000	0.000
Subtotal	0.000	0.000	0.000
Total	238.920	238.920	238.920

By checking Electricity Sales and Purchase Receipts /9/ during this period, it is confirmed that the transaction time of $EG_{export,y}$ and $EG_{import,y}$ is 24:00 of last day of each month. By checking Statement from local power grid company /27/, it is confirmed that the electricity data for the period of 01/01/2020-19/01/2020 are sourced from daily meter records and has confirmed by the local power grid company.

Therefore, $EG_{facility,y}$ is calculated as:

Table 4-6 The verified $EG_{facility,y}$ of the Project (Unit: MWh)

Period	$EG_{export,y}$ (MWh)	$EG_{import,y}$ (MWh)	$EG_{facility,y}$ (MWh)
	a	b	c=a-b
01/01/2019-31/12/2019	108,258.480	238.920	108,019.560
01/01/2020-19/01/2020	9,699.360	0.000	9,699.360
Total (01/01/2019 to 19/01/2020)	9,699.360	0.000	117,718.920

The verification team has confirmed the emission reductions of the project have been conservatively calculated in line with above mentioned Formula 1&2 in the emission reduction calculation spreadsheet /2/. The verification team has checked and confirmed the emission reduction is to be correctly accounted. The total emission reduction is as follow:

Table 4-7 Verified Emission Reductions during this monitoring period

Period			$EG_{\text{facility},y}$ (MWh)	$EF_{\text{grid},C}^{M,y}$ (tCO ₂ /MWh)	BE_y (tCO ₂ e)	PE_y (tCO ₂ e)	LE_y (tCO ₂ e)	ER_y (tCO ₂ e)
Year	From	To	A	B	C=A*B	D	E	F=C-D-E
2019	01/01/2019	31/12/2019	108,019.560	1.0280	111,044	0	0	111,044
2020	01/01/2020	19/01/2020	9,699.360	1.0280	9,970	0	0	9,970
Total			117,718.920	/	121,014	0	0	121,014

4.4.3 Comparison of ERs

Based on the above assessment, CCSC can conclude that the emission reduction during the monitoring period from 01/01/2019 to 19/01/2020 have been quantified correctly in accordance with the project description and applied methodology /12/, and the emission reduction during this monitoring period is verified as 121,014 tCO₂e. Compared with the estimated emission reductions under the same days of 384 from 01/01/2019 to 19/01/2020 in the registered VCS-PD /3/, 129,855 (equals to 123,430*384/365) tCO₂e, the verified emission reduction is 6.81% less than the estimated value. CCSC considers the value of verified emission reduction is conservative.

4.5 Quality of Evidence to Determine GHG Emission Reductions and Removals

The evidences used to determine the GHG emission reductions are assessed as follows:

Assessment of the Evidence Quality	
Parameters monitored	$EG_{\text{facility},y}$
	$EG_{\text{export},y}$
	$EG_{\text{import},y}$

Monitoring method	Quantity of net electricity generation supplied by the project plant/unit to the grid in year y ($EG_{\text{facility},y}$) is calculated as the difference of Electricity exported to the grid by the project ($EG_{\text{export},y}$) and Electricity utilized by the project ($EG_{\text{import},y}$). $EG_{\text{export},y}$ and $EG_{\text{import},y}$ are measured by meter M1 and M2.
Measuring/Reading/Recording frequency	The parameters $EG_{\text{export},y}$ and $EG_{\text{import},y}$ are continuously measured, daily recorded and monthly aggregated.
Calibration frequency/ interval	See Table 4-2 Verified calibration information of monitoring meters. Through on-site assessment and checking the calibration records of meters, the team confirmed that all the monitoring meters meet the rated accuracy level and the calibration frequency fulfils the requirement as described in the monitoring plan.
Calibration cover the monitoring period	The verification team confirms that the validity period of all conducted calibrations covers this monitoring period from 01/01/2019 to 19/01/2020.
Data reported	Through cross checking with Electricity Sales and Purchase Receipts /9/, the monitored data can be confirmed as acceptable to calculate emission reductions.

In conclusion, all necessary documentation is collected, referenced and is easily accessible in hard-copy or electronic format. The data pertaining to the monitored parameters are maintained in the identified internal records and consistent with the values stated in the Monitoring Report /1/ and ER calculation spreadsheet /2/. Monitoring data have been cross-checked with Electricity Sales and Purchase Receipts.

4.6 Non-Permanence Risk Analysis

The project is not AFOLU project, and thus non-permanence risk analysis is not applicable for the project.

5 VERIFICATION CONCLUSION

CCSC has carried out the verification of the project "Heilongjiang Wangyunfeng Wind Power Project". The verification was performed based on the requirements set by Voluntary Carbon Standard (VCS) version 4.3 /11/, as well as criteria given to provide for consistent project operations, monitoring and reporting. This verification covers the period from 01/01/2019 to 19/01/2020 inclusive.

In the course of the verification 1 Clarification Request (CL), no Corrective Action Requests (CARs) and no forward request (FAR) was raised. The verification is based on the VCS-MR /1/, the VCS-PD /3/, ER calculation spread sheet /2/ and supporting documents available to CCSC.

As the result of the verification, CCSC confirms that:

- The project has been implemented and operated as per the registered VCS-PD /3/ and that all physical features (technology, project equipment, and monitoring and metering equipment) of the project are in place;
- The VCS-MR /1/ and other supporting documents provided are complete in accordance with the latest applicable version of the VCS Registration & Issuance Process /15/ and in accordance with the additional requirements stated by the VERRA;
- The actual monitoring systems and procedures comply with the monitoring systems and procedures described in the registered VCS PD and the approved methodology i.e. ACM0002 (version 12.1.0) /12/;
- The GHG emission reductions are calculated without material misstatements and in a conservative and appropriate manner.

Based on the evidence and information that are considered necessary to guarantee that GHG emission reductions are appropriately calculated, CCSC confirms the following statement:

Verification period: From 01/01/2019 to 19/01/2020

Verified GHG emission reductions and removals in the above verification period:

Year	Baseline emissions or removals (tCO ₂ e)	Project emissions or removals	Leakage emissions (tCO ₂ e)	Net GHG emission reductions or removals (tCO ₂ e)

		(tCO ₂ e)		
01/01/2019~31/12/2019	111,044	0	0	111,044
01/01/2020~19/01/2020	9,970	0	0	9,970
Total	121,014	0	0	121,014

APPENDIX A: ABBREVIATIONS

CAR	Corrective Action Request
CDM	Clean Development Mechanism
CER	Certified Emission Reduction(s)
CL	Clarification request
CO ₂	Carbon Dioxide
CO ₂ e	Carbon Dioxide Equivalent
CCSC	China Classification Society Certification Co., Ltd.
DOE	Designated Operational Entity
DNA	Designated National Authority
EF	Emission Factor
EIA	Environmental Impact Assessment
ER	Emission Reduction
ETN	Electricity Transaction Note
FAR	Forward Action Request
GHG	Greenhouse Gas(es)
MR	Monitoring Report
NECPG	Northeast China Power Grid
PD	Project Description
PDD	Project Design Document
PP	Project Proponent
UNFCCC	United Nations Framework Convention on Climate Change
VVB	Validation/Verification Body
VCS	Verified Carbon Standard
VCU	Verified Carbon Unit

APPENDIX B: REFERENCE

Documents provided by the Project Participant and relevant background documents have been reviewed or referenced for the periodic verification conclusions.

Ref no.	Reference Document
/1/	Hegang Longyuan Wind Power Co., Ltd., VCS Monitoring report version 01 dated 12/07/2022, version 02 dated 19/07/2022, version 03 dated 28/10/2022
/2/	Hegang Longyuan Wind Power Co., Ltd., ER calculation spreadsheet version 1.0 dated 12/07/2022
/3/	VERRA website: The registered VCS-PD dated 21/12/2012
/4/	EB website: The registered CDM PDD version 02 dated 01/08/2011
/5/	Bureau Veritas Certification Holding SAS: Registered Validation Report No. CHINA-Val/0231/2009 dated 04/01/2012
/6/	DNV: Verification Report Report No. 2013-9027, dated 23/04/2013, MP (20/01/2010 to 30/01/2012)
/7/	DNV: Verification Report for 1 st CER issuing, Report Number: 2013-9026, dated 17/04/2013, MP (31/01/2012-31/12/2012)
/8/	CTI: Verification Report Report No. CTINB-2022-0519-26, dated 27/06/2022 of MP (01/01/-2013-31/12/2018)
/9/	Electricity Sales and Purchase Receipts issued by the grid company for this monitoring period
/10/	Calibration reports of the meters
/11/	VERRA, VCS Standard, version 4.3
/12/	CDM Executive Board, ACM0002 (version 12.1.0)
/13/	VERRA, Monitoring Report Template Form version 4.1
/14/	VERRA, VCS Program Guide version 4.2
/15/	VERRA, Registration & Issuance Process version 4.2

/16/	China's National Plan on Implementation of the 2030 Agenda for Sustainable Development
/17/	Chinese DNA, Notification on Determining Baseline Emission Factor of China's Grid issued on 02/07/2009
/18/	China National Economic Trading Commission, Technical Administrative Code of Electric Energy Metering, DL/T 448-2016
/19/	The State Bureau of Quality and Technical Supervision, Technical Norm of the Calibration of AC Watthour Meters at place of installation, JJG 1055-1997
/20/	Daily and Monthly reading records of the electricity measured by meter during this monitoring period
/21/	"Notice on Strengthening Enterprise Greenhouse Gas Emission Report Management" issued by Ministry of Ecology and Environment of P.R.China
/22/	"List of key emissions in the national carbon emissions transaction quota management in 2019-2020" issued by Ministry of Ecology and Environment of P.R.China
/23/	Qualification certificate of the meter calibration entity (Hegang Metrological Verification Institution), issued by Heilongjiang quality supervision and Administration Bureau on 22/06/2018 and is valid until 21/06/2021
/24/	staff roster during the operation period of the project activity
/25/	Wind Turbine Purchase Agreement signed between Contruction Office of Longyuan Hegang Wangyunfeng and Gamesa Wind (Tianjin) Co., Ltd
/26/	Photos of electricity meters
/27/	Statement from local power grid company

APPENDIX C: RESOLUTION OF CLARIFICATION REQUESTS AND CORRECTIVE ACTION REQUESTS AND FORWARD ACTION REQUESTS

Table 1. CL from this verification

CL ID	CL-1	Section no.	4.1.1	Date: 13/07/2022
Description of CL				
In Table 1 of the Monitoring Report (version 01 dated 12/07/2022), the “Current Project Contributions” of SDG target 7.2 and 13.0 were the same as that of “Contributions Over Project Lifetime”. Please clarify the reason.				
Project participant response				Date: 19/07/2022
The “Current Project Contributions” of SDG target 7.2 and 13.0 has been updated which is the same as SDG target achieved during this monitoring period.				
Documentation provided by project participant				
updated MR				
DOE assessment				Date: 20/07/2022
In the updated MR, the “Current Project Contributions” of SDG target 7.2 and 13.0 has been updated which is the same as SDG target achieved during this monitoring period and confirmed by CCSC to be correct. Therefore, CL-1 was closed.				

Table 2. CAR from this verification

CAR ID	N/A	Section no.	N/A	Date: N/A
Description of CAR				
N/A				
Project participant response				Date: N/A
N/A				
Documentation provided by project participant				

N/A
DOE assessment
Date: N/A
N/A

Table 3. FAR from this verification

FAR ID	N/A	Section No.	N/A	Date: N/A
Description of FAR				
N/A				
Project participant response				Date: N/A
N/A				
Documentation provided by project participant				
N/A				
DOE assessment				Date: N/A
N/A				