



AMBATOLAMPY SOLAR PV



Document Prepared by

LGAI Technological Center, S.A. (Applus+ Certification)

Report ID	BELL_VCS_VER_5125
Project title	Ambatolampy Solar PV
Project ID	2307 ¹
Verification period	01-January-2024 to 31-March-2025 (both dates included)
Original date of issue	12-September-2025
Most recent date of issue	24-September-2025
Version	3.0
VCS Standard Version	VCS Standard, Version 4.7

¹ <https://registry.verra.org/app/projectDetail/VCS/2307>

Client	AERA Group
Prepared by	LGAI Technological Center, S.A. (Applus+ Certification)
Approved by	Mr. Agustín Calle de Miguel LGAI Technological Center S.A. (Applus+ Certification) - VVB Technical Manager
Work carried out by	Lead Auditor & Technical Expert (TA 1.2): Dr. N. Premjit Singh Auditor: Mr. Saurabh Gaikwad Local Support: Ms. Nathalie Raharilaza Technical Reviewer & Technical Expert (TA 1.2): Mr. Denny Xue

Summary:

LGAI Technological Center, S.A. (hereinafter referred to as Applus+ Certification) has been contracted^{2/} by AERA Group to conduct the fourth verification for the project - “Ambatolampy Solar PV”, VCS ID-2307^{27/} regarding the relevant requirements of VCS programme guidelines and standard (VCS standard version 4.7, & VCS program guide version 4.4)^{10/}. Relevant requirements of the UNFCCC for CDM project activities^{16//17//28/}, as well as criteria for consistent project operations, monitoring and reporting have been applied for verification.

The monitoring period covered under this verification is from 01-January-2024 to 31-March-2025 (both days included).

The project activity was initially registered under CDM^{34/} with UNFCCC project ID: 10481² on 03-May-2019. Afterwards, it was gap validated to VCS on 04-November-2020, with VCS project ID as 2307³.

The verification includes confirming the implementation of the monitoring plan of the registered CDM PDD^{4/}, registered and revised VCS PD-MR (VCS ID 2307)^{4//6/} and the application of the monitoring methodology as per ACM0002, Version 22.0: “Grid-connected electricity generation from renewable sources”^{17/}.

The main purpose of this project activity is to generate clean form of electricity through renewable energy sources (solar photovoltaic). New Energy Africa Ambatolampy⁴ (NEA Ambatolampy) (formerly known as Green Yellow Madagascar)^{23/} is the project proponent/developer, operator & owner of the

² <https://cdm.unfccc.int/Projects/DB/RWTUV1556909746.23/view>

³ <https://registry.terra.org/app/projectDetail/VCS/2307>

⁴ In 2020, the Malagascan company Axian Energy acquired the majority of the shares of Green Yellow Ambatolampy. On January 9, 2023, Green Yellow Ambatolampy, the sole shareholder of Green Yellow Madagascar, changed its corporate name to “New Energy Africa Ambatolampy (NEA Ambatolampy)”

project and AERA Group is the carbon consultant. The project consists of the construction and operation of a greenfield solar power plant in Ambatolampy, in the South-East of Vakinankaratra region, 90km South of Antananarivo, Madagascar. It involves the setting up of photovoltaic (PV) panels which captures solar energy and convey such energy to the convertor station in order to produce electricity exported to the national grid. Besides the initial capacity of 20 MWp operating since 10-July-2018^{/1/}, the second phase (with capacity of 20 MWp) of the Ambatolampy project was commissioned on 17-August-2022^{/1/}, bringing the total installed capacity to 40 MWp.

The project activity has been operational since commissioning (10-July-2018)^{/1/} and during 4th monitoring period i.e., from 01-January-2024 to 31-March-2025 (including both days) has generated 70,206 MWh of net electricity, thereby resulting in emission reductions of 47,036 tCO₂e.

The project being a renewable energy generation activity, leads to reduction in fossil fuel dominated electricity generation. The project activity results in reductions of greenhouse gas (GHG) emissions that are real, measurable, and verifiable and plays beneficial role in the mitigation of climate change.

The scope of the verification is the independent and objective review of the Monitoring Report (MR). The MR is reviewed against the relevant criteria and decisions by the CDM Executive Board and VCS executive board, including the approved baseline and monitoring methodology^{/17/}. The verification was based on the guidance given in the CDM validation and verification standard for project activities, version 03.0^{/16/}, reviewed against registered CDM PDD, version 1.4^{/4/}, registered VCS PD-MR, version 1.2^{/4/}, revised VCS PD-MR, version 2.2^{/6/} (revised during previous monitoring period due to project description deviations) and final validation report^{/4/}, VCS program guide version 4.4 and VCS Standard Version 4.7.^{/10/}

A risk-based approach has been followed to perform this verification. In the course of verification, 05 Corrective Action requests (CARs), 00 Forward Action requests (FARs), and 04 Clarification requests (CLs) were raised. All the CARs and CLs have been closed successfully.

The review of the Monitoring report and additional documents related to baseline and monitoring methodology; the subsequent background investigation, remote audit interviews and project proponent have provided LGAI Technological Center S.A. (Applus+ Certification) with sufficient evidence to verify the fulfillment of the stated criteria of VCS.

The monitoring is transparent, adequate and in line with applied baseline and monitoring methodology of ACM0002, Version 22: "Grid-connected electricity generation from renewable sources".^{/17/}

The assessment team has employed a risk-based approach to assess the completeness and accuracy of the claims and conservativeness of the assumptions in the MR. The main focus of the assessment team is to identify the significant risks for the project implementation and the generation of VCU. The verification is not meant to provide any consulting towards the project proponent. However, stated requests for clarifications and/or corrective actions may have provided input for improvement of the monitoring report combined.

The only purpose of the verification is its usage during the issuance process as part of the VCS project cycle. Therefore, LGAI Technological Center S.A. (Applus+ Certification) can't be held liable by any party for decisions made or not made based on the verification opinion, which will go beyond that purpose. The verification has been planned and organized to achieve a Reasonable Level of assurance as per

the requirement of VCS. No sampling procedure applied for document verifications. The entire documents checked/verification conducted to arrive at positive verification conclusions.

LGAI Technological Center S.A. (Applus+ Certification) confirms that the project is implemented in accordance with the registered CDM PDD/^{4/}, registered and revised VCS PD-MR/^{4/}. The monitoring system is in place and the emission reductions are calculated without material misstatements. Our opinion relates to the project's GHG emissions, and the resulting GHG emission reductions reported and related to the valid and registered project baseline and monitoring and its associated documents. Based on the information seen and evaluated, we confirm that the emission reductions from the project activity "Ambatolampy Solar PV" during the period 01-January-2024 to 31-March-2025 (including both days) amount to 47,036 tCO₂e.

CONTENTS

1	INTRODUCTION	7
1.1	Objective	7
1.2	Scope and Criteria	8
1.3	Level of Assurance.....	8
1.4	Summary Description of the Project	9
2	VERIFICATION PROCESS	13
2.1	Method and Criteria.....	13
2.2	Document Review	22
2.3	Interviews	23
2.4	Site Visits	26
2.5	Resolution of Findings	28
2.6	Eligibility for Validation Activities	28
3	VALIDATION FINDINGS	29
3.1	Methodology Deviations.....	29
3.2	Project Description Deviations.....	29
3.3	New Project Activity Instances in Grouped Projects.....	31
3.4	Baseline Reassessment	31
4	VERIFICATION FINDINGS.....	32
4.1	Project Details	32
4.2	Safeguards and Stakeholder Engagement	37
4.3	Accuracy of Reduction and Removal Calculations	66
4.4	Quality of Evidence to Determine Reductions and Removals.....	75
4.5	Non-Permanence Risk Analysis.....	80
5	VERIFICATION OPINION.....	81
5.1	Verification Summary	81
5.2	Verification Conclusion	82
5.3	Ex-ante vs Ex-post ERR Comparison	83

APPENDIX 1: COMMERCIALLY SENSITIVE INFORMATION	85
APPENDIX 2: DOCUMENTS REVIEWED OR REFERENCED (VERIFICATION).....	86
APPENDIX 3: CORRECTIVE ACTION REQUESTS, CLARIFICATION REQUESTS AND FORWARD ACTION REQUESTS (CAR/CL/FAR)	94
APPENDIX 4: COMPETENCE OF TEAM MEMBERS AND TECHNICAL REVIEWERS....	108
APPENDIX 5: ABBREVIATIONS.....	113
APPENDIX 6: BREAKDOWN RECORDS.....	114

1 INTRODUCTION

1.1 Objective

LGAI Technological Center S.A. (hereinafter referred to as “Applus+ Certification” or the VVB) has been contracted^{/2/} by “AERA Group” to perform the fourth periodic verification of the renewable energy project titled “Ambatolampy Solar PV ” (VCS ID-2307) under VCS Program guide V4.4 and VCS standard version 4.7^{/10/}. The verifiers have reviewed the GHG data collected to date for monitoring period from 01-January-2024 to 31-March-2025 (both days included) covered in this verification. The objective of this verification is a thorough and independent assessment of the registered project activity against the applicable VCS requirements by the VVB. The verification process shall determine whether the proposed project activity complies with the requirements of latest VCS guidelines^{/10/}, applicability conditions of the selected methodology^{/17/}, relevant host country regulations and guidance issued by the VCS Board. The objective of this verification activity is to have an independent third party for the assessment of project design, Monitoring Report and Final Verification report and to ensure a thorough assessment of the proposed project activity against the applicable CDM and VCS requirements. In particular;

- The project's baseline is assessed against “ACM0002 – Version 22.0” ^{/17/}
- The project’s monitoring plan is assessed against “ACM0002 – Version 22.0” ^{/17/}
- CDM validation and verification standard for project activities, Version 03.0^{/16/}
- VCS Program Guide v.4.4^{/10/}
- VCS Standard Version v.4.7^{/10/}
- VCS Program Definitions v4.5 ^{/10/}
- VCS Registration & Issuance Process v4.6 ^{/10/}
- VCS Validation and Verification Manual v3.2 ^{/10/}

LGAI Technological Center, S.A. (Applus+ Certification) as the Validation/Verification Body (VVB) for the project activity is accredited as a DOE by UNFCCC and also meets the competence requirements as set out in the normative reference ISO 14065:2020.

Verification is a requirement for all VCS projects and is seen as necessary through the provision of objective evidence, provide assurance to stakeholders of the quality of the project and that the requirements for a specific intended future use or application have been fulfilled regarding its intended GHG claims (i.e. generation of verified certified units (VCUs)).

The objective of verification is to have an independent review and ex post determination by a Validation/Verification Body (VVB) of the monitored reductions in GHG emissions that have occurred as a result of the registration of VCS project and its continuous monitoring. Certification is the written assurance by the VVB that, during a specific time period, a proposed VCS project activity achieved an amount of reductions in anthropogenic emissions by sources of GHGs as verified.

1.2 Scope and Criteria

The scope of verification is to assess the claims and assumptions made in the VCS monitoring report (MR) against the VCS criteria ^{/10/}, including but not limited to, VCS standard^{/10/}, applied methodology^{/17/} and other relevant rules and requirements established for VCS project activities.^{/10/}

The scope is defined as an independent and objective review of the Monitoring report MR^{/6/} prepared as per the registered CDM PDD^{/4/}, registered and revised PD-MR^{/4/} and registered approved methodology ACM0002 – Version 22.0^{/17/}. The MR is reviewed against the criteria (See Section 1.1 above) including the approved applied methodology ACM0002 – Version 22.0^{/17/}. The verification has been conducted in accordance with the VCS Standard version 4.7^{/10/}, other valid and applicable VCS Regulatory Documents and template (see Appendix 2 of this verification report below). UNFCCC rules and requirements (where applicable) and associated decisions of the VCS Secretariat and the UNFCCC Executive Board (where applicable) (hereinafter also can be referred to as regulatory documents).

The verification is not meant to provide any consulting towards the project proponent. However, stated requests for clarifications and/or corrective actions may have provided input for improvement of the Monitoring report. In line with Guidelines for Application of materiality in verifications (Version 02.0) ^{/20/}, the verification team has conducted a complete verification of all the information presented in the monitoring report and data monitored as presented in the emission reductions calculation spread sheet. It follows the paper trail back to the raw data such as meter reading records and invoices^{/11/}. There are no material errors, overestimation of Emission Reductions, omission or misstatement. Verification team conducted a remote audit to verify metering/monitoring arrangement. The verification team has reviewed all the documents like commissioning date supportive evidences^{/1/}, technical specifications^{/3/}, O & M practices, Monthly electricity generation records (monthly production statements)^{/11/}, Invoices ^{/11/}, grievance register^{/15/}.

The only purpose of the verification is its usage during the issuance processes as part of the VCS project cycle. Therefore, LGAI Technological Center S.A. (Applus+ Certification) can't be held liable by any party for decisions made or not made based on the verification opinion, which will go beyond that purpose.

1.3 Level of Assurance

Applus+ Certification has planned and performed the verification by obtaining evidence and other information and explanations that assessment team considers necessary to give reasonable assurance that reported estimated GHG emission reductions are fairly stated. All documentary evidences were checked, remote audit was conducted through video conferencing

using ICT tool “Microsoft Teams”. Technical details including metering/monitoring arrangement verified through photos^{/18/} and supportive evidences shared by PP to arrive at a verification conclusion by the assessment team.

The level of assurance of the verification report falls under reasonable assurance engagements. Reasonable assurance is a high level of assurance regarding material misstatements, but not an absolute one.

Reasonable assurance includes the understanding that there is a remote likelihood that material misstatements will not be prevented or detected on a timely basis. To achieve reasonable assurance, the auditor needs to obtain sufficient appropriate audit evidence to reduce audit risk to an acceptably low level. This means that there is some uncertainty arising from the use of sampling (where applicable), since it is possible that a material misstatement will be missed.

Through an exhaustive process of documentary review, interviews with the project proponent, remote audit, assessment on GHG Emission Reductions calculations against applicable methodology and any other regulatory document and reporting of objective evidence, the VVB is able to reach a reasonable level of assurance on the conduction of the verification process. The achieved level of assurance for this verification is thus a reasonable level of assurance as per the requirements set out in the applied VCS Standard version 4.7 clause 4.1.10 (1) ^{/10/}.

VVB applied a materiality threshold of 5% with respect to omission or misstatements concerning reported quantities as per VCS Standard version 4.7, clause 4.1.10 (4) ^{/10/}.

Additionally, according to the VCS Validation and Verification Manual version 3.2 ^{/10/}, while all material errors, omissions and misrepresentations must be addressed for a project to receive a positive validation or verification opinion, when non-material errors have been found in the project documents, the VVB requested the project proponent to correct them and ensured that such errors have been addressed where applicable. The evidence used to achieve a reasonable level of assurance is specified in section 2.3 and 2.4 of this report. Materiality for the project is 5% which is in accordance with para 4.1.10(4) of VCS Standard v4.7^{/10/}, however the assessment team has verified 100% data (no sampling plan is applied), hence it is sufficient to meet the materiality requirements of the project.

In our opinion, the estimated GHG emissions reductions were calculated correctly on the basis of the approved baseline and monitoring methodology “ACM0002, Version 22.0”^{/17/} and the VCS standard v.4.7 (paragraph 4.1.10) ^{/10/}.

1.4 Summary Description of the Project

The project consists of the construction and operation of a greenfield 40 MWp solar power plant in Ambatolampy, in the South-East of Vakinankaratra region, Madagascar. It involves the setting up of photovoltaic (PV) panels which captures solar energy and convey such energy to the convertor station in order to produce electricity exported to the national grid. Besides the initial capacity of 20 MWp operating since 10-July-2018^{/1/}, the second phase of the Ambatolampy project was commissioned on 17-August-2022^{/1/}, bringing the total installed capacity to 40 MWp.^{/24/}

The project activity was initially registered under CDM, with UNFCCC project ID: 10481 on 03-May-2019^{/34/}. Afterwards, it was gap validated to VCS on 04-November-2020, with VCS project ID as 2307^{/27/}.

This clean energy supply thus implies a substantial reduction in the production of carbon from the predominantly thermal-based grid mix (dominated by imported fossil fuels currently consumed by thermal power stations (514 MW) versus hydropower plants (162 MW)^{5/27/}, thereby reducing the associated greenhouse impact upon the atmosphere.

The initial Phase-1 features total 73,008 units of solar PV modules manufactured by Jinko Solar^{/3/} of models Eagle 60 JKM 270 PP-60 (14,832 units) and Eagle 60 JKM 275 PP-60 (58,176 units) connected to the RI-TANA grid operated by JIRAMA. The first phase also comprised of 15 inverters of make INGECON SUN 1220TL.^{/3/}

The phase-2 (also called extension phase), which was commissioned on 17-Aug-2022 added 37,050 units of solar PV modules manufactured by JA solar^{/3/} of model JAM72S30-540/MR and 77 new inverters of model SUNGROW SG250HX^{/3/} for a total capacity of 20MWp. The extension phase also features the Battery Energy Storage System (BESS) of type M2L Series, which is manufactured by SUNGROW^{/3/}. The BESS is mainly charged with electricity generated from the associated renewable energy power plant. Grid imported energy is only used on a minority basis, and corresponding GHG emissions shall be accounted for as project emissions. The extension phase is connected to the same RI-TANA grid operated by JIRAMA.

The project's monitoring equipment are composed of 7 meters in total, 3 for each phase (1 Main (Model: Landis+Gyr E650⁶, class 0.2S)^{/3/}, 1 Check (Model: ZTE DTSD178-M⁷, class 0.5S)^{/3/} and 1 Internal Control (Model: Phoenix contact EEM-MA600⁸, class 0.2S))^{/3/}, measuring the net electrical energy delivered to RI-Tana grid and located before 20/63kV transformer^{/3/} at JIRAMA substation. They also measure the consumption of the plant, including BESS charging from the grid. The 7th meter (Model: ZTE DTSD178-M⁹, class 0.5S)^{/3/}, measuring office consumption, including lights, cameras, etc. (labelled as 'invoiced imports' on the ER sheet^{/7/}), is located at the JIRAMA VIE base, next to the offices.

The verification team confirmed these technical details about the PV plant components by cross checking the manufacturer's technical specification documents^{/3/}, photographs of component's nameplates provided by PP^{/18/} and through remote audit^{/19/}.

⁵ IRENA, 2022. "Energy Profile : Madagascar" available online [here](#)

⁶ <https://www.landisgyr.eu/product/landisgyr-e650/>

⁷ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nul.html#3

⁸ <https://www.phoenixcontact.com/fr-fr/produits/appareil-de-mesure-eem-ma600-2901366>

⁹ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nul.html#3

The location details of the project are as follows:

Sr. No.	Name of project Proponent	Location	Latitude	Longitude
1	New Energy Africa Ambatolampy ¹⁰ (NEA Ambatolampy) (formerly known as GreenYellow Madagascar)	Ambatolampy, in the South-East of Vakinankaratra region, 90km South of Antananarivo, Madagascar.	19° 29'22"S	47° 26'42"E

The location of the project activity mentioned in the MR is checked through the Google Maps (<https://www.google.co.in/maps>) and found consistent with registered CDM PDD/^{4/}, registered/^{4/} and revised VCS PD-MR/^{6/} and it is accepted. The status of the project activity is verified through the maintenance and breakdown records/^{13/} of the plant and confirmed that the project activity was fully operational during the monitoring period, with few incidents of breakdown./^{13/}

The project activity is developed by New Energy Africa Ambatolampy (NEA Ambatolampy) (formerly known as Green Yellow Madagascar)/^{23/}. The former entity has signed a Power Purchase Agreement with the company JIRO SY RANO MALAGASY (i.e. JIRAMA)/^{9/}, which is the state-owned utility in Madagascar that is responsible for generation, transmission and distribution of electricity. AERA Group is the Carbon Consultant for the activity.

Technical specifications/^{3/} of the equipments i.e. solar PV modules, invertors, transformers, BESS and monitoring equipment involved in the project activity as reported under section 3.1 and section 4.2 of the MR are verified through remote audit and the latest photographs/^{18//19/} and are found to be consistent with the information as mentioned in the registered and revised PD-MR/^{4/} and the MR for this verification period/^{4/}. The start date of the project activity is 10-July-2018, which is date of commissioning of phase-1 of the project activity, as verified through the commissioning documents/^{1/}. The technical lifetime of the project activity is 25 years, the same is verified through the power purchase agreement/^{9/} signed for the project activity. VVB concluded that the project has been implemented as per the requirement of the registered CDM PDD/^{4/}, registered and revised VCS PD-MR/^{4/} and approved monitoring plan.

As per the revised VCS PD-MR/^{4/}, the project's 10 year-fixed crediting period is from 10-July-2018 to 09-July-2028. The current verification period is from 01-January-2024 to 31-March-2025.

During the current monitoring period, it was observed that few unforeseen incidents/events evolved that can impact the operation of the project activity, which was verified from breakdown records/^{13/}. The project undergone continuous operation and only scheduled maintenance is observed as per the manufacture's specification as evident from generation. The only noteworthy event is the unavailability of a protection cell on a transformer of the initial phase. This lasted from January until February 2024 and impacted the project production on that period. Please refer to the Appendix 6 for more information about the plant breakdowns.

¹⁰ In 2020, the Malagascan company Axian Energy acquired the majority of the shares of Green Yellow Ambatolampy. On January 9, 2023, Green Yellow Ambatolampy, the sole shareholder of Green Yellow Madagascar, changed its corporate name to "New Energy Africa Ambatolampy (NEA Ambatolampy)"

The organisational roles and responsibilities^{/8//8/} as mentioned in the registered CDM PDD, registered and revised PD-MR^{/4/} are followed onsite, which was confirmed through remote audit^{/8/} and documentary review. All the emergency preparedness as mentioned in the CDM PDD, registered and revised PD-MR, MR^{/4//6/} is followed onsite and no discrepancies were found regarding the same as confirmed during the remote audit interviews^{/8/} with the PP representatives.

The project uses the UNFCCC approved consolidated large-scale methodology ACM0002 “Grid-connected electricity generation from renewable sources” Version 22.0^{/17/} and pertains to the defined UNFCCC Sectoral Scope 1, Technical Area 1.2 Renewables.

The project activity was initially registered under CDM, with UNFCCC project ID: 10481^{/34/} on 03-May-2019. Afterwards, it was gap validated to VCS on 04-November-2020, with VCS project ID as 2307^{/27/}. Project has not claimed any issuances till date under CDM.

The project is not registered under any other GHG Program other than the CDM and VCS, and can be found in the following links respectively:
<https://cdm.unfccc.int/Projects/DB/RWTUV1556909746.23/view> and
<https://registry.verra.org/app/projectDetail/VCS/2307>.

The VVB has cross-checked the available registries of Gold Standard (GS) ^{/29/}, International Carbon Registry (ICR) ^{/30/} and the Global Carbon Council (GCC) ^{/30/} and has not found this project activity registered in any of these schemes.

The current monitoring period is covered from 01-January-2024 to 31-March-2025 (inclusive of both dates) and the project activity has exported 70,206 MWh of net electricity to RI-TANA grid. As a result of exporting renewable energy to the fossil fuel intensive national grid of the host country, the accrued emission reductions for the current monitoring period are calculated and certified as a result of this verification to be 47,036 tCO₂e.

Based on the assessment of the documents, the assessment team can confirm that the project activity is fully functional and implemented as described in the registered and revised VCS PD-MR^{/4/}

2 VERIFICATION PROCESS

The registered VCS project is undergoing 4th verification period, the approach adopted to ensure the quality of emission reductions is described in the following sections.

2.1 Method and Criteria

Verification Process:

The project assessment is based on the “CDM validation and verification standard for project activities, Version 03.0”^{/16/}, “VCS program guide v.4.4” and “VCS standard v.4.7”^{/10/} and is conducted using standard auditing techniques and pre-approved audit plan^{/19/} to assess the correctness of the information provided by the project proponent. The Verification process has been conducted in accordance with the Applus+ Certification’s procedures and in line with the applicable regulatory documents, *inter alia*, the VCS Standard version 4.7^{/10/}, other valid and applicable VCS Regulatory Documents and templates^{/10/}, the UNFCCC CDM M&P and the latest version of the applicable UNFCCC CDM regulatory documents and relevant requirements (where applicable); applying, as a minimum, standard auditing techniques.

The Verification process has been conducted following the regulatory documents and based on the ISO 14064-3:2019 and ISO 14065:2020 using standard auditing techniques as required by the VCS Standard v4.7.^{/10/}

The verification process has been conducted remotely and a risk analysis for remote inspections has been performed prior to the determination of the suitability to conduct the assessment using ICT (Information and Communication Technology) means¹¹, in accordance with the VCS Standard version 4.7 Para 4.1.13.^{/10/}

The ICT means have been used to an extent sufficient to cover all the verification process and have demonstrated enough effectiveness to conduct the verification in accordance with the relevant applicable regulatory requirements.

This process has included: the review of data and information presented to verify their completeness; the review of the monitoring plan and monitoring methodology, paying particular attention to the frequency of measurements and the QA/QC procedures; an evaluation of data management; and an evaluation of the QA/QC system in place in the context of its influence on the generation and reporting of emission reductions.

No virtual sites have been included in the verification process according to the definition in the IAF MD4:2025 document^{/33/}. Instead, the documentation has been provided upon request from the VVB by other means (such as mail, transfer applications, etc.)

¹¹ According to the IAF MD4:2025, ICT is the use of technology for gathering, storing, retrieving, processing, analysing and transmitting information. It includes software and hardware such as smartphones, handheld devices, laptop computers, desktop computers, drones, video cameras, wearable technology, artificial intelligence, and others.

Before the assessment begins, members of the team covering the technical scope(s), sectoral scope(s), and relevant host country experience for evaluating the VCS project activity are appointed in accordance with the Applus+ Certification's procedures and policies, that are in accordance with the ISO 14065:2020 regulatory provisions.

Applus+ Certification has completed a strategic review and risk assessment of the project's activities and processes in order to gain a full understanding of:

- Activities associated with all the sources contributing to the project's emissions and emission reductions, including leakage if relevant;
- Protocols used to estimate or measure GHG emissions from these sources;
- Collection and handling of data;
- Controls on the collection and handling of data;
- Means of verifying reported data; and
- Compilation of the information in VCS monitoring report.

Based on the above, the VVB prepared a Verification Plan and applied an evidence-gathering plan designed to collect sufficient and appropriate evidence upon which to base the conclusion and to consider the inherent risk for the verification. The evidence-gathering plan is based on analytical procedures and tests and considers the thresholds for materiality as per the regulatory documents applied for this verification (5% as per the applied VCS Standard version 4.7)^{10/}.

The applied evidence-gathering plan is used by the VVB to determine the conformity of statements made by the client against the principles and requirements of the applied regulatory documents during this verification.

The evidence-gathering plan designed by the VVB takes into consideration, as a minimum:

- The selection and management of the data and information;
- The processes for collecting, processing, consolidating, aggregating and reporting the data and information;
- Systems and processes in place to ensure the validity and accuracy of the data and information;
- The design and maintenance of the system to control the data and information;
- Systems, processes and personnel that support system in place, including activities for ensuring data quality;
- The results of instrument maintenance and calibration where appropriate;

- The results of previous validation activities and verifications, where available and appropriate.

The audit team has performed a Risk Assessment and elaborated a feasible audit plan^{/19/} that covers all aspects of the audit and establishes measures to eliminate or reduce the identified risks:

Risks to address while conducting the remote audit:

Potential Risks	Risk identified	Description of mitigation measures in case the risk has been identified
The remote assessment cannot be done in quite environment	☒ Yes ☐ No	PP/stakeholder and VVB are able to provide a quite environment for remote audit in respective offices. If an interview with the stakeholders that may connect through mobile phone is done, the VVB will encourage them to go to the PP's office or provide a local support for the conduction of the interviews and can also be shared recorded in video. Otherwise, if there is noise not allowing VVB to understand well what the stakeholders in open place are saying, the VVB will stop that conversation until is able to hear everything appropriately. This may imply further rounds of remote inspection, if deemed necessary.
There is no option to terminate the remote assessment and continue in a later date, if there are problems or the VVB finds further risks not yet identified	☐ Yes ☒ No	VVB can terminate and continue in a later date, because there is no deadline approaching so there will be enough time to retake the audit if needed. In case of connectivity problems are found, the VVB can continue in a later date or interview PP's representatives separately.
There is no option to do a further round of remote inspection in case the VVB determines its necessity due to the answers provided to the findings	☐ Yes ☒ No	VVB always keep an option to do a further round remote inspection in case require.
The PPs may not authorize to take screenshots of documents or records or may not authorize to show them by ICT means	☐ Yes ☒ No	The PP has allowed to take screenshots of documents or records and will show them by ICT means in case this is required by the VVB.

Risks Related to The Project:

Potential Risks	Risk identified	Description of mitigation measures in case the risk has been identified
Risks related to organizational and procedural aspects		
Key stakeholders and/or end users of project technology not willing / able to be interviewed through ICT	☐ Yes ☒ No	The key stakeholders Project Proponent, local O & M staff, local stakeholders will join the remote inspection through ICT Means
High amount of documentation to be reviewed remotely	☐ Yes ☒ No	There is not a high amount of documentation that cannot be reviewed remotely or provided by PP for VVB's Desk Review.
Relevant data flows cannot be accessed remotely	☐ Yes ☒ No	No risk identified, as data is stored in Soft and Hard copy as well.
Established record-keeping system cannot be accessed remotely	☐ Yes ☒ No	PP has established hard and soft record keeping system which can be accessed remotely or provided by PP for VVB's Desk Review.

Potential Risks	Risk identified	Description of mitigation measures in case the risk has been identified
Risks related to the project activity and its configuration		
The boundary of the project activity cannot be evaluated remotely	☐ Yes ☒ No	The boundary of the project activity can be evaluated remotely. VVB Team has cross checked the project location coordinates through Google Maps which were confirmed to be correct. It was also confirmed that the project activity is connected to the RI-Tana Grid by cross checking the PPA document. Hence, the project boundary was confirmed to be correct.
The features of the project activity cannot be evaluated remotely	☐ Yes ☒ No	The features of the project activity can be evaluated remotely via live video/pics or supporting documents.
Is not possible to observe sources of emissions that are not included in the project activity	☐ Yes ☒ No	It is possible to observe sources of emissions that are not included in the project activity through the video/ picture taken of the site by PP and due to the type of project, this is unlikely to occur.
Is not possible to check how the controls of the activities are carried out	☐ Yes ☒ No	It is possible to check how the controls of the activities are carried out.

		VVB Team during the remote audit can check the controls of the activities through interviews with the O&M personnel and by cross-checking the monitoring system in place and the SCADA System.
Is not possible to check how the calculations are tracked	☐ Yes ☒ No	It is possible to check how the calculations are tracked as the PP can demonstrate the plant operations through video call and through documentary evidence such as generation records, invoices raised and emission reduction worksheet.
May be a non-conformity with core scheme's rules and requirements that cannot be observed through ICT	☐ Yes ☒ No	There is no potentially identified non-conformity with core scheme's rules and requirements that cannot be observed through ICT means.
Would not be possible to know about how any negative feedback / observations received from stakeholders are being sufficiently addressed by the project	☐ Yes ☒ No	The PP has a grievance mechanism in place that has been shared and contains detailed information enough to allow any required interview with stakeholders to know about how any negative feedback / observations received from stakeholders are being sufficiently addressed by the PP.

Potential Risks	Risk identified	Description of mitigation measures in case the risk has been identified
Risks related to monitoring aspects		
The monitoring parameters and the monitoring plan are complex	☐ Yes ☒ No	VCS PD-MR is checked and Monitoring parameters/plan found in line with applied methodology (ACM0002, Version 22.0) having monitoring parameter i.e., $EG_{facility,y}$ and are not complex. The parameters are accessible based on the supporting data presented and interviews.
Data processing and reporting methods are not available through ICT	☐ Yes ☒ No	The remote interview with PP/stakeholder is enough to know about data processing and reporting.
A fiscal metering method is applied and its results cannot be accessed remotely	☐ Yes ☐ No ☒ N/A	Not applicable.

The records and results of the sampling or surveys conducted at household or end-user level by PPs cannot be cross-checked through ICT	☐ Yes ☐ No ☒ N/A	N/A (no sampling)
Status of the monitoring period being verified cannot be checked through ICT	☐ Yes ☒ No	Status of the monitoring period can be checked through ICT means.
May be a non-conformity with potential reversal of GHG benefits and other SDG Impacts that cannot be observed through ICT	☐ Yes ☒ No	There are no observed SDGs in the PA and any potential non-conformity with potential reversal of GHG benefits are suitable to be observed through ICT means and/or desk review tasks.
Data and information may have not been properly checked during previous assessments for the project.	☐ Yes ☒ No ☐ N/A	Each audit is independent from the latest one and any information will be checked again for this verification covering those validation aspects suitable to any potential changes.
Based on previous assessments of the project there could be data and information that cannot be checked without an onsite inspection	☐ Yes ☒ No ☐ N/A	Based on previous assessments of this project, as evident from the documents available on registry page and the initial desk review documents, there is not any data and information which can't be checked through remote inspection. Hence, this risk is not identified.

Risks Related to The Project:

Potential Risks	Risk identified	Description of mitigation measures in case the risk has been identified
There are outstanding FARs from previous onsite visits that may require onsite inspection	☐ Yes ☒ No	No FARs remaining that may need an onsite inspection to be verified.
There are design changes or temporary deviations since the previous onsite inspection that cannot be observed through ICT	☐ Yes ☒ No	No envisaged changes that may need an onsite inspection to be verified.
There are gaps in the monitoring data that cannot be justified as per the applicable	☐ Yes ☒ No	VVB will check and confirm the monitoring data based on submitted electricity generation records, invoices, calibration certificates for

requirements through ICT		energy meters and if a gap in the monitoring data is identified same can be raised to PP. Hence no risk identified.
--------------------------	--	--

At the end of this phase, Applus+ Certification produced a verification plan which, based on the risk assessment of the parameters and data collection and handling processes for each of those parameters, describes the verification approach and the sampling plan (if applicable).

Applus+ Certification has verified the implementation of the monitoring plan and the data presented in the Monitoring Report (MR) version 1.3, dated on 23-September-2025^{/6/} for the monitoring period applicable to this verification process. This involved a remote audit^{/6/} & interviews of project proponent representative's and a desk review of the Monitoring Report. This verification report describes the findings of this assessment.

The process of verification involved the following relevant milestones (respective dates are mentioned in the table below):

- The signature of the contract for verification between the PP and the VVB^{/2/};
- A kick-off meeting/communication to require the documentary material to perform an initial desk review;
- An initial desk review of the documentary evidence prepared by the Project Proponent;
- The issuance of findings coming from this initial desk review (if any);
- The conduction of a remote audit, including interviews and video-calls (see Sections 2.3 and 2.4 below);
- The issuance of findings from the remote inspection and communication of such deviations (if any) to the Project Proponent;
- The assessment of their resolution and closure, when appropriate;
- Once all the findings have been closed, the elaboration of this Verification Report, in which such findings (if any) are described;
- The conduction of an independent Technical Review;
- Upon conclusion of the Technical Review, the VVB may perform a final quality check before the issuance of the Final Verification Report (FVR) and signature of the corresponding Verification Deed.

The process of this verification assessment has not implied any sampling plan.

Verification schedule is described in the below table:

Scope of the assessment	Date
Contract signed	16-May-2025
A kick-off meeting/communication to request the documentary material to perform an initial desk review;	27-May-2025
Initial Desk review (list of documents)	05-June-2025
Remote audit & interviews	16-July-2025
DVR (Findings Document) submission to PP	22-July-2025
Finalization of DVR and preparation of FVR	12-September-2025
Final Verification Report	24-September-2025

Appointment of the assessment team

Before the assessment begins, members of the team covering the technical scope(s), sectoral scope(s), and relevant host country experience for evaluating the VCS project activity are appointed in accordance with the LGAI Technological Center S.A. (Applus+ Certification) procedures and policies, that are in accordance with the ISO 14065:2020 regulatory provisions.

According to the applicable sectoral scope / technical area and experience in the sectoral or national business environment, LGAI Technological Center S.A. (Applus+ Certification) has composed an assessment team in accordance to compliance with the contract review and Assessment Team appointment rules in the internal Quality Management System of LGAI Technological Center S.A. (Applus+ Certification) as well as in compliance with the applicable requirements in the Accreditation Standard.

The composition of audit team (Applus+ Certification's verification team) has been approved by the LGAI Technological Center S.A. (Applus+ Certification) Central site during its Contract Review process, ensuring that the required skills and capabilities are covered by the team.

The qualification levels for Assessment Team members that are assigned by aforementioned appointment rules are as presented below:

- Lead Auditor (LA).
- Auditor (A).
- Technical Expert (TE).
- Technical Reviewer (TR).
- Any of the above-mentioned roles in training (iT, e.g. AiT for auditor in training, TEiT for Technical Expert in Training, etc.).

The Sectoral Scopes / Technical Areas required knowledge linked to the applied methodology(ies) is covered by the Assessment Team as shown below:

Name	Role	SS/TA Coverage	Financial Aspect	Attendance to on-site visit ¹²	Host Country Experience
Dr. N. Premjit Singh	LA/TE	YES (1.2)	N/A	N/A	NO
Mr. Saurabh Gaikwad	A	YES (1.2)	N/A	N/A	NO
Ms. Nathalie Raharilaza	Local Support	NO	N/A	N/A	YES
Mr. Denny Xue	TR/TE	YES (1.2)	N/A	N/A	N/A

The complete list of CVs is included as Appendix 4 of this report.

Document review

The Monitoring report (version 1.3)^{6/} submitted by the PP was reviewed against the approved methodology, registered and revised VCS PD-MR^{4/}, CDM PDD^{4/}, final validation report^{4/} and other relevant criteria to verify the correctness, credibility, and interpretation of the presented information.

Furthermore, a cross-check between information provided and information from other sources has been done. A complete list of all documents and evidence material reviewed is included in this report below in Appendix 2.

Remote Audit

A Remote audit is conducted by LGAI Technological Center S.A. (Applus+ Certification) assessment team who performed video/telephonic conferences with project's stakeholders to confirm selected information and to resolve issues identified in the document review. The details are provided in this report in the below sections, Resolution of Clarification and Corrective Action Request.

Resolution of Clarification and Corrective Action Request

The objective of this phase of Verification was to resolve the requests for corrective actions and clarification and any other outstanding issues which need to be clarified for Applus+ Certification positive conclusion on the Monitoring report. The Corrective Action Requests and Clarification Requests raised by Applus+ Certification were resolved during communications between the Client and Applus+ Certification to guarantee the transparency of the verification process, the concerns raised, and responses given are summarized below in the Appendix 2 of this report.

¹² The assessment has been conducted remotely, please refer to Section 2.3 and Section 2.4. below for further information.

The final MR Version 1.3/⁶/ submitted by PP serves as the basis for the final assessment presented. Additional changes to the project during the verification process are not considered to be significant with respect to the main CDM/VCS objectives. The two CDM/VCS main objectives are the reduction of anthropogenic GHG emissions and the contribution of sustainable development to the host country.

Internal quality control

As final step of a verification of the final documentation including the verification report have to undergo an internal quality control by the technical review committee.

Details of the Technical Reviewer(s) are provided within the verification Report in Section 2.1 and Appendix 4 for further references of knowledge and capability to conduct the quality checking.

After the Technical Review process, the final documentation may undergo a final quality checking process called Administrative Review, done by the Applus+ Certification's Project Manager and/or Technical Support.

For final approval, the final set of documents are prepared by the VVB's Technical Manager or its deputy and signed by the authorized signatory of the VVB.

In case any of the persons performing this final internal quality-control and approval process has acted as a part of the Assessment Team or Technical Review team, the approval can only be given by VVB's personnel who are not part of those teams.

After confirmation of the PP, the positive verification opinion and relevant documents are submitted to the VCS board through the VCS web-platform by the PP.

2.2 Document Review

The details of the documents observed during the verification process which included the followings:

- Compliance of the Monitoring Report with the current version of the template and its required contents;
- Monitored parameters and reporting requirements;
- Assessment of data and calculation of emission reductions or net removals (Conservativeness, use of calculation methods and assumptions, emission factors, reliability/reproducibility);
- Assessment on the differences from the estimated value of ERs in the registered PD and the achieved ERs in the Monitoring Period;
- Remaining forward action requests from validation or previous verifications;
- Ongoing communication method with stakeholders;

- Sustainable development contributions.

The VCS Monitoring Report (MR) version 1.3, dated on 23-September-2025^{/6/} and the Emission Reductions (ER)^{/7/} Calculations were assessed as part of the verification. In addition, the registered CDM PDD version 1.4, dated 05-July-2019^{/4/}, registered Project Description-Monitoring Report (PD-MR) version 1.2, dated on 15-July-2020^{/4/}, revised Project Description-Monitoring Report (PD-MR) version 2.2, dated on 24-January-2025^{/6/}, in particular, the baseline estimations and the monitoring plan, and the VCS Validation-Verification Report and latest Verification Report, as well as relevant documents, were reviewed. A detailed list of the reviewed documents can be observed in the Appendix 2 of this Verification Report.

2.3 Interviews

In accordance with the paragraph 4.1.12 of VCS standard v.4.7^{/10/}, Site visit shall be conducted under the following circumstances:

- 1) The first verification of the project after validation;
- 2) Verification of project baseline reassessments; and,
- 3) Verifications that assess a project description deviation where the deviation impacts the applicability of the methodology, additionality or the appropriateness of the baseline scenario.

Since the current ongoing verification is fourth periodic verification for this project activity and there is no baseline reassessment involved and no new project deviations identified, the onsite visit is not mandatory.

Hence, as part of verification, a remote inspection has been performed by VVB team via video conferencing using ICT tool Microsoft Teams on dated 16-July-2025^{/19/}.

Following ICT means have been used for the conduction of this Verification process. Those ICT means supporting the process in this sense, have been used as described above in Section 2.1 to an extent sufficient to cover the background necessities of the Verification process and have demonstrated enough effectiveness to conduct it in accordance with the relevant applicable regulatory requirements.

The audit team confirms that have been evaluated and provided appropriate measures to safeguard the confidentiality of data in any format as a result of the asynchronous documentary review, in line with the ISO 14065:2020 regulatory provisions. This implies:

- Take appropriate measures to safeguard the confidentiality of data in any format;
- Prevent the access and retention of more documented information than it would in a normal face to face audit;
- Agree a secure system to share information;
- Once the audit is complete, the Audit Team should delete from its system or remove access to any documented information and records not required to be retained as objective evidence;
- Any screenshots of documents or records or other kind of evidence that the Audit Team takes should be previously authorized by the project developer and proponents;

- This authorization can be given verbally during the remote inspection when there is a request to capture any shown information.

Based on the above, the VVB prepared a Verification Plan and applied an evidence-gathering plan designed to collect sufficient and appropriate evidence upon which to base the conclusion and to consider the inherent risk for the verification. The evidence-gathering plan is based on analytical procedures and tests and considers the thresholds for materiality as per the regulatory documents applied for this Verification (5% as per the applied VCS Standard version 4.7). /^{10/}

This is 4th periodic verification of the project activity and VVB checked the technical details and specifications/^{3/} of the equipment's mentioned in section 1.8 of registered and revised VCS PD-MR/^{4/} & section 3.1 of monitoring report of previous monitoring period/^{4/} and monitoring report for current monitoring period/^{4/} and the actual implementation status of the project activity during the current monitoring period. Detailed analysis of the same has been provided in section 1.4 and section 4 of this verification report. Further, there are no new deviations from the project description occurred during this monitoring period. Furthermore, VVB Team has conducted a remote audit/^{19/} and interviews with PP representatives after independent risk assessment which is in line with the requirement of the paragraph 4.1.13 of VCS Standard v.4.7 /^{10/}. The VVB has taken alternative measures to reach reasonable level of assurance and conducted remote audit/^{19/} through Microsoft Teams ICT tool/Telephone with site personnel & with the PP representatives.

Technical details & metering/monitoring arrangement/^{3/} are verified through remote inspection, onsite photographs/name plates/^{18/} and calibration evidence/^{5/}shared by PP. All the documents were cross checked to ensure conservative estimation of emission reduction.

During the remote audit, the PP representatives were questioned about the implementation of the project activity. Several topics like the verification of commissioning date of plant and electricity meters, the generation, recording, and monitoring of the data and the error accountability were discussed. To cross check the information provided by PP, various documents like technical specifications, commissioning dates supportive evidences/^{1/}, Power Purchase Agreement (PPA)/^{9/}, Monthly electricity generation records (monthly production statements)/^{11/}, invoices/^{11/}, etc. were also verified. The names of the persons interviewed during remote audit through ICT tool Microsoft Teams meeting/video & telephonic interview are given below:

No.	Interviewee	Date	Subject	Team member
-----	-------------	------	---------	-------------

	Name	Role & Organization			
1.	Mr. Harold Goret	Carbon Analyst, AERA Group	16-July-2025	Project Implementation, Electricity generation records & invoicing procedure, Operational data, Monitoring equipment, monitoring plan, safeguarding measures, HSE programmes, training programmes, Management practices, data collection, recording- storage and archiving procedure, data transferring and results achievement and reproducibility, Organigram, operation and maintenance staff of the plant, QA/QC, calibration, Grievance mechanism. Grievances identified during current monitoring, waste management and environmental impacts, Issues related to local	Dr. N. Premjit Singh (Lead Auditor/Technical Expert), Mr. Saurabh Gaikwad (Auditor) Ms. Nathalie Raharilaza (Local Support)
2.	Ms. RAZAFIARISOA Haingonirina	Impact and Sustainability, AXIAN ENERGY			
3.	Mr. TATA Harison Jérémie	Operations Manager, NEA Ambatolampy			
4.	Mr. RANDRIANIRINA Luca Victorien	HSSSES Referent, NEA Ambatolampy			
5.	Mr. RAKOTOMALALA Laha Harizo	Operations Manager, NEA Ambatolampy			
6.	Mr. RAHARISON Rubain Edwar	Supervisor, SECUR PRO			
7.	Ms. RASOANIAINA Robine	Housekeeper (Local Stakeholder)			
8.	Ms. RASOANIAINA Sarobidy	Substitute Housekeeper (Local Stakeholder)			
9.	Mr. RAMAROSANDRATANA Moïse	Mayor of the Commune of Ambohipihaonana in the District of Ambatolampy (Local Stakeholder)			

10.	Mr. RANAIVOSON Raymond	Chief of the fokotany of MAHAZOARIVO (Local Stakeholder)		area development, Awareness about the project under GHG reductions programmes, ER calculations, etc.	
-----	---------------------------	--	--	--	--

Interviews with local stakeholders:

The verification team has interviewed the local stakeholders (details mentioned in above table), and they were questioned for various topics as summarized below.

- Effect of project on their livelihood and income
- Any problem related to project installation in nearby areas
- Are they happy with the benefits and development as CSR activity of the PP?
- General feedback about the project
- Do they know about the grievance and feedback back register/mechanism?
- Any feedback; Concern (C) Positive (P) and Negative (N)

All the stakeholders expressed their satisfaction with the project activity and provided positive and satisfactory answers to the questions mentioned above.

2.4 Site Visits

In accordance with the paragraph 4.1.12 of VCS standard v.4.7/¹⁰/, Site visit shall be conducted under the following circumstances:

- The first verification of the project after validation;
- Verification of project baseline reassessments; and,
- Verifications that assess a project description deviation where the deviation impacts the applicability of the methodology, additionality or the appropriateness of the baseline scenario.

Since the current ongoing verification is fourth periodic verification for this project activity and there is no baseline reassessment involved and no new project deviations identified, the onsite visit is not mandatory.

Hence, as part of verification, a remote inspection/¹⁸/ has been performed by VVB team via video conferencing using ICT tool Microsoft Teams on dated 16-July-2025/¹⁹/.

To achieve a reasonable level of assurance, the assessment team has followed the alternative means to substantiate the verification criteria as described in the section 2.1 of this report.

Duration of Remote audit: 16-July-2024			
Activity performed during Remote audit	Site location	Date	Team member
No physical onsite visit was performed (Refer Section 2.3 of this report for details). Assessment team checked the description of project activity and its implementation, Compliance of the project implementation with the registered project design document, Compliance of the registered monitoring plan with applied methodology, calibration frequency requirements for measuring instruments, Baseline emission, Emission reduction calculation, technical description of the project and Monitoring. Assessment team also checked that whether the monitoring plan as described in the VCS PD-MR^{4/} is actually practised onsite. Also, assessment team checked any change in host country criteria which may affect the baseline of the project activity.	The PV plant is located in Ambatolampy, in the South-East of Vakinankaratra region, 90km South of Antananarivo, Madagascar. (Remote audit conducted through video conferencing via Microsoft Teams meeting)	16-July-2025	Dr. N. Premjit Singh (Lead Auditor/Technical Expert), Mr. Saurabh Gaikwad (Auditor) Ms. Nathalie Raharilaza (Local Support)

2.5 Resolution of Findings

As an outcome of the verification process, the assessment team may raise different types of findings.

Where a non-conformance arises the assessment team shall raise a Corrective Action Request (CAR). A CAR is issued, where:

- a) Non-compliance with the monitoring plan or methodology are found in monitoring and reporting and has not been sufficiently documented by the project proponents, or if the evidence provided to prove conformity is insufficient;
- b) Modifications to the implementation, operation and monitoring of the project activity has not been sufficiently documented by the project proponents;
- c) Mistakes have been made in applying assumptions, data or calculations of emission reductions that will impact the quantity of emission reductions;
- d) Issues identified in a FAR during validation to be verified during verification or previous verification(s) have not been resolved by the project proponents.

The assessment team shall raise a Clarification Request (CL) if information is insufficient or not clear enough to determine whether the applicable requirements have been met.

A FAR (Forward Action Request) is raised during verification if the monitoring and reporting require attention and/or adjustment for the next verification period.

All CARs and CLs raised during verification shall be resolved prior to submitting a request for issuance.

Raised CARs and CLs for this project activity's verification process are listed in Appendix 3 of this Verification Report.

The total number of CARs for this Verification has been 05 and the total number of CLs for this Verification has been 04.

2.5.1 Forward Action Requests

This is 4th periodic verification of the project activity and no FAR was raised from validation or previous verification as verified from the validation report and previous verification report.

2.6 Eligibility for Validation Activities

This section is not applicable for present verification, as LGAI Technological Center, S.A. (Applus+ Certification) holds the necessary accreditation for the validation and verification for projects under Scope 1 / Technical Area 1.2.

3 VALIDATION FINDINGS

3.1 Methodology Deviations

PP has not sought any methodology deviations. Hence, this section is not applicable for present verification.

3.2 Project Description Deviations

- **No project description deviations have been applied for this monitoring period.**
- **Approved Deviations from previous monitoring period no. 3 (01-January-2022 to 31-December-2023)^{/19/}, already approved on 17/02/2025¹³:**
 - a) As a consequence to its capacity change, all mentions to “20 MW”, including in the former title of the project “Ambatolampy 20 MW solar PV” are removed or updated to display “40 MW” instead.
 - b) On January 9th, 2023, PPs Green Yellow Madagascar changed its company name to “New Energy Africa Ambatolampy (NEA Ambatolampy)”, a subsidiary of the African company Axian^{/19/}. The same is reflected in the MR^{/19/}, section 1.4 ‘project proponent’.
 - c) The project deviates in section 1.1 and 1.11 of the registered VCS-JPD-MR^{/19/} regarding the total capacity of the project. The capacity of the project changed from 20 MWp to 40 MWp as new panels have been added as a phase II to the project in order to increase electricity production. The commercial agreement^{/19/} for this extension was executed on November 27th, 2020, and the commercial operation date of the added capacity occurred during this monitoring period, on August 17th, 2022^{/19/}.
 - d) The project deviates in section 1.11^{/19/} regarding the equipment and technology description for the project activity. While the equipment of phase 1 remain unchanged, the description of the extension equipment, which involves solar PV modules of different models^{/19/}, is added.
 - The project’s phase 1 is composed of 14,832 modules JKM 270 PP-60 and 58,176 modules JKM 275 PP-60 that are connected in strings of 24 modules, split between 3 inverters/transformers packs located on 5 Ingeteam skids (PTR1 to PTR5)^{/19/}.

¹³ Full content and outcomes of the deviation are available on the following public link :
<https://registry.terra.org/app/projectDetail/VCS/2307>

- The project's phase 2, the extension, comprises 37,050 PV modules of type JAM72S30-540/MR that are connected in strings of 24 modules, split between 77 inverters of type SUNGROW SG250HX. These new panels were not in operation during previous monitoring periods. The project extension also features the installation of 5MW/5MWh storage system batteries associated with the RIA (Réseau Interconnecté d'Antananarivo - Antananarivo Interconnected Grid), which will provide sufficient smoothing of the new plant's daily PV output. The aim is to smooth out PV variations due to intermittency over the day. ^{/19/}

- Detailed characteristics of the extension solar PV modules^{/19/}:

Manufacturer	JA solar
Model	JAM72S30-540/MR
Quantity	37,050
Peak Power (W)	540
Type of cells	Mono
Rated voltage (Vmpp) (V)	41.64
Rated current (Impp) (A)	12.97
Efficiency (%)	20.9
Dimensions (mm)	2279 x 1134 x 35 mm

- Updated single line diagram^{/19/} of the PV plant can be found in Annex of the monitoring report.

- The project updates its description of monitoring equipment in section 1.11 and 6.1 of the JPD-MR^{/19/}.
- The JPD-MR^{/19/} from VCS validation, dated 15-July-2020, is updated to include the above-mentioned deviations and is assessed by VVB. Such revised JPD-MR^{/19/} will be available on the project webpage of the VCS registry.
- Crediting period for the project activity is updated to 10 years with no option of renewal, in order to comply with conditions for First-of-its-kind project criteria in additionality tool 23^{/19/}.

The above-mentioned deviations were approved during previous monitoring period^{/19/} and already approved by VERRA. VVB team had provided detailed robust assessment on these deviations in its verification report^{/19/}.

- Outcomes of the deviations include assessment of impact on:
- Applicability of the methodology: In the context of this deviation, the project updates the version of the applied methodology ACM0002, from v20.0 to v22.0, in section 1.2 and 3.2 of the JPD-MR/^{19/}. The applicability against the additional applicability conditions of the methodology ACM0002, version 22.0/^{19/} is demonstrated in the revised PD-MR/^{19/}. VVB team provided detailed assessment in its verification report for 3rd verification/^{19/}, which is already approved.
 - Project additionality: Additionality was re-assessed in the context of this deviation, using Tool 23, Version 03.0/^{19/}. Following requirements assessment, the project was identified as first-of-its-kind and thus additional, in line with Tool 01 version 07.0. VVB team provided detailed assessment in its verification report for 3rd verification/^{19/}, which is already approved.
 - Appropriateness of the baseline scenario: the original baseline context and emission factor still remains the same and applicable. The assessment team confirmed the absence of impact on baseline scenario of the project activity due to the project description deviations sought during the current verification. VVB team provided detailed assessment in its verification report for 3rd verification/^{19/}, which is already approved.

Hence, it was confirmed by the verification team that the above-mentioned approved deviations were appropriately described and justified in the monitoring report for previous verification period and respective verification report from VVB team, and the project remains in conformance with the VCS rules/^{19/}.

The VVB assessment team confirmed that the project description deviations were valid and appropriate.

3.3 New Project Activity Instances in Grouped Projects

The project is not a grouped project. Thus, this section is not applicable.

3.4 Baseline Reassessment

Did the project undergo baseline reassessment during the monitoring period?

☐ Yes ☒ No

4 VERIFICATION FINDINGS

4.1 Project Details

Item	Evidence gathering activities, evidence checked, and assessment conclusion:			
	Audit type	Period	Number of years	Validation/verification body name
Audit history	CDM Validation	Validation date: 03-May-2019	-	TÜV NORD CERT GmbH
	VCS Gap Validation	Validation date: 04-November-2020	-	ESPL
	VCS Verification 1	10-July-2018 to 30-April-2020	22 months (1 year, 10 months)	ESPL
	VCS Verification 2	01-May-2020 to 31-December-2021	20 months (1 year, 8 months)	Carbon Check (India) Private Limited
	VCS Verification 3	01-January-2022 to 31-December-2023	24 months (2 years)	LGAI Technological Center S.A. (Applus+ Certification)
	VCS Verification 4	01-January-2024 – 31-March-2025	15 months (1 year, 3 months)	LGAI Technological Center S.A. (Applus+ Certification)

	The above audit history of the project has been verified and confirmed to be correct by the assessment team from the CDM project website¹⁴, VERRA project portal¹⁵, Validation-Verification report, registered VCS PD-MR, registered CDM PDD, the previous monitoring reports & respective verification reports of 1st, 2nd and 3rd MP/4/.
Double counting and participation under other GHG programs	The current project activity is not receiving or seeking credits for reductions and removals from a project activity under another GHG program other than CDM and VCS. Verification team checked independently other registries such as UNFCCC CDM¹⁶, Gold Standard for the Global Goals (GS4GG¹⁷), Global Carbon Council (GCC¹⁸), International Carbon Registry (ICR¹⁹) etc./28//29//30//19/ and confirmed that project is not participating in any other GHG programs other than CDM and VCS program. Also, International REC (I-REC) registry (https://www.irecstandard.org/) is cross-checked and found that this project is not under I-REC as well. The Project has been registered under UNFCCC CDM with project ID as 10481²⁰.The project proponent has ensured that for a same monitoring period, the project's GHG emission reductions will either be claimed under CDM programme or VCS programme, but never both. Thus, double counting for the current monitoring period is ruled out. Verification team further confirms that project activity is not rejected by any other GHG program. The project proponent has submitted a declaration dated 07-April-2025/¹²/ to the verification team declaring that the project is not registered under any other carbon standard other than CDM and VCS and is not rejected or under the process of registration in any other GHG program.

¹⁴ <https://cdm.unfccc.int/Projects/DB/RWTUV1556909746.23/view>

¹⁵ <https://registry.verra.org/app/projectDetail/VCS/2307>

¹⁶ <https://cdm.unfccc.int>

¹⁷ <https://www.goldstandard.org/>

¹⁸ <https://projects.globalcarboncouncil.com/>

¹⁹ <https://www.carbonregistry.com/>

²⁰ CDM: Ambatolampy 20 MW solar PV (unfccc.int)

No double claiming with emissions trading programs or binding emission limits	The project activity is not participating in other emission trading programs or binding emission limits as confirmed in declaration submitted by the project proponent^{/12/}. VVB confirms that project activity is not included in ET program and not used for compliance with an emission trading program or to meet binding limits on GHG emissions. Project Proponent has submitted a declaration dated: 07-April-2025^{/12/} for no double counting with any other GHG program. PP also declared that that the credit claimed under VCS for the current monitoring period is not claimed under any other GHG mechanism and will not be claimed in the future either. This has also been confirmed by the assessment team by interview with the concerned person from the project proponent.
No double claiming with other forms of environmental credit	The project has not sought, received or planning to receive any other forms of environmental credit for reductions and removals from another GHG-related environmental credit system. The project proponent has submitted a declaration dated: 07-April-2025 ^{/12/} to VVB team declaring that the project is not claiming any other form of GHG related environmental credit under any other emissions trading programs or binding emission limits. The assessment team has also cross-checked the issuance records available on the Verra^{/27/} and CDM^{/34/} website and thus confirmed & ensured that the emission reductions generated from the project activity are not & will not be double counted, hence accepted by the assessment team. The GHG credits from 01-January-2024 to 31-March-2025 (both days included) will be claimed under VCS only. At any point of time during the crediting period, the project proponent will abide by the declaration of “No Double Counting”^{/12/}
Supply chain (scope 3) emissions double claiming	The project activity is solar energy-based project developed by project proponent New Energy Africa Ambatolampy (NEA Ambatolampy) and the carbon consultant AERA Group. The basic objective of the project is to generate electricity and supply to RI-TANA grid. The project proponent and project developer are not involved in any other business activity where they can act as a buyer or seller of a product whose emission footprint is changed by the project activity. The project activity is not a part of any supply chain. Hence, there is no possibility for double claim. This has been confirmed by the assessment team by interview with the concerned person from the project proponent.

Sustainable development contributions

The Project activity is claiming SDG 7, SDG 8 and SDG 13. The same is described in Section 1.12 of VCS MR/^{6/}. VVB confirmed that the project implementation has led in contribution to SDG 7, SDG 8 and SDG 13. The project supplies clean, affordable and renewable energy without reliance on fossil fuels for generation of electricity to meet the growing demands in the region. The generated electricity avoided release of 47,036 tCO_{2e} into the atmosphere.

As declared by the project proponent in section 1.12 of the monitoring report/^{6/}, the project contributes to below sustainable development goals:

SDG	SDG Target	SDG Indicator	VVB assessment
7	7.2	7.2.1 Renewable energy share in the total final energy consumption	The project contributes to this SDG by delivering 70,206 MWh electricity to the national grid during the current monitoring period. The verification team has verified the reported electricity export/import data through monthly generation records (monthly production statements)/^{11/} and the monthly invoices/^{11/} issued by NEA Ambatolampy to the utility company JIRO SY RANO MALAGASY (JIRAMA) National Grid company) which were shared by the PP and found it to be consistent. The project has provided 261,334 MWh of electricity to the grid till date i.e. from the date of commissioning of the project till end of this monitoring period. The project has provided 70,206 MWh electricity in the current monitoring period. This has been verified from the previous period verification reports/^{4/} and the current monitoring report/^{6/}.

			Verification Term	Net Electricity Generation Value (MWh)
			1 st Verification	56,465
			2 nd Verification	47,392
			3 rd Verification	87,271
			4 th Verification	70,206
			Total till date	261,334
	8	8.5	8.5.2 Unemployment rate, by sex, age, and persons with disabilities	The project contributed to this SDG by providing employment to the people. The project has created 11 permanent positions for the operation, maintenance of the plant. Some additional employees are also hired for the security and cleaning of project site. The project activity has provided employment to a total of 80 positions during its construction period. The Employment evidences ^{/14/} provided by the project proponent have been verified to confirm the same and it was further cross-checked during remote audit with PP representatives.
	13	13.0	Tonnes of greenhouse gas emissions avoided or removed	The project contributes to this SDG by avoiding GHG emission due to reduction in consumption of fossil fuels in electricity production and using solar energy instead for electricity generation. The

				project has avoided 175,043 tCO₂e being emitted to the environment till date i.e. from the date of commissioning of the project till end of this monitoring period. The project has avoided 47,036 tCO₂e in the current monitoring period. This has been verified from the previous period verification reports^{/4/} and the current monitoring report^{/6/}.												
				<table><tr><th>Verification Term</th><th>ER Value (tCO₂e)</th></tr><tr><td>1st Verification</td><td>37,847</td></tr><tr><td>2nd Verification</td><td>31,766</td></tr><tr><td>3rd Verification</td><td>58,394</td></tr><tr><td>4th Verification</td><td>47,036</td></tr><tr><td>Total till date</td><td>175,043</td></tr></table>	Verification Term	ER Value (tCO ₂ e)	1 st Verification	37,847	2 nd Verification	31,766	3 rd Verification	58,394	4 th Verification	47,036	Total till date	175,043
	Verification Term	ER Value (tCO ₂ e)														
	1 st Verification	37,847														
	2 nd Verification	31,766														
	3 rd Verification	58,394														
	4 th Verification	47,036														
Total till date	175,043															
Additional information relevant to the project	No commercially sensitive information has been mentioned in the monitoring report to have been excluded from the public version of the project documents. This has also been confirmed during interview with the concern person from the project proponent.															

4.2 Safeguards and Stakeholder Engagement

4.2.1 Stakeholder Identification

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Stakeholder identification	In the context of the project capacity extension, additional consultations took place locally in order to obtain the public's opinion and create a climate of transparency and integration. The identification of such stakeholders was done in collaboration with the local authorities, especially the fokontany of Antevana and

Menabe that are situated nearby the project site (a fokontany was originally a traditional Malagasy village. Today, according to the 2010 constitution, "fokontany officials participate in drawing up their commune's development program"). The local authorities were informed of the extension project from the start, and when contact was established; they expressed their willingness to work with GreenYellow Madagascar to develop the project. The local authorities facilitated the identification of vulnerable people and other local stakeholders interested in the project. The stakeholders were invited orally by the project developers, during visits to the fokontany and town, and also by the local authorities.

List of stakeholders included in meetings and discussions regarding the extension:

- Mayor
- Client (JIRAMA)
- District chief
- Local population
- Representatives of vulnerable people

Since the additional consultations that took place in the context of the extension, no other stakeholders were identified.

As part of the public consultation process, the local stakeholder consultation meetings for extension phase took place through two missions, in Ambatolampy, with Mission no. 1 from December 3 to 7, 2019 held in offices of GreenYellow and Mission No. 2 from January 10 to mid-March 2020 held in the municipal premises of the fokontany Lovahinjafy. No negative comments were reported, as verified from the PREE report for extension^{/22/}. The details of first phase remained unchanged^{/21//4/} and same, which was verified from the validation report. ^{/4/}

Since validation, the stakeholder make-up for first phase has not changed, thus this section is not applicable for first phase.

It was confirmed by the audit team during the interviews with PP representatives and the local stakeholders during remote audit interviews, that the stakeholder composition for the first phase of project activity remains the same since the start of project activity and for second phase also it remains almost the same. Therefore, this section is not applicable.

Legal or customary tenure/access rights	Audit team confirms that there are no legal or customary tenure/access rights to territories and resources, including collective and conflicting rights held by stakeholders, indigenous people (IPs), Local communities (LCs), and customary rights holders with regards to the project and confirmed during the interview with PP. The project is solar energy generation, and it is established on the project proponent's land for which the land acquisition was made before validation of initial PD^{4/}. Hence, this section is Not Applicable for the project activity.
Stakeholder diversity and changes over time	Verification team reviewed the ESIA report^{24/} for the initial phase and PREE report for extension phase ^{22/} and confirmed that stakeholders identified for this project activity are diverse in nature – in terms of socio-economic status, age and gender wise and the diversity is unlikely to change over time. The prime local stakeholders of the project activity are the people from local communities nearby the project site. Two lists of stakeholders have been elaborated, first in the context of the initial phase, then in the extension phase. In both lists, most stakeholders were from the same categories (local/regional/national authorities, JIRAMA, locals etc.) although a few differences can be found for instances, a brick factory owner was engaged in initial phase and not in extension, while subcontractors and medias were engaged in extension and not during initial phase. Hence, overall, the stakeholder diversity remained same without major changes. This was further confirmed from the PP during the remote interviews^{19/} conducted by the audit team.
Expected changes in well-being	As confirmed from the monitoring report^{6/}, it was identified that access to the social well-being is one of the expectations from vulnerable groups. During the interviews with local stakeholders and as checked from supporting evidences for CSR activities^{31/}, it was noted that several CSR activities are being conducted by the PP, which result in social well-being of the stakeholders including the vulnerable groups. Moreover, the deterioration of local stakeholder's wellbeing was identified in the initial EIA as a potential impact, due to the physical presence of the project site and the change in landscape. However, it was confirmed that the limited built environment (the PV power plant site is only visible from the roads and areas in its immediate vicinity) made this impact identified as negligible. No impact on wellbeing was identified in the extension EIA.

	Additionally, the representatives of Project proponent confirmed during the remote audit interviews/^{19/} that the following expected changes occurred in well-being: 1. Social well-being: The project helped in generating employment opportunities during the construction and operation phases. The project activity leads development of infrastructure like roads, livelihood and promotes small scale business with improved power generation. Verification team confirmed the same through interview with PP representative. /^{19/} 2. Economic well-being – The project activity results in employment generation which helps economic well-being of the people as confirmed during the interviews. /^{19/} 3. Environmental well-being: Solar being a renewable source of energy, it reduces the dependence on fossil fuels and conserves natural resources which are on the verge of depletion. Due to its zero emissions, the Project activity also helps in avoiding significant amount of GHG emissions as verified from the emission reduction calculation sheet/^{7/}. During the current monitoring period, the project activity has reduced 47,036 tCO_{2e}.
Location of stakeholders	The majority of stakeholders included are living in the nearby communities of the project site i.e. in the vicinity of Ambatolampy. This was confirmed through the interviews with local stakeholders and PP representatives. /^{19/}
Location of resources	Local communities use of the PV power plant site is limited to pasture for their livestock and access road to the forest resources located north of the PV power plant site. Local communities land use of the PV power plant site is not based on formal or traditional rights and local communities are aware that their land use of the site is forbidden. The initial EIA mentioned the relevance to arrange alternative access road outside of the Project site to maintain communities' access to natural resources north of the PV power plant site.

4.2.2 Stakeholder Consultation and Ongoing Communication

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Ongoing consultation	Project Proponent has submitted the copies of grievance register/^{15/} kept at site for the ongoing communication with local stakeholders. VVB confirmed that at the project site, there were two distinct grievance logbooks made available at the plant for any comments or grievance. One involving grievances for internal stakeholders (NEA employees and local community), and one for external companies like

security and other subcontractors. The grievance register/^{19/} is kept in plant site office for seeking complaints/grievances from local community as a part of ongoing communication with stakeholders in line with clause 3.18.3 of VCS Standard, v.4.7./^{10/}

As part of ongoing consultation process, the PP has maintained following communication channels for the local stakeholders:

- a) Submitting the grievances/comments in the Grievance register kept at plant site office and also in the 2 fokontany and townhall.
- b) Annual meetings with the community in order to consider the community expectations from the project
- c) Phone number: + 261 34 00 308 69
- d) E-mail : Mairamou.Hamanadji@axian-group.com

This was further confirmed by the audit team from PP's representatives and the local stakeholders during the remote audit interviews. /^{19/}

The assessment team concludes that the PP has effective communication channels for the local stakeholders.

Details about Stakeholder engagement activities undertaken for the initial phase and extension phase:

Stakeholder engagement activities undertaken for the initial phase include meetings held during the site visit between the 5th and the 8th of July 2016. Stakeholder engagement involved face to face meetings and consultations with local authorities, key informants and group meetings with local communities. Information regarding technical characteristics of the project, indicative location and indicative duration was disclosed. Stakeholders commented and gave their concerns and expectations, as related in the 2016 EIA./^{21/}

GreenYellow, as part of the conception phase of the Project, has engaged extensively with various stakeholders at the national and regional level including JIRAMA, the government of Madagascar, etc.

In the context of the extension, field investigations were carried out in order to agree individual and public consultations with all project stakeholders, with two missions:

- Mission 1: meeting with internal stakeholders, the Fokontany chief and subcontractors (held in the offices of GreenYellow from 03 to 07 December 2019)
- Mission 2: meetings with the mayor, the client, the district chief, the local population and representatives of vulnerable groups. (held in the municipal premises of the fokontany Lovahinjafy from 10 January to mid-March 2020)

	In the first mission, the main objectives were identification of major environmental and social issues of PPs activities, the expectations and concerns of local population, PP's environmental commitment programme and explaining the project progress including the extension project. In the second mission, face-to-face interviews on the same themes that were mentioned during the first mission were carried out. A formal public hearing, chaired by local authorities, was organized to share general information with the local population and gather their opinions. These details were confirmed to be correct by the assessment team by checking the ESIA report^{/21/} for initial phase and PREE report for extension phase.^{/22/} Moreover, regarding ongoing communication during monitoring period, there are annual meetings with the community in order to consider the community expectations from the project. Project proponent ensured that this would continue in the future and will be useful for the selection of projects for NEA Ambatolampy's environmental and social program. Assessment team through remote audit and interviews with PP representatives & local stakeholders confirmed that, the ongoing communication process also includes the presence of grievance logbooks in the plant and also in the 2 fokontany and townhall, which are checked once per month (once per week since autumn 2024). Finally, contact information (mail and phone number) from two resource persons acting as relays from project developers and proponents NEA Ambatolampy are communicated with stakeholders: • Hery TIANA RASOLOARIVELO (QHSSSES supervisor) • Jeremie Harison TATA (Operations Manager Ambatolampy)
Date(s) of stakeholder consultation	Initial phase: • Several face-to-face meetings and focus group meetings held between the 05-July-2016 and 08-July-2016 Extension phase: • Mission 1 from 03-December-2019 to 07-December-2019 • Mission 2 from 10-January-2020 to mid-March-2020 These dates were verified by checking the ESIA report^{/21/} for the initial phase and PREE report^{/22/} for extension phase and confirmed to be correct.

	Details about initially registered first phase was further cross-checked by the verification team from the registered CDM PDD, registered VCS PD-MR and the respective FVR of the project.^{/4/}
Communication of monitored results	Results of the initial project consultations can be read in the EIA where the key concerns and expectations are summarized. Also, minutes of these various consultations were compiled in annexes at the end of the report. Key concerns and feedback from the stakeholders include: • transparency, trust, be informed of environmental and social policies (from JIRAMA) • social peace and consideration of community's social concerns (from local, regional and national authorities) • Identification of priority sectors to support local development, and access to jobs (from public authorities) • Access to health, educational and social well-being (from vulnerable groups) As a response to these concerns, the participation of the local population in the extension project is achieved through local recruitment and social actions that the project will bring. A list of the fokontany's expectations has been drawn up, and a report has been produced to this effect, in order to substantiate the Environmental and Social Action Plan (ESAP).^{/21/} Expectations range from health and education actions from the vulnerable people representatives to social peace, formulated by the local authorities. A table of all the stakeholders, with entities and expectations identified can be seen on table 16 of the PREE^{/22/}, provided to the VVB. Since the start of the extension phase, the CSR actions taken by GreenYellow and afterwards, NEA Ambatolampy, occurred in this regard. The choice of community projects supported by NEA Ambatolampy are directly decided with the local community, during public consultations, in order to take their concerns and priorities into consideration. Assessment team has cross-checked the above-mentioned details by reviewing the CSR Reports, ESIA report for initial phase and PREE report for extension phase and confirmed to be correct. ^{/21//22//31/} Verification team has checked ESIA report for the initial phase and PREE report for extension phase ^{/21//22/} and confirmed that the purpose of stakeholder engagement is to ensure Project's stakeholders are informed about the Project and that their views and opinions about the Project and its associated impacts are taken into

	consideration during the impact assessment process. The stakeholder consultation meetings were focused towards making aware local stakeholders including local community, local administration representatives, NGOs working for environmental cause etc., about the project activity that involves electricity generation using Solar energy produced by Solar plant with the primary objective of reducing emissions of GHGs in compared to pre-project or baseline scenario. The grievance logbook/^{15/} is always available on site for stakeholders to write in or ask for assistance to write any inquiry. The verification team confirmed from the grievance book maintained by the PP that few comments were received during the current monitoring period and successfully resolved by the PP (please refer to section 4.2.4 of this report for more details).
Consultation records	The comments and concerns of the stakeholders that were raised during to the stakeholder consultation conducted prior to execution of initial and extension phase were answered and the details are available in the respective ESIA and PREE report/^{21/22/}. Also, Environmental and Social Action Plan (ESAP) /^{21/} provides the action plan for several environmental and social indicators. These details were checked by the VVB team and found to be appropriate. The PP maintains grievance books/^{19/} for the records of all the comments/ grievances received for the project activity. The verification team confirmed from the grievance book maintained by the PP that few comments were received during the current monitoring period and successfully resolved by the project proponent (please refer to section 4.2.4 of this report for more details).
Stakeholder input	It was confirmed that the comments received during initial stakeholder consultations were duly considered in the project's development and preparation of its Environmental and Social Action Plan (ESAP)/^{21/}, whose objective is to set out the key actions that need to be undertaken by the Project in order to achieve compliance with the applicable environmental and social standards, and in particular those from the IFC²¹: • IFC Performance Standards 1 - Assessment and Management of Environmental and Social Risks and Impacts • IFC Performance Standard 2 - Labor and Working Conditions • IFC Performance Standard 3 - Resource Efficiency and Pollution Prevention

²¹ <https://www.ifc.org/content/dam/ifc/doc/2010/2012-ifc-performance-standards-en.pdf>

	• IFC Performance Standard 4 - Community Health, Safety, and Security • IFC Performance Standard 5 - Land Acquisition and Involuntary Resettlement • IFC Performance Standard 6 - Biodiversity Conservation and Sustainable Management of Living Natural Resources • IFC Performance Standard 8- Cultural Heritage NEA Ambatolampy retains an overarching responsibility to ensure that all the actions recommended in the ESAP/^{21/} are implemented even though it is not its directly responsible for their implementation. If the responsibility of an action lies with a NEA Ambatolampy contractor, NEA Ambatolampy will monitor the implementation of the action and will assess the efficiency and effectiveness of the action and require corrective actions where necessary. As verified by the assessment team from the grievance records/^{15/}, few comments were received during the monitoring period, which were successfully addressed by the PP representatives with appropriate solutions or provided clarifications for irrelevance of requests. Please refer to section 2.1.4 of MR/^{6/} and section 4.2.4 of this report for more details. Inputs received during consultation during registration, including public meeting comments and public comments, were mostly informative and did not impact the project design. The project proponent has considered suggestions and opinions of stakeholders. Verification team checked the ESIA and PREE report /^{21/22/} which provides information of stakeholder consultation during registration and execution, the feedback/comments received from stakeholders which are quite positive and no negative comments were received.
--	--

4.2.3 Free, Prior, and Informed Consent

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Consent	Verification team has reviewed the ESIA and PREE report / ^{21/22/} , the registered CDM PDD/ ^{4/} and registered/ ^{4/} and revised VCS PD-MR/ ^{4/} and respective FVR/ ^{4/} and noted that, since 2016, GREENYELLOW MADAGASCAR (Now NEA Ambatolampy) has acquired 53 hectares of the "1000 ha" estate through a lease. Prior to the project implantation, the land belonged to the state. Although various activities were carried out by the local habitants on phase 2 site prior to the construction,

	agreements were concluded and no conflict emerged from the land use, in past or in current phase. Moreover, the approach adopted for the initiation of the EIA and associated PPP (Public Participation Process) was to identify and contact potential I&APs as possible through a number of activities which included: - Stakeholder engagement has been undertaken as part of the site visit between the 05-July-2016 and 08-July-2016 for phase 1. - Direct invitations by the local authority representative (Fokontany chief) through direct communication. - Comments were invited verbally during face-to-face meetings and focus groups as well as remotely. - In the context of the extension, field investigations were carried out in order to agree individual and public consultations with all project stakeholders, with two missions: - Mission 1: meeting with internal stakeholders, the Fokontany chief and subcontractors (held in the offices of GreenYellow from 03-December-2019 to 07-December-2019) - Mission 2: meetings with the mayor, the client, the district chief, the local population and representatives of vulnerable groups. (held in the municipal premises of the fokontany Lovahinjafy from 10-January-2020 to mid-March-2020) Hence, it is clear from the above-mentioned information that project developer has followed a thorough procedure for acquiring the consent of local stakeholders and provided them with the means to freely submit any inputs/feedback/comments they have about the project activity, prior to its inception. The project activity was accepted by all the stakeholders involved. It was further confirmed from the local stakeholders and the representatives of project proponent & project developers during the remote audit interviews that there are no outstanding issues and conflicts related to project activity. Also, during remote interviews, it was confirmed by project developers and local stakeholders that, there are no ongoing conflicts on the project site or with local inhabitants.
Outcome of FPIC discussion	The project activity is currently under 4th verification. These aspects about FPIC have been covered under validation for first phase and for extension phase were covered under previous verification. During the operational phase, which began in June 2018, agreements have been reached with local population for the use of land belonging

	to GYM (Now NEA Ambatolampy), in particular for grazing of livestock and cutting/collecting of grass inside the site. An agreement had been signed between the local population through the Fokontany and GREENYELLOW MADAGASCAR (Now NEA Ambatolampy) on the recognition of the land as belonging to the developer, and the provisional use of the land by the local communities pending construction work on the extension site. No conflict emerged following the start of construction of the extension site. No displacement of population occurred as part of the extension since the phase 2 site was already owned by GYM (now NEA Ambatolampy). As confirmed by Project Developers and local stakeholders during the remote audit interviews^{/19/}, no relocation or physical/economical displacement of people occurred related to the project site. The main reason is the signed agreements between the local population through the Fokontany and PP.
--	---

4.2.4 Grievance Redress Procedure

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Grievance received and steps taken to resolve the grievance including the outcomes of the resolution	During the current monitoring period. two distinct grievance logbooks^{/15/} were made available at the plant for any comments or grievance. One involving grievances for internal stakeholders (NEA employees and local community), and one for external companies like security and other subcontractors. The presence of comments on grievance logbooks in the plant and also in the 2 fokontany and townhall are checked once per month (once per week since autumn 2024), in order to be quickly reviewed and addressed by NEA Ambatolampy. The other means of communication are also available to local stakeholders such as phone, mail and annual meetings conducted by the project proponent. The grievance logbook^{/15/} is always easily available on site for stakeholders to write in or ask for assistance to write any inquiry. The copies of the same were provided to the assessment team. Verification team checked the grievance register^{/15/} and ESAP Reports for current MP^{/19/} submitted by project proponent and found that total 2 grievance/feedback comments were received in grievance register and ESAP Reports^{/19/} during the current monitoring period: 01-January-2024 to 31-March-2025. Details of those comments are provided below:

1) Delayed payment of December 2024 salaries to SECUR-PRO, the company responsible for site security and guarding. (Grievance received on: 15-January-2025).

Resolution and outcome: In response, PPs contacted the company responsible for site security to address the issue. The specific concern was raised, and the company clarified that the payment had already been issued. They explained that the delay was caused by simultaneous late payments from multiple clients, which temporarily affected their cash flow.

The grievance was officially closed with the December 2024 payroll, and subsequent payrolls were confirmed to have been issued on schedule. Copies of the logbooks, email correspondence, and the grievance closure documentation have been submitted to VVB for reference^{/19/}.

VVB Opinion: Following the grievance raised regarding delayed payments to the site security company, the VVB team has reviewed the actions taken by PPs and assessed the supporting documentation^{/19/}. PPs promptly engaged with the responsible vendor (i.e. SECUR-PRO), who confirmed that the payment had been issued. The delay was attributed to a temporary cash flow disruption caused by concurrent late payments from multiple clients.

The Project Proponent (PP) has submitted a detailed clarification regarding the grievance related to delayed salary payments for December 2024. As conveyed by PP representatives, salary delays have been a recurring issue in previous years, typically resolved through verbal communication. This practice was corroborated during remote interviews^{/19/} conducted by the VVB team with both PP and SECUR-PRO officials (security provider company).

The specific grievance raised during the current monitoring period was formally documented in the grievance logbook on 15-January-2025, with the outstanding salaries disbursed on 21-January-2025.

Following internal discussions in February 2025, the PP initiated formal engagement with the security service provider, resulting in the signing of a letter of commitment in March 2025. This document outlines corrective actions aimed at ensuring the timely and consistent payment of salaries moving forward.

To substantiate the resolution, the PP has provided the following supporting documentation^{/19/}:

- a) Relevant grievance logbook entries related to the issue
- b) SECUR-PRO employee payslip
- c) Screenshot of email correspondence detailing the established payroll calendar
- d) Letter of Commitment signed March 2025 on the security workers salary payments issue

Upon thorough review, the VVB team confirmed that the submitted documentation sufficiently demonstrates resolution of the grievance. Furthermore, it is noted that no subsequent complaints have been reported since the implementation of the corrective measures, and the payroll schedule has been consistently maintained.

The grievance was formally closed with the December 2024 payroll cycle, and subsequent payrolls were verified to have been processed without issue. VVB has received and reviewed relevant documentation, as mentioned above. Based on this review, the VVB team considers the matter resolved and appropriately documented.

The same was also confirmed by assessment team during the remote audit interviews^{/19/} with the SECUR-PRO employee.

Based on the evidence reviewed and stakeholder confirmations, the VVB team concludes that the grievance has been appropriately addressed and resolved by the Project Proponent.

2) 2024: The neighbouring community mentioned a grievance in ESAP report concerning the upgrading of a stretch of road in the vicinity of the power plant that they said had been degraded by the plant's activity, but after investigation this was not the case, and this was passed on as a request

Resolution and outcome: The request was duly recorded but, after analysis, it was not originally classified as a grievance but reclassified as a request. Nevertheless, it was not included in the CSR projects, as these had been defined in advance with the CSR committee, that includes local stakeholders, according to the priorities identified and the budgets allocated. It should also be noted that the section of road mentioned has been in poor condition for more than five years and has not been used as the main access route to the site since the plant began operating.

VVB Opinion: The Project Proponent (PP) has provided clarification regarding the community concern referenced in the document titled “ESAP REPORT_2024_ NEA Ambatolampy signed” ^{/19/}. As explained by the PP representatives, the issue—initially raised by the neighbouring community regarding the condition of a stretch of road near the power plant—was reviewed and subsequently reclassified as a **request**, rather than a formal grievance.

This determination was based on the following considerations:

a) **Site Access Relevance:** The road in question has not served as the primary access route to the facility since the commencement of plant operations and has reportedly remained in poor condition for over five years.

	b) CSR Program Scope: The CSR initiatives for the reporting period were pre-defined in collaboration with the CSR committee, which includes representation from local stakeholders. These initiatives were selected based on identified community priorities and available budget allocations. c) Stakeholder Engagement: The matter was discussed during by VVB team during remote interviews with PP representatives and was found to have been appropriately addressed within the context of the project's community engagement and grievance management framework. Based on the review of documentation/^{19/} and stakeholder input, the audit team considers the PP's classification and handling of the concern to be consistent with established procedures and appropriately resolved. Therefore, assessment team confirms that the explanation provided by the PP is acceptable.
Grievance redress procedure	Grievance redressal mechanism is established as per registered and revised VCS PD-MR/^{4/} and local law. PP has placed grievance registers at project site for registering grievances if any related to the project activity by the stakeholders. The other means of communication are also available to local stakeholders such as phone, mail and annual meetings conducted by the project proponent. Assessment team checked the evidence of grievance register/^{19/} submitted to VVB. The same was also confirmed during interview with PP representatives and found appropriate. During remote audit, it was confirmed that Stakeholder's feedback is monitored continuously, and the stakeholders are well aware of the grievance redressal procedure. Thus, verification team concludes grievances redressal process is adequate and appropriate.

4.2.5 Public Comments

Comments received	Actions taken by the project proponent	Evidence gathering activities, evidence checked, and assessment conclusion
No comments received during the public comment period ²² .	(Stakeholder engagement, phase 1)	This is verification of the project. The expected comment is from the local stakeholder only. Verification team checked the feedback cum grievance

²² As identified in section 2.1.5 of the VCS-MR and checked from the VCS project webpage, this project was open for public comments from 29-June-2020 to 29-July-2020; no submissions/comments were received.

However, comments were raised during the stakeholder consultations (conducted prior to commissioning of both the phases), and they are listed in the table below: (Stakeholder engagement, phase 1) Meeting minutes with stakeholders groups reported the following comments²³ : • Unawareness of the project by commune representatives prior to the meetings • The mayor expects no negative impacts and only benefits • The commune representatives expect no conflict over the PV site with any communal, regional or national projects • Interest from the local inhabitants regarding the employment opportunities • Absence of conflict regarding the land use, since the local inhabitants said they did not use it beforehand. (Stakeholder engagement, phase 2)	Local employment opportunities have been created by the project No conflict was raised regarding land use. However, due to the potential resource on the acquired land, during the operational phase, which began in June 2018, agreements have been reached with local population for the use of land belonging to GYM, in particular for grazing of livestock and cutting/collecting of grass inside the site. (Stakeholder engagement, phase 2) • Project activities comply with all laws applicable to the project • No conflict emerged since the start of the project activity. • Local employment opportunities have been created by the project • Most of the Project developer's area of actions in terms of CSR activities concern improvement of health, education and social wellbeing, as it can be seen reported on the CSR activities report.	register/^{15/} and confirmed that few grievance/feedback comments were received during the current monitoring period and successfully resolved as discussed in section 4.2.4 above. Thus, verification team is of the opinion that the ongoing stakeholder mechanism is adequate and appropriate. Moreover, comments were raised during the stakeholder consultations conducted prior to project implementations which are mentioned in left columns along with their respective resolutions. (Stakeholder engagement, phase 1) Assessment team interviewed few local stakeholders during the remote audit/^{19/}. They confirmed that local employment opportunities/^{14/} have been created by the project in skilled and unskilled work tasks. Hence, this issue was considered to be appropriately resolved by the PP. Regarding the land use, although there have been no conflicts occurred till date, due to the potential resource on acquired land, during the operational phase, which began in June 2018, agreements have been reached with local population for the use of land belonging to GYM, in particular for grazing of livestock and cutting/collecting of grass inside the site. This was confirmed by the assessment team during the remote audit/^{19/} and hence issue was considered to be adequately resolved.
--	---	---

²³ Complete meeting minutes are available in the annex A of the EIA

Mission 1 and mission 2 reported various expectations from the stakeholders, including: • From national, regional and local authorities: law enforcement and social peace, conflict resolution, prioritizing local employment • From vulnerable groups and population: access to health, education and social wellbeing, access to employment	Exemple of activities in the rural community of Ambohipihaonana, in 2022 / 2023: 1) provision of table-benches for school equipments 2) deployment of mobile clinics for health access, with 357 medical consultations including 340 women and children.	(Stakeholder engagement, phase 2) • Assessment team confirmed that project activity complies with all laws applicable to the project. The Environmental Authorization letter provided by Ministry of Energy and Hydrocarbons dated 05-May-2021/^{25/} and CDM Letter of Approval by Secretariat General, BUREAU NATIONAL DE COORDINATION DES CHANGEMENTS CLIMATIQUES dated 21-January-2019/^{35/} were checked by the assessment team and confirmed that the project activity complies with all the applicable laws and regulations of the host country. • Assessment team confirmed that no conflict emerged since start of the project activity by discussing with PP representatives and local stakeholders. • Local employment opportunities have been created by the project, as confirmed during interviews with PP representatives, employees and local stakeholders. • Assessment team confirmed that most of the Project developer's area of actions in terms of CSR activities concern improvement of health, education and social wellbeing, as it can be seen reported on the CSR activities report/^{31/}. For Example, activities in the rural community of Ambohipihaonana, in 2022 / 2023: 1) provision of table-benches for school equipments 2) deployment of mobile clinics for health access, with 357 medical consultations including 340 women and children. These details were also confirmed through interviews with the PP and local people.
---	--	---

		Conclusion: As per the above-mentioned course of actions to the comments raised by stakeholders, assessment team confirms that the project proponent has taken due account of all comments raised and appropriate measures are put in place for their resolution.
--	--	---

4.2.6 Risks to Local Stakeholders and the Environment

4.2.6.1 Management Experience

As part of the remote audit/^{31/}, the assessment team conducted interviews with representatives of the Project Proponent (PP) and reviewed the organizational structure/^{31//31/} and operational history of the project. It was confirmed that the current management team has been in place since the commissioning of the NEA Ambatolampy solar power plant and possesses extensive experience in implementing renewable energy projects across multiple countries. The operation and maintenance (O&M) team also demonstrated significant expertise in the solar electricity sector, with several years of hands-on experience managing similar installations.

NEA Ambatolampy is a member of the Axian Energy cluster, which brings substantial institutional capacity and technical know-how in delivering clean, sustainable, and inclusive energy solutions. Axian Energy's mission is rooted in expanding access to affordable and environmentally responsible energy, particularly in underserved regions. The group designs, produces, and distributes hybrid, hydroelectric, and solar technologies tailored to local community needs.

Notable achievements include:

- Installation of mini solar power plants in 173 remote villages across Madagascar and Mali through its subsidiary Welight
- Operation of four hybrid power plants in Madagascar
- Development of large-scale solar projects in Senegal (MINERSOL – 15 MWp), Burkina Faso (SPESO Nagreongo – 30 MWp), and Rwanda (Gigaawatt Global – 8.5 MWp)

Axian Energy and its affiliated entities, including NEA Ambatolampy, integrate socio-economic and environmental considerations into their governance frameworks, with a strong emphasis on CSR initiatives aligned with their strategic objectives/^{31/}.

In addition, the **AERA Group**—responsible for carbon certification and verification—has over a decade of experience in the African market, with more than 200 successful validations under CDM, GS, and VCS standards, including over 100 projects focused on solar technology. This further reinforces the credibility and technical robustness of the project's carbon component.

It is also noted that, aside from the company's name change from Green Yellow Madagascar to NEA Ambatolampy during a previous verification cycle, no new entities have been introduced in the project's design or implementation. This continuity in ownership and execution mitigates risks related to institutional fragmentation or operational disruption.

Conclusion:

Based on the remote audit interviews^{/31/} and review of organization structure^{/31/}, the assessment team concludes that the Project Proponent and its affiliated entities possess the requisite technical expertise, operational experience, and institutional stability to support the ongoing implementation and long-term sustainability of the project. No risks were identified in relation to organizational capacity, project continuity, or stakeholder alignment.

4.2.6.2 Risk Assessment

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Natural and human induced risks to stakeholders' wellbeing	As part of the audit document review, the assessment team examined the findings of both the initial Environmental Impact Assessment (EIA) ^{/31/} and the extension EIA^{/31/} concerning potential impacts on local stakeholder wellbeing. The initial EIA identified a possible risk of deterioration in community wellbeing due to the physical presence of the project site and associated changes to the landscape. However, this impact was assessed as negligible, given the limited visibility of the photovoltaic (PV) power plant—restricted to roads and areas in its immediate vicinity—and the minimal alteration to the surrounding built environment. The extension EIA did not identify any additional or residual impacts on stakeholder wellbeing. Based on the documentation reviewed and the site context, the assessment team concludes that the project's physical footprint has not resulted in any material adverse effects on local wellbeing. Accordingly, the matter is considered to be appropriately assessed and does not present a significant risk under the current project configuration.
Risks to stakeholder participation	Stakeholder meetings were conducted during the validation stage of the project activity and again before start of execution of extension phase. There is no separate stakeholder consultation for the current verification other than ongoing communication with the stakeholders. Verification team has checked feedback register^{/15/} and found that there is no risk to stakeholders for registering their grievances. It was found that local stakeholders can anytime lodge their grievances if any, in the register over the operational lifetime of the project. Moreover, during current monitoring period few grievances were received and successfully resolved by the PP. Also, as per cross checked from the ESIA and PREE report^{/21//22/}, no risks related to stakeholder participation were identified. However, as identified in EIA, the only social impact is job creation, which is being mitigated by project developers by providing employment to the local population in

	skilled as well as unskilled jobs. Thus, resulting in social well-being of the region. Thus, assessment team confirms that there are no risks identified pertaining to stakeholder participation.
Working conditions	As described by project proponents in the monitoring report, Risks on occupational health and safety were considered moderate at construction phase for workers, whereas during operational phase, it is considered to be negligible. Mitigation & management measures taken such as provision of appropriate PPE to workforce and ensure their consistent use throughout the operational phase. Assessment team during the remote audit/^{31/} confirmed that all the safety provisions/measures are in place as per the Health and Safety by laws of the country. The workforce is provided with appropriate safety equipment and PPE. Their consistent use at the project site is ensured by the HSE team and also safety trainings are provided to the workers. This was confirmed by assessment team by checking the training certificates/^{31/} and interviews with the employees at site/^{31/}. The risks about occupational health and safety were considered to be moderate for the construction phase and negligible during the operation phase. Verification team checked the training certificates/^{14/} provided by project proponent and confirms that the necessary safety trainings are imparted by the competent training providers and the same was confirmed during interviews with project staff. Moreover, no accidents occurred during the current monitoring period as verified by assessment team during the interviews. Thus, it can be concluded that, the project proponent has undertaken necessary mitigation measures to reduce the identified risks about working conditions.
Safety of women and girls	No risks related to safety of women and girls were identified at the validation, nor during this verification period with employees. Regarding the safety of women and girls, the management team has experience with discrimination and sexual harassment management. The protection against sexual harassment is part of Axian Group's HR policy/^{40/}, same is cross checked by the VVB team. Upto now none has been observed on the project. Also, it was confirmed through remote audit and cross checked through Organigramme/^{32/}, that several women are employed by the PP NEA Ambatolampy and its parent company Axian Group. During the interviews, PPs mentioned that there have been no cases of discrimination and

	sexual harassment observed and the management team has experience with handling such issues. Therefore, the implementation of the project does not pose any threat to safety of women and girls, thus they are safe.
Safety of minority and marginalized groups, including children	As per EIA report^{/21//22/}, no risk related to safety of minority and marginalized groups identified. Children work is forbidden, and no children are employed on the platform. However, the major risk identified related to safety of marginalized groups is the increased traffic in the Project Area with associated risk of accident. Such accident between Project's vehicles and other road users and pedestrians was a risk identified with a major impact significance for construction phase, but negligible for operational phase. For avoidance/reduction of such accidents, following solutions/mitigation measures were considered: • Development and implementation of specific road traffic management procedures and plan • Strictly implement speed limitations including within settlements. • Limit Project's vehicles speed on unpaved road to ensure safe operations. These mitigation measures were considered to be appropriate by the assessment team in order to reduce the road accidents. This risk was identified with a major impact significance for construction phase, but negligible for operational phase During the audit, it was confirmed with PP and local stakeholders that, there are no children employed in the project and the child labour is strictly forbidden. Moreover, no other risks related to minority and marginalized group were noticed. The verification team concludes that there is no impact of project implementation in Ambatolampy on the safety of minority and marginalized groups, including children.
Pollutants (air, noise, discharges to water, generation and release of hazardous materials and chemical pesticides and fertilizers)	As described in the monitoring report^{/6/}, few risks were identified along with mitigation measures as mentioned below: a) Non-hazardous waste generated during construction activities have the potential to generate pollutions. The risk is identified at all phases of the project, at minor impact. With mitigation and management measures, the risk becomes negligible for all phases.

Mitigation or preventative measure taken:

- Waste Management Plan (WMP) following the principles of waste minimisation at source, segregation for reuse, recycling, and disposal of waste.
- Making suitable facilities available for the collection, segregation and safe disposal of waste.
- Creating waste collection area with clearly marked facilities such as colour coded bins and equipment for handling the waste.
- Ensure all wastes are managed by a licensed contractor.

The proposed mitigation measures were found to be appropriate to the assessment team and already implemented at the site, as confirmed during remote audit^{31/}.

- b) Project construction phase carbon emissions have been estimated by GreenYellow at 36 tonnes of CO₂. Overall air quality risk has been assessed as 'negligible' during construction phase, as well as operational phase.

Mitigation or preventative measure taken: Assessment team confirmed that the during construction phase, carbon emissions have been estimated by GreenYellow at 36 tonnes of CO₂. However, it is to be noted that these emissions are only relevant during the construction phase and during operational phase, those are considered as 'negligible'. This is supported by the fact that, solar power generation technology is considered to be one of the green technologies, with almost zero emissions. Therefore, overall air quality will be good.

- c) Noise and vibrations have been assessed as a minor impact significance during construction, and negligible with mitigation measures (such as grievance process for noise complaint). It is also negligible for operational phase.

Mitigation or preventative measure taken: During construction phase, due to the use of machinery, noise and vibrations can occur. These are considered to be impactful only during the construction and negligible with the application of mitigation measures such as noise reducing devices/noise barriers, frequent maintenance of machinery, etc. For operation phase, this is considered to be negligible.

- d) Hydrology and water consumption is estimated of minor impact during construction, becoming negligible with appropriate mitigation measure. This implies careful management of water consumption, and good design of on-site well.

Mitigation or preventative measure taken: The impact is considered to be negligible for the hydrology and the water consumption.

	No other risk related to pollutants other than negligible are identified during the operational phase. Verification team noted that, the above risks i.e. construction phase carbon emissions, Non-hazardous waste generated during construction activities and Noise and vibrations are considered to have occurred during the construction period only. Owing to the fact that construction period being a short-term activity, the impact is considered to be low. Verification Team confirmed that, the other risk related to household and other non-hazardous waste is taken care of, with proper waste management system, as confirmed during the remote audit. /31/ The project proponent confirmed during the remote audit that the risks that occurred during construction period are for a short period and hence considered to be negligible and mitigation measures are in place for the other applicable risk related to household waste.
--	---

4.2.7 Respect for Human Rights and Equity

4.2.7.1 Labor and Work

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Discrimination	During the remote audit, representative of PP confirmed that the national laws prohibiting the discrimination and sexual harassment are being followed strictly. Further, verification team did not find any complaint regarding the same registered in grievance logbook/¹⁵/ and through independent search. PP representative confirmed during the remote audit that there have been no reports of discrimination or sexual harassment for this monitoring period. The project staff including women also provided assurance that there have been no incidents of any discrimination or sexual harassment in the workplace. Non-discrimination and equal opportunity in labour and work conditions is one of the performance standards of the NEA Ambatolampy structure, reported in their Environmental and Social Reports/³¹/. The ESAP report 2024 and ESAP report Q1 2025/³¹/ were cross checked by assessment team to confirm this. Further, VVB team verified through grievance mechanism as well as the remote audit interviews with employees/³¹/ that no case of discrimination or sexual harassment was reported during the current monitoring period.
Sexual harassment	During the remote audit/³¹/, representative of PP confirmed that the national laws prohibiting the discrimination and sexual harassment are being followed strictly. Further, verification team did not find any

	complaint regarding the same registered in grievance logbook/^{15/} and through independent search. PP representative confirmed during the remote audit that there have been no risks or reports of sexual harassment for this monitoring period. The project staff including women also provided assurance that there have been no incidents of any discrimination or sexual harassment in the workplace. The ESAP report 2024 and ESAP report Q1 2025/^{31/} were also cross checked by assessment team to confirm this. Further, VVB team verified through grievance mechanism as well as the remote audit interviews with employees that no case of discrimination or sexual harassment was reported during the current monitoring period.
Gender equity in labor and work	PP provides equal opportunities in the context of gender equity and pay for labour and work as confirmed during the remote audit/^{19/} by the PP representatives. Moreover, the project is located in Madagascar, which is an ILO member state since 01/11/1960, and which ratified the following conventions: C100 - Equal Remuneration Convention, 1951 (No. 100)²⁴, since since 10 August 1962 C111 - Discrimination (Employment and Occupation) Convention, 1958 (No. 111)²⁵, 11 August 1961 Thus, as per legislation, there is an equal opportunity for men and women to obtain a job. As per organization chart, several women are employed by NEA Ambatolampy and Axian Group. Therefore, through the review of public resources, organization chart of PP company/^{32/} it can be concluded that the Gender equity in labor and work is followed by the PP.
Forced labor	The PP strictly follows the national laws prohibiting human trafficking, forced labour and child labour. There have been no reports of human trafficking, forced labour and child labour during this monitoring period as observed during the remote audit and confirmed through interviews with project staff/^{31/}.

²⁴

https://normlex.ilo.org/dyn/normlex/en/f?p=NORMLEXPUB:12100:0::NO:12100:P12100_INSTRUMENT_ID:312245:NO

²⁵

https://normlex.ilo.org/dyn/normlex/en/f?p=NORMLEXPUB:12100:0::NO:12100:P12100_INSTRUMENT_ID:312256:NO

	The ESAP report 2024 and ESAP report Q1 2025/^{31/} were also cross checked by assessment team to confirm this. The project aligns with the labour convention and labour rights of Madagascar, which is a member of the International Labour Organisation (ILO). No human traffic, no forced labour (all employees declared) and no children are employed by the project.
Child labor	The PP strictly follows the national laws prohibiting human trafficking, forced labour and child labour. There have been no reports of human trafficking, forced labour and child labour during this monitoring period as observed during the remote audit and confirmed through interview with project staff. /^{31/} The ESAP report 2024 and ESAP report Q1 2025/^{31/} were also cross checked by assessment team to confirm this. The project aligns with the labour convention and labour rights of Madagascar, which is a member of the International Labour Organisation (ILO). No human traffic, no forced labour (all employees declared) and no children are employed by the project.
Human trafficking	The PP strictly follows the national laws prohibiting human trafficking, forced labour and child labour. There have been no reports of human trafficking, forced labour and child labour during this monitoring period as observed during the remote audit and confirmed through interview with project staff. /^{31/} The ESAP report 2024 and ESAP report Q1 2025/^{31/} were also cross checked by assessment team to confirm this. The project aligns with the labour convention and labour rights of Madagascar, which is a member of the International Labour Organisation (ILO). No human traffic, no forced labour (all employees declared) and no children are employed by the project.

4.2.7.2 Human Rights

Risks identified	Evidence gathering activities, evidence checked, and assessment conclusion
No Risks identified	Project Proponent is following the International human rights law ²⁶ , and ILO Convention 169 ²⁷ .

²⁶ <https://www.ohchr.org/sites/default/files/Documents/Publications/fs9Rev.2.pdf>

²⁷ https://normlex.ilo.org/dyn/normlex/en/f?p=NORMLEXPUB:12100:0::NO::P12100_ILO_CODE:C169

The project is operated in Madagascar, which is an ILO member state since 01/11/1960, and which ratified the following conventions²⁸:

- C029 - Forced Labour Convention, 1930 (No. 29) P029 - Protocol of 2014 to the Forced Labour Convention, 1930 ratified on 06 Nov 2017 (In Force) since 01 Nov 1960
- C087 - Freedom of Association and Protection of the Right to Organise Convention, 1948 (No. 87) since 01 Nov 1960
- C098 - Right to Organise and Collective Bargaining Convention, 1949 (No. 98) since 03 Jun 1998
- C100 - Equal Remuneration Convention, 1951 (No. 100) since 10 Aug 1962
- C105 - Abolition of Forced Labour Convention, 1957 (No. 105), since 06 Jun 2007
- C111 - Discrimination (Employment and Occupation) Convention, 1958 (No. 111), since 11 Aug 1961
- C138 - Minimum Age Convention, 1973 (No. 138) Minimum age specified: 14 years, since since 31 May 2000
- C182 - Worst Forms of Child Labour Convention, 1999 (No. 182), since 04 Oct 2001

There are no human rights violation of any kind to any of the stakeholders during construction and operation of the project activity.

The project complies with all regulation and laws on human rights. The land on which the project was developed was previously owned by the state and later on leased/acquired by the PP. Thus, the main social impact is only job creation by the project, which is being mitigated by PPs by creating employment.

The project is a solar project activity which is implemented without cultural or social biases, safeguarding the rights of IPs, LCs, and customary rights holders to be free from discrimination. The same was confirmed through remote audit with the PPs, project staff and local stakeholders and also checked by declaration by the PP in the monitoring report/^{6/} and verifying the company HR policies/^{40/}.

Although no specific risk on human rights was identified in regard to the project, the AXIAN group does include a human right training policy.

²⁸ https://normlex.ilo.org/dyn/normlex/en/f?p=1000:11200:0::NO:11200:P11200_COUNTRY_ID:102955

4.2.7.3 Indigenous Peoples and Cultural Heritage

Risks identified	Evidence gathering activities, evidence checked, and assessment conclusion
No Risks identified	The project activity is implemented on the land which belonged to the state and use was forbidden. As per ESIA/^{21//22/}, no indigenous people were identified. Also, no impact on cultural heritage was identified during the operational phase. Hence, no tangible or intangible cultural heritage in the project implementation area has been hampered for the project activity, as confirmed by the assessment team from the local stakeholders interviewed during the remote audit/^{31/}. There is no indigenous and cultural heritage near the project. Verification team further cross checked the same by checking ESIA report/^{21//22/} and verified through on-site photographs and plant videos/^{18//19/} shared by the PP and concludes that there are no indigenous people identified as living on the land and the cultural heritage on the project site is also nil.

4.2.7.4 Property Rights

Risks identified	Evidence gathering activities, evidence checked, and assessment conclusion
No Risks identified	As verified by the assessment team from the ESIA report/^{21//22/} and from the local stakeholders during the remote interviews/^{19/}, there are no agreement signed on property rights, as prior to the project implementation, the land belonged to the state and use was forbidden. No conflict emerged during this monitoring period. Thus, not applicable. Prior to project implementation, the land belonged to the state and use was forbidden. No agreement has been signed on property rights. There were no pending property rights conflicts and disputes as confirmed by the local stakeholders in the interviews during the current monitoring period.

4.2.7.5 Benefit Sharing

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Summary of the benefit sharing plan	Since the benefits of the carbon credit lies with the project proponent and there is no benefit sharing plan. No agreement has been signed in the past, nor is currently in use since the start of construction and operation of the project phase 2. Hence, this section not applicable.
Benefit sharing during the monitoring period	Since PP is the sole owner of the revenue generated from the project activity and no agreement was affected during the monitoring period, there is no benefit sharing plan. Hence, this section not applicable.

4.2.8 Ecosystem Health

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Impacts on biodiversity and ecosystems	According to the Environmental and Social Impact Assessment (ESIA)^{/21//22/}, the habitats on the project site are of little interest in terms of biodiversity. As a consequence, biodiversity loss is identified as a negligible risk, whether for construction phase (increased human activity, noise, etc.) or operational phase (physical barrier). Hence, as there were no risks identified, mitigation measures are not applicable or necessary. It is worth noting that, during the remote audit^{/31/} it was confirmed with PP representatives and project staff that, there are no risks to the biodiversity and the ecosystem around the project site.
Soil degradation and soil erosion	A risk related to soil degradation regarding geology and soils during the decommissioning phase is mentioned by PP in the monitoring report^{/6/}, i.e. possible impact of potential land contamination in case of waste storage not managed properly or accidental events. However, no such risk was identified for the operational phase. During the remote audit, PP representatives ensured that they would take due care to minimize such impact by ensuring proper waste storage and avoiding accidental events. Verification Team concludes that the risk identified for decommissioning phase is considered to be low, as it is a short-term activity and there are no such risks noticed for operational phase. The same was confirmed through remote interviews with PP representatives and local stakeholders.^{/19/}

Water consumption and stress

Few risks and their respective mitigation measures have been identified by the PP in the monitoring report^{/6/}:

- Impact of minor significance identified regarding the potential decreased amount of groundwater during construction phase.

- The construction phase being a short-term activity, this impact is considered as negligible and of minor significance. Hence, no mitigation measures required.

- Water is consumed during monitoring periods as part of the periodical cleaning of the solar panels. Water is sourced from a well which is on site (inside the premises of the project site, next to the offices as seen during the previous OSV) which is then loaded on a truck and used for cleaning. The high-pressure device for water cleaning is powered by a small petrol generator unit.

- During the remote audit, assessment team confirmed that for the periodical solar panels cleaning, water is consumed during operational phase. The source of water is the water well located within the project site premises, which is then loaded on a truck which used diesel as fuel and used for cleaning. The high-pressure device for water cleaning is powered by a small petrol generator unit. The quantity of water used for cleaning the panels is considered as very low by ESIA.^{/21//22/}

Assessment team noted that, the project emissions due to the fuel usage for auxiliary purposes are negligible as per the methodology requirements. Moreover, the Project proponent is collecting data as KPI^{/39/} since 2023 for good practices and limitation of volumes consumed (including water, waste and fuel consumption).

Verification Team confirmed that the mitigation measures proposed for the risks identified during operational phase were found to be appropriate. During remote audit, PP representatives were asked about the above-mentioned risks and respective mitigation measures for minimization, and they confirmed that the proposed measures have been implemented.

Water consumption will be of moderate level and hence stress is not likely to be caused.

4.2.8.1 Rare, Threatened, and Endangered species

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Species or habitat	As per ESIA, the Project area is composed of modified habitats with no particular interest for biodiversity. The PV power plant site has been heavily modified for large scale farming by previous operators and there is no flora or fauna in the Project area known to have a specific conservation status. There are no negative impacts on rare, threatened, or endangered species found. This was confirmed during remote audit by the assessment team.^{/31/}
Areas needed for habitat connectivity	As per ESIA reports, no risk to adversely impact areas needed for habitat connectivity were reported. Therefore, assessment team confirms that there is no impact on areas needed for habitat connectivity due to project activity. The project has not adversely impacted areas needed for habitat connectivity during the monitoring period.

	Evidence gathering activities, evidence checked, and assessment conclusion
Habitats for rare, threatened, and endangered species	According to the Environmental and Social Impact Assessment (ESIA) ^{/31//31/}, the habitats on the project site are of little interest in terms of biodiversity. There is no impact on Habitats for rare, threatened, and endangered species. The project has not adversely impacted areas needed for habitat connectivity during the monitoring period.
Areas for habitat connectivity	As per ESIA reports^{/31//31/}, no risk to adversely impact areas needed for habitat connectivity were reported. There is no impact on areas needed for habitat connectivity. The project has not adversely impacted areas needed for habitat connectivity during the monitoring period.

4.2.8.2 Introduction of Species

Species introduced	Evidence gathering activities, evidence checked, and assessment conclusion
Not applicable, as no species introduced.	This section is not applicable since no new species have been introduced in the project implementation area as verified by the assessment team during the remote audit interviews with PP representatives.

Existing invasive species	Evidence gathering activities, evidence checked, and assessment conclusion
Not Applicable, as no invasive species exists.	This section is not applicable since there are no existing invasive species in the project implementation area as verified by the assessment team during the remote audit interviews with PP representatives.

Evidence gathering activities, evidence checked, and assessment conclusion	
Invasive species	This section is not applicable since there are no invasive species in the project implementation area as verified by the assessment team during the remote audit interviews with PP representatives.

4.2.8.3 Ecosystem conversion

Item	Evidence gathering activities and evidence checked
Ecosystem conversion	The project activity is not ARR, ALM, WRC or ACoGS project. Hence it is not applicable.

4.3 Accuracy of Reduction and Removal Calculations

Means of verification	The verification team assessed whether the data and calculations of GHG emission reductions achieved resulting from the revised VCS PD-MR ^{6/} . The verification team has checked whether calculations of baseline GHG emissions, project GHG emissions and leakage GHG emissions have been carried out in accordance with the formulae and methods described in the monitoring plan of the revised VCS PD-MR ^{6/} .
Findings	CL01, CAR02, CAR03, CAR 04, CAR 05 were raised during the verification process and closed successfully. Please refer Appendix 3 of this report for the detailed closure of the findings.
Conclusion	Baseline Emissions: The baseline emissions include only CO₂ emissions from electricity generation in fossil fuel power plants that are displaced due to the project activity. The baseline emissions for a given year are calculated by multiplying the Net Electricity Generation value with the grid emission factor. The grid in this case would be the 'RI-TANA Grid' Formula Used: - $BE_y = EG_{PJ,y} \times EF_{grid,CM,y} \dots \dots \dots (Equation 1)$ Where; BE_y= Baseline Emissions in year y (tCO₂e/year) EG_{PJ,y}= EG_{PJ,facility,y} = Quantity of net electricity generation that is produced

and fed into the grid as a result of the implementation of the project activity in year y (MWh/year)

$EF_{grid,CM,y}$ = Combined margin CO₂ emission factor for grid connected power generation in year y calculated using the Tool-7 “Tool to calculate the emission factor for an electricity system” (tCO₂/MWh)^{17/}

Ex-ante parameters:

As per the registered and revised VCS PD-MR/^{4/} & CDM PDD/^{4/} and requirement of the applied methodology/^{17/}, the following parameters are fixed Ex-ante:

Ex-Ante Parameter	Value	Source	Assessment
$EF_{grid,CM,y}$ Combined margin CO ₂ emission factor for grid connected power generation in year y calculated using the latest version of the “Tool to calculate the emission factor for an electricity system”	0.6703 tCO ₂ /MWh	JIRAMA 2015-2017 data/ ^{50/}	The baseline emission factors are taken ex-ante in line with the registered and revised VCS PD-MR/ ^{4/} as well as cross checked with section 4.1 of the validation-verification report/ ^{4/} and found correct. Combined margin CO ₂ emission factor ($EF_{grid,CM,y}$) is equal to 0.6703 tCO ₂ /MWh. The emission factor is fixed for the whole crediting period (10 years, fixed). The value is consistent with registered CDM PDD and VCS PD-MR/ ^{4/} and fixed ex-ante for the project activity.
$EF_{grid,OM,y}$ Operating Margin CO ₂ emission factor for grid connected power generation in year y	0.668 tCO ₂ /MWh	JIRAMA 2015-2017 data/ ^{50/}	The parameter is used for the ex-ante calculation of the emission factor for the project activity. The emission factor is fixed for the whole crediting period (10 years, fixed). The Operating margin CO ₂ emission factor

	calculated using the latest version of the “Tool to calculate the emission factor for an electricity system”			($EF_{grid,OM,y}$) is equal to 0.668 tCO ₂ /MWh. The value is consistent with registered CDM PDD and VCS PD-MR/4/ and fixed ex-ante for the project activity.
	$EF_{grid,BM,y}$ Build Margin CO ₂ emission factor for grid connected power generation in year y calculated using the latest version of the “Tool to calculate the emission factor for an electricity system”	0.677 tCO ₂ /MWh	JIRAMA 2015-2017 data/ ^{50/}	The parameter is used for the ex-ante calculation of the emission factor for the project activity. The emission factor is fixed for the whole crediting period (10 years, fixed). The Build margin CO ₂ emission factor ($EF_{grid,OM,y}$) is equal to 0.677 tCO ₂ /MWh. The value is consistent with registered CDM PDD and VCS PD-MR/4/ and fixed ex-ante for the project activity.
	The percentage share of total installed capacity of solar PV	0.1 %	Africa-EU Renewable Energy Cooperation Programme webpage	The parameter was used for additionality demonstration at ex-ante stage. The value is consistent with registered CDM PDD and VCS PD-MR/4/ and fixed ex-ante for the project activity.
	The total installed capacity of solar PV	0.53 MW	Electricity Regulation Office statistics (ORE, 2016)	The parameter was used for Additionality demonstration at ex-ante stage. The value is consistent with registered CDM PDD and VCS PD-MR/4/ and fixed ex-ante for the project activity.

The values are consistent with the registered CDM PDD/^{4/} and defined ex-ante for fixed crediting period of the project activity. The fixed ex-ante data and parameter have been listed in the monitoring report and confirmed by the verification team as correct and consistent with that stated in the registered CDM PDD/^{4/}. The verification team confirms that the MR/^{6/} and the ER calculation spreadsheet/^{7/} have considered the parameters fixed ex-ante correctly.

Ex-post parameter:

As per the registered monitoring plan and requirement of the registered methodology, the following parameter needs to be monitored:

EG_{facility,y} - Quantity of net electricity supplied by the project plant/unit to the grid in year y in MWh.

The value of the net electricity generation supplied to the grid is directly sourced from the monthly electricity generation records (monthly production statements)/^{11/}. Electricity outputs are recorded, stored and invoiced monthly to JIRAMA by NEA Ambatolampy, based on main meter (or check meter in case of main meter unavailability or default). The electricity generation supplied by the project activity is measured by the dedicated Bi-directional electronic electricity meters/^{7/} (a pair of main, check and Internal Control each for both the phase I and phase II) installed at the JIRAMA substation (metering point). These details were confirmed by the verification team during the remote audit/^{7/} and by checking the plant layout/^{26/}.

The details of electricity meters are follows:

3 meters are installed for each phase (1 main, 1 check and 1 Internal Control)/^{7/}, measuring the net electrical energy delivered to RI-Tana grid and located before 20/63kV transformer at JIRAMA substation. They also measure the consumption of the plant, including BESS charging from the grid. The 7th meter, measuring office consumption, including lights, cameras, etc. (labelled as ‘invoiced imports’ on the ER sheet), is located at the JIRAMA VIE base, next to the offices. They feature the following specifications:

For Initial Phase (Phase I):

Meter Type	Main Meter	Check Meter	Internal Control ²⁹
Meter ownership:	NEA Ambatolampy	JIRAMA	NEA Ambatolampy
Make	Landis+Gyr	ZTE	Phoenix contact

²⁹ These 'internal control' meters are not part of the PPA, they are for indicative purpose : they serve as internal control meters for NEA Ambatolampy.

	Model	E650 ³⁰	DTSD178-M ³¹	EEM-MA600 ³²
	Serial No	3507387521272	012000005221	17512310044_T
	Accuracy class	0.2S (±0.2%)	0.5S (±0.5%)	0.2S (±0.2%)
	Date of Calibration	n/a ³³	02-August-2021	n/a ³⁴
	For Extension Phase (Phase II):			
	Meter Type	Main Meter	Check Meter	Internal Control ³⁵
	Meter ownership:	NEA Ambatolampy	JIRAMA	NEA Ambatolampy
	Make	Landis+Gyr	ZTE	Phoenix contact
	Model	E650 ³⁶	DTSD178-M ³⁷	EEM- MA770 ³⁸
	Serial No	3507576049226	012000005522	1127052
	Accuracy class	0.2S (±0.2%)	0.5S (±0.5%)	0.2S (±0.2%)
	Date of Calibration	n/a ³⁹	17-August-2022	n/a ⁴⁰

³⁰ <https://www.landisgyr.eu/product/landisgyr-e650/>

³¹ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nul.html#3

³² <https://www.phoenixcontact.com/fr-fr/produits/appareil-de-mesure-eem-ma600-2901366>

³³ “As per manufacturer’s manual, meters are calibrated at the factory and do not require any further calibration during their entire service life.” Ambatolampy 20MW solar PV, PDD section B.7.1

³⁴ Since these meters are for indicative purpose, and are not included in the PPA nor involved in any facturing/ER calculation purpose, no specific calibration requirements are needed.

³⁵ These ‘internal control’ meters are not part of the PPA, they are for indicative purpose : they serve as internal control meters for NEA Ambatolampy.

³⁶ <https://www.landisgyr.eu/product/landisgyr-e650/>

³⁷ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nul.html#3

³⁸ <https://www.phoenixcontact.com/fr-fr/produits/appareil-de-mesure-eem-ma600-2901366>

³⁹ “As per manufacturer’s manual, meters are calibrated at the factory and do not require any further calibration during their entire service life.” Ambatolampy 20MW solar PV, PDD section B.7.1

⁴⁰ Since these meters are for indicative purpose, and are not included in the PPA nor involved in any facturing/ER calculation purpose, no specific calibration requirements are needed.

JIRAMA VIE base meter

JIRAMA VIE base meter:	
Meter Type	Main
Meter ownership:	JIRAMA
Make:	ZTE
Model:	DTSD178-M ⁴¹
Accuracy class:	0.5S ($\pm 0.5\%$)
Serial Number:	170164261685
Calibration date:	n/a

The export and import data are measured continuously by the electricity meters^{/3/}, recorded monthly in monthly production statements and the invoices^{/11/} are generated monthly. Monthly meter readings are taken from the electricity meters installed at metering point. The net electricity supplied to grid is calculated as the difference of the measured values of export and import of electricity.

The net electricity supplied to the grid by the project activity during the monitoring period (01-Janaury-2024 to 31-March-2025) is 70,206 MWh (33,820 MWh through initial phase and 36,386 MWh through extension phase).

It is to be noted that, information related to calibration requirements for the check and internal control meters is not available. PP confirmed that the calibration requirements and certificates of internal control and check meters are not available. Hence, as a conservative approach, in line with para. 366(a) of the CDM VVS for PAs, version 3.0/^{16/}, PP has applied a conservative error factor ($\pm 0.5\%$) to the net electricity generation value corresponding to the accuracy class of meters. This was appropriate and acceptable to the VVB team.

Thus, the electricity generation values after the application of conservative error factor have been used for the calculation of emission reductions^{/7/} during the current verification. These values are slightly higher for consumption and slightly lower for production, thus results in a conservative approach for Emission Reductions Calculation. Regarding Main Meter, the Verification Team has checked the manufacturer's manual, registered CDM PDD and VCS PD-MR/^{4/} and confirmed that the meters are calibrated at the factory and do not require any further calibration during their entire service life. Hence, no calibrations are required for main meter.

The manufacturer's specifications on the calibration requirements are not available for the check meter (previously called as backup meter as mentioned in project deviations). The state electricity regulator, JIRAMA is

⁴¹ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nul.html#3

	responsible for the calibration of the meters, but has not provided information on the frequency of the calibration. This was also confirmed during the remote audit. PP has justified that the calibration of check meter is not in the control of the PP. PP has thus applied the applicable error factor in accordance with the Table 1 of the Appendix of the CDM VVS for the project activities, version 3^{7/}. The same reasoning is applicable to the JIRAMA VIE base meter which monitors the office consumption. The 'Internal Control' meters are not part of the PPA, they are for indicative purpose only: they serve as internal control meters for NEA Ambatolampy. Since these meters are for indicative purpose and are not included in the PPA^{7/} nor involved in any facturing/ER calculation purpose, no specific calibration requirements are needed. The verification team has checked the net electricity generation supplied to the grid from the monthly "electricity generation records (monthly production statements)^{11/}" and cross verified with the invoices^{11/} raised by the Project Proponent (NEA Ambatolampy) to the Grid Company (JIRAMA) and found consistent. PP has used the conservative values i.e., minimum of net energy as after the application of error factor ($\pm 0.5\%$). All relevant monitoring parameters have been verified with regard to the appropriateness of the applied measurement/determination method, the correctness of the values applied for ER calculation, the accuracy, and applied QA/QC measures. Baseline emission factor ($EF_{grid,CM,y}$) for this project activity is fixed for the crediting period and calculated using JIRAMA 2015-2017^{50/} data and the CDM TOOL 07. ^{17/} BE_y baseline emissions, tCO₂e: $BE_y = EG_{PJ,y} \times EF_{grid,CM,y} \quad \text{..... Equation (1)}$ $= 70,206 \text{ MWh} \times 0.6703 \text{ tCO}_2\text{e/MWh}$ $= \mathbf{47,060 \text{ tCO}_2\text{e}} \text{ (rounded down figure)}$ The vintage wise calculation of emission reductions is provided in the below table:
--	--

	EG _{PJ,y}	EF _{grid,y}	BE _y
	MWh	(tCO ₂ /MWh)	(tCO _{2e})
From 01-January-2024 to 31-December-2024	56,577	0.6703	37,924
From 01-January-2025 to 31-March-2025	13,629	0.6703	9,136
Total	70,206	0.6703	47,060

Project Emissions:

There are project emissions from the extension phase and its associated Battery Energy Storage System (BESS). The emissions resulting from the use of electricity grid to charge it outside of daylight is considered thanks to the 'Consumption' data collection. This data includes, but is not limited to, electricity from the grid used during the night to charge the battery system. Using this data for PE_{BESS} calculations is therefore conservative.

As per the applicable methodology i.e. ACM0002, v22.0, para. 49, the formula used for the calculation of these project emissions are calculated according to the procedure described in CDM Tool05 v03.0:

$$PE_{EC,y} = \sum EC_{PJ,j,y} \times EF_{EF,j,y} \times (1 + TDL_{j,y}) \quad \text{.....Equation (2)}^{42}$$

Where:

$PE_{EC,y}$ = Project emissions from electricity consumption in year y (t CO₂ / yr)

$EC_{PJ,j,y}$ = Quantity of electricity consumed by the project electricity consumption source j in year y (MWh/yr)

$EF_{EF,j,y}$ = Emission factor for electricity generation for source j in year y (t CO₂/MWh)

$TDL_{j,y}$ = Average technical transmission and distribution losses for providing electricity to source j in year y

⁴² As per para 49 of applicable methodology ACM0002, V22.0 and as per the procedure described in TOOL05 under option A2 (a) of Paragraph 20, a conservative emission factor of 1.3 tCO₂/MWh is used. Also, a default value of 20% is chosen for data/parameter TDL_{j,y}.

		Vintage period	Project emissions (tCO ₂ e)
		From 01-January-2024 to 31-December-2024	17
		From 01-January-2025 to 31-March-2025	7
		Total	24

During this monitoring period 01-January-2024 to 31-March-2025, **24 tCO₂e** have been emitted as project emissions from that source and are therefore subtracted from the baseline emissions for final VCUs calculation. Detailed calculations are available on the Ex-post ER calculation spreadsheet^{/7/}.

Moreover, in line with para. 51 of ACM0002, version 22.0^{/17/}, assessment team by checking the ER sheet, confirmed that the charging using the grid has not amounted to more than 2 per cent of the electricity generated by the project renewable energy plant during the monitoring period.

Therefore,

$PE_y = PE_{BESS} = \mathbf{24\ tCO_2e}$. (rounded up figure)

Leakage:

As per applied methodology ACM0002, Version 22.0^{/17/}, CDM PDD and VCS PD-MR^{/4/} Leakage emissions are not considered for the project activity.

Hence, $ER_y = BE_y - PE_y$

$$ER_y = 47,060\ tCO_2e - 24\ tCO_2e$$

$$= \mathbf{47,036\ tCO_2e}$$
. (rounded down figure)

According to the applied methodology, the conservativeness of the achieved emission reduction was checked, and the detailed emission reduction calculation has been transparently provided in the ER sheet^{/7/}. All the formulae and the calculation procedure were checked by the verification team. In the opinion of verification team, the assumptions, emission factors and default values that were applied in the calculations have been justified. Also, the verification team confirms that there were no manual transposition errors between the data sets in the ER Sheet ^{/7/} during the current monitoring period. It is confirmed that the data has been measured directly from meters and it was cross checked from the monthly electricity generation records and the invoices^{/11/} raised and was able to verify the same.

Verification team confirms that the monitoring has been carried out in accordance with the monitoring plan, trainings and QA/QC procedure and emergency preparedness contained in the CDM PDD, registered and revised

	VCS PD-MR/ ^{4/} . Assessment team confirmed that the GHG emission reductions and removals have been quantified correctly in line with the registered and revised VCS PD-MR/ ^{4/} .
--	--

4.4 Quality of Evidence to Determine Reductions and Removals

Means of verification	The verification team checked the Calibration details of the monitoring meters with the calibration evidence ^{/5/} and whether the monitoring has been carried out in accordance with the applicable regulatory documents, <i>inter alia</i> , the applied methodology and registered monitoring plan. ^{/4//17/}																								
Findings	CLO1, CAR02, CAR03, CAR 04, CAR 05 were raised during the verification process and closed successfully. Please refer Appendix 3 of this report for the detailed closure of the findings.																								
Conclusion	The metering arrangement is dedicated bi-directional electronic energy meters of accuracy class 0.2s (main and Internal control) and 0.5s (check meter) at the JIRAMA substation. These meters record several parameters including electricity exported & imported. These electricity meters are being used by PP and national grid company for monthly generation reports ^{/11/} . The details of meters are as follow:																								
	For Initial Phase (Phase I):																								
	<table><tr><td>Meter Type</td><td>Main Meter</td><td>Check Meter</td><td>Internal Control⁴³</td></tr><tr><td>Meter ownership:</td><td>NEA Ambatolampy</td><td>JIRAMA</td><td>NEA Ambatolampy</td></tr><tr><td>Make</td><td>Landis+Gyr</td><td>ZTE</td><td>Phoenix contact</td></tr><tr><td>Model</td><td>E650⁴⁴</td><td>DTSD178-M⁴⁵</td><td>EEM-MA600⁴⁶</td></tr><tr><td>Serial No</td><td>3507387521272</td><td>012000005221</td><td>17512310044_T</td></tr><tr><td>Accuracy class</td><td>0.2S (±0.2%)</td><td>0.5S (±0.5%)</td><td>0.2S (±0.2%)</td></tr></table>	Meter Type	Main Meter	Check Meter	Internal Control ⁴³	Meter ownership:	NEA Ambatolampy	JIRAMA	NEA Ambatolampy	Make	Landis+Gyr	ZTE	Phoenix contact	Model	E650 ⁴⁴	DTSD178-M ⁴⁵	EEM-MA600 ⁴⁶	Serial No	3507387521272	012000005221	17512310044_T	Accuracy class	0.2S (±0.2%)	0.5S (±0.5%)	0.2S (±0.2%)
	Meter Type	Main Meter	Check Meter	Internal Control ⁴³																					
	Meter ownership:	NEA Ambatolampy	JIRAMA	NEA Ambatolampy																					
	Make	Landis+Gyr	ZTE	Phoenix contact																					
	Model	E650 ⁴⁴	DTSD178-M ⁴⁵	EEM-MA600 ⁴⁶																					
	Serial No	3507387521272	012000005221	17512310044_T																					
Accuracy class	0.2S (±0.2%)	0.5S (±0.5%)	0.2S (±0.2%)																						

⁴³ These 'internal control' meters are not part of the PPA, they are for indicative purpose : they serve as internal control meters for NEA Ambatolampy.

⁴⁴ <https://www.landisgyr.eu/product/landisgyr-e650/>

⁴⁵ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nu1.html#3

⁴⁶ <https://www.phoenixcontact.com/fr-fr/produits/appareil-de-mesure-eem-ma600-2901366>

	Date of Calibration	n/a ⁴⁷	02-August-2021	n/a ⁴⁸
	For Extension Phase (Phase II):			
	Meter Type	Main Meter	Check Meter	Internal Control ⁴⁹
	Meter ownership:	NEA Ambatolampy	JIRAMA	NEA Ambatolampy
	Make	Landis+Gyr	ZTE	Phoenix contact
	Model	E650 ⁵⁰	DTSD178-M ⁵¹	EEM-MA770 ⁵²
	Serial No	3507576049226	012000005522	1127052
	Accuracy class	0.2S	0.5S	0.2S
	Date of Calibration	n/a ⁵³	17-August-2022	n/a ⁵⁴
	JIRAMA VIE base meter			
JIRAMA VIE base meter:				
Meter Type		Main		
Meter ownership:		JIRAMA		
Make:		ZTE		

⁴⁷ “As per manufacturer’s manual, meters are calibrated at the factory and do not require any further calibration during their entire service life.” Ambatolampy 20MW solar PV, PDD section B.7.1

⁴⁸ Since these meters are for indicative purpose, and are not included in the PPA nor involved in any facturing/ER calculation purpose, no specific calibration requirements are needed.

⁴⁹ These ‘internal control’ meters are not part of the PPA, they are for indicative purpose : they serve as internal control meters for NEA Ambatolampy.

⁵⁰ <https://www.landisgyr.eu/product/landisgyr-e650/>

⁵¹ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nu1.html#3

⁵² <https://www.phoenixcontact.com/fr-fr/produits/appareil-de-mesure-eem-ma600-2901366>

⁵³ “As per manufacturer’s manual, meters are calibrated at the factory and do not require any further calibration during their entire service life.” Ambatolampy 20MW solar PV, PDD section B.7.1

⁵⁴ Since these meters are for indicative purpose, and are not included in the PPA nor involved in any facturing/ER calculation purpose, no specific calibration requirements are needed.

	Model:	DTSD178-M ⁵⁵
	Accuracy class:	0.5S ($\pm 0.5\%$)
	Serial Number:	170164261685
	Calibration date:	n/a
The main and internal control meters are of same accuracy class i.e., 0.2s and check meters are of accuracy class 0.5s as per the requirement of the registered PD-MR^{4/}. The same was checked during the remote audit and with photographs submitted by the PP^{18/} and were found to be correct. It is to be noted that, information related to calibration requirements for the check and internal control meters is not available. PP confirmed that the calibration requirements and certificates of internal control and check meters are not available. Regarding the Main Meters, the Verification Team has checked the manufacturer's manual, registered CDM PDD and VCS PD-MR^{7/} and confirmed that the meters are calibrated at the factory and do not require any further calibration during their entire service life. Hence, no calibrations are required for main meter. The manufacturer's specifications on the calibration requirements are not available for the check meter (previously called as backup meter as mentioned in project deviations). The state electricity regulator, JIRAMA is responsible for the calibration of the meters, but has not provided information on the frequency of the calibration. This was also confirmed during the remote audit. PP has justified that the calibration of check meter is not in the control of the PP. PP has thus applied the applicable error factor in accordance with the Table 1 of the Appendix of the CDM VVS for the project activities, version 3^{7/}. The same reasoning is applicable to the JIRAMA VIE base meter which measures the imports of office consumption. The 'Internal Control' meters are not part of the PPA, they are for indicative purpose only: they serve as internal control meters for NEA Ambatolampy. Since these meters are for indicative purpose and are not included in the PPA nor involved in any facturing/ER calculation purpose, no specific calibration requirements are needed.		

⁵⁵ https://en.dongfang-wisdom.com/html/ProductDetail_302-0-nul.html#3

Hence, as a result of unavailability of the calibration requirements and certificates for check and internal control meters, as a conservative approach, in line with para. 366(a) of the CDM VVS for PAs, version 3.0/^{16/}, PP has applied a conservative error factor ($\pm 0.5\%$) to the net electricity generation value corresponding to the accuracy class of check meters (0.5S). Although the accuracy class of main and internal control meters is 0.2s, $\pm 0.5\%$ error factor has been applied which is more conservative. This was found to be appropriate and acceptable to the VVB team.

Thus, the electricity generation values after the application of conservative error factor have been used for the calculation of emission reductions/^{7/} during the current verification. These values are slightly higher for consumption and slightly lower for production, thus results in a conservative approach for Emission Reductions Calculation.

The verification team has checked the net electricity generation supplied to the grid from the monthly “electricity generation records (monthly production statements)/^{11/}” and cross verified with the invoices/^{11/} raised by the Project Proponent (NEA Ambatolampy) to the Grid Company (JIRAMA) and found consistent. PP has used the conservative values i.e., minimum of net energy as after the application of error factor ($\pm 0.5\%$). All relevant monitoring parameters have been verified with regard to the appropriateness of the applied measurement/determination method, the correctness of the values applied for ER calculation, the accuracy, and applied QA/QC measures.

Project activity is in continuous operation. No major breakdowns except a few minor incidents were found to have occurred/^{13/} during the current monitoring period (please refer to Appendix-6 of this report for more details). Project proponent clarified that the breakdown incidents occurred during current MP did not affect the monitoring and measurement, so no conservative measure shall be applied to the ER calculations. Assessment team cross-checked the plant breakdowns sheet/^{13/} to confirm about this and noted that the breakdown incidents that occurred during the current MP did not have any effect on the monitoring and measurement. Overall, the plant was operating satisfactorily during the current MP. Hence, PP’s clarification was found to be appropriate and acceptable.

No unforced errors were observed. No sampling procedure applied for monitoring of the data parameter and entire documents were checked by the assessment team to arrive at positive verification conclusions. The monitoring plan is followed at the project site.

Emergency procedure preparedness is ensured at site thanks to the check and internal control meters. The immediate response capability is achieved through the implementation of a system of supervision and control that will transfer real-time all information about the state of the equipment (SCADA) connected to each transformer’s measuring unit as a back-up energy metering in case of feed-in points meters failure.

All relevant documents were checked to assess the correctness and quality of data submitted by the project proponent, which are used to determine emission reductions. All the records needed for monitoring are archived in line with the requirements of the registered monitoring plan. No significant lack of evidence and missing data were detected during remote audit discussion except the lack of calibration evidence for the electricity meters. Hence, the verification team confirms that the monitoring system ensures required quality of the monitoring system to ensure the quality of the monitored data. All internal data are subjected to QA/QC measures. The monitoring parameters have been measured / determined without material misstatements and is in line with all applicable standards and relevant requirements. The information inflow (from data generation, aggregation, to recording, calculation and reporting) is included in section 4 under each parameter and confirms to the requirement of the PD-MR/^{4/}. The export and import data are measured by the electricity meters, recorded continuously through electronic means and the invoices are generated monthly. The data is then reported annually on the VCS Monitoring Report as verified by the verification team through remote assessment. /^{7/}

It was also verified through remote inspection/^{19/} that the plant's team involved in the monitoring of project activity is well experienced. Hence, the verification team concludes that competent staff is employed by the project proponent to carry out the relevant tasks with sufficient accuracy.

Furthermore, it was confirmed during remote audit discussion that internal training program for the monitoring staff is conducted on regular basis.

The VVB confirms that the monitoring has been carried out in accordance with the applicable regulatory documents, *inter alia*, the applied methodology and that there are no material discrepancies between the project implementation and the project description, the implementation of the monitoring plan, its completeness and adequacy to the methodology.

If any discrepancies have been found, these are reported, assessed and closed accordingly in the form of CLs or CARs (see Appendix 3), as well as if any project/methodology deviation is sought for this monitoring period, can be found in Section 3 of this Verification Report.

As a result of verification of the Emission Reductions calculation process, the VVB confirms that all the parameters required for their determination have been included in the Monitoring Report/^{6/} and ER Calculation sheet/^{7/} for which this verification applies.

After verifying the data sources, data collection and aggregation processes and final calculations and reported figures, it is confirmed that the values of the parameters from the data sources are consistent with those finally reported in the Monitoring Report and ER Calculation sheet. /^{6/}/^{7/} The verification process for the same and the quality of used evidence have been clearly described above in Section 4 of this Verification Report.

	The verification team can confirm that sufficient evidence is available for the whole monitoring period and the same is verifiable and that the data collection system meets the requirements of the monitoring plan and the applied methodology according to the assessment carried out during the remote audit and in the document review.
--	---

4.5 Non-Permanence Risk Analysis

Not applicable as this is a renewable project type.

5 VERIFICATION OPINION

5.1 Verification Summary

LGA Technological Center S.A. (Applus+ Certification) has been contracted^{/2/} by AERA Group on behalf of New Energy Africa, Ambatolampy (NEA Ambatolampy) to perform the fourth periodic verification of GHG Emission Reductions for the project activity “Ambatolampy Solar PV” (VCS project ID #2307)^{/27/}.

The monitoring period included in the Monitoring Report^{/6/} for which this verification applies is: 01-January-2024 to 31-March-2025 (both days included).

The management of NEA Ambatolampy is responsible for the preparation of the GHG emissions data and the reported GHG emissions reductions on the basis set out within the project’s Monitoring Plan in the registered VCS PD-MR version 1.2, dated on 15-July-2020^{/4/}, revised VCS PD-MR, version 2.2 dated 24-January-2025^{/6/}, registered CDM PDD, Version 1.4 dated 05-July-2019^{/4/} and the approved methodology, ACM0002 Version 22.0.^{/17/}

VVB confirms that, GHG statement is the responsibility of the project proponent. The project activity fulfills the criteria for the verification as established in section 4 of the VCS standard version 4.7^{/10/}. Verification team has reviewed the monitoring report including registered and revised VCS PD-MR and subsequently carried out the remote audit/ follow-up interviews with PP representatives and confirm the fulfilment of stated criteria. Verification team has the unmodified opinion regarding the project activity, VVB team has checked all the details and found it consistent and free of material errors or misstatements.

Applus+ Certification’s verification approach has been based on the requirements of the applicable regulatory documents (defined within this Verification Report and listed in the Appendix 2). Our approach is risk-based, drawing on an understanding of the risks associated with reporting GHG emissions data and the controls in place to mitigate these.

The verification can confirm that:

- The project is implemented and operated as per the registered CDM PDD and registered & revised PD-MR^{/4/};
- The monitoring plan in registered CDM PDD and VCS PD-MR^{/4/} is as per the applied methodology^{/17/};
- The monitoring complies with the monitoring plan in the registered CDM PDD and VCS PD-MR^{/4/};
- The monitoring report and other supportive documents provided are complete and verifiable and in accordance with the applicable VCS requirements and any other applied regulatory document;
- The installed equipment being essential for generating emission reductions runs reliably and is calibrated appropriately (where applicable);

- The monitoring system is in place and generates GHG emission reductions data;
- The GHG emission reductions are calculated without material misstatements.

A Reasonable Level of assurance was achieved as planned, during verification process.

As per VCS Standard version 4.7 Para 4.1.10^{4/}, VVB team verified that, the criteria for verification of the project activity are in line with the relevant VCS Version 4 criteria. The objective of this verification activity is to have an independent third party for the assessment of the Monitoring report, emission reduction sheet and to ensure a thorough assessment of the project activity against the applicable regulatory requirements.

VVB concluded the assessment, as per para 4.1.18 of the VCS standard version 4.7 ^{10/}, with a positive verification opinion regarding the project activity. The VVB team has raised 04 Clarification (CLs), 05 Corrective action requests (CARs), and no FAR (forward action request). All the issues identified as CARs and/or CLs have been successfully closed and mentioned in Appendix 3 of this verification report. The VVB team clearly state that there is no material misstatement at the level of the GHG statement and GHG declarations made by the Project Proponent. VVB declared that the validation and/or verification of the GHG statement was conducted in accordance with ISO 14064-3:2019.

5.2 Verification Conclusion

Our verification approach was based on the requirements as defined under the applicable VCS regulatory requirements^{10/}. The verification has been conducted in accordance with the VCS standard version 4.7^{10/}, other valid and applicable VCS regulatory documents and templates ^{10/}(see under appendix 2 of this report), UNFCCC rules and requirements^{17/} (where applicable) and associated decisions of the VCS secretariat and the UNFCCC Executive Board (where applicable) and VCS requirement. Our approach is risk-based, drawing on an understanding of the risks associated with reporting GHG emissions data and the controls in place to mitigate these. Further, the verification has been planned and organized to achieve a Reasonable Level of assurance as per the requirement of paragraph 4.1.10(1) of the VCS standard V4.7^{10/}. No sampling procedure applied for document verifications. The entire documents checked/Power plant verification conducted to arrive at positive verification conclusions.

The verification team can confirm that:

- the project is implemented and operated as planned and described in the project description;
- the monitoring plan is as per the applied methodology^{17/};
- the monitoring process in Monitoring Report is as per the CDM PDD and VCS PD-MR;^{4//6/}
- the development and maintenance of records and reporting procedures are in accordance with the monitoring plan;
- the installed equipment being essential for generating emission reduction runs reliably and but could not produce the calibration evidence. Therefore, conservative error factor is applied in line with para. 366(a) of the CDM VVS for PAs, version 3.0^{16/};

- the monitoring system is in place and generates GHG emission reductions data;
- the GHG emission reductions are calculated without material misstatements.
- A Reasonable Level of assurance was achieved as planned, during verification process.

Verification period: From [01-January-2024] to [31-March-2025]

Verified GHG emission reductions and carbon dioxide removals in the above verification period:

Vintage period	Baseline emissions (tCO ₂ e)	Project emissions (tCO ₂ e)	Leakage emissions (tCO ₂ e)	Reduction VCUs (tCO ₂ e)	Removal VCUs (tCO ₂ e)	Total VCUs (tCO ₂ e)
01-Jan-2024 to 31-Dec-2024	37,924	17	0	37,907	0	37,907
01-Jan-2025 to 31-Mar-2025	9,136	7	0	9,129	0	9,129
Total	47,060	24	0	47,036	0	47,036

5.3 Ex-ante vs Ex-post ERR Comparison

Vintage period	Ex-ante estimated reductions/removals	Achieved reductions/removals	Percent difference	Explanation for the difference
01-Jan-2024 to 31-Dec-2024	45,478	37,907	-16.6%	The actual emission reduction achieved during this vintage is 16.6% lower than the estimated emission reductions in revised VCS PD-MR/ ⁶ / for corresponding vintage period. This is because of Multiple defaults of inverters as well as a default of a protection cell on the initial phase, which had an impact on production. This unavailability is detailed in section 3.1 of the monitoring

				report/ ^{6/} and Appendix-6 of this verification report.
01-Jan-2025 to 31-Mar- 2025	11,153	9,129	-18.2%	The actual emission reduction achieved during this vintage is 18.2% lower than the estimated emission reductions in revised VCS PD-MR/ ^{6/} for corresponding vintage period. This is because, Multiple defaults of inverters, which had an impact on production. This unavailability is detailed in section 3.1 of the monitoring report/ ^{6/} and Appendix-6 of this verification report.
Total	56,631	47,036	-16.9%	The actual emission reduction achieved during this vintage is 16.9% lower than the estimated emission reductions in revised VCS PD-MR/ ^{6/} for corresponding vintage period. This is because of multiple defaults of inverters and protection cells, which had an impact on production. This unavailability is detailed in section 3.1 of the monitoring report/ ^{6/} and Appendix-6 of this verification report.

APPENDIX 1: COMMERCIALLY SENSITIVE INFORMATION

<i>Section</i>	<i>Information</i>	<i>Justification</i>	<i>Assessment method and conclusion</i>
N/A	N/A	N/A	Not applicable as there is no commercial sensitive information available

APPENDIX 2: DOCUMENTS REVIEWED OR REFERENCED (VERIFICATION)

No.	Author	Title	References to the document	Provider
/1/	JIRAMA	Commissioning date supportive documents (Commercial Operation date issued by JIRAMA meters installation certificate dated 10-July-2018 for the initial phase (Phase I) and For extension phase (Phase II), proof of commissioning of meters reset document issued by JIRAMA, dated 17-August-2022)	10-July-2018, 17-August-2022	Project Proponent
/2/	VVB	Contract of the project Proponent with the VVB	Contract document signed between PP and VVB, Version 1.0, dated 25-April-2025	Project Proponent
/3/	Various Manufacturers	Technical Specifications for the PV plant components (Solar Modules, Inverters, Transformers, BESS, etc) as well as metering equipment	Manufacturer technical specifications	Project Proponent
/4/	Project Proponent & VVBs	Registered VCS Joint PD-MR (<u>VCS-Joint-Project-Description-Monitoring-Report-AMBATOLAMPY_011020.pdf</u>) VCS Joint Validation-Verification Report (<u>DVR_20.21.pdf</u>) Registered CDM PDD (<u>project design document</u>) CDM Validation Report (<u>Validation report</u>) VCS Monitoring Report for 2 nd Verification (<u>2210 - MR - VCS - AMBATO-v15-clean.pdf</u>)	Version 1.2, dated 15-July-2020 Version 01, dated 30-September-2020 Version 1.4, dated 05-July-2019 Version 1.4, dated 05-July-2019 Version 1.5, dated 24-August-2022	Others

No.	Author	Title	References to the document	Provider
		VCS Verification Report for 2 nd Verification (CC IPL1194 VR 260822. clean.pdf)	Version 03, dated 26-August-2022	
		Revised VCS Joint PD-MR (PDD - AMBATO - VCS Joint PD-MR updated Clean.pdf)	Version 2.2, dated 24-January-2025	
		VCS Monitoring Report for 3 rd Verification (VCS MR 2307 01012022-31122023 Clean.pdf)	Version 1.5, dated 24-January-2025	
		VCS Verification Report for 3 rd Verification (VCS VerR 2307 01012022-31122023 Clean.pdf)	Version 1.3, dated 27-January-2025	
/5/	JIRAMA	Meter installation and meter reset documents	-	Project Proponent
/6/	Project Proponent	Monitoring Report version 1.0 (Initial)	02-May-2025	Project Proponent
		Monitoring Report version 1.3 (Final)	23-September-2025	
/7/	Project Proponent	Ex-Post Emission Reduction sheet version 01	24-February-2025	Project Proponent
		Ex-Post Emission Reduction Sheet version 04	23-September-2025	
/8/	Project Proponent	Organization structure of the NEA Ambatolampy	-	Project Proponent
/9/	Project Proponent/ JIRAMA	Initial Power Purchase Agreement (PPA) Between GreenYellow Madagascar and JIRAMA	Signed on 30-November -2016	Project Proponent
		PPA Amendment No. 1 between GreenYellow Madagascar and JIRAMA	Signed on 24-May-2017	
		PPA Amendment No. 2 between GreenYellow Madagascar and JIRAMA	Signed on 17-July-2020	
		PPA Amendment No. 3 between NEA Ambatolampy and JIRAMA	Signed on 17-February-2023	
/10/	VERRA	Standard documents used in the project activity • VCS Standard, v4.7	VCS web site (https://verra.org/programs/verified-carbon-	VERRA

No.	Author	Title	References to the document	Provider
		- VCS Program Guide, v4.4 - VCS Program Definitions, v4.5 - Registration and Issuance Process, v4.6 - Validation and Verification Manual, v3.2 - VCS Monitoring Report Template, v4.4 - VCS Verification Report Template, v4.4	standard/vcs-program-details/	
/11/	Project Proponent/ JIRAMA	1) Monthly Generation Records (Monthly Production Statements) & respective invoices for the monitoring period 01-January-2024 to 31-March-2025 sent by PP to JIRAMA 2) Consumption/Import invoices sent by JIRAMA to PP for the monitoring period from 01-January-2024 to 31-March-2025	For the monitoring period 01-January-2024 to 31-March-2025	Project Proponent
/12/	Project Proponent	Self-Declaration regarding no double counting or participation in other GHG program or emissions trading program or any other mechanism that includes GHG allowance trading for the concerned monitoring period	07-April-2025	Project Proponent
/13/	Project Proponent	Breakdown details for the monitoring period	Incidents logbook - relevé des incidents 2024 Incidents logbook - relevé des incidents 2025	Project Proponent
/14/	Project Proponent	Employment evidence for plant persons and Training Certificates for the trainings conducted Staff changes - Changement de personnel ESAP REPORT Q1 2025_ NEA Ambatolampy (part 1) – signed	For the monitoring period from 01-January-2024 to 31-March-2025	Project Proponent

No.	Author	Title	References to the document	Provider
		ESAP REPORT_2024_ NEA Ambatolampy signed		
		Training matrix NEA Ambatolampy 2025		
/15/	Project Proponent	Grievance Registers maintained at site	For the monitoring period 01-January-2024 to 31-March-2025	Project Proponent
/16/	UNFCCC	CDM validation and verification standard for project activities, Version 03.0	https://cdm.unfccc.int/sunsetcms/storage/contents/stored-file-20210921115831128/reg_stan06_v03.0.pdf	Others
/17/	UNFCCC	Applied Methodology, ACM0002 Grid-connected electricity generation from renewable sources --- Version 22	Version 22.0 (https://cdm.unfccc.int/UserManagement/FileStorage/R0IJ1X9LQ7W2GOYHSMBFCPE3VKZ685)	Others
		TOOL23: Additionality of first-of-its-kind project activities, Version 03.0	Version 03.0 (https://cdm.unfccc.int/methodologies/PAmethodologies/tools/am-tool-23-v1.pdf)	
		Tool 07: Tool to calculate the emission factor for an electricity system (Version 07.0)	Version 07.0 (https://cdm.unfccc.int/methodologies/PAmethodologies/tools/am-tool-07-v7.0.pdf)	
/18/	NA	Onsite photographs of PV plant components /Videos /Meters photographs, etc	-	Project Proponent
/19/	VVB	Remote audit records	Dated 16-July-2025	VVB
/20/	UNFCCC	Guidelines for Application of materiality in verifications (version 02.0)	Version 02.0	UNFCCC

No.	Author	Title	References to the document	Provider
/21/	ERM	Simplified Environmental and Social Impact Assessment (ESIA) for a Solar Power Plant - Madagascar	September 2016	Project Proponent
/22/	Biotope Madagasikara	Programme d'engagement environnemental (PREE) GREENYELLOW MADAGASCAR (Environmental Commitment Program GREENYELLOW MADAGASCAR)	27-May-2021	Project Proponent
/23/	Project Proponent	Company Name Change document "Minutes of extraordinary general meeting of January 9, 2023"	09-January-2023	Project Proponent
/24/	Project Proponent	Execution File - Extension of 20MWc-5MW/5MWh of Ambatolampy Madagascar Photovoltaic Power Plant	-	Project Proponent
/25/	Ministry of Energy and Hydrocarbons	Environmental Authorization Letter for phase II	Dated:05-May-2021	Project Proponent
/26/	Project Proponent	Plant Single Line Diagrams & Layout	-	Project Proponent
/27/	VERRA	VCS webpage for the project, VCS ID 2307 https://registry.terra.org/app/projectDetail/VCS/2307	Last retrieved data on 24-September-2025	Others
/28/	UNFCCC	Official registry website of Clean Development Mechanism https://cdm.unfccc.int/Projects/projsearch.html	Last retrieved data on 24-September-2025	Others
/29/	GS	Official registry website of Gold Standard https://www.goldstandard.org/	Last retrieved data on 24-September-2025	Others
/30/	GCC	Official registry website of Global Carbon Council https://www.globalcarboncouncil.com/	Last retrieved data on 24-September-2025	Others
/31/	Project Proponent	Supportive Evidence of CSR Activities: Report on CSR activities in rural commune of Ambohiphaonana for year 2022 Report on CSR activities in rural commune of Ambohiphaonana for year 2023	January 2023 November 2023	Project Proponent

No.	Author	Title	References to the document	Provider
		ESAP REPORT Q1 2025_ NEA Ambatolampy (part 1) – signed ESAP REPORT_2024_ NEA Ambatolampy signed	14-April-2025 January 2025	
/32/	Project Proponent	Organization Chart for Ambatolampy Solar PV Plant	-	Project Proponent
/33/	IAF	<u>IAF MD4:2025 Document</u>	-	Others
/34/	UNFCCC	CDM webpage for the project, CDM ID 10481 <u>CDM: Ambatolampy 20 MW solar PV (unfccc.int)</u>	Last retrieved data on 24-September-2025	Others
/35/	SECRETARIA T GENERAL, BUREAU NATIONAL DE COORDINATION DES CHANGEMENTS CLIMATIQUES	Letter of Approval for the CDM Project "Ambatolampy 20 MW solar PV"	21-January-2019	Others
/36/	Office de Regulation de l'electricite (ORE), Madagascar (Electricity Regulatory Office, Madagascar)	Excel sheet of ELECTRICITY PRODUCTION PARK Situation December 2022	December 2022	Project Proponent
/37/	Project Proponent and SECURPRO	Supportive documents for grievance resolution of delayed salary payments to Security Staff a) Relevant grievance logbook entries related to the issue b) SECUR-PRO employee payslip	-	Project Proponent

No.	Author	Title	References to the document	Provider
		c) Screenshot of email correspondence detailing the established payroll calendar d) Email exchange on grievance resolution security team salaries e) Letter of Commitment signed March 2025 on the security workers salary payments issue		
/38/	Project Proponent	PVSyst Report for phase I (Initial phase) PVSyst Report for phase II (Extension phase)	07-November-2017 27-January-2021	Project Proponent
/39/	Axian Energy	HSSSES KPI'S-2024 AE Centrale AMBATOLAMPY NEA	18-January-2023	Project Proponent
/40/	Axian Group	Axian Group HR Policies	-	Project Proponent
/41/	Project Proponent	The commercial agreement for the extension	27- November-2020	Project Proponent
/42/	International Renewable Energy Agency	International Renewable Energy Agency website, on the profile of Madagascar: https://www.irena.org/-/media/Files/IRENA/Agency/Statistics/Statistical_Profiles/Africa/Madagascar_Africa_RE_SP.pdf	-	Others
/43/	International Energy Agency	International Energy Agency's website for the information regarding Madagascar, https://www.iea.org/countries/madagascar/energy-mix	-	Others
/44/	Africa Solar Industry Association (AFSIA)	A publication article by "Africa Solar Industry Association (AFSIA)" (https://www.afsiasolar.com/madagascar-the-axian-group-and-greenyellow-begin-the-expansion-works-of-the-largest-solar-power-plant-in-the-indian-ocean/)	dated 16-June-2021	Others
/45/	ESI Africa	Article by "ESI Africa" dated 03-February-2023 (https://www.esi-africa.com/east-africa/new-solar-pv-plant-gives-madagascar-energy-boost/)	dated 03-February-2023	Others
/46/	African Guarantee Fund	Article by "African Guarantee Fund" (https://africanguaranteefund.com/african-guarantee-fund-and-guarantco-	-	Others

No.	Author	Title	References to the document	Provider
		provide-greenyellow-with-a-mga-33-billion-c-eur-7-1-million-credit-guarantee-to-finance-a-20-mw-solar-plant-extension-with-a-5-mw-solar-battery-storage-system/		
/47/	Power Engineering International (PEI)	Article by “Power Engineering International (PEI)” dated 18-June-2021 (https://www.powerengineeringint.com/solar/madagascar-expands-solar-plant-with-20mw-and-battery-storage/)	dated 18-June-2021	Others
/48/	PV Magazine	An article from “PV Magazine” dated 06-February-2023 (https://www.pv-magazine.com/2023/02/06/financial-close-for-20-mw-of-pv-5-mwh-of-storage-in-madagascar/)	dated 06-February-2023	Others
/49/	N/A	An article from “WikiPedia” about Ambatolampy Solar Power Station (https://en.wikipedia.org/wiki/Ambatolampy_Solar_Power_Station)	-	Others
/50/	JIRAMA	JIRAMA 2015-2017 data	-	Others
/51/	Project Proponent	Environmental and Social Monitoring Report NEA Ambatolampy – 40MW for year 2024 Environmental and Social Monitoring Report NEA Ambatolampy – 40MW for January to March: Q1 2025	January 2025 14-April-2025	Project Proponent
/52/	Project Proponent	Waste Registry Spreadsheets for year 2024 and Q1: 2025	-	Project Proponent
/53/	ICR	Official registry website of International Carbon Registry (ICR): https://www.carbonregistry.com/	Last retrieved data on 24-September-2025	Others

APPENDIX 3: CORRECTIVE ACTION REQUESTS, CLARIFICATION REQUESTS AND FORWARD ACTION REQUESTS (CAR/CL/FAR)

Table 1. Remaining FAR from validation and/or previous verification

FAR ID	xx	Section no.	xx	Date : DD-Month-YYYY
Description of FAR				
NA.				
Project Proponent response				Date : DD-Month-YYYY
NA.				
Documentation provided by project Proponent				
NA.				
VVB assessment				Date: DD-Month-YYYY
NA.				

Table 2. CL from this verification

CL ID	01	Section no.	N.A.	Date: 21/07/2025
Description of CL				
Kindly submit the following documents for the verification purpose: 1) Electricity generation records (for total hours and any downtimes) 2) Electricity Sales/ Purchase Invoices for the proposed verification period 3) Clear photographs of electricity meters and the nameplates of PV plant components 4) Electricity meter specifications (Main Meters, Check Meters, etc.) 5) Electricity meters calibration certificates/ records 6) Host Country Letter of approval, dated 19/01/2021 related to Sustainable Development, mentioned in section 1.11 of MR. 7) Technical specifications from the manufacturer for: a) Solar panels (PV modules) b) Inverters c) Transformer d) Electricity meters e) BESS 8) Commissioning certificates issued by the respective authority (for both initial phase and second phase) 9) Line diagram for metering location / Plant layout 10) Organisation Structure				

11) Production License/ Power Purchase Agreement 12) Letter of declaration dated from PP confirming that the GHG Emission reductions or removals generated by the project activity will not be used for compliance with an emission trading program or to meet binding limits on GHG Emissions and has not created or sought any other form of environmental credit for the same period and is not rejected by any other GHG Program. 13) Environmental and Social Impact Assessment report (relevant one) 14) Stakeholder consultation process evidence (for first and extension phase) 15) Grievance logbook/suggestion placed at respective site office. 16) Evidence of grievance closure related to delay in salary issuance to security company (SECUR-PRO) and email exchange, as mentioned in section 2.1.4 or MR 17) Supportive evidence of Employment generation 18) Plant Operations logbook, providing details of any breakdowns/shutdown of plant. 19) Training records of trainings provided to company staff. 20) Environmental and Social Action Plan (ESAP) and PREE, mentioned in section 2.1.2 of MR. 21) Environmental and Social Reports (ESAP report 2024 and ESAP report Q1 2025) referenced in section 2.3.1 of MR 22) AXIAN group human right training policy	
Project Proponent's response	Date: 22/07/2025
VVB to assess the provided supporting package of documents	
Documentation provided by project proponent	
- Supporting documents package	
VVB assessment	Date: 19/08/2025
The VVB team confirms that the majority of the requested evidence and supporting documentation has been submitted by PP. These materials have been thoroughly reviewed by VVB team and deemed appropriate and acceptable. However, the following items from above list still remain outstanding: Item no. 8) Line diagram for metering location / Plant layout. Item no. 18) Plant Operations logbook, providing details of any breakdowns/shutdown of plant. PP is kindly requested to provide the above documents to facilitate further verification. Thus, CL#01 remains Open.	
Project Proponent's response	Date: 28/08/2025
Single line diagram as well as incidents logbooks (year 2024 + year 2025) are provided to VVB for assessment.	
Documentation provided by project proponent	
- Single line Diagram - Incidents logbooks 2024 & 2025	
VVB assessment	Date: 03/09/2025

The pending supporting documents (i.e. Line diagram for metering location / Plant layout and Plant Operations logbook) are now submitted by the PP to the VVB team.

Upon review, the VVB team found the documents to be appropriate and acceptable.

Thus, **CL#01 is hereby Closed.**

CL ID	02	Section no.	1.2 of MR	Date: 21/07/2025
Description of CL				
In Section 1.2 of the VCS Monitoring Report (MR), the “Audit History” table does not include information regarding the validation conducted for the project’s registration under the CDM registry. PP is requested to clarify.				
Project Proponent’s response				Date: 22/07/2025
Section 1.2 of the VCS Monitoring Report (MR) was updated to include information regarding the CDM registration in the audit history table.				
Documentation provided by project proponent				
- Updated MR				
VVB assessment				Date: 19/08/2025
The PP has appropriately revised the “Audit History” table in Section 1.2 of the Monitoring Report (MR), clearly reflecting the validation details associated with the project’s registration under the CDM registry. The updated entry includes the registration date (03-May-2019) and the validating Designated Operational Entity (TÜV NORD CERT GmbH). The VVB team has verified these revisions by cross-checking the information against the official CDM registry webpage for the project. The details have been found to be accurate and acceptable. Thus, CL#02 is hereby Closed.				

CL ID	03	Section no.	1.12 of MR	Date: 21/07/2025
Description of CL				
1) In section 1.12 of the MR, it is specified that, “The technology is manufactured by “Jinko Solar””. However, as per the registered revised PD-MR and section 3.1 of MR, modules manufactured by “JA Solar” have also been installed as part of the project. PP is requested to clarify why this additional information has not been reflected in Section 1.10. 2) In section 1.12 of MR, under Table 1: Sustainable Development Contributions, the statement for SDG 7 indicates: “Increase of renewable energy delivered to the Namibian grid from the project activity”. However, based on our review of the registered project documentation and supporting				

evidence, it was observed that the electricity generated by the project is actually delivered to the RI-Tana Grid in Madagascar. The PP is therefore requested to provide clarification regarding this discrepancy.	
Project Proponent's response	Date: 22/07/2025
1) VVB is right, the sentence in section 1.12 on the solar PV manufacturer was relevant to the initial phase only. Currently there are two manufacturers of solar PV on site: Jinko Solar for the initial phase, and JA Solar for the extension, as it can be seen in section 3.1 implementation status. Section 1.12 is revised to include those two manufacturers names. 2) This was corrected in section 1.12 of the MR	
Documentation provided by project proponent	
- Updated MR	
VVB assessment	Date: 19/08/2025
1) The PP has revised the statement in section 1.12 of MR, to clearly reflect the details of PV manufacturers of both the phases (Jinko Solar for the initial phase, and JA Solar for the extension phase). The VVB team has verified these revisions by cross-checking the information with the relevant PV manufacturer specifications applicable to each phase. The details have been found to be accurate and acceptable. Hence, Comment#1 is Closed.	
2) The PP has made the necessary correction in Section 1.12 of the Monitoring Report (MR), specifically under Table 1: Sustainable Development Contributions. The revised statement for SDG 7 now accurately reflects that the renewable energy generated by the project is delivered to the RI-Tana/Malagasy Grid in Madagascar, rather than the Namibian grid as previously stated. This revision aligns with the information verified in the registered project documentation and supporting evidence. The VVB team has reviewed the updated MR and confirms that the correction is appropriate and acceptable. Accordingly, Comment #2 is now closed.	
Thus, CL#03 is hereby Closed.	

CL ID	04	Section no.	2.1.4 and 2.2.1 of MR	Date: 21/07/2025
Description of CL				
1) In section 2.1.4 of MR, the “Resolution and Outcome” column indicates: “Copies of the logbooks as well as the mail exchange and grievance closing are provided to VVB.” Upon receipt of referenced documents, the VVB team reviewed the copies of logbooks and confirmed resolution of the raised grievance. However, upon examining the submitted email correspondence between the PP and the security service provider, SECUR-PRO, it was observed that the communication pertains to salary delays for the month of February 2025. There is no reference to any issue related to delayed salaries for December 2024. PP is requested to confirm and clarify whether the correct email exchange has been provided to the VVB team to substantiate the resolution of the December 2024 salary grievance.				
2) Upon review of the document titled “ESAP REPORT_2024_ NEA Ambatolampy signed”, the VVB team noted on page 16 that a grievance was received during the 2024 period. The report states: “2024: The neighbouring community mentioned a grievance concerning the upgrading of a stretch of road in the vicinity of the power plant that they said had been degraded by the plant's activity, but after investigation this was not the case, and this was passed on as a request.” However, this grievance is not recorded in the grievance table under Section 2.1.4 of the Monitoring Report (MR). The PP is requested to clarify the omission and explain how this grievance was reviewed and resolved.				
3) The Section 2.2.1 of the Monitoring Report (MR) outlines the experience of the Operations and Maintenance team at the Ambatolampy plant. However, the section does not provide information regarding the experience of the management teams of NEA Ambatolampy and AERA in implementing similar project activities or in engaging with local communities, as required by the MR template guidelines. PP is requested to clarify this omission and provide the relevant details.				
Project Proponent’s response				Date: 22/07/2025

1) The situation was asked about to PDs. They explained the following :

First complaint – December 2024:

Delayed payment of security guards' salaries for December 2024. This has been a recurring issue for several years, always resolved verbally.

Formal request made on January 15, 2025 (grievance logbook):

December salaries were finally paid on January 21, 2025.

After internal discussion of the situation in February: Discussion initiated to begin formal proceedings with the company manager.

Resolution in March 2025:

The manager was notified to find a permanent solution for the payment of agents' salaries. A letter of commitment formalizing the corrective measures was signed in March 2025.

Since these corrective actions : 1) No new complaints have been reported and 2) A payroll schedule has been established and adhered to.

The Secure Pro pay slip of the employee has been shared, as well as the pay calendar screenshot. Both documents are provided to VVB.

2) The situation was asked about to PDs. They explained the following :

The request was duly recorded but, after analysis, it was not classified as a grievance but reclassified as a request. Nevertheless, it was not included in the CSR projects, as these had been defined in advance with the CSR committee, that includes local stakeholders, according to the priorities identified and the budgets allocated. It should also be noted that the section of road mentioned has been in poor condition for more than five years and has not been used as the main access route to the site since the plant began operating.

3) Elements were added regarding management experience, for both NEA Ambatolampy as well as AERA Group, in the relevant section of the updated MR.

Documentation provided by project proponent

- Secure Pro employee pay slip
- Secure Pro pay calendar
- Updated MR

VVB assessment

Date: 19/08/2025

- 1) The Project Proponent (PP) has submitted a detailed clarification regarding the grievance related to delayed salary payments for December 2024. As conveyed by PP representatives, salary delays have been a recurring issue in previous years, typically resolved through verbal communication. This practice was corroborated during remote interviews conducted by the VVB team with both PP and SECUR-PRO officials (security provider company).

The specific grievance raised during the current monitoring period was formally documented in the grievance logbook on 15 January 2025, with the outstanding salaries disbursed on 21 January 2025.

Following internal discussions in February 2025, the PP initiated formal engagement with the security service provider, resulting in the signing of a letter of commitment in March 2025. This document outlines corrective actions aimed at ensuring the timely and consistent payment of salaries moving forward.

To substantiate the resolution, the PP has provided the following supporting documentation:

- a) Relevant grievance logbook entries relevant to the issue
- b) SECUR-PRO employee payslip
- c) Screenshot of email correspondence detailing the established payroll calendar

Upon thorough review, the VVB team confirms that the submitted documentation sufficiently demonstrates resolution of the grievance. Furthermore, it is noted that no subsequent complaints have been reported since the implementation of the corrective measures, and the payroll schedule has been consistently maintained.

Hence, the issue is considered to be appropriately addressed.

However, the letter of commitment formalizing the corrective measures, which was signed in March 2025 is not provided to the VVB team. PP is kindly requested to provide the relevant letter to facilitate further verification.

Hence, **Comment#1 is Open.**

- 2) The Project Proponent (PP) has provided clarification regarding the community concern referenced in the document titled “ESAP REPORT_2024_ NEA Ambatolampy signed”. As explained by the PP representatives, the issue—initially raised by the neighbouring community regarding the condition of a stretch of road near the power plant—was reviewed and subsequently reclassified as a **request**, rather than a formal grievance.

This determination was based on the following:

- a) The road in question has not served as the main access route to the site since the plant commenced operations and has reportedly been in poor condition for over five years.
- b) The CSR program priorities were pre-defined in consultation with the CSR committee, which includes local stakeholders, and were based on identified needs and allocated budgets.
- c) The matter was discussed during remote interviews with PP representatives and found to be appropriately addressed in context.

While the reclassification is acknowledged and the explanation deemed reasonable, any community-raised concern initially perceived as a grievance—regardless of its final classification—must be transparently documented in the grievance redress procedure table in Section 2.1.4 of the

Monitoring Report (MR). This ensures traceability and compliance with VERRA's requirements for stakeholder engagement and grievance handling.

Accordingly, **Comment #2 remains open** pending inclusion of the referenced concern in the grievance table, along with justification for its reclassification.

- 3) The Project Proponent (PP) has incorporated the necessary revisions in Section 2.2.1 of the revised Monitoring Report (MR), which now clearly outlines the management experience of both NEA Ambatolampy and AERA Group in implementing similar project activities. The updated content aligns with the prescribed template guidelines and provides a more transparent account of the entities' relevant expertise.

The VVB team has reviewed the revised section and confirms that the information presented is accurate, appropriate, and consistent with the requirements.

Hence, **Comment#3 is Closed.**

Thus, **CL#04 remains open.**

Project Proponent's response

Date: 28/08/2025

- 1) Mentioned letter of commitment, formalizing the corrective measures, signed in March 2025 has been received and is provided to VVB for assessment.
- 2) Referenced concern details have now been included in the updated version of the Monitoring Report, in section 2.1.4.

Documentation provided by project proponent

- Letter of Commitment signed March 2025 on the security workers salary payments issue

VVB assessment

Date: 03/09/2025

- 1) PP has now provided the requested letter of commitment, which outlines corrective actions aimed at ensuring the timely and consistent payment of salaries moving forward. Following a thorough review, the VVB team has determined that the letter is appropriate and acceptable in addressing the identified issue. Hence, **Comment#1 is hereby Closed.**
- 2) PP has now included the details of referenced grievance in the grievance redress procedure table under Section 2.1.4 of the Monitoring Report (MR) in accordance with VCS requirements. The update also provides the rationale for reclassifying the matter as a "request" rather than as a "grievance". During the remote audit, the VVB team verified the explanation to be accurate and found it appropriate in addressing the issue. Hence, **Comment#2 is hereby Closed.**

Thus, **CL#04 is Closed.**

Table 3. CAR from this verification

CAR ID	01	Section no.	1.11.2 of MR	Date: 21/07/2025
Description of CAR				
Kindly look into the following findings in the MR: 1) The filename assigned to the Monitoring Report (MR) does not conform to the formatting requirements specified in the template guidelines. PP is requested to review and revise the filename to ensure consistency with the prescribed naming conventions. 2) The date entries within the Monitoring Report (MR) do not consistently follow the required format: DD-Month-YYYY, as specified in the MR template guidelines. The Project Proponent (PP) is requested to review all date references throughout the report and ensure uniformity with the prescribed format. 3) In section 1.11.2 of MR, neither of the option is selected in response to requested information on “No Double Claiming with Other Forms of Environmental Credit”. PP is requested to review this section and ensure that the appropriate declaration is completed to demonstrate compliance.				
Project Proponent’s response				Date: 23/07/2025
1) The name of the Monitoring Report file has been updated to comply with Verra's naming conventions. 2) The date format has been revised throughout all sections of the MR, to follow the required format: DD-Month-YYYY 3) Section mentioned has been updated in the Monitoring Report				
Documentation provided by project proponent				
- Updated MR				
VVB assessment				Date: 19/08/2025
1) The Project Proponent (PP) has revised the Monitoring Report (MR) filename to align with the naming conventions prescribed by VERRA. The VVB team has reviewed the updated file and confirms that the changes have been appropriately implemented and are in full compliance with the required format. Hence, Comment#1 is closed. 2) The Project Proponent (PP) has reviewed and revised all date entries within the Monitoring Report (MR) to ensure consistency with the prescribed format: DD-Month-YYYY, as outlined in the MR template guidelines. The VVB team has verified the corrections in revised MR and confirms that the revised entries are appropriate and compliant with template guidelines. This was found to appropriate and acceptable. Hence, Comment#2 is closed. 3) The Project Proponent (PP) has reviewed Section 1.11.2 of the Monitoring Report (MR) and has now selected the appropriate option for declaration regarding “No Double Claiming with Other Forms of Environmental Credit,” in accordance with the MR template requirements. The VVB team has verified the revision and confirms that the selected option adequately demonstrates compliance with template requirements and reflects correct information. Hence, Comment#3 is closed.				

Thus, CAR#01 is closed.

CAR ID	02	Section no.	3.1 & 3.2.2 of MR	Date: 21/07/2025
Description of CAR				
Kindly look into the following findings in the MR: 1) In section 3.1 of monitoring report, the paragraph below technical specifications table indicates that the unavailability of a protection cell on a transformer of the initial phase lasted from “January until April 2024”. However, the breakdown period table in the same section reflects the duration of unavailability as “January to February 2024”. PP is requested to clarify about this discrepancy and confirm the accurate period of unavailability. 2) In section 3.2.2 of MR, no information has been provided regarding whether the approved deviations impact the applicability of the methodology, the project additionality, or the appropriateness of the baseline scenario, as per MR template guidelines. Please review.				
Project Proponent’s response				Date: 11/08/2025
1) This default lasted from January to February of the year 2024. The sentence in section 3.1 has been corrected accordingly. 2) This matter was considered during the MR redaction. Considering the length of this deviation section regarding applicability of the methodology, project additionality and appropriateness of the baseline scenario, could VVB please clarify if a summary of those changes would be acceptable. A footnote with a link to the publicly available validated JPD-MR with all deviations described would be added for clarity. If this is not an option, then all the information will be reflected in the relevant section of MR.				
Documentation provided by project proponent				
- Updated MR				
VVB assessment				Date: 19/08/2025

- 1) The Project Proponent (PP) has clarified that the unavailability of the protection cell on the transformer during the initial phase lasted from January to February 2024. The discrepancy in Section 3.1 of the Monitoring Report (MR) has been corrected to reflect the accurate duration, consistent with the breakdown period table.
The VVB team has reviewed the revision and confirms that the correction is appropriate and resolves the inconsistency.
Accordingly, **Comment #1 is considered satisfactorily addressed and is hereby closed.**
- 2) The Project Proponent (PP) has addressed the concern raised in Section 3.2.2 of the Monitoring Report (MR) by incorporating a summary of the approved deviations and their implications on the applicability of the methodology, project additionality, and baseline scenario. A footnote referencing the publicly available validated JPD-MR has also been included to provide further detail and transparency.
The VVB team has reviewed the revised content and confirms that the information now presented is appropriate and compliant with the MR template guidelines.
Accordingly, **Comment #2 is considered satisfactorily addressed and is hereby closed.**

Thus, CAR#02 is closed.

CAR ID	03	Section no.	5.1 of MR	Date: 21/07/2025
Description of CAR				
Please look into the following findings:				
1) In section 5.1 of MR, in the table of “Calculation of Baseline Emissions”, the values presented under column “ BE_Amb1 ” are inconsistent with corresponding values in column E of “Ambatolampy ER MP4” tab in ER sheet. PP is requested to review this discrepancy and ensure alignment between the MR and ER sheet data.				
Project Proponent’s response				Date: 25/07/2025
1) Indeed, in the MR table those values were corresponding to the total VCUs calculation in the ER sheet (including PE). This was corrected in section 5.1 of the MR, in the relevant table. Correct values of Baseline Emissions are now displayed.				
Documentation provided by project proponent				
- Updated MR				
VVB assessment				Date: 19/08/2025

- 1) The Project Proponent (PP) has revised the table in Section 5.1 of the Monitoring Report (MR) to correct the values presented under the column “BE_Amb1”.

The revised MR now accurately reflects the baseline emission values, consistent with the data presented in column E of the “Ambatolampy ER MP4” tab in the Emission Reduction (ER) sheet. The VVB team has cross-checked the updated MR and confirms that the corrections are appropriate and align with the supporting documentation. The discrepancy has been resolved. The MR now accurately reflects baseline emissions aligned with the ER sheet.

Accordingly, **Comment #1 is considered satisfactorily addressed and is hereby closed.**

Thus, **CAR#03 is closed.**

CAR ID	04	Section no.	ER sheet	Date: 21/07/2025
Description of CAR				
1) The ER sheet presents the details of SDG Contributions under the tab “SDG Impact VCS 4” in ER sheet. However, the values reported under the “Current Project Contributions” column for SDG 7, SDG 8, and SDG 13 are inconsistent with the corresponding figures provided in Section 1.12 of the Monitoring Report (MR). PP is requested to review these discrepancies and ensure alignment between both documents. 2) In the tab “Ambatolampy ER MP4” of ER sheet, the appropriate formulae have not been applied in the cells H29, I28, I29 and I30. The PP is requested to review the respective cell-specific comments provided in the ER sheet and incorporate the necessary corrections to ensure consistency and accuracy. 3) In the ER sheet, under the tab “Phase ext MP4,” the “Consumption” value for February 2024 in cell F7 has been found to be inconsistent with the corresponding value recorded in the Production Sheet for the same month (Feb-24), as cross-checked by VVB Team. PP is requested to clarify about this discrepancy and confirm which value accurately reflects the project data. 4) In ER sheet, under tab “Phase ext MP4”, the column G contains the values for “Invoiced Imports.” However, these values have not been deducted in the calculation formula for the parameter “EG_{facility,y}” under column H. PP is requested to clarify about this approach.				
Project Proponent’s response				Date: 11/08/2025
1) Values in the tab “SDG Impact VCS4” have been updated to display the correct values in the ER sheet. 2) Equations with round ups and round downs were added in the formulas. As a consequence, PE go from 11 to 13 on the MP and the claimed VCUs decrease from 47,049 to 47,047. The project documents are updated in this regard. 3) VVB is right, it appears there is an error on the February production sheet. Indeed, the January production sheet indexes for consumption are : 121,670 on 01/01/2024 and 122,150 on 01/02/2024. On the February production sheet indexes, the data is given as 121,670 instead of 122,150, while it should have been 122,150 according to the January sheet. Therefore, the consumption is given as 680 (January + February) instead of February only (200). Project developers were asked to confirm such error on the February sheet, and they were asked if a corrected version of the sheet would be issued. 4) VVB is right, this was an oversight in the ER sheet. Same has been corrected in the latest version.				

Documentation provided by project proponent	
- Updated ER sheet	
VVB assessment	Date: 19/08/2025
1) The Project Proponent (PP) has revised the “SDG Impact VCS 4” tab in the revised ER sheet to correct the values reported under the “Current Project Contributions” column for SDG 7, SDG 8, and SDG 13. These updates ensure consistency with the corresponding figures presented in Section 1.12 of the Monitoring Report (MR). The Validation and Verification Body (VVB) has reviewed the revised ER sheet and confirmed that the corrections are accurate and aligned with the MR. The discrepancy has been resolved. The ER sheet and MR are now aligned. Accordingly, Comment #1 is considered satisfactorily addressed and is hereby closed. 2) The Project Proponent (PP) has revised the formulae in respective cells of the “Ambatolampy ER MP4” tab in the revised ER sheet, incorporating appropriate rounding functions to ensure consistency and accuracy. As a result of these corrections, the Project Emissions (PE) reflected in the Monitoring Report (MR) increased from 11 tCO₂e to 13 tCO₂e, and the claimed Verified Carbon Units (VCUs) decreased from 47,049 tCO₂e to 47,047 tCO₂e. The VVB team has reviewed the updated ER sheet and confirmed that the correct formulae have been applied and the project documentation has been appropriately updated. The formula discrepancies have been resolved. The ER sheet and MR are now aligned. Accordingly, Comment #2 is considered satisfactorily addressed and is hereby closed. 3) PP clarified that, there is an error in production sheet for month Feb-24 for extension phase, which resulted in incorrect data records in ER sheet. PP is requested to confirm about this error and provide the correct version of production sheet for the month Feb-24 for extension phase as clarified in above response to facilitate further verification. Hence, Comment#3 is OPEN. 4) The Project Proponent (PP) acknowledged the oversight in the calculation of the parameter “EG_{facility,y}” under column H of the “Phase ext MP4” tab in the ER sheet, where “Invoiced Imports” from column G had not been deducted. The ER sheet has since been revised to incorporate the necessary correction. The VVB team has reviewed the updated ER sheet and confirms that the formula has been appropriately amended to reflect the deduction of invoiced imports. The correction is accurate and consistent with the intended calculation method. Accordingly, Comment #4 is considered satisfactorily addressed and is hereby closed. Thus, CAR#04 is OPEN.	
Project Proponent’s response	Date: 28/08/2025
3) In a follow-up email exchange with the Project Proponents, they confirmed the nature of the error found on the mentioned invoice, i.e. wrong consumption indexes in the extension February 2024 sheet. Corrected invoice has been provided to the VVB.	
Documentation provided by project proponent	
- relevé productions-consommations ph2 fev-24 corr.pdf	

VVB assessment	Date: 03/09/2025
3) The Project Proponent (PP) has acknowledged an editorial error in the previously submitted production sheet for February 2024 pertaining to the extension phase. Corresponding email communication between the PP and the consultant has been shared with the VVB team, confirming the nature of the discrepancy. Furthermore, the corrected version of the production sheet has now been submitted, effectively resolving the open issue. Based on the review of the updated documentation and supporting correspondence, Comment #4 is deemed satisfactorily addressed and is hereby closed. Thus, CAR#04 is closed.	

CAR ID	05	Section no.	N.A.	Date: 21/07/2025
Description of CAR				
Please refer to the additional comments in the MR and ER sheet and resolve the same.				
Project Proponent's response				Date: 12/08/2025
Comments in the MR and ER sheet have been addressed				
Documentation provided by project proponent				
- Updated ER sheet - Updated MR				
VVB assessment				Date: 19/08/2025
The comments in the MR and ER sheet are not closed yet. The open comments require PP's attention. Kindly refer to MR and ER sheet for open comments. Thus, CAR#05 is Open.				
Project Proponent's response				Date: 28/08/2025
Remaining comments have been answered in the latest versions of ER sheet and Monitoring Report provided, for VVB assessment.				
Documentation provided by project proponent				
- Updated ER sheet - Updated MR				
VVB assessment				Date: 03/09/2025
The PP has addressed all comments raised in the Monitoring Report (MR) and Emission Reduction (ER) sheet. The VVB team has reviewed the revised MR and ER sheet and confirms that the PP has incorporated the necessary corrections and clarifications at the relevant sections. Based on this review, the updates are deemed satisfactory and fully resolve the identified issues. Thus, CAR#05 is closed.				

Table 4. FAR from this verification

FAR ID	XX	Section No.	XX	Date:
Description of FAR				
NA				
Project Proponent's response				Date: DD/MM/YYYY
NA				
Documentation provided by project proponent				
NA				
VWB assessment				Date: DD/MM/YYYY
NA				

APPENDIX 4: COMPETENCE OF TEAM MEMBERS AND TECHNICAL REVIEWERS

Before the assessment begins, members of the team covering the technical scope(s), sectoral scope(s), and relevant host country experience for evaluating the VCS project activity are appointed in accordance with the LGAI Technological Center S.A. (Applus+ Certification) procedures and policies, that are in accordance with the ISO 14065:2020 regulatory provisions.

According to the applicable sectoral scope / technical area and experience in the sectoral or national business environment, LGAI Technological Center S.A. (Applus+ Certification) has composed an assessment team in accordance to compliance with the contract review and Assessment Team appointment rules in the internal Quality Management System of LGAI Technological Center S.A. (Applus+ Certification) as well as in compliance with the applicable requirements in the Accreditation Standard.

The composition of audit team (Applus+ Certification's verification team) has been approved by the LGAI Technological Center S.A. (Applus+ Certification) Central site during its Contract Review process, ensuring that the required skills and capabilities are covered by the team.

The qualification levels for Assessment Team members that are assigned by aforementioned appointment rules are as presented below:

- Lead Auditor (LA).
- Auditor (A).
- Technical Expert (TE).
- Technical Reviewer (TR).
- Any of the above-mentioned roles in training (iT, e.g. AiT for auditor in training, TEiT for Technical Expert in Training, etc.).

The Sectoral Scopes / Technical Areas required knowledge linked to the applied methodology(ies) is covered by the Assessment Team as shown below:

No.	Role	Type of resource	Last name	First name	Affiliation (e.g. name of central or other office of VVB or outsourced entity)	Involvement in			
						Desk review	On-site inspection	Interview(s)	Verification findings
1.	Lead Auditor (LA), Technical Expert (TE)	IR	Singh	N. Premjit	LGAI Technological Center S.A. (Applus+ Certification)	Yes	No	Yes	Yes
2.	Auditor (A)	IR	Gaikwad	Saurabh	LGAI Technological Center S.A. (Applus+ Certification)	Yes	No	Yes	Yes

3.	Local Support	EI	Raharilaza	Nathalie	LGAI Technological Center S.A. (Applus+ Certification)	No	No	Yes	No
----	---------------	----	------------	----------	--	----	----	-----	----

Technical reviewer and approver of the verification and certification report

No.	Role	Type of resource	Last name	First name	Affiliation (e.g. name of central or other office of DOE or outsourced entity)
1.	Technical reviewer (TR), Technical Expert (TE)	EI	Xue	Denny	LGAI Technological Center S.A. (Applus+ Certification)
2.	Approver	IR	Calle de Miguel	Agustin	LGAI Technological Center S.A. (Applus+ Certification)

Short CVs of the Team:

Dr. N. Premjit Singh	Dr. N Premjit Singh has a PhD in Mechanical Engineering from the Indian Institute of Technology (IIT) Madras, Chennai, India. M.Tech in Energy Technology, Tezpur University, Napaam, India, and B.Tech in Mechanical Engineering, NERIST, Nirjuli, India. He has extensive experience of about 8 years with DOEs, including UNFCCC CDM and other carbon related schemes (e.g., VCS, GS, GCC), and 5 years+ in research projects, renewable energy, and energy audits. In Applus+ as an internal staff member since March 2023, he has been the Product Assurance Manager for CDM/VCS/GS4GG/GCC Department to ensure the quality of the performance of different assessments, coordinate the global team for technical reviews, and identify the training needs for the auditors and technical reviewers to improve the quality of reports. He holds experience as a Lead Auditor, Validator and Verifier for GHG mitigation projects and programmes of activities in Sectoral Scope 1.2 (Renewables) and 3.1. (Energy Demand) and is qualified as per Applus+
-----------------------------	--

	procedures as Lead Auditor, Validator, Verifier, Technical Expert for SS/TA 1.2. and Technical Reviewer. Dr. N Premjit Singh is based in Gurugram, India. Dr. N Premjit Singh may participate as part of the Audit Team as Lead Auditor and Technical Expert.
Mr. Saurabh Gaikwad	Mr. Saurabh Gaikwad holds a Bachelor of Technology (B. Tech) degree in Environmental Engineering from KIT's College of Engineering in Kolhapur, Maharashtra, India. With nearly 4 years of hands-on experience in Carbon Markets and Climate Change, he has contributed to a wide range of international mechanisms, including UNFCCC CDM, VCS, GS4GG, GCC, etc. During this time, he has played diverse roles in audit teams across the project lifecycles, such as Auditor, Technical Expert, Trainee Validator/Verifier, Auditor in Training, Lead Auditor in Training, and Technical Reviewer in Training. Since June 2022, Mr. Saurabh Gaikwad has been working at Applus+ Certification. Currently, he works in the position of Senior Project officer at Carbon Projects Certification Unit (CPCU) of Applus+ Certification. In this role, he actively participates in different stages of the VVC processes and conducts administrative reviews of final submission documents and post submission registry findings reviews, ensuring high-quality deliverables and compliance with relevant standards. Additionally, he serves as Auditor, Technical Reviewer and Technical Expert for the Validation and Verification of mitigation activities across diverse sectors – including renewable energy, energy efficiency, community based projects, waste management and handling, manure projects, etc. under leading carbon standards such as CDM, VCS, GS4GG, GCC, etc. Mr. Saurabh Gaikwad is based in Pune, India. Mr. Saurabh Gaikwad participated as part of the Audit Team as Auditor (A).
Ms. Nathalie Raharilaza	Ms. Nathalie Raharilaza is a local/regional support contracted by the VVB in order to provide support with local context of Madagascar and if necessary to mitigate the risks from some stakeholders not being able to express adequately in English but in French or local language when conducting the Validation and/or Verification interviews. She provided support to perform the interviews to the project's stakeholders, in coordination with the VVB's Audit team.
Mr. Denny Xue	Mr. Denny Xue (Master's Degree in Environmental Engineering, Bachelor's Degree in Thermal Engineering) is an Auditor appointed by

	Applus+ Certification (LGA Technological Center, S.A) for the GHG project assessment, auditing and technical review. He has more than 10 years of work experience in CDM/GS4GG/VCS project assessment and technical review with Applus+. Before he joined Applus+ Certification (LGA Technological Center, S.A), he has been working for Shanghai Chuanji Investment and Management which is a CDM consultancy company as a project manager for CDM project development. Mr. Denny Xue is based in Shanghai, China. Mr. Denny Xue participates as part of the Technical Review experts' panel.
--	---

APPENDIX 5: ABBREVIATIONS

Abbreviations	Full texts
BM	Build Margin
CAR	Corrective Action Request
CDM	Clean Development Mechanism
CER	Certified Emission Reduction(s)
CEA	Central Electricity Authority
CL	Clarification request
CM	Combined Margin
CMS	Central Monitoring system
CO ₂	Carbon dioxide
CO ₂ e	Carbon dioxide equivalent
DNA	Designated National Authority
DOE	Designated Operational Entity
DR	Document Review
EF	Emission Factor
EIA	Environmental Impact Assessment
ER	Emission Reductions
FAR	Forward Action Request
GHG	Greenhouse gas(es)
GWP	Global Warming potential
GY Madagascar	Green Yellow Madagascar
JIRAMA	Jiro Sy Rano Malagasy
NEA Ambatolampy	New Energy Africa Ambatolampy
PD	Project Description
JPD-MR	Joint Project Description and Monitoring Report
PP	Project Proponent
PV	Photovoltaic
QA/QC	Quality Assurance and Quality Control
UNFCCC	United Nations Framework Convention on Climate Change
VCS	Voluntary Carbon Standard
VCS PD	VCS Project Description
VCUs	Voluntary Carbon Units

APPENDIX 6: BREAKDOWN RECORDS

Period	Description
January-February 2024	Default of a protection cell on the initial phase
April-May 2024	Multiple defaults of inverters on the extension phase
May-August 2024	Multiple defaults of inverters on the initial phase
May-August 2024	Multiple defaults of inverters on the initial phase
Sept-Oct 2024	Lack of capacitors harmonic filters (initial phase)
December 2024 – March 2025	Default of Batteries Rack (PCS 1) on extension phase