



SOLITUDE 16MW SOLAR PV



Report ID	VCS.VER.24.36
Project title	Solitude 16 MW solar PV
Project ID	2308
Verification period	01-January-2023 to 31-December-2023
Original date of issue	12/08/2024
Most recent date of issue	30/08/2024
Version	1.0
VCS Standard Version	4.7
Client	Voltas Yellow Ltd
Prepared by	Earthood Services Private Limited

Approved by	Dr. Kaviraj Singh Managing Director
Work carried out by	Team Leader: Jinesh Amlani Technical Area Expert 1.2: Jinesh Amlani Verifier: Anurag Verma Technical Expert (TA 1.2): Shifali Guleria Technical Reviewer (TA 1.2): Shifali Guleria

Summary:

The project activity involves the generation of electricity through a greenfield solar photovoltaic plant with a capacity of 16.328 MWp in Solitude near the village of Triolet in the north of Mauritius, in the district of Pamplemousses. The solar plant consists of 59,376 photovoltaic modules that supply the generated electricity to the Central Electricity Board (CEB) grid.

Earthood Services Private Limited (Earthood) is contracted to conduct the fourth verification of the VCS registered project activity Solitude 16 MW Solar PV Project by the project proponent Voltas Yellow. The assessment is performed in line with the VCS requirements for project activities. The review of the MR, supporting documentation and subsequent follow-up actions (telephonic interviews with stakeholders) have provided Earthood with sufficient evidence to determine the fulfilment of stated criteria including but not limited to the VCS Standard/5/and other relevant rules and requirements established by Verra.

During the current monitoring period, from 01/01/2023 to 31/12/2023, the plant successfully delivered 22.2 GWh of electricity to the national grid and the actual emission reductions were calculated as 21,847 tCO₂e.

A risk-based approach has been followed to perform this verification assessment and no uncertainties are associated with the verification. A total of 2 CLs, 2 CARs has been raised during the verification process of the project activity and successfully closed as detailed in appendix IV of this report.

Earthood Services Private Limited can certify that the emission reductions achieved in the monitoring period 01/01/2023 to 31/12/2023 by VCS project activity "Solitude 16MW Solar PV Project" (VCS ID:2308) amount to 21,847 tCO₂e. Therefore, this is being submitted for request of issuance, as per VCS procedures.

CONTENTS

1	INTRODUCTION	5
1.1	Objective	5
1.2	Scope and Criteria	5
1.3	Level of Assurance.....	6
1.4	Summary Description of the Project	6
2	VERIFICATION PROCESS	6
2.1	Method and Criteria.....	6
2.2	Document Review	7
2.3	Interviews	8
2.4	Site Visits	9
2.5	Resolution of Findings	9
2.6	Eligibility for Validation Activities	10
3	VALIDATION FINDINGS	10
3.1	Methodology Deviations.....	10
3.2	Project Description Deviations.....	10
3.3	New Project Activity Instances in Grouped Projects.....	10
3.4	Baseline Reassessment	10
4	VERIFICATION FINDINGS.....	11
4.1	Project Details	11
4.2	Safeguards and Stakeholder Engagement	14
4.3	Accuracy of Reduction and Removal Calculations.....	22
4.4	Quality of Evidence to Determine Reductions and Removals.....	22
4.5	Non-Permanence Risk Analysis.....	28
4.6	Verification Summary	28
4.7	Verification Conclusion	28
4.8	Ex-ante vs Ex-post ERR Comparison	29
	APPENDIX I: ABBREVIATIONS.....	31
	APPENDIX II: REFERENCES	32
	APPENDIX III: COMPETENCE STATEMENT	33

APPENDIX IV: AUDIT FINDINGS.....	33
APPENDIX V: COMMERCIALLY SENSITIVE INFORMATION.....	38

1 INTRODUCTION

1.1 Objective

Voltas Yellow Ltd (PP) has contracted Earthood Services Private Limited (VVB) to conduct the verification of the project activity “Solitude 16MW Solar PV Project” (VCS ID:2308) located in Mauritius against the requirements of VCS Program.

The objective of the verification assessment is to determine that the

- The project complies with all the applicable VCS requirements of the current version of the VCS Standard v4.7 and program guide v4.4/05/.
- Project conformity with the registered monitoring plan/01/ and applied methodology, ACM0002: Grid-connected electricity generation from renewable sources — Version 21/06/
- The data/information reported is accurate, complete, consistent, transparent, and free of material error or omission.

The verification is an independent assessment of the project by a verification body that determines whether the project complies with the VCS rules and requirements.

1.2 Scope and Criteria

The verification scope of this assignment is defined as an independent and objective review of the VCS Monitoring report and the supporting annexures, which is reviewed by the assessment team against the relevant criteria including but not limited to monitoring methodology, applicable tools, VCS standard and guidance. The assessment team has applied a risk-based approach as per recommendations prescribed in the latest version of VCS Validation and Verification Manual.

The scope of this assignment is to:

- Conduct verification assessment in accordance with Earthood’s own QMS that is based on the VCS VVM along with the guidance provided by the VCS board to determine if the project meets all applicable VCS requirements, including those specified in the VCS standard, relevant methodology, tools, and guidelines and processing the same with VCS Program Guide.
- Assess the accuracy, conservativeness, relevance, completeness, consistency, and transparency of the information provided by the project proponents.
- Determine whether information provided by the project proponents is reliable and credible.
- Present information in the form of verification report in a factual, neutral, coherent manner and referencing the sources and assumptions, and other forms of verification means employed.
- Report the findings and conclusions in an objective manner.
- Safeguard the confidentiality of all information obtained during verification; and

- Adhere to the principles of independence, ethical conduct, fair presentation, and due professional care in assessment process.

1.3 Level of Assurance

- ☐ Limited level of assurance
- ☒ Reasonable level of assurance

Earthood's verification approach is based on the understanding of the risks associated with reporting of GHG emission data and the controls in place to mitigate these. Earthood planned and performed the verification by obtaining evidence and other information and explanations that Earthood considers necessary to give reasonable level of assurance that reported estimated GHG emission reductions are fairly stated.

In our opinion the estimated and actual GHG emissions reductions were calculated correctly based on the registered monitoring plan/01/ and monitoring methodology/06/.

The assessment result has a reasonable level of assurance in verification that GHG assertions are free of material errors, omissions, and misrepresentations. The documents and evidence reviewed are included under Appendix II of this report.

1.4 Summary Description of the Project

Solitude 16 MW solar PV project consists of the construction and operation of a greenfield solar photovoltaic power plant in Solitude near the village of Triolet in the north of Mauritius, in the district of Pamplemousses. The total installed capacity of solar PV plant amounts to 16.328 MW_{DC} which will capture solar energy and evacuate the produce electricity to Mauritius national grid.

The verification team based on the assessment of the documents, physical inspection during the site visit and interview with the PP and the plant personnel was able to confirm that the project activity is fully functional and implemented as described in the registered VCS PD/01/.

2 VERIFICATION PROCESS

2.1 Method and Criteria

The verification of the project consists of following steps:

Desk review-

- Review of data and information provided in the MR/03/ and corresponding annexures.

- Cross check the information with the sources without limitations to the information provided by the project proponent.

Follow up actions-

- On site audit to inspect the project design, including, but not limited to, implementation status and monitoring mechanism.
- Interview with relevant personnel and local stakeholders responsible for information given in the VCS MR.

Reporting of findings -

- Resolution of findings
- Draft verification report

Independent technical review –

The project documentation is reviewed by internal technical reviewer to independently confirm whether the applicable GHG program requirements were objectively met or not, in addition to whether internal procedures were followed while arriving at the validation and verification opinion. The technical reviewer may accept or reject the verification opinion prepared by the assessment team and gives the reasons. The resolved findings may be opened at this stage, or new findings may be identified that are required to be addressed by assessment team and/or project proponents, as appropriate. The technical reviewer is the decision maker on behalf of the Earthood Services Private Limited. A positive opinion is issued if all the findings have been satisfactorily resolved and in all other cases a negative opinion is issued unless the contract is terminated by either party before reaching the final opinion. Earthood keeps all documents and records in a secure and retrievable manner for at least two years after the end of the project crediting period.

2.2 Document Review

The verification is performed primarily as a document review of the documents submitted at various stages of assessments. The review is performed by the assessment team using dedicated protocols. The assessment team cross checks the information provided in the documents, Project Description/01/, ER sheet/04/ & Monitoring Report/03/ and information from sources other than those used, if available, and conducts independent background investigations. Earthood conducted a desk review as under:

- A. A review of the data and information presented to verify their completeness.
- B. A review of the monitoring plan, the monitoring methodology including applicable tool(s) and, where applicable, the applied standardized baseline, paying particular attention to the frequency of measurements, the quality of metering equipment including calibration requirements, and the quality assurance and quality control procedures.
- C. An evaluation of data management and the quality assurance and quality control system in the context of their influence on the generation and reporting of emission reductions.

2.3 Interviews

During the current verification period, an onsite visit was conducted to the plant site on 31/05/2024 to verify the implementation of the project activity. The on-site interviews with the PP representatives were conducted to discuss aspects of project implementation such as monitoring plan, the operations at the project site (outages, if any), and other details like calibration of the monitoring equipment used during the current monitoring period, etc.

The required documents and details for the verification of project activity implementation were collected from the project developer, through follow up emails, Microsoft teams video calls and interviews.

The interviews were conducted in English and the need for the Local Expert requirement was identified by the assessment team for the onsite audit.

The details of the key personnel interviewed, and the main topics of the interviews are as follows-

Sr.No.	Name	Affiliation	Topics discussed	Assessment team
1.	Jinesh Amlani	Earthood Manager (Team Leader, TA 1.2)	-Project Implementation status	Jinesh Amlani
2.	Josian Arlanda	Site Supervisor, GreenYellow Indian Ocean	-Operation and Maintenance of Facility, Monitoring practices, Data collection, data storage, QA/QC -Roles &Responsibilities	
3.	Marion Michot	CSR/HSE Coordinator, GreenYellow Indian Ocean	-Calibration requirements -GHG calculations -Ongoing grievance mechanism -Awareness programmes undertaken by PP	
4.	Gopika Callychurn	Operation Analyst GreenYellow Indian Ocean	• Non-Involvement in Emissions Trading Programs and Other Binding Limits or Other Forms of Environmental Credit.	
5.	Reshad Laulloo	Earthood Local Expert		

6.	Vijay Chuturdharee	Agri Engg & Director of planter's Co-op Association	Confirm their identity and relation to the project activity, what was discussed during the consultation. How the grievance logbook was maintained at the site.	
----	--------------------	---	--	--

2.4 Site Visits

During this verification, ESPL has conducted an onsite visit on 31/05/2024 to achieve the reasonable level of assurance that is in conformance with VCS rules. The details of the interviews conducted, and on-site activities undertaken have been described under section 2.3 above.

2.5 Resolution of Findings

The objective of this step is to identify, discuss and conclude on the issues related to the monitoring, implementation and operations of the registered project activity that could impair the capacity of the

registered project activity to achieve emission reductions or influence the monitoring and reporting of emission reductions. This is done based on the desk review and onsite assessment. The verification team prepares and/or updates a verification protocol (internal document) that records the conformities and nonconformities, which may be of following types:

CAR (Corrective Action Request) is raised if one of the following occurs: Non-compliance with the monitoring plan, the methodology or the standardized baseline are found in monitoring and reporting and has not been sufficiently documented by the project participants, or if the evidence provided to prove conformity is insufficient.

Modifications to the implementation, operation and monitoring of the registered project activity has not been sufficiently documented by the project participants Mistakes have been made in applying assumptions, data or calculations of emission reductions that will impact the quantity of emission reductions, change to the key sustainable development indicators. Issues identified in a FAR during validation to be verified during verification or previous verification(s) have not been resolved by the project participants.

Clarification request (CL) is raised if information is insufficient or not clear enough to determine whether the applicable requirements have been met. All CARs and CLs raised by the Earthhood during verification shall be resolved prior to submitting a request for issuance.

FAR (Forward Action Request) is raised during verification if the monitoring and reporting require attention and/or adjustment for the next verification period.

The total of 02 CL, 02 CARs were raised in the current verification that were successfully addressed during the current verification assessment. No FAR was raised during this monitoring period. All the findings that were raised and communicated to project participant during the verification have been included under Appendix IV. The section also includes the response, if provided, by the project participants and an assessment by the verification team if it was closed out or otherwise.

2.5.1 Forward Action Requests

No FAR is raised.

2.6 Eligibility for Validation Activities

No validation activity is undertaken thus this is not applicable.

3 VALIDATION FINDINGS

Project is registered under VCS only (VCS ID-2308)/07/. It is confirmed from the declaration/8/ provided by the project owner of “Solitude 16MW Solar PV Project” that the net GHG emission reductions generated by the project activity will not be used for compliance with any other emissions trading program or to meet binding limits on GHG emissions for the same monitoring period.

The project activity is not a part of any other GHG Program. The same has been verified from the CDM and GS websites.

3.1 Methodology Deviations

No methodology deviation has been applied for this monitoring period. Therefore, this section is not applicable to the project.

3.2 Project Description Deviations

No deviation has been applied for this monitoring period compared to the project description. Therefore, this section is not applicable.

3.3 New Project Activity Instances in Grouped Projects

This is not a grouped project.

3.4 Baseline Reassessment

Did the project undergo baseline reassessment during the monitoring period?

☐ Yes

☒ No

4 VERIFICATION FINDINGS

4.1 Project Details

The project activity consists of the construction and operation of a greenfield 16.328 MW_{DC} solar photovoltaic power plant in Solitude near the village of Triolet in the north of Mauritius, in the district of Pamplemousses.

The project has been operational since 19/12/2018. Under the fourth monitoring period from 01/01/2023 – 31/12/2023, the project has delivered 22.2 GWh of electricity to the national grid as verified from the invoices raised to CEB /17/, thereby offsetting an equivalent amount of electricity generated from fossil fuel-based plants, which has resulted in corresponding emission reductions of 21,847 tCO_{2e}.

It has also been verified as per the guidelines in ACM0002 Version 21.0 that the calculations for the GHG emission reductions are done in accordance with the aforesaid methodology/06/. The project activity is not a part of any other GHG allowance trading program, and the concerned monitoring period was not found overlapping with any of the VCS or CDM verifications so far. The total emission reductions applied for the current monitoring period under VCS are 21,847 tCO_{2e} and are not accounted for in any other program. Therefore, the assessment team concluded that all physical features of the project activity in the registered PD are in place and the project participant has operated the project activity as per the registered PD /01/.

Assessment team concludes the following:

1. There are no material discrepancies between project implementation and the project description provided in the registered PD/01/.
2. The monitoring plan is implemented completely and the monitoring system (i.e., process and schedule for obtaining, recording, compiling, and analyzing the monitored data and parameters) is appropriate.
3. There are no material discrepancies between the actual monitoring system, and the monitoring plan set out in the project description and the applied methodology/06/.
4. The project activity is registered confirmed been registered with CDM Ref No:10483/13/. It has been confirmed by the assessment team that PP is not claiming emission reductions for the same monitoring period in both the programmes. PP has confirmed and provided a no double counting declaration for the same/8/.
5. The project has not received or sought any other form of environmental credit or has become eligible to do so since validation or previous verification.
6. The GHG emission reductions or removals generated by the project have not been included in an emissions trading program or any other mechanism that includes GHG allowance trading/8/.
7. The project activity is complying with indicators for sustainable development as discussed in detail under section 1.12 of MR.

22.2 GWh of electricity to the national grid as verified from the invoices raised/17/ which has resulted in a reduction of 21,847 tCO_{2e} GHG emissions. The assessment team conducted a site visit to verify the implementation of the monitoring plan as per the registered PD/1/. It was confirmed through the interview of the PP and monitoring personnel that the quantity of net electricity generation supplied by the project plant to the grid is calculated as difference between:

- (a) the quantity of electricity supplied by the project plant/unit to the grid.
- (b) the quantity of electricity the project plant/unit from the grid, both reliably monitored and invoiced based on calibrated EDM I electricity meters.

The SDG contributions are listed under section 1.12 of the MR, and the contributions were confirmed with the PP during the on-site audit. The main sustainable development contributions have been listed under Energy security and supply, Health, Employment opportunities and Technology transfer.

Item	Evidence gathering activities, evidence checked, and assessment conclusion:
Audit history	The details of the audit history as described under section 1.2 of the MR have been confirmed from the publicly available information and previous verification reports on the project webpage and is found consistent/07/.
Double counting and participation under other GHG programs	The project is not receiving or seeking credit for reductions and removals from a project activity under another GHG program. This has been verified through the letter of declaration/08/ shared by the PP. Also, secondary research has been carried out by the assessment team in the registries such as CDM, GS, GCC and project is not registered in any other GHG program.
No double claiming with emissions trading programs or binding emission limits	The project reductions and removals or project activities are not included in an emissions trading program or binding emission limit. This has been verified through the letter of declaration/08/ shared by the PP.
No double claiming with other forms of environmental credit	The project activity is not sought, received, or is planning to receive credit from another GHG-related environmental credit system. This has been verified through the letter of declaration/08/ shared by the PP.
Supply chain (scope 3) emissions double claiming	The project activities do not affect the emissions footprint of any product(s) (goods or services) that are part of a supply chain.

Sustainable development contributions	The project activity is complying for sustainable development as discussed under section 1.12 of MR. PP has claimed six SDGs under this section namely, SDG 1, 2, 4, 7, 8 and 13. SDG 1.4: Indicator 1.4.1: Proportion of population living in households with access to basic services: Under this SDG goal, 15 women are working daily during the MP (01-Jan-2023 to 31-Dec-2023) in Caritas Solitude – Lakaz Lespwar which was being verified through “Appendix to MR GreenYellow Ethics charter” (Appendix n° 7)/21/. This activity is helping families in their time of need by providing them with employment. SDG 2.4: Indicator 2.4.1 Proportion of agricultural area under productive and sustainable agriculture. Under this SDG goal, the plants and vegetables were being planted in a more sustainable manner which cover one of the four zones of the PV plant which was verified through Geo tagged plant site photos/15/. SDG 4.4: Provide training in agro/bio-organic farming for women in agriculture: 15 women from the solitude community and farmers at Caritas Solitude were given training course by the GreenYellow whose objective was to create awareness about the environment and their health during the current monitoring period which was being verified through “Appendix to MR GreenYellow Ethics charter” (Appendix n° 8)/21/. SDG 4.7: Provide awareness to younger generation about climate change and energy transition: During this MP (01-Jan-2023 to 31-Dec-2023) 183 children and students were being invited to the Solitude Solar farm to better the solar technology which is also verified using Voltas Log – Solitude 16 MW/24/. SDG 7.2: 7.2.1 - Renewable energy share in the total final energy consumption: During the fourth MP (01-Jan-2023 to 31-Dec-2023) the project has successfully produced 22.2 GWh of electricity energy which is also verified using “Appendix to MR GreenYellow Ethics charter” (Appendix n° 5-Jan-Dec 23 Production bills)/21/. This helps the native country to expand their renewable energy potential and become carbon neutral.
---------------------------------------	--

	SDG 7.b: 7.b.1 - Installed renewable energy-generating capacity in developing countries (in watts per capita): During this MP (01-Jan-2023 to 31-Dec-2023) 10,000 Mauritian households were provided with solar electricity that will help become self-reliant and sufficient which is also verified using ER spread sheet/04/ and Electricity sale and purchase invoices to Central Electricity Board, Mauritius/17/. SDG 8: Proportion of local/regional employment opportunities: During this MP (01-Jan-2023 to 31-Dec-2023) a total of 175 workers during the construction and roughly 10-15 workers during the operation phase were provided local employment which is also verified using “Appendix to MR GreenYellow Ethics charter” (Appendix n° 7 “Staff Log”)/21/. SDG 13: Tons of greenhouse gas emissions avoided or removed: During this MP (01-Jan-2023 to 31-Dec-2023), the project reduces 21,847 tCO₂ GHG emissions that was being verified through Appendix to MR GreenYellow Ethics charter”(Appendix n° 5-Jan-Dec 23 Production bills and Appendix n° 6-Jan-Dec 23 Consumption bills)/21/. It will generate indirect employment by increasing the competition amongst the local industries by reducing the country’s dependency on fossil fuels.
Additional information relevant to the project	N/A

4.2 Safeguards and Stakeholder Engagement

4.2.1 Stakeholder Identification

This part is not applicable to the project activity. N/A

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Stakeholder identification	N/A
Legal or customary tenure/access rights	N/A

Stakeholder diversity and changes over time	N/A
Expected changes in well-being	N/A
Location of stakeholders	N/A
Location of resources	N/A

4.2.2 Stakeholder Consultation and Ongoing Communication

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Ongoing consultation	The project proponent has established the on-going communication mechanism with the stakeholders involved, who can reach them in case of any grievances through: Direct communication: A grievance logbook/20/ and contact information of the authorized person from the owner company is available at village head's office so that the local stakeholders can reach these people whenever they have any complaints, suggestions, or ideas about the project. Also, during the on-site visit, local stakeholders were interviewed about the ongoing consultation and grievance mechanism, and it has been confirmed that the locals have knowledge about the same.
Date(s) of stakeholder consultation	Grievance Logbook/20/ has been available since the last monitoring period. During the on-site visit, logbook has been checked and is found to be available in the project site office.
Communication of monitored results	The grievances logbook/20/ and contact information of the authorized person from the owner company is available at village head's office so that the local stakeholders can reach these people whenever they have any complaints, suggestions, or ideas about the project. This information was confirmed by the assessment team during the on-site visit and through interviewing the local stakeholders/19/.
Consultation records	Logbook and declaration

Stakeholder input	No feedback is provided to the logbook. The logbook has been checked and no feedback has been provided by the local stakeholders. During the onsite visit/19/ local stakeholders were interviewed and they have no negative inputs regarding the project activity.
-------------------	--

4.2.3 Free, Prior, and Informed Consent

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Consent	A First Local Stakeholder Consultation (LSC) meeting was conducted at the site office of Voltas Yellow Ltd on July 6, 2018, to gather feedback and concerns from stakeholders regarding the PV-Based Power Generator project by Voltas Yellow Ltd in Solitude, District of Pamplemousses, Mauritius. Invitations were sent via cards and a press advertisement in the local newspaper. Participants were encouraged to provide their feedback openly and transparently following a presentation on the proposed project activities. All public comments received during the 1-hour meeting were addressed, and no negative feedback was reported. The meeting began with an informative presentation on solar PV-based power generation and its role in mitigating global warming. The presentation covered topics such as global warming, the impact of greenhouse gases (GHGs), the significance of the Kyoto Protocol, and the Clean Development Mechanism (CDM) as a means of reducing GHG emissions. Dr. Revin Panray Beeharry, the meeting facilitator, elaborated on the climate change process and discussed strategies for combating it by promoting cleaner technologies, including solar PV. He highlighted the direct and indirect benefits of such projects and reassured participants about the minimal environmental impact of the project activities. Dr. Beeharry also emphasized that the project would contribute positively to the socio-economic development of the Solitude and Triolet areas and support sustainable development goals as advocated by the Kyoto Protocol and the United Nations Framework Convention on Climate Change. During the Question-and-Answer session, the audience gained a clearer understanding of how the PV project is less polluting and has no side effects compared to conventional power generation methods. Attendees shared their perspectives on the improvements and

	benefits the project would bring to the village. The audience expressed optimism about such positive development projects and considered the potential long-term sustainability of the initiative, questioning whether it would endure for at least 20 years that was being verified through “Appendix n° 4 - Stakeholder Minutes of Meeting at Solitude 11072018 for Green Yellow Ltd (Final)21/
Outcome of FPIC discussion	Overall, stakeholders expressed satisfaction with the initiative and were supportive of the project, viewing it as a catalyst for socio-economic development in the area. The project has not involved any land encroachment, relocation of individuals without consent, or any form of physical or economic displacement which can be verified through “Appendix n° 4 - Stakeholder Minutes of Meeting at Solitude 11072018 for Green Yellow Ltd (Final)21/ which contains no such concerns.

4.2.4 Grievance Redress Procedure

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Grievance received and steps taken to resolve the grievance including the outcomes of the resolution	No grievance received during the current monitoring period. The logbook has been checked and no feedback has been provided by the local stakeholders. During the onsite visit/19/ local stakeholders were interviewed and they have no negative inputs regarding the project activity.
Grievance redress procedure	During the current verification, it was communicated by PP and confirmed by assessment team that there is no grievance registered in the grievance logbook/20/. The project proponent has established the on-going communication mechanism with the stakeholders involved, who can reach them in case of any grievances through: Direct communication: A grievance logbook /20/ and contact information of the authorized person from the owner company is available at village head’s office so that the local stakeholders can reach these people whenever they have any complaints, suggestions, or ideas about the project. The same has been confirmed by the

assessment team during the onsite visit and interviewees with the local stakeholder/19/

4.2.5 Public Comments

Comments received	Actions taken by the project proponent	Evidence gathering activities, evidence checked, and assessment conclusion
N/A	N/A	N/A

4.2.6 Risks to Local Stakeholders and the Environment

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Risks to stakeholder participation	No risk identified, the stakeholders were interviewed during the site visit and no negative feedback is received
Working conditions	The interviewed plant site personnel reported no health and safety risks or untoward incidents during the current MP. During the site visit, the working environment of the project site was observed, and the workers were provided with Occupational Health & Safety Policy - Global/23/.
Safety of women and girls	Currently, no woman is employed in an on-site operational role which has been confirmed during the on-site visit/19/ and employment records/16/, however no risk is identified
Safety of minority and marginalized groups, including children	No risk identified as observed during the on-site visit/19/
Pollutants (air, noise, discharges to water, generation of waste, release of hazardous materials)	It was confirmed during the on-site audit/19/ that the operation of the solar PV modules generates no noise, which was also confirmed during the interviews conducted with the local stakeholder. During the on-site visit, it was also observed that the water discharge was segregated and sent to authorized waste handlers to treat it accordingly. This was confirmed by the on-site audit/19/ conducted by the PP for wastewater discharge treatment.

4.2.7 Respect for Human Rights and Equity

4.2.7.1 Labor and Work

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Discrimination and sexual harassment	No discrimination and harassment based on sex has occurred, and none will be granted permitted. The GreenYellow is committed in terms of discrimination and sexual harassment through the policy: <u>“Politique Anti-harcèlement et non discrimination 202303”</u> (Appendix n°2)/22/ and the same document was checked and was found to be appropriate.
Management experience	In the project design/implementation there is no new entity involved as of now.
Gender equity in labor and work	The aspect of gender equity and work has also been considered while performing the project activity. The same was verified through “Appendix to MR GreenYellow Ethics charter” (Appendix n°1)/21/ document and was found to be appropriate and valid.
Human trafficking, forced labor, and child labor	The human trafficking, forced labor and child labor issues were well handled at the project site which were also confirmed through “Appendix to MR GreenYellow Ethics charter” (Appendix n°1)/21/ document and were found to be valid and appropriate.

4.2.7.2 Human Rights

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Human rights	Human rights issue was addressed correctly at the project activity site that was verified through “Appendix to MR GreenYellow Ethics charter” (Appendix n°1)/21/ document and was found to be appropriate.

4.2.7.3 Indigenous Peoples and Cultural Heritage

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Preservation and protection	The project is not affected by the indigenous people rights and cultural heritage due to its location.

of cultural
heritage

4.2.7.4 Property Rights

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Disputes over rights to territories and resources	N/A
Respect for property rights	Legal contracts have been signed between Voltas Yellow Ltd and each stakeholder before the project's implementation. These contracts aim to protect and preserve the property rights of stakeholders, including intellectual properties, local communities, and customary rights holders. The contracts will be reviewed during the project's audit.

4.2.7.5 Benefit Sharing

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Summary of the benefit sharing plan	The contracts do not include a benefit-sharing plan; they only grant Voltas Yellow the right to occupy the land in exchange for paying rent to the owners.
Benefit sharing during the monitoring period	N/A

4.2.8 Ecosystem Health

An Environmental Impact Assessment (EIA) was required for the solar power plant as a "Power Generating Plant" and was conducted in accordance with ESPA requirements. An EIA license was obtained on September 5th, 2017, from the Ministry of the Environment and Sustainable Development for the establishment and operation of the solar PV farm.

To date, we have submitted eight Environmental Monitoring Reports (EMRs), which are bi-annual reports, for the operational phase of the 16.328 MW Photovoltaic Power Generating Plant. These submissions comply with section 18(2)(l) of the Environment Protection Act 2002 and clause 4 of the EIA license ENV/DOE/EIA/1716, granted on September 5th, 2017, for the proposed Photovoltaic Plant at Solitude.

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Impacts on biodiversity and ecosystems	No risk identified
Soil degradation and soil erosion	Areas cleared during construction that are not covered by the PV panels have been covered with topsoil to allow vegetation to regenerate. Additionally, to manage run-off from the water collected by the solar panels, vegetation has been planted to capture the excess run-off. This vegetation not only prevents erosion but also provides habitat for fauna species. Landowners are permitted to cultivate compatible crops within the PV farm.
Water consumption and stress	Only clear water without chemicals is used to clean the solar panels. The amount of water used is monitored annually to ensure consumption remains constant and non-excessive.
Usage of fertilizers	A process has been implemented to use fertilizers only in areas of the PV plant that are inaccessible to machines. The use of fertilizers in these areas is monitored.

4.2.8.1 Rare, Threatened, and Endangered species

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Species or habitat	The project is neither located in nor adjacent to habitats for rare, threatened, or endangered species.

4.2.8.2 Introduction of Species

Species introduced	Evidence gathering activities, evidence checked, and assessment conclusion
N/A	N/A

Existing invasive species	Evidence gathering activities, evidence checked, and assessment conclusion
N/A	N/A

4.2.8.3 Ecosystem conversion

Item	Evidence gathering activities and evidence checked
Ecosystem conversion	N/A

4.3 Accuracy of Reduction and Removal Calculations

The emission reductions are based on the introduction of renewable energy (solar power plants) by the project activity.

The emission reduction calculation is accurate from the point of data collection, transfer and the formulas applied are in accordance with the applied methodology/06/ and registered PD/01/.

The default values applied for calculations were consistent with the registered PD/01/.

The data transfer from the monthly generation sheets to final emission reduction calculation sheet/04/ has been transparently described and followed. The final values are reproducible, and all the calculations are linked and clearly presented in the emission reduction calculation sheet/04/.

The assessment team can conclude that the monitoring for the concerned period has been done in accordance with the procedures laid out in the registered documents and the resulting emission reductions are measurable and conservative.

4.4 Quality of Evidence to Determine Reductions and Removals

The emission reductions calculations for this verification were verified as per the monitoring plan against all the necessary evidence as listed under Appendix II of the verification report, that were found to be appropriate and reliable sources of information. The information was also cross-checked through the received documents and interviews conducted and observations made during the physical site visit conducted by the assessment team.

The assessment team confirms that appropriate methods and formulae for calculating baseline emissions have been followed. The assumptions, emission factors and default values that were applied in the calculations are justified. The actual emission reduction achieved during the current monitoring period is less than the estimated amount of emission reductions at the time of validation, therefore no further assessment was required. All the data was made available and has been monitored as per the required monitoring frequency. The means of verification for the values of parameters, used for baseline emission calculation, is described above in previous sections.

Parameters available at the time of Validation:

Parameters	Value	VVB Assessment
EF _{grid,y}	0.9915 tCO ₂ /MWh	CO ₂ emission factor of the grid is calculated in accordance with "Tool to calculate the emission factor for an electricity

		system"/11/. The value shall be constant for the entire first crediting period. The value was found to be consistent with the PD/01/, across the MR/03/ and the ER sheet/04/.
EF _{grid,OM,y}	1.0282 tCO ₂ /MWh	Operating Margin CO₂ emission factor for grid connected power generation in year y calculated using the CDM "Methodological Tool to calculate the emission factor for an electricity system". Source of data is IGES List of Grid Emission Factors. The value was found to be consistent with the registered CDM PDD/02/, registered VCS PD/01/ the ER sheet/04/ and is fixed ex-ante for the project activity.
EF _{grid,BM,y}	0.8814 tCO ₂ /MWh	Build Margin CO₂ emission factor for grid connected power generation in year y calculated using the CDM "Methodological Tool to calculate the emission factor for an electricity system". Source of data IGES List of Grid Emission Factors. The value was found to be consistent with the registered CDM PDD/02/, across registered VCS PD/01/, MR/03/ and the ER sheet/04/.
The percentage share of total installed capacity of solar PV	2.6%	The percentage share of total installed capacity of the solar PV in the total installed grid connected power generation capacity in the host country. Source of data-http://publicutilities.govmu.org/ The value is consistent with registered CDM PDD/02/ and registered VCS PD/01/ and fixed ex-ante for the project activity.
The total installed capacity of solar PV	21.2 MW	The total installed capacity of grid-connected solar PV in the host country. Source of data http://publicutilities.govmu.org/ The value is consistent with CDM PDD/02/ and registered VCS PD/01/ across the MR/03/.

Parameters monitored during the Verification:

Parameter	EG_{facility,y} Quantity of net electricity generation supplied by the project plant/unit to the grid in year y
-----------	---

Means of verification	Criteria/ Requirements	Assessment /observations											
	Measuring/Reading/Recording Frequency	The parameter is monitored continuously and recorded monthly for the estimation of GHG Emission Reductions. The parameter is being monitored continuously through the main EDM1 meter with Accuracy class 0.2S installed at CEB JINFEI substation.											
	Is measuring and reporting frequency in accordance with the monitoring plan and monitoring methodology? (Yes/No)	Yes, the frequency is in-line to the registered monitoring plan/01/											
	Monitoring Equipment	Electricity meters of the following details have been installed at JINFEI substation. <table border="1"> <tr> <td colspan="3">Make: EDM1 Model: MK6E</td></tr> <tr> <td colspan="3">Accuracy class: 0.2S</td></tr> <tr> <td>Meter</td><td>Main</td><td>Back-up</td></tr> <tr> <td></td><td>#16538506</td><td>#16538507</td></tr> </table> The meter details were cross verified at the time of On-site audit and the geotagged meter pictures were shared by the PP from the on-site/19/.	Make: EDM1 Model: MK6E			Accuracy class: 0.2S			Meter	Main	Back-up		#16538506
Make: EDM1 Model: MK6E													
Accuracy class: 0.2S													
Meter	Main	Back-up											
	#16538506	#16538507											

	Is the accuracy of the monitoring equipment as stated in the monitoring plan? If the monitoring plan does not specify the accuracy of the monitoring equipment, does the accuracy of the monitoring equipment comply with local/national standards, or as per the manufacturer's specifications	As per the MR, the accuracy of the EDM1 meter is 0.2S and has also been verified during the site inspection. The calibration frequency of the meters as per the PPA is confirmed of the installed meters was carried out on 22/06/2020, therefore the meters are found to be calibrated until 21/06/2024 and no calibration was required during the current monitoring period/09/.
	Is the accuracy valid for the entire measuring range or do different accuracy levels apply to different measuring ranges?	As per the monitoring plan/01/, the accuracy of 0.2S is valid for the entire measuring range. As per PPA para 12.1.4, CEB shall inspect each CEB meter upon installation and at least once every year thereafter, The periodic test was not conducted during the current MP i.e.,2022 since the same is at the discretion of the CEB these test, however the latest accuracy test was conducted on 14/02/2023 and both the meters were found to be functioning well within the defined range/10/, therefore the VVB concluded that meters reading obtained during the monitoring period were accurate and thus found acceptable by the VVB.

	Calibration frequency/interval:	The state electricity regulator, CEB is responsible for the certification of CEB meters through an accuracy test at least once every 4 years thereafter or at any time the readings of Net Energy from the CEB meter and seller Back-up meter differ by an amount greater than 0.5%. The initial calibration conducted on 22/06/2020 is still valid during the monitoring period (valid up to 21/06/2024)/09/.
	Is the calibration interval in line with the monitoring plan and/or methodology? If the monitoring plan does not specify the frequency of calibration, is the selected frequency in accordance with the local/national standards, pending until the findings are closed or as per the manufacturer's specifications?	As per the monitoring plan in the registered PD/01, meter is supposed to be calibrated once in 4 years. The initial calibration conducted on 22/06/2020 still valid during the monitoring period (valid up to 21/06/2024)/09/.
	Is the calibration of measuring equipment carried out by an accredited person or institution?	The calibrations are performed by CEB (state regulator).
	Is(are) calibration(s) valid for the whole reporting period?	Yes, it is valid for the entire Monitoring Period. The initial calibration conducted on 22/06/2020 is still valid during the monitoring period (valid up to 21/06/2024)/09/. Therefore, it is confirmed that no calibration was required during the current monitoring period.

	Is the calibration carried out for a measuring range comparable with the range for which measurements have been carried out?	Yes, the calibration has been carried out for measuring range comparable with the range for which measurements have been carried out.
	How were the values in the monitoring report verified?	Cumulative value of $EG_{Facility,y}$ for entire monitoring period is reported in the monitoring report, however the monthly values are reported in the ER calculation sheet/04/. The monthly values were verified from monthly generation and import invoices/17/ issued by Voltas Yellow Ltd and CEB. The value of this parameter for the current monitoring period was verified as net 22.2 GWh/17/.
	Does the data management ensure correct transfer of data and reporting of emission reductions and are necessary QA/QC processes in place?	Yes, the adequate QA/QC procedures were followed by the PP. The data transfer process for the stated parameter is in accordance with the registered monitoring plan/01/and applied methodology/06.
Findings	CLO2 was raised and closed.	
Conclusion	The parameter has been monitored appropriately, in accordance with the registered monitoring plan (as per measurement methods and procedures to be applied) and applied methodology. The monitoring results were recorded consistently as per the approved frequency in the monitoring plan. The verification team can confirm that the project is implemented as per the registered PD and there is no discrepancy observed between the actual monitoring system and the monitoring plan set out in the project description and the applied methodology outlined in the registered VCS PD/01/. The emission reduction calculation for the project activity is based on the electricity supplied by the solar panels. Since 100% data was verified, the assessment team can ascertain that the values taken for emission reduction calculation are free from material errors.	

4.5 Non-Permanence Risk Analysis

Not applicable for the project activity.

4.6 Verification Summary

Earthood Services Private Limited (ESPL), contracted by Voltas Yellow Ltd, has performed the independent verification of the emission reductions for the VCS project activity (VCS ID- 2308) grid connected solar PV Project in Mauritius for the monitoring period 01/01/2023 to 31/12/2023 as reported in the Monitoring Report version 5.0 dated 08/07/2024. Voltas Yellow Ltd is responsible for the collection of data in accordance with the monitoring plan and the reporting of GHG emissions reductions from the project activity.

ESPL commenced the verification based on the baseline and monitoring methodology ACM0002, Version 21.0/06/, the monitoring plan contained in the revised VCS PD/01/ Version 1.2 dated 08/09/2020 and VCS guidelines version 4.4. The verification approach of the assessment team is based on the understanding of the risks associated with reporting of GHG emission data and the controls in place to mitigate these.

ESPL planned and performed the verification by obtaining evidence and other information and explanations that ESPL considered necessary to give reasonable assurance that reported GHG emission reductions are fairly stated.

4.7 Verification Conclusion

In our opinion the GHG emissions reductions reported for the project activity for the period 01/01/2023 to 31/12/2023 are calculated and stated in the Monitoring Report/03/ version 5.0 dated 08/07/2024. The GHG emission reductions were calculated correctly based on the approved baseline and monitoring methodology ACM0002, Version 21.0/06/ and the VCS standard/05/.

Verification period: From 01/01/2023 to 31/12/2023 (including both days)

Verified GHG emission reductions and carbon dioxide removals in the above verification period:

Vintage period	Baseline emissions (tCO ₂ e)	Project emissions (tCO ₂ e)	Leakage emissions (tCO ₂ e)	Reduction VCUs (tCO ₂ e)	Removal VCUs (tCO ₂ e)	Total VCUs (tCO ₂ e)
01-Jan-2023 to 31-Dec-2023	21,847	0	0	21,847	0	21,847
Total	21,847	0	0	21,847	0	21,847

The non-permanence risk rating (%)	N/A
If applicable, the Long-term Average (LTA), whether it has been properly updated, and if it has been reached.	N/A
Whether a loss has been appropriately accounted for, in accordance with the VCS Program rules, if applicable.	N/A

ii) Complete the table below:

Vintage period	Baseline emissions (tCO ₂ e)	Project emissions (tCO ₂ e)	Leakage emissions (tCO ₂ e)	Buffer pool allocation (tCO ₂ e)	Reductions VCU's (tCO ₂ e)	Removals VCU's (tCO ₂ e)	Total VCU issuance (tCO ₂ e)
01-Jan-2023 to 31-Dec-2023	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total	N/A	N/A	N/A	N/A	N/A	N/A	N/A

4.8 Ex-ante vs Ex-post ERR Comparison

Vintage period	Ex-ante estimated reductions/removals	Achieved reductions/removals	Percent difference	Explanation for the difference
01-May-2020 to 31-Dec-2021	48,765	39,578	19%	Lower plant performance due to power phase damage (manufacturing defect)
01-Jan-2022 to 31-Dec-2022	28,978	23,557	19%	Lower plant performance due to power phase damage (manufacturing defect)
01-Jan-2023 to 31-Dec-2023	28,777	21,847	24%	Lower electricity generation in 2023 due to earth fault on 22 kV cable, in May and October.

Total	106,520	84,982	20%	
-------	---------	--------	-----	--

Approved by



Dr. Kaviraj Singh

Managing Director

Earthood Services Private Limited

Date: 30-09-2024

Place: Gurugram, Haryana

APPENDIX I: ABBREVIATIONS

Abbreviations	Full texts
BE	Baseline Emission
CAR	Corrective Action Request
CDM	Clean Development Mechanism
CEB	Central Electricity Board
CL	Clarification Request
CO ₂	Carbon di oxide
CP	Crediting Period
DR	Desk Review
EB	Executive Board
EF	Emission Factor
ER	External Resource
EIA	Environmental Impact Assessment
ESPL	Earthood Services Private Limited
FAR	Forward Action Request
GHG	Green House Gas
GP	Grouped Project Activity
MR	Monitoring Report
PD	Project Description
PDD	Project Design Document
PP	Project Proponent
PPA	Power Purchase Agreement
tCO ₂ e	Tons of Carbon dioxide equivalent
TA	Technical Area
TR	Technical Reviewer
UNFCCC	United Nations Framework Convention on Climate Change
VCS	Verified Carbon Standard
VCU	Verified Carbon Units
VVB	Validation and Verification Body

APPENDIX II: REFERENCES

Sr.No.	Title of document	Version	Provided by
1.	Registered VCS PD	Version 1.2 dated:08/09/2020	VCS
2.	Registered CDM PDD	Version 1.4, dated:02/05/2019	CDM
3.	VCS Monitoring Report (Final)	Version 5.0 dated 08/07/2024	PP
4.	ER spread sheet	-	PP
5.	a) VCS Standard b) VCS Programme guide	Version 4.7 Version 4.4	VCS
6.	Methodology: ACM0002. "Largescale Consolidated Methodology: Grid-connected electricity generation from renewable sources"	Version 21.0	CDM
7.	VCS Project Webpage: https://registry.terra.org/app/projectDetail/VCS/2308	Last accessed on 14/08/2024	VCS
8.	No double counting declaration by PP	Dated: 29/05/2023	PP
9.	Electricity meter calibration report	22/06/2020	CEB
10.	Accuracy Test: Electricity meters annual inspection record conducted by CEB for main meter and check meter:	14/02/2023	CEB
11.	Tool 07: Tool to calculate the emission factor for an electricity system	Version 6.0	CDM
12.	EIA License	05/09/2017	PP
13.	CDM webpage PA 10483 https://cdm.unfccc.int/Projects/DB/RWTUV1557984446.68/view).	Last accessed on 14/08/2024	PP
14.	Line diagram for metering location	-	PP
15.	Geo tagged plant site photos	-	PP
16.	Employment records	Current MP	PP

17.	Electricity sale and purchase invoices to Central Electricity Board, Mauritius.	2022	PP
19.	VVB On-Site Visit records	17/05/2023	WB
20.	Grievance Logbook	2022	PP
21.	Appendix n° 4 - Stakeholder Minutes of Meeting at Solitude 11072018 for Green Yellow Ltd (Final)	2023	PP
22.	“Politique Anti-harcèlement et non discrimination_202303” (Appendix n° 2)	2023	PP
23.	Occupational Health & Safety Policy - Global	February 2022	PP
24.	Visitors Log – Solitude 16 MW	2023	PP

APPENDIX III: COMPETENCE STATEMENT

Name	Jinesh Amlani		
Education	M.Sc. Energy Systems B.Sc. Physics		
Experience	8+ years		
Field	Climate Change & Environment		
Approved Roles			
Team Leader	YES (VM Only)		
Validator	YES (VM Only)		
Verifier	YES (VM Only)		
Local expert	YES (India)		
Financial Expert	NO		
Technical Reviewer	YES		
TA Expert (X.X)	YES (TA.1.2, TA 3.1)		
Reviewed by	Shifali Guleria (Quality Manager)	Date	16/05/2024
Approved by	Deepika Mahala (Technical Manager)	Date	16/05/2024

Name	Anurag Verma

Education	M.Tech (ESN Programme) B.E (Mechanical Engineering)		
Experience	6 months		
Field	Climate Change & Environment		
Approved Roles			
Team Leader	NO		
Validator	YES		
Verifier	YES		
Local expert	NO		
Financial Expert	NO		
Technical Reviewer	NO		
TA Expert (X.X)	NO		
Reviewed by	Shifali Guleria (Quality Manager)	Date	27/05/2024
Approved by	Deepika Mahala (Technical Manager)	Date	27/05/2024

Competence Statement			
Name	Shifali Guleria		
Education	M.Sc. (Environmental Studies and Resource Management), TERI University		
Experience	3+ year		
Field	Climate Change		
Approved Roles			
Team Leader	YES		
Validator	YES		
Verifier	YES		
Methodology Expert	YES (AMS-I.A., AMS-II.G., AMS-II.E., AMS-III.A.V., AMS-I.D, ACM0002)		
Local expert	YES		
Financial Expert	NO		
Technical Reviewer	YES		
TA Expert	YES (1.2, 3.1)		
Reviewed by	Deepika Mahala	Date	18/02/2022
Approved by	Ashok Gautam	Date	18/02/2022

APPENDIX IV: OVERVIEW FINDINGS

Table 1. CL from this verification

CL ID	01	Section no.	Date : 17/05/2024
Description of CL			

In section 3 “ <i>Implementation Status of the Project Activity</i> ” PP shall provide substantial documents for the shutdown event which occurred during the monitoring period of the plant due to the earth fault on the 22 kV cable in the months of May and October.	
Project participant response	Date : 03/06/2024
<i>The incident report & Insurance claim form have been provided for the fault occurred in May.</i> <i>The fault which occurred in October was of transient nature and no incident report has been made.</i> <i>Only the corresponding insurance claim form has been provided.</i>	
Documentation provided by project participant	
May: “23 05 10_Incident report” “23 05 11 Claim form Solitude 22kV Cable earth fault” October: “23 10 11 Claim form Solitude 22kV Cable Earth Fault”	
DOE assessment	Date: 25/06/2024
VVB has assessed both the documents May: “23 05 10_Incident report” & “23 05 11 Claim form Solitude 22kV Cable earth fault” as well as October: “23 10 11 Claim form Solitude 22kV Cable Earth Fault” and confirmed that both the documents are appropriate which further validates the PP’s claim that the earth fault actually took place in the 22kV cable line of Solitude Solar Power Plant. The finding stands CLOSED. This CL is CLOSED.	

CL ID	02	Section no.		Date : 17/05/2024
Description of CL				
1. In section 5.4 “<i>GHG Emission Reductions and Carbon Dioxide Removals</i>” Table 2, PP shall provide substantial documents for lower plant performance due to power phase damage (manufacturing defect) that occurred during the monitoring period 01-Jan-2022 to 31-Dec-2022. 2. In section 5.4 “<i>GHG Emission Reductions and Carbon Dioxide Removals</i>”, PP shall elaborate on the all the reasons applicable for the percentage difference between the ex-ante emission reductions and the achieved emission reductions for the given project activity.				
Project participant response				Date : 03/06/2024

1. The low plant performance due to power phase damage in 2022, was recurring since 2020. The delivery and replacement of defective parts on site took place only by 2022 due to the COVID pandemic. Attached document <i>"Manufacturer_Defect_PowerPhase_mail"</i> as supporting evidence. 2. The percentage difference between the ex-ante emission reductions and the achieved emission reductions for the given project activity has been explained by two major reasons: - 2021 & 2022: Power phase damage. - 2023 : Earth Fault 22kV cable However, the difference can also be explained by the following reasons : - 2021 : Power supply communication circuit card failure - 2022 : Faulty inverter fans and faulty harmonic filters - 2023 : Faulty inverter fans	
Documentation provided by project participant	
<i>"Manufacturer_Defect_PowerPhase_mail"</i>	
DOE assessment	Date: 25/06/2024
1. VVB has assessed the document <i>"Manufacturer_Defect_PowerPhase_mail"</i> and confirmed that there were incidents of power phase blocks in 2020 but the document does not provide any evidence for the delivery and replacement of defective parts on site took place by 2022 due to the COVID pandemic. The finding stands OPEN. 2. VVB has assessed the justification that is being provided for the percentage difference between the two emission reductions for the project activity and confirmed that the document <i>"Manufacturer_Defect_PowerPhase_mail"</i> does not validate the claim that the power phase damage actually occurred in 2021 & 2022 but however the earth cable fault in 22kV line that occurred in 2023 stands valid and appropriate. The finding stands OPEN. This CL is OPEN.	
Project participant response	Date : 12/08/2024
• 2020/2021 : Diagnosis of problem and further analysis prior to final replacement • 2021/2022 : delivery of power phases for replacement	
Documentation provided by project participant	
<i>"BCLYSPLU02775 (002)" - Bill of landing</i>	
DOE assessment	Date: 12/08/2024

1. VVB has assessed the document “BCLYSPLU02775 (002)”- *Bill of landing* dated 09/02/2022 and further confirmed that there was an actual delivery and replacement of the defective parts which took place on the site in the year 2022 after the diagnosis of problem and its further analysis prior to final replacement. The finding stands **CLOSED**.
2. VVB has assessed the document “BCLYSPLU02775 (002)”- *Bill of landing* dated 09/02/2022 which states that the plant site imported 3 pallets STC power block phase of 1000V validating the fact that there was an actual power phase damage that took place on site in 2021/2022. The finding stands **CLOSED**.

This CL is **CLOSED**.

Table 2. CAR from this verification

CAR ID	01	Section no.		Date : 17/05/2024
Description of CAR				
In section 1.1 “ <i>Summary Description of the Implementation Status of the Project</i> ” of the monitoring report version 4.3, PP shall add the details of dates of construction, commissioning and continued operation periods also as per the monitoring report template version 4.3				
Project participant response				Date : 03/06/2024
<i>Details of dates has been provided in the Monitoring Report</i>				
Documentation provided by project participant				
DOE assessment				Date: 25/06/2024
VVB has assessed the section 1.1 “ <i>Summary Description of the Implementation Status of the Project</i> ” of the monitoring report and found out that the details of dates of construction, commissioning and continued operation periods still needs to be added as per the monitoring report template version 4.3				
The finding stands OPEN .				
Project participant response				Date : 12/08/2024
Details of dates has been provided in the Monitoring Report in this chapter: “1.1 Summary Description of the Implementation Status of the Project”				
Documentation provided by project participant				
VCS MR Solitude 01012023-31122023_v5				
DOE assessment				Date: 12/08/2024

VVB has assessed the updated document “VCS MR Solitude 01012023-31122023_v5” dated 08/07/2024 and confirmed that the details of the dates of construction, commissioning and continued operation periods have been provided correctly that were cross verified with the “23 11 17 VY - EMP bi-annual report No.10 - October 2023” document dated 17 November 2023. This finding stands **CLOSED**.

This CAR is **CLOSED**.

CAR ID	02	Section no.		Date : 17/05/2024
Description of CAR				
In section 1.12 “Sustainable Development Contributions” SDG 8.3 under Proportion of local/regional employment opportunities it is stated that during the operations phase 10 to 15 jobs were generated but according to Appendix n°7 “Staff Log” document only 9 jobs were created during the operation phase. PP shall clarify the same.				
Project participant response				Date : 03/06/2024
<i>Clarification has been made in the Monitoring Report</i>				
Documentation provided by project participant				
DOE assessment				Date: 25/06/2024
The VVB has assessed the clarification that is being in the monitoring report and found out to be in line with the Appendix n°7 “Staff Log” document. The finding stands CLOSED .				
This CAR is CLOSED .				

APPENDIX V: COMMERCIALY SENSITIVE INFORMATION

No commercially sensitive information has been provided.

