



**Verified Carbon
Standard**

ZANO SOLAR POWER

1ST VERIFICATION REPORT



Report ID	1308
Project title	Zano Solar Power
Project ID	4389
Verification period	24-October-2023 to 31-December-2024
Original date of issue	21-April-2025
Most recent date of issue	16-September-2025
Version	03
VCS Standard Version	4.7
Client	Quadran Burkina Faso S.A.
Prepared by	re-carbon Gözetim Denetim ve Belgelendirme Ltd. Şti.

Approved by	Mrs. Fikriye Seda Atabek
Work carried out by	Mrs. Beyda Altuntaş

Summary:

The “Zano Solar Power (VCS Registry No.: 4389)” project activity is operated by” Quadran Burkina Faso S.A.”. The project activity is located close to the Zano village, in the Tenkodogo district of the Bougou province of Burkina Faso with the goal of generating electricity from the renewable power source “solar” and supply that to the national electricity grid.

The solar power plant includes 43 x “960 LONGI LR5-72HPH- 545M/550M” modules, 88 x “SUNGROW250HX” inverters, 3 x “SUNGROW MVS6750 (0.8kV – 33kV)” transformers, 396 “PVH Axone-DUO” trackers and the necessary project-internal cable connections. The project activity began commercial operation on 24/10/2023, when starting to export electricity to the national grid, thereby avoiding GHG emissions.

The purpose of this Verification was the independent and objective review of the project activity's monitored GHG reductions, as described and calculated in the Monitoring Report (Version 04), dated 22/05/2025. The Monitoring Report is based on the Monitoring Plan in the validated and registered Project Description (Version 4), dated 13/09/2024. The scope of this Verification covers a Monitoring Period that spans from 24 October 2023 to 31 December 2024 (both dates inclusive).

This verification was carried out in accordance with the requirements of ISO 14064-3 through a comprehensive review of the Monitoring Plan and Report. This included assessing the accuracy of calibration data, verifying compliance with the Monitoring Plan as described in the project documentation and conducting a remote site visit along with interviews with key stakeholders to ensure the accuracy and completeness of the project data. Additionally, all supporting documents were thoroughly reviewed.

During the process of this Verification, 11 Corrective Action Requests and 04 Clarification Requests were raised, all of which were resolved before the issuance of this Verification report. 01 Forward Action Requests were issued during the Verification of this project activity.

Although the Verification was conducted rigorously, there remains some uncertainty regarding the accuracy of the emission reductions due to the use of conservative assumptions in the baseline scenario and potential variations in future activity levels. These uncertainties however do not exceed 5%.

In conclusion, Re Carbon Ltd. is of the opinion that the " Zano Solar Power (VCS Registry No.: 4389)" project activity in Burkina-Faso, as outlined in the Monitoring Report (Version 04), dated 22/05/2025, complies with all relevant requirements of 14064-2, VCS and all applicable host Party criteria. The project activity correctly applies the baseline and monitoring methodology “ACM0002: Grid-connected electricity generation from renewable sources” (Version 21.0).

Therefore, Re Carbon Ltd. **certify** that the total” emission reductions from the project activity during the monitoring period, spanning from 24/10/2023 to 31/12/2024 (both dates inclusive) amount to **27,097 tCO_{2e}** and request issuance of these VCU's.

CONTENTS

1	INTRODUCTION	5
1.1	Objective.....	5
1.2	Scope and Criteria	5
1.3	Level of Assurance.....	5
1.4	Summary Description of the Project	6
2	VERIFICATION PROCESS	7
2.1	Method and Criteria.....	8
2.2	Document Review	9
2.3	Interviews.....	10
2.4	Site Visits.....	11
2.5	Resolution of Findings	12
2.6	Eligibility for Validation Activities	13
3	VALIDATION FINDINGS	14
3.1	Methodology Deviations.....	14
3.2	Project Description Deviations.....	14
3.3	New Project Activity Instances in Grouped Projects.....	14
3.4	Baseline Reassessment	14
4	VERIFICATION FINDINGS.....	15
4.1	Project Details	15
4.2	Safeguards and Stakeholder Engagement	17
4.3	Accuracy of Reduction and Removal Calculations.....	32
4.4	Quality of Evidence to Determine Reductions and Removals.....	33
4.5	Non-Permanence Risk Analysis.....	34
5	VERIFICATION OPINION.....	35
5.1	Verification Summary	35
5.2	Verification Conclusion	36
5.3	Ex-ante vs Ex-post ERR Comparison	36
	APPENDIX 1: COMMERCIALLY SENSITIVE INFORMATION	37
	APPENDIX 2: VERIFICATION PROTOCOL	38
	APPENDIX 3: VERIFICATION TEAM AND ITR COMPETENCE.....	49

Appendix 3-1: Appointment Certificates	50
APPENDIX 4: RISK ASSESSMENT FOR REMOTE SITE VISIT.....	53

1 INTRODUCTION

1.1 Objective

Under a Verification Agreement dated 26/02/2025, “re-carbon Gözetim Denetim ve Belgelendirme Ltd. Şti.” (hereafter referred to as “Re Carbon Ltd.”) was engaged by “Quadran Burkina Faso S.A.” (hereafter referred to as “PP”) to carry out the 1st Verification from CP 01 of the “Zano Solar Power (VCS Registry No.: 4389)” project activity. The aim of this Verification was to conduct an independent and objective review to determine whether:

- the Monitoring Report (MR) is in conformity with the requirements of the Monitoring Plan (MP) in the validated and registered Project Description (PD) and the approved methodology.
- the project activity is in conformity with the MP and the registered PD, and
- the data reported in the MR are complete and transparent.

1.2 Scope and Criteria

The scope of this Verification covers the independent and objective review of the project activity's monitored GHG reductions for a Monitoring Period, spanning from 24 October 2023 to 31 December 2024 (both dates inclusive).

Hereby, the MR (Version 04), dated 22/05/2025 was assessed against conformity with the requirements of the MP, as described in the validated and registered Project Description (PD) (Version 4), dated 13/09/2024, as well as the requirements of “ACM0002: Grid-connected electricity generation from renewable sources” (Version 21.0) and VCS (Version 4.7.)

The sole purpose of this Verification and certification is for use in the issuance process as part of the VCS project cycle. As such, Re Carbon Ltd. cannot be held liable by any party for decisions made or not made based on the Verification and Certification opinion that extend beyond this purpose.

1.3 Level of Assurance

Re Carbon Ltd. hereby confirm that the level of assurance provided in this Verification Report is “reasonable” with respect to material errors, omissions, and misrepresentations. To ensure this level of assurance, all data used in the GHG emission reduction calculations were reviewed in full, without reliance on sampling.

Due to safety concerns, the site visit for this initial verification was approved by VCS to be conducted remotely¹. The remote site visit however was still conducted in full compliance with all relevant protocols and with a commitment to transparency. This included the use of “live video”, the presence of Re Carbon Ltd.’s Local Expert (firm in Arabic, French and English) and an unbiased representation of the local community (participants selected by RE Carbon Ltd.). The audit was furthermore based on documentary evidence and stakeholder assertions and RE Carbon Ltd. found no issues or misrepresentations that affected the level of assurance as a result of the “remoteness” of the site visit.

¹ VCS Exemption Declaration dated 01 April 2025

In line with Verra's exemption letter dated 01 April 2025, a dedicated Risk Assessment for Remote Site Visit was prepared and is provided in Appendix 4 to this report. This assessment concludes that the residual risk of material misstatement or nonconformity due to the remote audit is low, and that the assurance level remains reasonable.

1.4 Summary Description of the Project

The project activity comprises a 24 MWc greenfield solar power plant located near the "Zano" village of the "Tenkodogo" district in the province of "Bougu" in Burkina-Faso. The electricity generated by the plant is fed into the national electricity grid of Burkina-Faso, hereby replacing fossil-fuel based grid electricity with electricity, generated from a renewable energy source (solar) and hence reducing GHG emissions from the fossil fuel-intensive grid mix (mainly fossil-fuel (87%) and hydropower sources (13%).

The solar power plant includes 43 x "960 LONGI LR5-72HPH- 545M/550M" photovoltaic modules, 88 x "SUNGROW250HX" inverters, 3 x "SUNGROW MVS6750 (0.8kV/33kV) transformers, 396 x "PVH Axone-DUO" trackers and project-internal cabling, as well as a power line to the "Zano" substation.

Throughout the monitoring period, the project activity has operated efficiently, generating a total of **47,291 MWh** of net electricity, delivered to the grid. There were no changes to the project activity or applicable legislation during this first monitoring period. Re Carbon Ltd. confirmed the project's technical details during a remote on-site audit through site visit interviews, a virtual walk-over of the project site and a thorough review of the technical specifications, photos and supporting documentation.

During this remote visit, the physical address and the "centroid" coordinates (Lat: 11° 42'13.248" N // Lon: 0° 07'26.4" W (WGS84)) of the project activity were confirmed and cross-referenced with documents and "Google-Earth" (*.kmz file).

2 VERIFICATION PROCESS

Verification activities are being planned and executed in line with Re Carbon Ltd.'s "Assessment Planning and Execution SOP" as follows:

- The Team Leader (TL) performs a strategic analysis to understand the activities and complexity of the project activity and to determine the nature and extent of the Verification activities.
- The TL develops a Verification Assessment Plan that describes the Verification activities and schedules during the desk review, prior to the site visit. The TL communicates this Verification Assessment Plan to the PP in order to ensure that related PP-Personnel are informed prior to the remote site visit. An "Assessment Planning Form" is sent to the PP by the TL for approval (or suggestions of changes) by the PP.
- The TL conducts a risk assessment of the GHG statement to identify potential risks of material misstatements or nonconformities with the criteria. This assessment takes into account the results of the materiality evaluation. The TL evaluates the risk of misstatement and determines the appropriate nature and scope of evidence-gathering activities.
- The evidence-gathering plan is developed based on the results of the TL's risk assessment and aims to reduce Verification risk to an acceptable level. It outlines the type and scope of evidence-gathering activities.

The Verification is conducted in accordance with the "VCS Verification Report Template," which includes the Protocol and other relevant reference documents. Upon completion of the Verification process, a draft Verification report, along with the Verification protocol and opinion, is prepared by the Team Leader (TL)

Thereafter, the full documentation, including the draft Verification report and its annexes, undergoes an internal quality control process at Re Carbon Ltd., referred to as the "Independent Technical Review" (ITR). This review is performed by a separate Team Leader who was not involved in the Verification activities for the specific project. During the ITR, the draft Verification Report and all supporting documents (e.g., emission factor calculations, additionality justifications, relevant Excel sheets, etc.) are thoroughly reviewed. As a result of this process, additional Clarification Requests (CLs) and Corrective Action Requests (CARs) may be issued to the PP to address any points requiring further clarification.

Once all CLs and CARs are resolved and ITR approval is granted, the final Verification report is prepared and reviewed by the Certification Manager. A "submission package" is then sent to the PP, along with the positive Verification opinion and all relevant documents. In case of a negative Verification opinion, the Verification Agreement is terminated.

For the Verification of this specific project activity, particularly in assessing the emission reductions achieved during the applicable monitoring period, a Verification Team was appointed, considering their required technical expertise in "solar energy", their knowledge of Project-Level Group 01 and GHG Project Type "Renewable Energy Production", as well as their experience in the host country, Burkina-Faso.

The selection of team members and the Independent Technical Reviewer (ITR) also took into account their relevant VCS Verification experience and prior roles in similar Verification Projects. The Verification Team and the ITR were assigned to this Verification activity on 28/02/2025, following the evaluation of these factors and the completion of RE Carbon Ltd.'s internal contract review process.

The details of the Verification Team and the ITR for this project activity are given in the table below:

Name	Role	Host Country Experience	Scope Coverage	Technical Expertise	Involvement
Mrs. Beyda Altuntaş	Team Leader	No	Yes	Yes	Administrative, Desk Review, Site Visit, Reporting
Dr. Karim Choukri	Regional Expert	Yes	No	No	Administrative, Desk Review, Site Visit, Reporting
Mrs. Seda Atabek	ITR	No	Yes	Yes	Independent Technical Review (ITR)

2.1 Method and Criteria

While applying standard auditing techniques, this Verification was conducted in line with Re Carbon Ltd.'s "Assessment Planning and Execution SOP", the requirements specified in the VCS Standard (Version 4.7), ISO 14064-3 and the requirements of the validated project activity's MP.

A Verification consists of four phases, aka (i) Document Review, (ii) remote site visit assessment, (iii) Resolution of outstanding issues and (iv) Reporting and Certification.

For this 1st Verification, related to Crediting Period 01 for the "Zano Solar Power (VCS Registry No.: 4389)" project, the aim was to conduct an independent and objective review to determine whether:

- the Monitoring Report (MR) is in conformity with the requirements of the Monitoring Plan (MP) in the validated and registered Project Description (PD) and the approved methodology.
- the project activity itself is in conformity with the MP and the registered PD, and
- the data reported in the MR are complete and transparent.

The project activity and the MR were assessed against the requirements of "ACM0002: Grid-connected electricity generation from renewable sources" (Version 21), the VCS Standard (Version 4.7) and related VCS Documents.

The Verification Schedule for this project activity is given below:

Activity	Timeline		Total Days
	From	To	
Desk Review	14.03.2025	17.03.2025	4
Review of the MR version 01	14.03.2025	17.03.2025	4
Site Visit	18.03.2025	18.03.2025	1
Issuance of the Verification Protocol version 01	20.03.2025	20.03.2025	1
Review of PPs Initial Set of Responses	27.03.2025	08.04.2025	13
Issuance of the Verification Protocol version 02	08.04.2025	08.04.2025	1
Review of PPs Second Loop Responses	11.04.2025	11.04.2025	1
Closing of all the CARs and CLs	16.04.2025	16.04.2025	1
Issuance of the Verification Report version 01	21.04.2025	09.05.2025	5

ITR Process	09.05.2025	17.05.2025	8
Issuance of the Verification Report version 02	17.05.2025	22.05.2025	5
Submission for Final Approval	23.05.2025	26.05.2025	3
Submission to the PP	23.05.2025	26.05.2025	3

2.2 Document Review

The basis for the Verification activity is the MR (Version 01), dated 06/02/2025 which was submitted to Re Carbon Ltd. on 14/03/2025. This MR was revised several times due to issued CARs and CLs, with (Version 04), dated 22/05/2025 being the final version. Re Carbon Ltd. reviewed and confirm that there is one FAR from previous stages of the project activity which was closed during the verification process. The MR and the monitoring activities were assessed against:

- the registered PD (Version 4), dated 13/09/2024.
- “ACM0002: Grid-connected electricity generation from renewable sources”, (Version 21.0,) the relevant VCS rules and regulations and
- the final Validation report of “LGAI Technological Center, S.A. (Applus+ Certification)” (Version 5.0), dated 13/09/2024
- Previous Verification Reports.

The Desk Review included the following actions:

- An assessment of the data and information provided to verify their completeness
- A review of the Monitoring Plan and methodology, with a focus on the measurement frequency, the quality of metering equipment (including calibration requirements) and the quality assurance and quality control procedures
- An evaluation of data management, as well as the quality assurance and quality control system, in terms of their impact on the generation and reporting of emission reductions.

The list of the documents which were reviewed during the Verification period is given in the table below:

Document Number	Document Name	Version	Date (dd/mm/yyyy)
D01	MR	01	06/02/2025
D02	MR	02	27/03/2025
D03	MR	03	11/04/2025
D04	ER Calculation Excel Sheet	01	06/02/2025
D05	ER Calculation Excel Sheet	02	27/03/2025
D06	VCS Standard Version	4.7	-
D07	ACM0002 - Grid-connected electricity generation from renewable sources	21.0	-
D08	PPA		20/11/2019
D09	Technical Specifications of equipment: Energy meter, PV module, Inverter and Transformer	-	-
D10	Single line diagram	-	26/12/2021
D11	SCADA electricity data for the monitoring period	-	10/2023-12/2024
D12	Declaration by PP for No double counting of Emission Reductions		20/03/2025
D13	Feasibility Study	-	31/12/2023

Document Number	Document Name	Version	Date (dd/mm/yyyy)
D14	List of employees	-	2023,2024
D15	Training records	-	01/11/2023, 07/10/2024
D16	EIA Report	-	16/06/2020
D17	Generation License	-	06/04/2020
D18	EIA license	-	07/08/2020
D19	Quadran Burkina and Sonabel Monthly Meter Readings	-	10/2023-12/2024
D20	Organization structure	-	-
D21	Operation and maintenance agreement	-	-
D22	Validation Report	5.0	13/09/2024
D23	Registered PDD	04	13/09/2024
D24	First Index Protocol of Main and Bak-up Meters	-	21-24/09/2023, 12-14/03/2024
D25	Connection Agreement	-	08/10/2023
D26	Stakeholder Meeting Records	-	29/04/2024
D27	Annual Social and Environmental Activity Report	-	2023 & 2024
D28	Facility Agreement	-	23/08/2021
D29	PREM Report	-	21/02/2020
D30	Health Insurance Certificate for Employees	-	08/05/2025
D31	Signed Work Contract (Confidential)	-	31/12/2021
D32	MR	04	22/05/2025

2.3 Interviews

During the remote site visit on 18/03/2025, Re Carbon Ltd. conducted in-person interviews to verify the accuracy and correctness of the information provided. In addition to the details in the PD, the MR and supporting documents, further information was shared during these interviews. The list of individuals interviewed is provided in the table below:

Reference Number	Means of Interview	Full Name	Affiliation	Organization
I01	Remotely	Mr. Ba**Br**S	Executive Director QBF/Qairy Country Director	QFS/QAIR
I02	Remotely	Mr. Mo**Ch**	E&S Manager	QAIR
I03	Remotely	Mrs. Ke**Sa**	Security Personnel	QAIR
I04	Remotely	Mrs. Ke**Ha**	Women's Representative	NGO
I05	Remotely	Mr. Ge**Sa**	Headman	Zano Village
I06	Remotely	Mr. Ra**Ba**	Translator	QAIR
I07	Remotely	Mr. Da**Be**	Coordinator	QAIR
I08	Remotely	Mr. Ko**Ho**	Site Manager	QAIR
I09	Remotely	Mr. Da**Ba**	Operator	Elsewedy
I10	Remotely	Mr. To**E **	Site Manager	Elsewedy

Reference Number	Means of Interview	Full Name	Affiliation	Organization
I11	Remotely	Mr. To**Be**	Operational Chief	PIC Security
I12	Remotely	Mr. Ya**Bo**	Video Operator	PIC Security
I13	Remotely	Mr. Za**Sa**	Video Operator	PIC Security
I14	Remotely	Dr. Karim Choukri	Regional Expert	RE Carbon Ltd.
I15	Remotely	Mrs. Beyda Altuntaş	Team Leader	RE Carbon Ltd.
I16	Remotely	Ms. Gaia Ludington	Consultant	AERA Group

2.4 Site Visits

During the remote site visit on 18/03/2025, the below listed topics were assessed:

Topics Verified	Source of Information
Implementation and operation of the proposed VCS project activity as per the registered PD	Document review, remote site visit and interviews with the PP representatives and stake holders.
Review of information flows for generating, aggregating, and reporting the monitoring parameters	Document review, on-site visit and interviews with the PP representatives and stake holders.
Interviews with relevant personnel to confirm that the operational and data collection procedures are implemented in accordance with the Monitoring Plan in the PD	Interviews with the PP representatives
Cross-check between information provided in the Monitoring Report and data from other sources such as plant logbooks, inventories, purchase records or similar data sources	Document review and on-site visit
Check of the monitoring equipment including calibration performance and observations of monitoring practices against the requirements of the PD and the selected methodology	Document review, on site visit and interviews with the PP representatives.
Review of calculations and assumptions made in determining the GHG data and emission reductions	Document review
Identification of quality control and quality assurance procedures in place to prevent or identify and correct any errors or omissions in the reported monitoring parameters	Document review, interviews with the PP representatives.
Virtual walk-over of the entire power plant, including a visit to the solar panels, inverters, transformers, switchyard and control building.	Physical walk-over by PP and live camera view for VVB.

2.5 Resolution of Findings

The goal of this phase of the Verification is to address any outstanding issues that need clarification for Re Carbon Ltd. to reach a (positive or negative) conclusion on the monitoring report and emission reductions.

To ensure transparency, a Verification protocol was tailored for this specific project activity. This protocol clearly outlines the requirements, Verification methods, and results from verifying the identified criteria throughout the Verification process. The part of this Verification protocol that consists of the findings and their resolutions is given in Appendix-2 of this Verification report.

A user-guide to this Verification Protocol is given below:

Draft Report Clarifications, Forward Action and Corrective Action Requests by Re Carbon Ltd.	Ref. to Questions in Table-1	Summary of the PP's Response	Conclusion by RE Carbon Ltd.
All CL, FAR and CARs determined during the Verification are listed here	Gives reference to the checklist questions in Table-1 of the Verification Protocol	Is used to summarize the responses by the PP regarding the non-conformities	Is used to summarize the responses and conclusions by RE Carbon Ltd.

The Verification Protocol is filled out by Re Carbon Ltd. in line with the descriptions above; all CARs, CLs and FARs are listed in a transparent and clear manner. ,

In line with Re Carbon Ltd.'s internal procedures and VCS Standard (Version 4.7), Re Carbon Ltd. reports non-conformities in forms of Corrective Action Requests (CARs), Clarification Requests (CLs) and Forward Action Requests (FARs). When and for which type of non-conformities CARs, CLs and FARs are issued is explained below:

Re Carbon Ltd. raises a **CAR** if one of the following occurs:

- Non-conformities with the Monitoring Plan or methodology are found in the monitoring and reporting, or if the evidence provided to prove conformity is insufficient.
- Mistakes were made in applying assumptions, data or calculations of emission reductions that will impair the estimate of emission reductions.
- Issues identified in a FAR during Validation to be verified during Verification have not been resolved by the PP.

Re Carbon Ltd. raises a **CL** if information is insufficient, not transparent or not clear enough to determine whether the applicable CDM and/or VCS requirements were met.

Re Carbon Ltd. raises a **FAR** for actions where the monitoring and reporting require attention and/or adjustment for the next Verification period.

According to these principles a total of 11 CARs and 04 CLs were issued, all of which are listed in the Verification Protocol. One FAR was raised.

2.5.1 Forward Action Requests

Re Carbon Ltd. raises a FAR for:

In the “Inclusion & Diversity Policy” document, Qair Group stated that it will implement a “confidential reporting process” within 2027.

If the next monitoring period does not include 2027, the risks related to “Safety of women and girls” shall be addressed by the verifying VVB accordingly. If however, the next monitoring period does include 2027, the implementation of the “confidential reporting process” shall be checked and confirmed within the scope of the “Inclusion & Diversity Policy” document by the verifying VVB.

One FAR from the Final Validation Report (Version 5.0, dated 13/09/2024) was addressed and successfully resolved during this verification, as follows:

FAR-1: Verification of the commissioning certificate to confirm the commissioning date of the project activity at the time of verification.

Response to FAR-1: A SONABEL Declaration was provided as supporting evidence for the commissioning date, along with official invoices from SONABEL for cross-checking. The VVB confirmed the commissioning date of the project activity, closing this FAR.

2.6 Eligibility for Validation Activities

This part is not applicable, since Re Carbon Ltd. did not undertake any “Validation Activities” within the scope of this Verification. However, Re Carbon Ltd. is accredited by ANAB for the Validation and Verification of project activities in “Project-Level Group 1” with “GHG Project Type: Renewable Energy Production” in which the project activity falls into. References to previous Validations and Verifications of VCS projects, performed by RE Carbon Ltd. can be found under <https://re-carbon.net/vcs-projects>.

3 VALIDATION FINDINGS

3.1 Methodology Deviations

N/A, since no methodology deviation was applied during this or previous monitoring periods.

3.2 Project Description Deviations

N/A. There were no deviations to the project description within this monitoring period.

3.3 New Project Activity Instances in Grouped Projects

As this project activity is not a “grouped project”, this section is not applicable

3.4 Baseline Reassessment

Did the project activity undergo baseline reassessment during the monitoring period?

☐ Yes

☒ No

4 VERIFICATION FINDINGS

4.1 Project Details

During a remote on-site visit on 18/03/2025, RE Carbon Ltd. confirmed by cross-referencing observations with documentary evidence (review of permit-related documents, technical specifications, photos, etc.), as well as personal interviews and a physical walk-over of the project site:

- The project activity comprises a 24MWc solar power plant located near the Zano village of the Tenkodogo district in the province of Bougou in Burkina Faso. The electricity generated by the plant is fed into the national distribution grid of Burkina Faso.
- The solar power plant includes 43 x “960 LONGI LR5-72HPH- 545M/550M” modules, 88 x “SUNGROW250HX” inverters, 3 x “SUNGROW MVS6750 (0.8kV – 33kV)” transformers, 396 “PVH Axone-DUO” trackers and the necessary project-internal cable connections. The generated electricity is fed into the national electricity grid via a power line, ending at the “Zano” substation.
- The data collection and storage system (SCADA) is implemented and operating.
- 2 electricity meters (1 main meters and 1 back-up meter) are installed and operate.

Hence, RE Carbon conclude and affirm that the project activity is fully implemented and operational, consistent with the specifications outlined in the registered PDD (Version 04), dated 13/09/2024. The electricity meters were checked and confirmed by verifying their serial numbers, calibration dates and their validity, their accuracy class and technical specifications.

According to the validated PD, the estimated annual emission reduction is 25,967 tCO₂e, whereas the calculated reduction for this monitoring period (from 24/10/2023 to 31/12/2024) is 22,610 tCO₂e per year. The actual (and measured) electricity generation for the entire monitoring period is **47,291 MWh**, corresponding to an emission reduction of **27,097 tCO₂e**.

Hence, the emission reduction for the current monitoring period is approximately 12,5% lower than the value, estimated in the PD. This difference is likely due to the natural variability in solar power generation, as electricity output depends on solar irradiance, which can fluctuate from the long-term average due to changes in weather patterns, cloud cover, and atmospheric conditions.

The project start date was determined as 24 October 2023. Re Carbon Ltd. reviewed the Power Purchase Agreement (PPA), meter readings, invoices, and supporting clarifications from the PP. The PPA specifies that the initial 30 days of electricity delivery constituted a test period with a tariff at 50% of the contracted rate. Continuous electricity generation commenced on 24 October 2023, which represents the actual start date of the project activity under VCS rules. While SONABEL recognized 1 April 2024 as the Commercial Operation Date (COD) for tariff purposes, this does not affect the VCS start date.

Accordingly, Re Carbon Ltd. validate **24 October 2023** as the official start date for emission reduction accounting. This date has been consistently applied in calculating the emission reductions for the first monitoring period. No discrepancies or limitations affecting the determination of the start date were identified. The commissioning date and installed capacities were verified against the SONABEL-issued commissioning protocol during the remote site visit.

Item	Evidence gathering activities, evidence checked, and assessment conclusion:

Audit history	This is the 1st Verification (24-October-2023 to 31-December-2024) within the seven years and twice renewable crediting period (CP 01), spanning from 24/10/2023 to 23/10/2030. Re Carbon Ltd. verified the project activity's audit history under https://registry.terra.org/app/projectDetail/VCS/4389 and concluded that the information present in that section of the MR is appropriate.
Double counting and participation under other GHG programs	“Double counting” was assessed by Re Carbon Ltd., through reviewing the following databases: 1. ICR project database (www.carbonregistry.com), 2. GS project database (www.goldstandard.org), 3. GCC project database (www.globalcarboncouncil.com), 4. BCR project database (www.globalcarbontrace.io) and 5. CerCarbono database (www.ecoregistry.io) The project activity is not listed on either of these. RE Carbon Ltd. hence confirm that (to the best of its knowledge) no other VER carbon credits are being issued for this project activity.
No double claiming with emissions trading programs or binding emission limits	N/A. The project activity is (to the best of RE Carbon Ltd.'s knowledge) registered only under VCS (See above).
No double claiming with other forms of environmental credit	N/A. The project activity is (to the best of RE Carbon Ltd.'s knowledge) registered only under VCS (See above).
Supply chain (scope 3) emissions double claiming	N/A. The project activity is (to the best of RE Carbon Ltd.'s knowledge) registered only under VCS (See above).
Sustainable development contributions	Re Carbon Ltd. reviewed the supporting documents for the activities that result in SD contributions from the project activity for each SDG. SDG Target 13.0: During the monitoring period, the project activity prevented the emission of 27,097 tons of tCO₂e. Re Carbon Ltd. reviewed and confirmed that the calculations in both the Monitoring Report and the ER calculation sheet are accurate.

	SDG Target 7.2: During the monitoring period, 47,291 MWh of renewable electricity was supplied to the national grid. Re Carbon Ltd. reviewed and verified the reported electricity export/import data, cross-referencing it with the monthly electricity reports, and found the information to be consistent. SDG Target 8.8: On average over the monitoring period, 3 local individuals were full-time employed at the project activity. However, for specific works (e.g. tree planting, waste handling, structural improvements, etc.) up to 55 local individuals were being temporarily (on daily basis) employed from the Zano village. The project activity contributes positively to sustainable development. This was verified through interviews of on-site personnel during the remote site audit.
Additional information relevant to the project	N/A

4.2 Safeguards and Stakeholder Engagement

4.2.1 Stakeholder Identification

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Stakeholder identification	The stakeholders interviewed as part of the Validation of the project activity on 26/06/2023 were: Mr. Alexandre Dunod (Consultant, representing the PP), Ms. Gaia Ludington (Consultant, representing the PP), Mr. Yamneda Alassane (President of the Village Development Council), Mr. Kere Adama (Former Municipal Councilor of the Zano village), Mr. Kere Souleymane (Headman of the Zano village), Mr. Yamneda Kassoum (Imam) and Ms. Kere Habibou (Women's Representative). While the roles of these stakeholders have remained the same during the monitoring period, some individuals holding these positions have changed. The updated (and by RE Carbon Ltd. sampled stakeholders) are: Ms. Gaia Ludington (Consultant, representing the PP), Mr. Ge*** Sa*** (Headman of the village), Ms. Kere Habibou (Women's Representative) and 7 on-site employees.

	During the remote site visit, Re Carbon Ltd. confirmed, that the sampled stakeholders represented “their role” within the Validation Report.
Legal or customary tenure/access rights	In accordance with Burkina-Faso law, the land required for project access, implementation, and operation was provided to the PP through a combination of expropriating private land plots and granting easement rights for state-owned land. “SONABEL” (the national electricity company) with official legal authority, bought the land in 2016. Re Carbon Ltd. verified this through a review of relevant documents (Official letter by SONABEL, generation license, grid connection agreement, facility agreement) and confirmed it during the remote site visit through stakeholder interviews.
Stakeholder diversity and changes over time	Re Carbon Ltd. consider the roles of the stakeholders listed in the Environmental & Social Impact Assessment Report (ESIA), approved on 31/08/2020 and the Validation Report (Version 5.0), dated 13/09/2024, to be adequately "diverse." While the individuals holding these roles may change over time, the "diversity" of these stakeholder roles remained unchanged as of the date of the remote site visit on 18/03/2025.
Expected changes in well-being	Based on interviews during the remote site visit, Re Carbon Ltd. confirm that the project activity does not negatively affect the “well-being” of the stakeholders.
Location of stakeholders	Residents of the Zano village represent the local stakeholders of the project activity. Individuals working at the project activity reside mainly in the Zano village. Re Carbon Ltd. confirmed this during the remote site visit on 18/03/2025.
Location of resources	The primary resource utilized by this project activity is “solar radiation”. Based on observations made during the remote site visit on 18/03/2025 and interviews with stakeholders, it was confirmed that the project land, which was originally used for farming, was legally converted to “land for solar energy use”. This change was carried out in accordance with national laws and regulations, including the Land and Agrarian Reorganization Act (RAF) – Law No. 034-2012/AN and the Expropriation for Public Interest – Law No. 009-2018/AN, with legal authorization granted through SONABEL. All 107 farmers affected by the land-use change received compensation and support from the project activity. This was also taken into account during the ESIA.

Re Carbon Ltd. confirms that no additional land/areas are being impacted by the project activity and cross-verified this during the remote site visit.

4.2.2 Stakeholder Consultation and Ongoing Communication

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Ongoing consultation	The project activity's MP from the registered PD (Version 4), dated 13/09/2024 foresees regular consultations with stakeholders throughout the project's operation phase and describes how the project activity continues to engage with local communities, stakeholders, or affected parties to ensure their concerns, feedback, and input are taken into account. During the remote site visit on 18/03/2025, local stakeholders amongst the list Chapter 2.3. above, were interviewed on: • Environmental and Social impact of project activity on villagers • Communication and relationship between PP and villagers • Grievance and requests from PP • Accessibility of Grievance mechanism • Fair approach for every group of stakeholders such as women, children, disability groups • Employment opportunities • Complaints or requests regarding the current use of previously used agricultural land as solar power plants and project activity Based on the feedback received during the interviews, input from the headman of the Zano village and the Annual Activity Reports for 2023 and 2024 (which confirm that the local community raised no concerns regarding the project activity's operations), Re Carbon Ltd. concludes that an effective grievance mechanism is in place and that no complaints were recorded during the monitoring period
Date(s) of stakeholder consultation	During the monitoring period and according to the records provided by the PP, stakeholder consultation meetings were held in June, October, November, December 2023 and in April, September 2024. Re Carbon Ltd. reviewed the meeting minutes from these consultations and verified by cross-checking with the Annual Activity Reports that the meetings took place as recorded.
Communication of monitored results	The logbook and contact information of the PP is available at the village head's office so that local stakeholders are able to reach the

	PP whenever they have any complaints, suggestions or ideas about the project activity.
Consultation records	The minutes of meeting during the stakeholder consultation meetings are available at the project site. Furthermore, a grievance book where stakeholders can note down their concerns/complaints is available at the village head's office. Re Carbon Ltd. examined both virtually and photographic evidence was taken.
Stakeholder input	N/A. No negative feedback was received from local stakeholders.

4.2.3 Free, Prior, and Informed Consent

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Consent	Free, Prior, and Informed Consent" (FPIC) is a principle that ensures individuals or communities are fully informed about a project or decision that affects them and that they voluntarily agree to it before it takes place. It is often applied in contexts involving Indigenous peoples, local communities, or vulnerable groups, particularly in relation to land use, natural resource extraction, or development projects.
Outcome of FPIC discussion	The "Zano Solar Power" project activity is a solar power plant that is fully licensed, permitted, and approved in accordance with the laws and regulations of Burkina-Faso. The land required for access, implementation, and operation of the project activity was acquired in full compliance with the laws and regulations of Burkina-Faso, with previous landowners being compensated as per the legal requirements. The project site is not located on land owned by Indigenous Peoples (IPs) or Local Communities (LCs). On 31/08/2020 the project activity was granted an "Environmental Clearance Certificate". The project activity did not require economic or physical displacement, relocate people without consent from them, or had any impact on land. Re Carbon Ltd. confirmed this through interviews during the remote site visit and through a document review. A "consent" in the sense of "FPIC" was not required.

4.2.4 Grievance Redress Procedure

Item	Evidence gathering activities, evidence checked, and assessment conclusion
------	--

Grievance received and steps taken to resolve the grievance including the outcomes of the resolution	The grievance book was examined by Re Carbon Ltd. and photographic evidence was taken. There were neither any negative comments in the book, nor raised during interviews with local stake holders during the remote audit.
Grievance redress procedure	According to the Stakeholder Engagement Plan (SEP) (Plan d'Engagement des Parties Prenantes (PEPP)), dated 21/02/2020, the project outlines a "Grievance Redress Procedure" to address complaints or concerns raised by individuals, communities, or stakeholders impacted by the project's activities, policies, or decisions. A "grievance box" is provided in an accessible area at the project site. RE Carbon Ltd. verified and confirmed the presence of this box during the virtual walk-over as part of the remote site visit. Additionally, the village headman confirmed the box's existence during the stakeholder interview.

4.2.5 Public Comments

Comments received	Actions taken by the PP	Evidence gathering activities, evidence checked, and assessment conclusion
No public comment was received from stakeholders outside of the 30-day public comment period. Hence, this is not applicable; Re Carbon Ltd. reviewed and confirm this.	N/A	N/A

4.2.6 Risks to Local Stakeholders and the Environment

4.2.6.1 Management Experience

Based on the outcome of the remote site visit, interviews with stakeholders and the document review, no risks were identified regarding the management team's expertise or the execution of the project activity. The training evidence supports that the team is adequately equipped to meet the project requirements. Therefore, no risk was identified.

4.2.6.2 Risk Assessment

Item	Evidence gathering activities, evidence checked, and assessment conclusion
------	--

Natural and human induced risks to stakeholders' wellbeing

Workplace accidents during the operation of the solar power plant could harm workers or nearby community members. For instance, accidents could occur with heavy machinery, during turbine maintenance.

The project activity operates on a remote location, far away from settlements. The project activity's operating personnel is receiving regular H&S trainings. This was confirmed by RE Carbon Ltd. through interviews conducted during the remote site visit and a document review (Training certificates).

Land acquisition or expropriation could lead to displacement of local communities, loss of access to land for farming or grazing, or other livelihoods.

The land used for the project activity was originally designated for farming but was legally reclassified for solar energy use. This conversion was carried out in compliance with national laws and regulations, including the "Land and Agrarian Reorganization Act (RAF)" (Law No. 034-2012/AN) and the "Expropriation for Public Interest Law" (Law No. 009-2018/AN), with legal authorization from SONABEL. All 107 farmers impacted by the land-use change were compensated and provided with support by the project activity. The issue was also addressed in the Environmental and Social Impact Assessment (ESIA). RE Carbon Ltd. confirmed this through interviews conducted during the remote visit and the document review.

RE Carbon Ltd. confirmed this through a document review and interviews conducted during the remote visit where the local community (represented by the headman of the Zano village and the Imam) did not raise any complaints regarding the expropriation procedure.

Resistance or opposition from local communities or stakeholders who feel that the project negatively impacts their way of life or environment could lead to unrest or protests.

The responses gathered during the remote site visit interviews as well as feedback from the headman of the Zano village and the Annual Activity Reports for the years 2023 and 2024 confirm that the local community has no complaints regarding the project activity's operations.

Visual impacts and changes to the landscape could affect the aesthetic value of the area, potentially leading to psychological or emotional distress among residents.

The responses gathered during the remote site visit interviews as well as feedback from the headman of the Zano village and the Annual Activity Reports for the years 2023 and 2024 confirm that the local community has no complaints regarding the project activity's operations.

Loss of access to land or resources, especially if the project activity interferes with farming, grazing, or other vital community resources.

	The land used for the project activity was originally designated for farming but was legally reclassified for solar energy use. This conversion was carried out in compliance with national laws and regulations, including the “Land and Agrarian Reorganization Act (RAF)” (Law No. 034-2012/AN) and the “Expropriation for Public Interest Law” (Law No. 009-2018/AN), with legal authorization from SONABEL. All 107 farmers impacted by the land-use change were compensated and provided with support by the project activity. The issue was also addressed in the Environmental and Social Impact Assessment (ESIA). RE Carbon Ltd. confirmed this through interviews conducted during the remote visit and the document review. Cultural or heritage impacts if the project activity is located near sites of cultural or historical significance to local communities or indigenous peoples. Impact of the project activity on “Cultural Heritage” was defined as “minor” and “negligible on the residents” within the ESIA approved on 07/08/2020. RE Carbon cross-checked this with interviews of local stakeholders during the remote site visit.
Risks to stakeholder participation	Lack of Awareness and Information: The stakeholders may not fully understand the project, leading to confusion or opposition: Based on feedback gathered during the remote site visit, RE Carbon Ltd. understand that the local community is generally well-informed about the project. This was further confirmed by a review of the Regular Stakeholder Meetings Reports and during the remote stakeholder interview, where the village headman and Imam (assisted by a translator fluent in French, English, and Bissa) affirmed the community's awareness Cultural and Language Barriers: The risk of miscommunication or exclusion of certain groups due to language or cultural differences. To mitigate potential language and cultural barriers during the remote on-site audit, a translator from the Tenkodogo district, fluent in Bissa, English, and French, was engaged to facilitate communication with local stakeholders. This ensured clearer understanding and promoted more inclusive participation and continued cultural sensitivity Power Imbalances and Inequitable Participation: Certain groups may dominate decision-making, leaving others marginalized. While the village's leadership structure may influence decision-making, efforts were made by the PP to involve key community representatives and ensure fair participation throughout the village. The stakeholders involved in the project are diverse enough to ensure that a broad range of perspectives are being represented. With the project activity having been operational for over a year, all affected villagers having received compensation for the land they lost and stakeholder consultation meetings are being held regularly, RE Carbon Ltd. is of the opinion that

	potential concerns related to equity and participation are being effectively addressed. Lack of Trust and Previous Negative Experiences: Distrust from past projects may reduce stakeholder engagement. The responses gathered during the remote site visit interviews as well as feedback from the headman of the Zano village and the Annual Activity Reports for the years 2023 and 2024 confirm that the local community has no complaints regarding the project's operation. Conflicting Interests: Stakeholders may have opposing views or interests, leading to tension or delays. The responses gathered during the remote site visit interviews as well as feedback from the headman of the Zano village and the Annual Activity Reports for the years 2023 and 2024 confirm that the local community has no complaints regarding the project activity's operation.
Working conditions	Safety Hazards (Accidents and Injuries): Accidents during maintenance activities. No risks related to working accidents were identified. Workers are trained and H&S regulations are strictly being adhered to. The project activity is operated in compliance with national labor laws and safety standards. This was further confirmed by RE Carbon Ltd. through interviews conducted during the remote site visit. Long Working Hours and Fatigue: Worker fatigue due to long hours or inadequate rest. Regarding worker fatigue due to long hours or insufficient rest, no risks related to excessive working hours were identified. The project is fully compliant with Burkina Faso's national labor laws, which set a 40-hour workweek, typically distributed over 5 working days. This was confirmed by RE Carbon Ltd. through interviews conducted during the remote site visit, a review of the PP's work contract template for on-site personnel and one on-site worker's signed work contract, serving as an example. This was confirmed by RE Carbon Ltd. through interviews conducted during the remote site visit and a review of the site personnel's payrolls. Exposure to Harsh Environmental Conditions: Health risks from extreme weather (heat, cold, wind). No such risks were identified. The PP is providing adequate clothing and shelter to the site personnel. This was confirmed visually by RE Carbon Ltd. during the remote site visit.

	Lack of Proper PPE: Injuries due to inadequate personal protective equipment. No such risks were identified. The PP is providing adequate PPE to the site personnel. This was confirmed visually by RE Carbon Ltd. during the remote site visit. Inadequate Training: Accidents from lack of proper training or skills. The project activity's operating personnel is receiving regular H&S trainings. This was confirmed by RE Carbon Ltd. through interviews conducted during the remote site visit and a document review (Training certificates).
Safety of women and girls	Gender-Based Violence (GBV): Increased risk of harassment or assault from male workers in the remote area. The "Inclusion & Diversity Policy" of "Qair Group" enforces a "zero tolerance" stance against "discrimination and harassment". Re Carbon Ltd. confirm this through a document review of the policy. Cultural Barriers to Reporting: Fear of stigma preventing women from reporting harassment or violence. The "Inclusion & Diversity Policy" of "Qair Group" enforces a "zero tolerance" stance against "discrimination and harassment". As per this policy, a confidential reporting process, available to all, will be established and monitored starting from 2027. Support will be provided to victims. Based on the Annual Activity Reports from 2023 and 2024 and interviews with female local stakeholders during the remote site visit, Re Carbon Ltd. confirm that there is no such risk.
Safety of minority and marginalized groups, including children	Discrimination and Exclusion: Marginalized groups may be excluded from benefits and decision-making. Burkina Faso has ratified international conventions, such as the ILO Minimum Age Convention (C138) and the Worst Forms of Child Labor Convention (C182), demonstrating its commitment to combating child labor. The key provisions include: • The legal minimum age for employment is 15 years. • Individuals under the age of 18 are prohibited from engaging in hazardous work, which includes labor-intensive tasks such as artisanal gold mining and cotton harvesting. Despite these legal frameworks, enforcement remains a challenge due to limited resources and insufficient labor inspections, resulting in persistent child labor, particularly in rural areas and the informal sector. Around 35.7% of children aged 10 to 14 work, mainly in agriculture.

While Burkina Faso has legal measures in place to protect children and marginalized groups, practical implementation faces obstacles. Efforts are needed to strengthen enforcement, raise awareness, and support vulnerable communities.

For this project activity however, RE Carbon Ltd. confirm that these issues are not applicable, as the project activity operates fully in compliance with Burkina Faso's legal framework. This is supported by cross-checking with relevant documents (Inclusion & Diversity Policy" of "Qair Group") and remote stakeholder interviews.

Child Labor and Exploitation: Risk of child labor or exploitation in nearby communities.

As a VVB, RE Carbon Ltd. focus on verifying the compliance of the project with the applicable legal and regulatory frameworks, including those related to child labor. Burkina Faso has ratified international conventions such as the ILO Minimum Age Convention (C138) and the Worst Forms of Child Labor Convention (C182), which set legal standards to protect children from exploitation. While the project itself operates fully in compliance with national laws and international standards, the risk of child labor or exploitation in nearby communities falls outside the direct control of the PP or the VVB. It is the responsibility of local authorities to enforce child labor laws. The project does not engage in activities that would encourage or directly support child labor.

Increased Vulnerability to Accidents: Children and marginalized groups may be more vulnerable to accidents.

Re Carbon Ltd. confirm that this is not applicable for the project activity. Child labor is strictly forbidden as per Burkina Faso Law as explained as above and children are not being employed in the operation of the project activity.

Limited Access to Services: Difficulty accessing essential services like healthcare and education.

During the Monitoring Period, the project activity's personnel were health-insured through a private bulk-health insurance, covering all workers at the project site, covering the periods 16/03/2022 to 15/03/2024 and 01/07/2024 to 30/06/2025. Evidence was provided by the PP through a copy of "Policy Number 10100004-323" by "Union des Insurances du Burkina (UAB)" on behalf of "Quadran Burkina Faso". This was furthermore confirmed by RE Carbon Ltd. through interviews conducted during the remote site visit and a review of the insurance policy.

Cultural and Language Barriers: Exclusion due to cultural or language differences.

To address potential cultural and language barriers during the project activity's engagement with the local community, the PP has taken steps to ensure that all relevant stakeholders are effectively included in the

	decision-making processes. A translator from the local area, fluent in Bissa, French and English is engaged during stakeholder meeting in order to facilitate clear communication between the PP and the villagers. This helps to ensure that cultural differences are being respected and that information is accurately conveyed to all community members. Additionally, the PP recognizes the importance of cultural sensitivity in engagement and decision-making processes. By fostering an inclusive approach and addressing any language or cultural barriers, the PP has worked to avoid the exclusion of any particular group. RE Carbon Ltd. confirmed this approach by document review (Regular Stakeholder Consultation Reports), cross-checked by interviews with local stakeholders during the remote site visit.
Pollutants (air, noise, discharges to water, generation and release of hazardous materials and chemical pesticides and fertilizers)	As the project activity is a solar power plant there are no emissions or discharges of waste water, hazardous materials or chemicals, pesticides or fertilizers, imminent to the project activity. Re Carbon Ltd. did not observe any significant pollution during the virtual walk-over of the project activity's site.

4.2.7 Respect for Human Rights and Equity

4.2.7.1 Labor and Work

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Discrimination	No risks identified. The remote site visit interviews confirmed no incidents of discrimination.
Sexual harassment	No risks identified. The remote site visit interviews confirmed no incidents of sexual harassment.
Gender equity in labor and work	Burkina Faso ratified ILO Convention No. 100 (Equal Remuneration) and Convention No. 111 (Discrimination). The remote on-site visit interviews confirmed no incidents violating gender equality.
Forced labor	Burkina Faso ratified ILO Convention No. 29 (Forced Labor) and Convention No. 105 (Abolition of Forced labor). The remote on-site visit interviews confirmed no incidents related to Forced Labor.
Child labor	Burkina Faso ratified ILO Convention No. 138 (Minimum Age), setting the minimum age for employment at 15 years and Convention No. 182

	(Worst Forms of Child Labor). Furthermore the Labor Code and other laws set the minimum age for employment at 15 and for hazardous work at 18. Burkina Faso Law provides against child trafficking, commercial sexual exploitation, and the use of children in illicit activities. The remote on-site visit interviews confirmed no incidents related to “Child labor”.
Human trafficking	Burkina Faso ratified the “Protocol to Prevent, Suppress and Punish Trafficking in Persons, Especially Women and Children” which aims to prevent, suppress, and punish trafficking of persons. The remote on-site visit interviews confirmed no incidents and/or observations of “human trafficking”.

4.2.7.2 Human Rights

Risks identified	Evidence gathering activities, evidence checked, and assessment conclusion
No risk identified	Burkina Faso ratified several ILO conventions that uphold human rights in the workplace, including (i) Convention No. 87 (Freedom of Association) and (ii) Convention No. 98 (Right to Organize and Collective Bargaining) The remote on-site visit interviews confirmed no incidents and/or observations of negative impacts on “human rights”.

4.2.7.3 Indigenous Peoples and Cultural Heritage

Risks identified	Evidence gathering activities, evidence checked, and assessment conclusion
No risk identified	Burkina Faso has ratified several UNESCO conventions related to cultural heritage, including: - Convention for the Protection of Cultural Property in the Event of Armed Conflict (1954) - Convention on the Means of Prohibiting and Preventing the Illicit Import, Export, and Transfer of Ownership of Cultural Property (1970) - Convention for the Safeguarding of the Intangible Cultural Heritage (2003) - Convention concerning the Protection of the World Cultural and Natural Heritage (1972) The potential impact of the project activity on cultural heritage was assessed and determined to be “minor” and “negligible on the residents”, as outlined in the Environmental and Social Impact

	Assessment (ESIA), which was approved on 07/08/2020. To ensure the accuracy of this assessment, RE Carbon Ltd. cross-checked the findings through interviews with local stakeholders during the remote site visit. This helped confirm that no significant cultural heritage sites or indigenous groups were directly affected by the project activity. The conclusion of the ESIA, based on the evidence gathered, supports the view that the project will have no significant adverse impact on cultural heritage or indigenous communities.
--	--

4.2.7.4 Property Rights

Risks identified	Evidence gathering activities, evidence checked, and assessment conclusion
No risk identified	The remote site visit interviews confirmed no incidents and/or observations of negative impacts on property rights, additional to the “expropriation” as described above.

4.2.7.5 Benefit Sharing

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Summary of the benefit sharing plan	The PP does not anticipate benefit sharing in terms of "regularly distributing the outcomes" of the project activity with local stakeholders (e.g. the provision of “free electricity” is not foreseen by Burkina Faso Law). This approach is supported by Re Carbon Ltd.’s expertise in Burkina Faso legislation.
Benefit sharing during the monitoring period	In terms of “local benefits”, the PP mainly contributes to communities’ benefit from the social responsibility plan and PRME of the project. In terms of “contributions”, the PP has made efforts for the benefit of the nearby communities and commits to continuing with these. As per the Annual Activity Report for 2023 the project activity provided support for training plant protection officers, distributing seeds, fertilizers, and urea, as well as providing electricity connections and subsidies for beneficiary households. As per the Annual Activity Report for 2024 the project activity provided support for electrification, agricultural activities, women’s empowerment and social assistance with some projects concluding towards the end of the year (e.g. fruit tree endowment, professional capacity building). The support activities were consistently followed up with monitoring and reporting. The Annual Activity Reports, the meeting attendance lists, meeting records and photographic evidence were provided to RE Carbon Ltd. as evidence documents. The execution of these activities was confirmed by Re Carbon Ltd. during the remote site visit and interviews with the local stakeholders.

4.2.8 Ecosystem Health

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Impacts on biodiversity and ecosystems	Impact of the project activity on “Biodiversity and Ecosystems” was defined as “minor” and “negligible on the residents” within the EIA Folder, approved on 07/08/2020. RE Carbon Ltd. cross-checked this with interview of local stakeholders during the remote site visit.
Soil degradation and soil erosion	Impact of the project activity on “Soil and Erosion” was defined as “minor” and “negligible on the residents” within the EIA Folder, approved on 07/08/2020. RE Carbon Ltd. cross-checked this with interview of local stakeholders during the remote site visit.
Water consumption and stress	Impact of the project activity on “Water consumption” was defined as “minor” and “negligible on the residents” within the EIA Folder, approved on 07/08/2020. RE Carbon Ltd. cross-checked this with interview of local stakeholders during the remote site visit.

4.2.8.1 Rare, Threatened, and Endangered species

Item	Evidence gathering activities, evidence checked, and assessment conclusion
Species or habitat	The impact of the project activity on rare, threatened, and endangered species or habitats was assessed as "none" in the Environmental & Social Impact Assessment (EISA) folder, which was approved on 07/08/2020. This conclusion was based on a thorough review of the project's potential impacts on local biodiversity, including a site-specific assessment of species and habitats within the project area. To verify these findings, RE Carbon Ltd. conducted additional evidence gathering through interviews with local stakeholders during the remote site visit. These discussions helped confirm that no rare, threatened, or endangered species were present in the project area, and that the project activity does not disrupt critical habitats. Based on the evidence gathered and the stakeholders' feedback, the assessment conclusion remains that the project activity does not have a significant impact on rare or endangered species.
Areas needed for habitat connectivity	During the remote (virtual) walk-over of the project site, RE Carbon Ltd. confirmed that the physical footprint of the project activity is relatively small and does not intersect with any known wildlife corridors or ecologically sensitive areas. Given its limited size and the nature of the installation, the project is not expected to pose a barrier to the movement or migration of local fauna. Based on this observation, and in the absence of any reported disruption to local wildlife by stakeholders, RE Carbon Ltd. concluded that the project activity does not negatively affect habitat connectivity in the region.

Evidence gathering activities, evidence checked, and assessment conclusion	
Habitats for rare, threatened, and endangered species	According to the Environmental & Social Impact Assessment (ESIA) Folder approved on 07/08/2020, the “African Rosewood “ (Pterocarpus Erinaceus), a protected and endangered flora species, was identified at the project site. However, the site was not classified as a “critical habitat” for this species and therefore, no additional protection measures were deemed necessary. During the remote (virtual) walk-over of the site, RE Carbon Ltd. confirmed the absence of any significant threats to this species. Given the passive nature of a solar power plant (with no moving machinery, noise, or pollution) the project is not expected to negatively impact the local presence or growth of Pterocarpus Erinaceus.
Areas for habitat connectivity	During the remote (virtual) walk-over of the project site, RE Carbon Ltd. confirmed that the physical footprint of the project activity is relatively small and does not intersect with any known wildlife corridors or ecologically sensitive areas. Given its limited size and the nature of the installation, the project is not expected to pose a barrier to the movement or migration of local fauna. Based on this observation, and in the absence of any reported disruption to local wildlife by stakeholders, <i>RE Carbon Ltd.</i> concluded that the project activity does not negatively affect habitat connectivity in the region.

4.2.8.2 Introduction of Species

Species introduced	Evidence gathering activities, evidence checked, and assessment conclusion
N/A	Since the project activity is a renewable energy project, this section is not applicable

Existing invasive species	Evidence gathering activities, evidence checked, and assessment conclusion
N/A	Since the project activity is a renewable energy project, this section is not applicable

Evidence gathering activities, evidence checked, and assessment conclusion	
Invasive species	Since the project activity is a renewable energy project, this section is not applicable

4.2.8.3 Ecosystem conversion

Item	Evidence gathering activities and evidence checked
------	--

Ecosystem conversion

N/A. No land was cleared or drained of existing natural ecosystems during the monitoring period.

4.3 Accuracy of Reduction and Removal Calculations

Throughout the monitoring period, SONABEL records were used as the primary data source. Emission reduction calculations were cross-verified using SONABEL's backup data, including SCADA datasets, which served as an internal consistency check. In line with Burkina Faso's billing meter reading regulations, generation values are reported as "effective production values." This approach calculates the net output by subtracting the previous month's cumulative production from the current month's total, ensuring a conservative estimate. This methodology was consistently applied and is clearly documented in the ER Excel Sheet for full traceability. The net electricity generated during the current monitoring period is shown in the table below:

Period	Effective Net electricity supplied to grid:	Compliance Check
24/10/2023 - 31/12/2023	7,832 MWh	SONABEL Records and SCADA data set
01/01/2024 - 31/12/2024	39,459 MWh	SONABEL Records and SCADA data set
Total	47,291 MWh	SONABEL Records and SCADA data set

The emission factor, baseline data, and parameters established prior to Validation have been applied in full alignment with the registered PD and the baseline Excel sheet used in the Validation of the project activity. Emission reductions were calculated in accordance with the approved methodology ACM002 (Version 21.0), using the following formula:

$$ER_y = BE_y - PE_y$$

Where:

ER_y = Emission reductions in year y (tCO₂e/year)

BE_y = Baseline emissions in year y (tCO₂e/year)

PE_y = Project emissions in year y (tCO₂e/year)

As the project activity is a solar power plant, **PE_y = 0**, and leakage is deemed negligible in accordance with the methodology. Therefore, emission reductions are equal to the calculated baseline emissions.

Baseline emissions (BE_y) during the monitoring period were determined using the formula:

$$BE_y = EG_{facility,y} \times EF_{grid,CM,y}$$

Where:

EG_{facility,y} = Net electricity generated and fed into the grid by the project in year y (MWh/year)

F_{grid,CM,y} = Combined margin CO₂ emission factor for grid-connected power generation (tCO₂/MWh)

The grid emission factor (**EF_{grid,CM,y}**) was calculated once during the project's Validation using the latest version of the *Tool to Calculate the Emission Factor for an Electricity System* and remains fixed throughout the first 7-year crediting period. For this project, the validated emission factor is **0.573 tCO₂/MWh**, as fixed ex-ante in the registered PD.

Emission reductions were calculated by multiplying net electricity generation by this fixed grid emission factor. For the current monitoring period, total emission reductions amounted to **27,097 tCO₂e**.

All calculations are consistent with the registered PD and ACM002 (Version 21.0). RE Carbon Ltd. confirms the accuracy of the reported electricity generation and emission reductions and verifies compliance with the applicable methodology. The approach used for calculating baseline emissions—multiplying net electricity generation by the validated grid emission factor—is fully aligned with the registered PD.

The vintage breakdown of emission reductions for the current monitoring period is provided in the table below:

Period	Emission reductions (tCO ₂ e)
24/10/2023 – 31/12/2023	4,487
01/01/2024 – 31/12/2024	22,610
Total (24/10/2023 – 31/12/2024)	27,097

The calculations were verified by Re Carbon Ltd. and the data source (SONABEL screenshots) were provided by the PP as outlined above.

Re Carbon Ltd. confirm that the electricity generation figures and the GHG emission reduction calculations mentioned above are accurately presented and quantified and are in compliance with both, the monitoring methodology ACM002 (Version 21.0) and the monitoring plan outlined in the registered PD.

4.4 Quality of Evidence to Determine Reductions and Removals

The GHG emission reductions are determined based on the net electricity generated and supplied to the grid by the project activity, along with the combined margin emission factor, which was validated during the project's registration. According to the registered PD, the combined margin emission factor is fixed at 0.573 tCO₂/MWh for the first crediting period of 7 years. The primary parameter requiring Verification is the net electricity generation, which is derived from SONABEL meter reading protocol records. These records are cross-checked with SCADA records, which are officially maintained and automatically saved by government authorities, ensuring the data's integrity and reliability.

To ensure materiality and accuracy, the Verification process adheres to the guidelines outlined in the "CDM Guideline on the Application of Materiality in Verifications (Version 02)," following a strict no-sampling approach. Every data point used in the GHG emission reduction calculations was thoroughly reviewed. As an additional cross-check, SONABEL meter reading protocol records (cross-checked with SCADA data), containing monthly generation and consumption data for the plant, were analyzed by Re Carbon Ltd.

The calibration and testing details of the electricity meters (Main and Back-up) were reviewed and confirmed. These meters, which are sealed and approved by SONABEL, ensure accurate measurement of electricity generation and consumption.

Electricity meters, installed at site	
Main Meter	
Brand	Prometer
Type	100
Class	0.2S ($\pm 0.2\%$)
Serial No.	WP050493
Back-up Meter	
Brand	Prometer
Type	100
Class	0.2S ($\pm 0.2\%$)
Serial No.	WP060048

Re Carbon Ltd. confirm that the evidence used to calculate GHG emission reductions is both sufficient in quantity and appropriate in quality, fully complying with the monitoring methodology and the registered PD.

4.5 Non-Permanence Risk Analysis

N/A (The project activity is not an AFOLU project).

5 VERIFICATION OPINION

5.1 Verification Summary

Re Carbon Ltd. conducted the 1st Verification of the VCS “Zano Solar Power”, a project with the VCS-registry reference number “4389” for the monitoring period from 24/10/2023 to 31/12/2024 (both dates inclusive). The Verification scope includes the assessment and certification of GHG emission reductions reported in the Monitoring Report (Version 04), dated 22/05/2025.

“Aera Group” (as the Consultant) was responsible, on behalf of the PP “Quadran Burkina Faso S.A.”, for preparing the GHG emissions data and reporting of the project’s GHG emission reductions, based on the framework outlined in the project’s Monitoring Plan (Version 03), as specified in the project activity’s registered PD. The PP is responsible for developing and maintaining records and reporting procedures in line with this Monitoring Plan, including the calculation and determination of GHG emission reductions, detailed therein.

The Verification was carried out by a team consisting of “Mrs. Beyda Altuntaş” as Team Leader, “Dr. Karim Choukri” as Regional Expert, and “Mrs. Fikriye Seda Atabek” as the Independent Technical Reviewer (ITR). The project activity was evaluated against the Verification criteria for such projects and their GHG emission reductions outlined in the VCS Program Guide (Version 4.4), the VCS Standard (Version 4.7) and VCS Methodology Requirements (Version 4.4.).

As detailed in Appendix 4, residual risks from the remoteness of the site visit were assessed as low and the assurance level remains reasonable.

Having applied the requirements of ISO 14064-3 in verifying the monitoring period for the project activity “Zano Solar Power” in Burkina Faso, Re Carbon Ltd. hereby confirm that the project has been implemented in accordance with the validated and registered PDD (Version 4), dated 13/09/2024 and the Monitoring Plan therein. The monitoring system is in place, and the emission reductions were calculated without material misstatements, in accordance with ISO 14064-2 and the approved methodology “ACM0002: Grid-connected electricity generation from renewable sources” (Version 21.0)."

Based on the results of our document review and the remote site visit assessment, Re Carbon Ltd. is of the opinion that the implementation of the project activity has resulted in the avoidance of 27,097 tCO₂e during the monitoring period, spanning from 24/10/2023 to 31/12/2024 (both dates inclusive).

Therefore, Re Carbon Ltd. recommend the issuance of Verified Emission Reductions (VERs) for the 27,097 tCO₂e of emission reductions, achieved during the monitoring period.

5.2 Verification Conclusion

Verification period: From 24/10/2023 to 31/12/2024 (both dates inclusive).

Verified GHG emission reductions and carbon dioxide removals in the above Verification period:

Vintage period	Baseline emissions (tCO ₂ e)	Project emissions (tCO ₂ e)	Leakage emissions (tCO ₂ e)	Reduction VCU (tCO ₂ e)	Removal VCU (tCO ₂ e)	Total VCUs (tCO ₂ e)
24-Oct-2023 to 31-Dec-2023	4,487	0	0	4,487	0	4,487
01-Jan-2024 to 31-Dec-2024	22,610	0	0	22,610	0	22,610
Total	27,097	0	0	27,097	0	27,097

The non-permanence risk rating (%)	N/A
If applicable, the Long-term Average (LTA), whether it has been properly updated, and if it has been reached.	N/A
Whether a loss has been appropriately accounted for, in accordance with the VCS Program rules, if applicable.	N/A

5.3 Ex-ante vs Ex-post ERR Comparison

Vintage period	Ex-ante estimated reductions/removals	Achieved reductions/removals	Percent difference	Explanation for the difference
24-Oct-2023 to 31-Dec-2023	4,936	4,487	-10%	Since the project activity comprise of a SPP, seasonal variations in the amount of precipitation and temperature affect the monthly generation rates and may create deviations from the estimated values.
01-Jan-2024 to 31-Dec-2024	25,967	22,610	-13%	
Total	30,903	27,097	-12.5%	

		
Beyda ALTUNTAŞ Prepared by: (Team Leader)	Fikriye Seda ATABEK Reviewed by: (ITR and Decision Maker)	Esin TUNALI Accepted by: (Certification Manager)
Ankara, 16/09/2025		

APPENDIX 1: COMMERCIALY SENSITIVE INFORMATION

N/A as no commercially sensitive information included

APPENDIX 2: VERIFICATION PROTOCOL

Resolution of Corrective Action, Forward Action and Clarification Requests

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
CAR-1 a) There is contradiction about project name according to Verra Registry Website. Correct the contradiction in line with Verra Registry. b) VCS Standard version is wrong according to latest version of VCS Standard. Correct the contradiction throughout the MR. c) There is "Error" in table of content. Also, there are some French words in MR, correct the contradiction with English.	Cover Page	a) Indeed., Name update request has been submitted to VERRA and still pending their side. if you check you'll see that the PD and all Deeds have the name "Zano solar power". Evidence provided. b) The correct version of standard has been updated to version 4.7. c) <i>"error" deleted from table of content</i>	Review 1: a) OK, closed (Related mail circulation between consultancy and Verra has been checked and confirmed, however there is no sufficient conclusion yet by Verra. If this issue will not have been closed until the end of the verification process VVB will open a FAR for this situation). b) According to FVR dated 10-July-2024 version 3.0 project has been validated under "VCS Standard V4.5" and this is not matching with the indicated version in MR also this is contradiction that how verification process used older version from validation process which is previous then verification and MR? On the other hand, at the time of final Verification Report

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
			and Monitoring Report submission Verra will have been requested most up to date versions of all. c) OK, closed (Related correction has been now done). Review 2: b)OK, closed (Most up to date version has been indicated)
CAR-2 a) There is contradiction about total emission reduction value for this monitoring period between ER Excel sheet calculation and MR. b) There is missing indication about baseline scenario. c) There is missing explanation about technical details of installed equipment (i.e number of panels, related inverters, connected substation etc.) d) There is missing explanation about A summary description of the implementation status of the technologies/measures (e.g., plant, equipment, process, or management or conservation measure) included in the project, including relevant implementation	1.1	a) indeed, there was a typo error from previous calculation. Now corrected and consistent between MR and ER sheet b) as per template guidelines <i>"Provide a summary description of the implementation status of the project, including the following (no more than one page):"</i> <i>A summary description of the implementation status of the technologies/measures (e.g., plant, equipment, process, or management or conservation measure) included in the project, including relevant implementation dates (e.g., dates of construction, commissioning, and continued operation periods).</i> <i>The total GHG emission reductions and carbon dioxide removals generated in the</i>	Review 1: a) OK, closed (Related values has been corrected in line with related evidence document) b) OK, closed (It is good practice to indicating baseline scenario in project description section with explanation of situation that absence of the project activity for understanding the integrity of project activity, VCS Guideline requires minimum necessities however related explanations confirmed). c) OK, closed (Related details has been added in line with related evidence document)

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
dates (e.g., dates of construction, commissioning, and continued operation periods). e) There is missing information about previous processes of project activity (i.e. related crediting period and sequential indication of both crediting and monitoring period etc.). f) It is unclear that how commissioning date is after generation license issuance, please explain the related process and indicate the full name of "commissioning" meaning.		<i>monitoring period</i>" the baseline scenario is not included in this section, but it is stated in that section that "Prior to the implementation of the project, the existing scenario consisted in power generation and imports from SONABEL existing grid mix, mainly composed of fossil-fuel (87%) and hydropower sources (13%)." Which is the baseline scenario. c) Technical elements now added d) there are information on the implementation status, including relevant dates. Please be more precise on what is missing. more relevant date added e) yes indeed, theses information are not required in that section, as per template guidelines, but are available section 1.2 – 1.6 and 1.7. more relevant dates added to timeframe table f) the generation license is the state granting Quadran Burkina, to become an electricity producer. It is thus dated before construction of the plant, during the administrative and financial journey that happens at the beginning of the project, generation license was obtained on 6 April 2020 The commissioning is the date when the project starts producing and selling	d) Dates of construction, commissioning, and continued operation periods, operational start dates, related agreement dates, and relevant other important dates has to be indicated in timeframe table. e) Timeframe table has to be included all related process and dates with other dates as requested above. f) Since officially the project can supply electricity to the national grid after obtaining the generation license and obtaining the necessary approvals, the commissioning date cannot be earlier than the date of obtaining the generation license this situation has to be explain in MR alongside the relevant documents and legal regulations. Review 2: d) OK, closed (Related dates has been indicated in line with relevant evidence document).

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
		electricity, thus reducing emissions. Which is 24 October 2023 Commissioning is not earlier than generation license, but 3 years after.	e) OK, closed (Related dates have been indicated in line with relevant evidence document). f) OK, closed (Commissioning date sentence has been changed as "CommissioningStart date of project, day when electricity is fed into the grid and invoicing starts" and thus complication has been solved)
CAR-3 There is wrong indication about Validation Period according to VCS MR Template Guideline. Validation period has to be covered with crediting period and all period indication has to be "DD-Month-YYYY-- DD-Month-YYYY" format.	1.2	The period has been modified to be 24-March-2023 (date of contract with validation DOE) 10-July-2024 (date of final FVR)	Review 1: Crediting period relatively validation period has to be in line with registered/approved Validation Report (dated 10-July-2024 version 3.0). Also after correction of validation period it has to be indicated in DD-Month-YYYY format too. Review 2: OK, closed (Indicated)
CAR-4 a) There is missing evidence document for project specific area including KMZ File. b) There is missing reference for converting the related coordinates. Provide the coordinate converter reference.	1.8	a) kmz file and kml file now provided. b) as only one set of coordinates is mandatory, only 11°42'13248"N ; -0°07'26.4W indicated now c) source now indicated (Google maps). d) The maps indicate the country in its sub region and zooms on the project with the unit and scale (km), the second one is a	Review 1: a) Since remote site visit has been conducted even, we are in the 1. Verification process, KMZ file has to be provided for checking and confirming the all related parts of project activity

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
c) There is missing explanation and indication about data source of coordinates. d) Indicated maps are not representative including the project specific area and unclear including the exact indication of units. Also, maps are has to be indicated with data source too.		zoom on the project , which is delineated on the first map	directly so this issue is still remained. b) OK, closed. (Values are corrected with traceable indication) c) OK, closed (Reference has been indicated) d) OK, closed. Review 1: a)OK, closed (KMZ file has been provided)
CAR-5 a) There are missing explanations for each SDG according to VCS MR Template. b) According to remote site visit interviews and employee records there is no 50 employees as indicated. Correct the contradiction about employee number with separation of temporary and permanent employee numbers according to related evidence document and monitoring period throughout the MR. c) There is missing information about employee trainings in line with remote site visit interviews. If any additional trainings are applied it has to be explained accordingly in MR in line with related evidence document.	1.12	a) number of SDG corresponding to explanation added. Though explanation for each SDG already present in MR b) According to evidence there are indeed over 50 employees per month in average. Please see page 20 of 202501 QBF RA ES 2024 Zano Final and page 22 of QBF RA ES 2023 Zano Final. For the monitoring period (15 month) it's an average of 57 full time workers, out of which, on average 55 are local people, and on average 24 (full -time) are temporary workers, thus 33 are full time permanent workers. c) There is indeed in the MR template, no specific place to write about the trainings. As the SDG is about the number of jobs created, there is no room for training in section 1.12. trainings were thus added to section 4.3, though they have nothing to do with monitoring.	Review 1: a) The only SDG 7 has been indicated with relevant indicators (SDG 7.2.1) SDG 13 and SDG 8 does not show the related indicator and also there is no such explanation about SDG 8.5 "Total number of jobs created". Related SDGs has to be corrected in line with SDG Website. b) According to this situation it has to be indicated that permanent and contemporary employee numbers separately and also according to related evidence document it has to be explain and proof that all employees are

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
d) There is missing evidence document about employee records. Also, only employees have to be take into consideration which are have contract only with the project owner in line with PPA, no one from substory company or relevant. e) There are wrong and missing indication about all related SDG's identification and related indicators full explanation. Correct the contradiction according to SDGs website.		d) as stated in a) the evidence for employee records are in Qair annual reports. The 3 employees from the company in line with PPA do not make the project happen, all the sub contractors would not have a job if not for the project. e) for SDG 7, the UN web site indicates 7.2.1 Renewable energy share in the total final energy consumption when MR states : 7.2. 1 Renewable energy share in the total final energy consumption thus it is not clear where the missing information is?. For indicator 2, SDG 8, the target is SDG 8.5, but as no indicator available on the website suits the project, number 8.5.X was deleted, and now the project-tailored indicator does not have a number. As indicated per VCS template "<i>Number and text of SDG indicator or, if no official SDG indicator is applicable, user-defined indicator</i>" we used a user-defined indicator, which is the number of jobs created as no indicator from UN site suits the project.. For SDG 13 it's done according to template with 13.0. Please be more specific on what's wrong and missing.	connected main company (i.e in line with evidence document of subgroup of main company etc) c) According to remote site visit there are employee training has been explained verbally however there is no indication about employee trainings neither section 1.12 nor section 4.3 of MR. Also SDG 8.5 explanation is wrong according to SDG Website it has to be indicated with related indicator and corrected explanation. Also please see above request relatively. d) Same as above request. e) Same as above request. Review 2: A,b,c,d,e)OK, closed (All related explanations has been indicated in line with evidence documents)
CAR-6 a) There is missing evidence document for stakeholder consultation records, attendance	2.1.2	a) the list of stakeholders is available annex E of "compensation and reinstallation plan Zano" page 138. The annual reports have pictures and summary	Review 1: a) Related evidence document has to be

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
list, dates, stakeholder inputs, invitations and etc. Also all requested documents related parts has to be in English. (If stakeholder explanation has been indicated in EIA Report, please indicate the exact para or pages) b) Related dates has to be indicated in DD-Month-YYYY" format.		reports of all interaction with stakeholders. Provided in English, along with minutes of 29 April 2024 meeting. b) exact dates have not been communicated. Thus dates only indicated as month – year.	provided this issue is still remain. b) OK, closed. Review 2: a)OK, closed (Related evidence document is provided).
CAR-7 Section 3.1 is insufficient including the description of the implementation status of the project activity, installed technology(ies), technical process and equipment, including the diagrams.	3.1	Details now added to section 3.1	Review 1: OK, closed (Related details has been indicated).
CAR-8 a) There is wrong indication unit of EGfacility,y parameter. Since this parameter has to be covered with the MP not yearly basis. b) Source of data row has to be explained by official data source full name or entity name (i.e. SONABEL monthly meter reading etc) c) There are missing information about all related parts of monitoring equipment including meter numbers with separation of main and cross check meters, calibration date and frequency, first index date, test date and frequency, all related meters serial number, accuracy	4.2	a) unit for EGfacility now changed in MR version 2.0 b)"Readings done monthly both by representative of Quadran Burkina and Sonabel" now added to source of data row. C) most of these information are already available in MR (brand, accuracy class, installation and verification date, main and back up etc). Added some information to make it clearer. d) the back up meter was changed on 12-March-2024. Indeed it wasn't explained, explanation added section 3.1 and 4.2 e) official data source is PPA and manufacturer specifications as indicated.	Review 1: a) OK, closed (Units has been indicated MP basis) b) OK, closed (Related indication has been done) c) OK, closed (Related information has been added in line with related evidence document) d) OK, closed (Related explanation has been indicated in line with related evidence document). e) OK, closed (Related explanation has been added)

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
class, brand, type and indication of which meters are for cross check with related information and which meters are main source with related information as requested. d) If there is meter change it has to be indicated or explained. e) Calibration frequency and related rules and regulations has to be indicated by official data source, if any. f) There is missing explanation about main and cross check data source according to remote site visit interviews.		f) mention of Sonabel's meters. Out of PP's responsibility though.	f) OK, closed (Related explanation has been added)
CAR-9 a) There is missing indication of organizational structure, responsibilities and competencies of the personnel that carried out the monitoring activities. Organizational Chart has to be indicated, a diagram as possible. b) There is missing indication about main and cross check data source exact names (i.e. SONABEL meters readings, SCADA System reading etc) c) Section 4.3 has to be revised according to VCS MR Template details.	4.3	Section 4.3 revised; please be specific in case anything else is missing. Section 4.3 revised once again	Review 1: a) Explanation about organizational structure and responsibilities of employees is still missing please check the VCS Guideline for this situation again. b) OK, closed (Section 4.3 totally revised) c) OK, closed (Section 4.3 totally revised) Review 2: a)OK, closed (related explanation has been indicated with details)

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
CAR-10 a) Related Table has to be included each month in related monitoring period with related values in line with evidence document and ER Excel sheet. b) Percentages of differences has to be indicated in plus or minus indication.	5.4	a) as per template indications, the table has not been changed, and requires to "Complete the tables below by vintage period (calendar year)" which has been included. No monthly data should be added to this table. Monthly data available in ER calculation excel sheet. b) percent difference now indicated with a minus percent.	Review 1: a) OK, closed. b) OK, closed. (Indicated).
CAR-11 There are 2 FAR has been issued from Validation stage (Validation Report version 3.0 dated 10 July 2024) it has to be indicated throughout the MR and has to be responded appropriately otherwise Verification stage won't be conduct. Related FARs has to be responded in related part of MR.	7.1	As there are no dedicated place in MR to answer validation FAR it was thought that the FAR's would be reported in DVR. Thus the answers are: FAR01: Verifying VVB to check the commissioning certificate to verify the commissioning date of the project activity at the time of verification : ➤ please see the "lettre de notification de fin de période de 30 jours". The first invoices are also available for cross checking of the date. As discussed during audit COD certificate from SONABEL not available yet. FAR 02: During on-site visit and based on desk review, VVB has noted 2023 counts by PP is not yet finalized and thus, actual project values for comparison with the feasibility report are not available. The verifying VVB shall check the 2023 counts	Review 1: Even though there is no available heading on behalf of FAR in the VCS MR Template related FAR responses has to be explained in Section 1.1 of MR especially for understanding the integrity of project activity. Also, related FAR responses has to be explained in this stage because if there is any other contradiction about FAR responses, VVB may request further clarification so indicate and proof related responses in Section 1.1 of MR. Review 2: OK, closed (All FARs has been responded and indicated appropriately and evidence document has been provided relatively).

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
		and confirm that the project activity is still additional with the actual project values. ➤ Certified accounts of 2023 provided. Please come back to us if you need anything else.	
CL-1 There is missing evidence document for “No Double Counting” such as signed declaration from project owner.	1.10	“No double counting” declaration now provided.	Review 1: Even though related evidence document has been provided response row has to be fulfilled initially. Review 2: OK, closed (Indicated)
CL-2 There is no evidence document for closing date of received grievances that “20/10/2023” Also please see above CARs	2.1.4	Please see evidence named “Fiche de cloture 2023-016” which states that the date of opening is 10/10/2023 and date of closing is 20/10/2023, signed by both parties.	Review 1: OK, closed (Related evidence document provided).
CL-3 There is missing indication data source link of related tool in EFgrid,CM,y parameter table.	4.1	Link now added to table section 4.1	Review 1: OK, closed (Indicated).
CL-4 There are unnecessary boxes in appendices section, if there are not applicable it has to be deleted.	6	Boxes in appendice section now deleted.	Review 1: OK, closed (Provided).
FAR-1	4.2.6.2		

Draft Report Clarifications, Forward Action and Corrective Action Requests By Verification Team	Ref. to Checklist Questions in Table-1	Summary of Project proponents' Response	Verification Team Conclusion
In the “Inclusion & Diversity Policy” document, Qair Group stated that it will implement a “confidential reporting process” within 2027. If the next monitoring period does not include 2027, the risks related to “Safety of women and girls” shall be addressed by the verifying VVB accordingly. If however, the next monitoring period does include 2027, the implementation of the “confidential reporting process” shall be checked and confirmed within the scope of the “Inclusion & Diversity Policy” document by the verifying VVB.			

APPENDIX 3: VERIFICATION TEAM AND ITR COMPETENCE

SHORT CVs

1. Assessors

1.1.Mrs. Beyda Altuntaş holds a B.Sc. degree in “Regional Planning” from Gazi University / Ankara and currently undergoes a M.Sc. program in the same. With re-carbon, Beyda is an internal Team Leader and technical expert for “Project-Level Group 1 - GHG Project Type: Renewable Energy Production”. Beyda is also a Regional Expert for Türkiye.

1.2.Mrs. Fikriye Seda Atabek holds B.Sc. degree in “Chemical Engineering” and a M.Sc. degree in “Energy Science and Technology”. She is a lead auditor and trainer for ISO 50001 and has been working in the fields of “Management systems”, “ISO 14064” and “Energy Management in Industry” since 2004. Seda has been involved in more than 100 GS and VCS projects as an ITR, Team Leader, Validator and Verifier. With re-carbon, Seda is a free-lance Team Leader, ITR and a “Project-Level Group 1 - GHG Project Types: Renewable Energy Production and Energy Efficiency Improvements” Expert. Seda is also a Regional Expert for Türkiye.

2. Regional Experts

2.1.Dr. Karim Choukri holds a B.Sc. degree in Automatics from the Polytechnic Faculty of Khouribga University in Khouribga, a M. Sc. degree in New Energies and Sustainable Development from the National School of Mineral Industry (ENIM), Rabat and a PhD in Renewable energy integration and Energy Strategies with the Hassan First University (UH1) in Settat. With re-carbon, Karim is a free-lance Regional Expert for **Algeria, Mauritania, Morocco and Tunesia.**

Appendix 3-1: Appointment Certificates

CERTIFICATE OF APPOINTMENT



Within the scope and in strict accordance to the appointments indicated below, the bearer may:

- Participate in assessments conducted by re-carbon Ltd.
- Take the appointed positions within and outside of an assessment team
- Bring specific expertise to assessments

This Certificate of Appointment is valid unless there are changes in the related requirements for the qualification and appointment and/or the personnel's work agreement is terminated. There is no defined validity period for this Certificate. However, The Certificate may be updated, suspended or cancelled at any time, as a result of performance assessments and/or other reasons as defined above.

This Appointment Certificate is granted on the date of **27.03.2024** by

Christian Johannis
(General Manager)



This Certificate of Appointment is given to

Mrs. Beyda Altuntaş

as a confirmation of compliance with re-carbon's internal qualification requirements for the following positions:

PROJECT LEVEL GROUP	GHG PROJECT TYPE EXPERTISE	EQUIVALENT GHG TECHNICAL AREA EXPERTISE reference only	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT
1	Renewable Energy Production	3.2	02.02.2024	02.02.2024	21.03.2024		15.12.2023	02.02.2024	02.02.2024	21.03.2024		15.12.2023					15.12.2023
1	Energy Efficiency Improvements	3.2															
6	Methane Collection & destruction	3.2															
5	Livestock & other anaerobic digester operations	3.2															
6	Agricultural methane emission reduction	3.2															
5	Agricultural carbon emission reduction	3.2															
6	Capture & destruction of landfill gas	3.2															
6	Capture & use of landfill gas	3.2															
6	Avoidance of methane production in wastewater treatment	3.2															
SDS Criteria:			02.02.2024	02.02.2024	21.03.2024		15.12.2023	02.02.2024	02.02.2024	21.03.2024		15.12.2023					15.12.2023



PROJECT LEVEL GROUP	GHG PROJECT TYPE EXPERTISE	EQUIVALENT GHG TECHNICAL AREA EXPERTISE reference only	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT
1	Renewable Energy Production	3.2	02.02.2024	02.02.2024	21.03.2024		15.12.2023					15.12.2023	02.02.2024	02.02.2024	21.03.2024		15.12.2023
1	Energy Efficiency Improvements	3.2															
6	Methane Collection & destruction	3.2															
5	Livestock & other anaerobic digester operations	3.2															
6	Agricultural methane emission reduction	3.2															
5	Agricultural carbon emission reduction	3.2															
6	Capture & destruction of landfill gas	3.2															
6	Capture & use of landfill gas	3.2															
6	Avoidance of methane production in wastewater treatment	3.2															
SDS Criteria:			02.02.2024	02.02.2024	21.03.2024		15.12.2023					15.12.2023	02.02.2024	02.02.2024	21.03.2024		15.12.2023

COUNTRY EXPERTISE:

Türkiye for all above listed GHGRSs

E+	15.01.2024	15.03.2024	15.01.2024	15.03.2024
E-	15.03.2024	15.03.2024	15.01.2024	15.03.2024
CCMA	15.03.2024	15.03.2024	15.01.2024	15.03.2024

CERTIFICATE OF APPOINTMENT



Within the scope and in strict accordance to the appointments indicated below, the bearer may:

- Participate in assessments conducted by re-carbon Ltd.
- Take the appointed positions within and outside of an assessment team
- Bring specific expertise to assessments

This Certificate of Appointment is valid unless there are changes in the related requirements for the qualification and appointment and/or the personnel's work agreement is terminated. There is no defined validity period for this Certificate. However, The Certificate may be updated, suspended or cancelled at any time, as a result of performance assessments and/or other reasons as defined above.

[Signature]

This Appointment Certificate is granted on the date of **13.12.2024** by

Christian Johannes
(General Manager)



This Certificate of Appointment is given to

Dr. Karim Choukri

as a confirmation of compliance with re-carbon's internal qualification requirements for the following positions:

PROJECT LEVEL GROUP	GHG PROJECT TYPE EXPERTISE	CONSULTANT QUALIFICATION AREA EXPERTISE	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT
1	Renewable Energy Production	1.2															
1	Energy Efficiency Improvements	3.1															
5	Methane Collection & destruction	1.2															
5	Livestock & other anaerobic digester operations	1.2															
5	Agricultural methane emission reduction	1.1															
5	Agricultural carbon emission reduction	1.1															
6	Capture & destruction of landfill gas	1.1															
6	Capture & use of landfill gas	1.1															
6	Avoidance of methane production in wastewater treatment	1.1															
SDS Criteria:																	



PROJECT LEVEL GROUP	GHG PROJECT TYPE EXPERTISE	CONSULTANT QUALIFICATION AREA EXPERTISE	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT
1	Renewable Energy Production	1.2															
1	Energy Efficiency Improvements	3.1															
5	Methane Collection & destruction	1.2															
5	Livestock & other anaerobic digester operations	1.2															
5	Agricultural methane emission reduction	1.1															
5	Agricultural carbon emission reduction	1.1															
6	Capture & destruction of landfill gas	1.1															
6	Capture & use of landfill gas	1.1															
6	Avoidance of methane production in wastewater treatment	1.1															
SDS Criteria:																	
COUNTRY EXPERTISE:																	
Morocco, Algeria, Mauritania and Tunisia for all GHGRs																	

F-C-044 / 27.03.2024 - 02

CERTIFICATE OF APPOINTMENT



Within the scope and in strict accordance to the appointments indicated below, the bearer may:

- Participate in assessments conducted by re-carbon Ltd.
- Take the appointed positions within and outside of an assessment team
- Bring specific expertise to assessments

This Certificate of Appointment is valid unless there are changes in the related requirements for the qualification and appointment and/or the personnel's work agreement is terminated. There is no defined validity period for this Certificate. However, The Certificate may be updated, suspended or cancelled at any time, as a result of performance assessments and/or other reasons as defined above.

[Signature]
Christian Johannes
(General Manager)

This Certificate of Appointment is given to

Mrs. Fikriye Seda Atabek

as a confirmation of compliance with re-carbon's internal qualification requirements for the following positions:

This Appointment Certificate is granted on the date of **17.01.2025** by

Christian Johannes
(General Manager)



PROJECT LEVEL GROUP	GHG PROJECT TYPE EXPERTISE	EQUIVALENCY GHG TECHNICAL AREA EXPERTISE (relevant only)	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT
1	Renewable Energy Production	1.2	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022					
1	Energy Efficiency Improvements	1.2	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022					
6	Methane Collection & destruction	1.3.2															
6	Livestock & other anaerobic digester operations	1.3.2															
6	Agricultural methane emission reduction	1.5.1															
6	Agricultural carbon emission reduction	1.5.1															
6	Capture & destruction of landfill gas	1.3.1															
6	Capture & use of landfill gas	1.3.1															
6	Avoidance of methane production in wastewater treatment	1.3.1															
SDS Criteria:			08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022	08.02.2022					



PROJECT LEVEL GROUP	GHG PROJECT TYPE EXPERTISE	EQUIVALENCY GHG TECHNICAL AREA EXPERTISE (relevant only)	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT	VERIFIER	VALIDATOR	TEAM LEADER	ITR	EXPERT
1	Renewable Energy Production	1.2											01.07.2022	01.07.2022	01.07.2022	01.07.2022	01.07.2022
1	Energy Efficiency Improvements	1.2											07.07.2022	07.07.2022	07.07.2022	07.07.2022	07.07.2022
6	Methane Collection & destruction	1.3.2															
6	Livestock & other anaerobic digester operations	1.3.2															
6	Agricultural methane emission reduction	1.5.1															
6	Agricultural carbon emission reduction	1.5.1															
6	Capture & destruction of landfill gas	1.3.1															
6	Capture & use of landfill gas	1.3.1															
6	Avoidance of methane production in wastewater treatment	1.3.1															
SDS Criteria:													07.07.2022	07.07.2022	07.07.2022	07.07.2022	07.07.2022

COUNTRY EXPERTISE:

Türkiye for all above listed GHGRs

S+	15.03.2024	15.03.2024	15.03.2024	15.03.2024	15.03.2024
S-	15.03.2024	15.03.2024	15.03.2024	15.03.2024	15.03.2024
CORSA	15.03.2024	15.03.2024	15.03.2024	15.03.2024	15.03.2024

APPENDIX 4: RISK ASSESSMENT FOR REMOTE SITE VISIT

1. Risk Identification

- Incomplete or biased evidence: All evidence submitted by the Project Proponent (PP)—including documents, photographs, and videos—was reviewed by Re-carbon Ltd. within the framework of independent and impartial verification in accordance with applicable standards.
- Nature of Evidence: The supporting evidence consisted exclusively of official and non-alterable documents, such as:
 - “Quadran Burkina and SONABEL Monthly Meter Readings,” representing legally authorized records from the Government of Burkina Faso;
 - the Power Purchase Agreement (PPA) with “Quadran Burkina Faso,” a governmental partnership of the Zano Solar Power Plant;
 - employee training certificates issued by “Sungrow South Africa” under an independent training program;
 - the single-line diagram issued by “Elsweddy Electric,” a subsidiary of “Quadran Burkina Faso,” holding legal authorization;
 - and all other relevant documentation, listed comprehensively in Section 2.2 Table of Document Review of the Verification Report.
- Verification by Regional Expert: All evidence was cross-checked and verified by the designated regional expert of Re-carbon Ltd. (Dr. Karim Choukri) against the applicable legal and regulatory requirements of Burkina Faso.
- Remote Audit and Photographic Verification: Additionally, Re-carbon Ltd. conducted a remote audit, including a real-time walk-through via video connection, during which photographic evidence of the relevant components of the project activity was collected to substantiate compliance.
- Miscommunication in remote interviews:
 - While remote interactions may generally pose risks of loss of nuance, translation challenges, or incomplete stakeholder input, no such limitations were encountered during this verification. The process was further strengthened through the use of live video, the presence of Re-Carbon Ltd.’s local expert fluent in Arabic, French, and English, and the inclusion of an unbiased representation of the local community, with participants selected by Re-Carbon Ltd.

- Inability to physically verify equipment:

Absence of physical presence could have limited the ability to directly inspect meters, transformers, and other equipment.

- Although remote verification can in principle limit the ability to directly inspect meters, transformers, and other equipment, no such limitations were encountered during this audit.
- During the remote site visit, Re-Carbon Ltd. comprehensively reviewed the technical components of the project activity via a real-time walk-over live video conducted by the on-site technician. All relevant technical and official evidence was provided and verified, including the single-line diagram issued by “Elsweddy Electric,” a subsidiary of “Quadran Burkina Faso” holding legal authorization; the connection agreement issued by “Quadran Burkina Faso”; the first index protocols of both meters issued by “Elsweddy Electric”; and the PREM Report and Environmental and Social Impact Statement (ESIS) issued by “ERM” and “INSUCO,” independent environmental evaluation companies.
- These measures ensured a level of assurance and verification quality fully equivalent to an on-site physical inspection.

- Limited stakeholder participation:

- Vulnerable groups (women, minorities, marginalized community members) might not have been adequately represented in remote interviews.
 - Although remote interviews can sometimes result in insufficient representation of vulnerable groups (such as women, minorities, or marginalized community members), no such limitation was observed during this verification.
 - During the remote site visit, stakeholders were independently selected by Re-Carbon Ltd. to ensure comprehensive coverage of all relevant groups, including women, minorities, marginalized community members, and their representatives. According to the attendance list², Mr. Ge**Sa** participated as the general representative of local residents in his capacity as Headman and Imam of Zano Village; Mrs. Ke**Ha** attended as the representative of the women’s community; and Mrs. Ke**Sa** participated as the representative of minorities and as a female employee of the project activity. All stakeholders were selected by Re-Carbon Ltd. independently, ensuring objective and inclusive interviews.
 - These measures ensured full and unbiased representation of all stakeholder groups despite the remote auditing.

- Technology limitations:

² Please see confidential Attendance List and photographic evidence of stakeholders that taken by Re-carbon Ltd.

- Although video transmission interruptions, camera angles, or insufficient coverage can potentially restrict the scope of observation, no such limitations were encountered during this remote audit.
- During the remote site visit, Re-Carbon Ltd. comprehensively reviewed the technical components of the project activity via a real-time walk-over live video conducted by the on-site technician, ensuring full visibility of all relevant areas and equipment³.
- These measures provided an observation quality fully comparable to that of an on-site inspection and cross checked with provided official evidence documents which are listed in Section 2.2 Table of Verification Report.

2. Mitigation Measures

- Triangulation of evidence: SCADA datasets, SONABEL monthly meter reading protocols, and commissioning certificates were cross-verified against PP's documents and live video walkthroughs.
- Independent local presence: A local translator and regional expert (fluent in Bissa, French, and English) were engaged by Re Carbon Ltd., not the PP, to ensure unbiased facilitation of stakeholder interviews and inclusion of women's representatives and local community leaders.
- Virtual walk-throughs: The PP conducted a live camera walkthrough of the project site, including solar panels, inverters, transformers, switchyard, and control building. Serial numbers, calibration stickers, and validity dates of meters were shown in real time.
- Inclusive stakeholder engagement: Interviews were conducted with diverse stakeholders: PP staff, women's representative, headman of Zano village, security personnel, NGO representatives, and local employees. Representation was confirmed against the Stakeholder Engagement Plan.
- Documentation & redundancy: All live video sessions were recorded and supplemented by photographic evidence. GPS coordinates were cross-checked with Google Earth *.kmz files. SCADA data were compared against SONABEL's records to ensure consistency.

3. Residual Risk & Conclusion

Following the above mitigation measures:

- The risk of material misstatement is assessed as low.
- The risk of nonconformity with audit criteria is assessed as low.
- The overall assurance level of this verification remains reasonable, in accordance with ISO 14064-3.

³ Please see confidential Attendance List and photographic evidence of stakeholders that taken by Re-carbon Ltd.

Re Carbon Ltd. concludes that the remote site visit provided sufficient⁴, reliable, and independent evidence to verify the project's compliance with the VCS Standard v4.7 and the approved methodology ACM0002 (Version 21.0).

⁴ Please see Verra Exemption Letter, 01 April 2025.