



There are two ways to request a copy of the document image.

1) By fax using the request form. Click on the following link
http://www.ladbs.org/permits/permit_related_forms/Research_Request_form.pdf to download the request form.

2) In person. Bring the following summary to one of the following Record counters.

COUNTER HOURS

MONDAY, TUESDAY, THURSDAY, FRIDAY: 7:30 AM to 4:30 PM
WEDNESDAY: 9:00 AM to 4:30 PM

Metro	Van Nuys
201, N. Figueroa St. 1st Floor, Room 110 Record Counter Los Angeles,CA 90012	6262 Van Nuys Blvd Record Counter Van Nuys,CA 91401

Address: 1634 BENEDICT CANYON

Document Type	Sub Type	Document Date	Document Number	Reel Batch Frame	
BUILDING PERMIT	BLDG-NEW	12/4/1935	1935LA22857	HIST: P1254 001 0113	
BUILDING PERMIT	NEW CONSTRUCTION	12/4/1935	1935LA22857	IDIS: P5258 01641 0000 thru P5258 0001 HIST: P1254 001 0113	
BUILDING PERMIT	BLDG-NEW	12/4/1935	1935LA22858	HIST: P1254 001 0115	
BUILDING PERMIT	NEW CONSTRUCTION	12/4/1935	1935LA22858	IDIS: P5258 01642 0000 thru P5258 0001 HIST: P1254 001 0115	
BUILDING PERMIT	BLDG-ALTER/REPAIR	2/13/1936	1936LA03139	HIST: P1256 001 0950	
BUILDING PERMIT	BLDG-ALTER/REPAIR	2/13/1936	1936LA03139	IDIS: P5260 01569 0000 thru P5260 0001 HIST: P1256 001 0950	
BUILDING PERMIT	BLDG-ALTER/REPAIR	11/17/1938	1938LA38664	HIST: P1296 002 1207	
BUILDING PERMIT	BLDG-ADDITION	11/17/1938	1938LA38664	IDIS: P5301 01864 0000 thru P5301 0001 HIST: P1296 002 1207	
BUILDING PERMIT	BLDG-ALTER/REPAIR	1/9/1939	1939LA00875	HIST: P1299 001 1749	
BUILDING PERMIT	BLDG-ALTER/REPAIR	1/9/1939	1939LA00875	IDIS: P5304 00875 0000 thru P5304 0001 HIST: P1299 001 1749	
BUILDING PERMIT	BLDG-ALTER/REPAIR	4/20/1939	1939LA15498	HIST: P1304 002 0099	
BUILDING PERMIT	BLDG-ALTER/REPAIR	4/20/1939	1939LA15498	IDIS: P5309 01473 0000 thru P5309 0001 HIST: P1304 002 0099	

Document Type	Sub Type	Document Date	Document Number	Reel Batch Frame	
BUILDING PERMIT	BLDG-ADDITION	3/6/1964	1964WL50199	IDIS: P5846 01539 0000 thru P5846 0001 HIST: P	
BUILDING PERMIT	SWIMMING-POOL/SPA	3/20/1964	1964WL50380	IDIS: P5846 01862 0000 thru P5846 0001 HIST: P	
BUILDING PERMIT	BLDG-ALTER/REPAIR	3/4/1965	1965WL56320	IDIS: P5857 02403 0000 thru P5857 0001 HIST: P2075 002 1582	
BUILDING PERMIT	ALTERATION	9/10/1966	1966WL65185	HIST: P2083 002 0629	
BUILDING PERMIT	ALTERATION	9/10/1966	1966WL65186	HIST: P2083 002 0631	
BUILDING PERMIT	BLDG-ALTER/REPAIR	9/20/1966	1966WL65185	IDIS: P5868 02872 0000 thru P5868 0001 HIST: P2083 002 0629	
BUILDING PERMIT	BLDG-ALTER/REPAIR	9/20/1966	1966WL65186	IDIS: P5868 02873 0000 thru P5868 0001 HIST: P2083 002 0631	
BUILDING PERMIT	BLDG-ALTER/REPAIR	9/8/2005	05016-20000-18984		
BUILDING PERMIT	BLDG-ADDITION	12/22/2005	05014-10000-11594	IDIS: P2317 00343 0000 thru P2317 00343 0002	
BUILDING PERMIT	NONBLDG-NEW	12/22/2005	05020-10000-04754		
BUILDING PERMIT	BLDG-ALTER/REPAIR	1/27/2006	06016-30000-01653		
BUILDING PERMIT	BLDG-ALTER/REPAIR	2/2/2006	06016-90000-02091		
BUILDING PERMIT	BLDG-ALTER/REPAIR	8/24/2006	05014-10001-11594		
CERTIFICATE OF OCCUPANCY		4/28/1965	1964WL50199	IDIS: O0511 02478 0000 thru O0511 02478 0001 HIST: O114 1 351	
CERTIFICATE OF OCCUPANCY		4/28/1965	1964WL50199	IDIS: O0606 00195 0000 thru O0606 00195 0001 HIST: O93	
CERTIFICATE OF OCCUPANCY		4/28/1965	1964WL50380	IDIS: O0606 00195 0000 thru O0606 00195 0001 HIST: O93	
CERTIFICATE OF OCCUPANCY		9/6/2006	05014-10000-11594		
CERTIFICATE OF OCCUPANCY		9/6/2006	05014-10001-11594		
CERTIFICATE OF OCCUPANCY		9/6/2006	CERT 23932		
COMMISSION	BAAB BOARD FILE	12/31/1980	BF 804327	HIST: B0012 006 0315	
COMMISSION	BAAB BOARD FILE	5/27/1981	BF 804327	HIST: B0012 006 0315 thru B0012 0331	
GRADING	GRADING PRE-INSP REPT	12/1/2005		IDIS: G524 00300 0000 thru G524 00300 0000	
GRADING	GRADING PRE-INSP REPT	3/15/2006		IDIS: G524 00301 0000 thru G524 00301 0000	
MECHANICAL PERMIT	HVAC	1/20/1987	0187W5109	HIST: T0082 007 0254	
RANGE FILE	MISCELLANEOUS	11/4/2005		IDIS: R559 00243 0000 thru R559 00243 0002	

Document Type	Sub Type	Document Date	Document Number	Reel Batch Frame	
RANGE FILE	MISCELLANEOUS	2/14/2006		IDIS: R618 00567 0000 thru R618 00567 0002	

City of Los Angeles - Department of Building and Safety
GRADING PRE-INSPECTION REPORT


Address: 1634 N Benedict Canyon Dr (90210)		Permit Application: 05014-10000-11594	
CD: 5	Grad Dist.: STGRDM4	Log No.: LA06273	
Purpose: ONE-STORY ADDITION, REPLACE ALL (E) DOORS AND WINDOWS		Property Posted: Yes	Posting Date: 12/01/2005
		GPI Fees Paid: No	Posting Fees Paid: Yes
TRACT: TR 9249			
BLOCK: N/A LOT(S): 10		ARB:	COUNTY REF. NO.:
INSPECTORS REPORT OF FIELD CONDITIONS			
Approved Graded Lot:		Bearing Value:	
Fill over 100 feet:		Buttress Fill:	
Slope of Surface:		Natural Soil Classification Per Table 18.1.A	
Cut: °	Height: ft		
Fill: °	Height: ft	Expansive Soil:	
Natural: °	Height: ft	Slide Area:	
Sewer Available:		PSDS Sized Per Code:	
Site Street		Roof Gutters:	
Condition of Street for Drainage Purposes		Recommended Termination of Drainage	
Driveway Grade: %		Maximum Rough Grade Allowed: %	
GRADING APPROVAL TO ISSUE PERMIT(S) OK TO ISSUE. SEE BELOW FOR COMMENTS. DO NOT ISSUE UNTIL BELOW REQUIREMENTS HAVE BEEN SATISFIED.			
CONDITIONS & REQUIREMENTS PRECEDENT TO ISSUING PERMIT			
1. A grading permit is required for . 2. A retaining wall permit is required. . 3. OSHA permit required for . 4. All footings shall be founded in undisturbed natural soil per Code. 5. Comply with the provisions of Section 91.1804.4 for expansive soil conditions. 6. In the event excavations reveal unfavorable conditions, the services of a soils engineer and/or geologist may be required. 7. report(s) are required. Submit three copies (1 original and 2 copies), with appropriate fees, to the Grading Section for review and approval. 8. Incorporate all recommendations of the approved report(s) and Department letters dated into the plans. to sign plans. 9. Site is subject to mudflow. Comply with provisions of Section 91.7014.3. 10. Buildings shall be located clear of the toe of all slopes which exceed a gradient of 3 horizontal to 1 vertical as per Section 91.1806.5.2. 11. Footings shall be set back from the descending slope surface exceeding 3 horizontal to 1 vertical as per Section 91.1806.5.3. 12. Swimming pools and spas shall be set back from descending and ascending slopes as per Section 91.1806.5.4. 13. Department approval is required for construction of on or over slopes steeper than 2 horizontal to 1 vertical. 14. Provide complete details of engineered temporary shoring or slot cutting procedures on plans. Call for inspection before excavation begins. 15. All concentrated drainage, including roof water, shall be conducted, via gravity, to the street or an approved location at a 2% minimum. Drainage to be shown on the plans. 16. A Registered Deputy Inspector is required for . 17. All fill or backfill shall be compacted by mechanical means to a minimum 90% relative compaction as determined by ASTM method D-1557. Subdrains shall be provided where required by Code. 18. Specify on the plans: "The soils engineer is to approve the key or bottom and leave a certificate on the site for the grading inspector. The grading inspector is to be notified before any grading begins and, for bottom inspection, before fill is placed. Fill may not be placed without approval of the grading inspector." 19. Existing non-conforming slopes shall be cut back at 2:1 (26 degrees) or retained. 20. All cut or fill slopes shall be no steeper the 2:1 (26 degrees). 21. Stake and flag the property lines in accordance with a licensed survey map. 22. Approval required by the Department of for .			
ADDITIONAL REQUIREMENTS Posting Only. GPI fees waived			
Inspector Signature <i>John Weight</i>		Inspector, Office, Phone John Weight, Metro , 213-482-0396	Date 12/01/2005

City of Los Angeles - Department of Building and Safety
GRADING PRE-INSPECTION REPORT

Address: 1634 N Benedict Canyon Dr (90210)		
CD: 5	Grad Dist.: STGRDM4	Log No.: LA06750 Permit Application: 06010-10000-00949
Purpose: 12' X 14' OPEN AIR GAZEBO		Property Posted: No Posting Date:
		GPI Fees Paid: Yes Posting Fees Paid: No
TRACT: TR 9249		
BLOCK: N/A LOT(S): 10		ARB: COUNTY REF. NO.:

INSPECTORS REPORT OF FIELD CONDITIONS	
Approved Graded Lot: No Fill over 100 feet: No Slope of Surface: Ascending Cut: 4° Height: Varies ft @ Pad Fill: 4° Height: Varies ft @ Pad Natural: 26+° Height: 35+ ft Rear slope Sewer Available: N/A Site Above Street Condition of Street for Drainage Purposes A/C Driveway Grade: % Existing	Bearing Value: Table 18.1.A Buttress Fill: Natural Soil Classification Per Table 18.1.A silty clay/bedrock Expansive Soil: Yes Slide Area: No PSDS Sized Per Code: N/A Roof Gutters: Yes Recommended Termination of Drainage to street Maximum Rough Grade Allowed: %
GRADING APPROVAL TO ISSUE PERMIT(S) OK TO ISSUE. SEE BELOW FOR COMMENTS. ☒ DO NOT ISSUE UNTIL BELOW REQUIREMENTS HAVE BEEN SATISFIED.	

CONDITIONS & REQUIREMENTS PRECEDENT TO ISSUING PERMIT
1. A grading permit is required for excavation and backfill. 2. A retaining wall permit is required. 3. OSHA permit required for vertical cuts 5 feet or over. 4. All footings shall be founded in undisturbed natural soil per Code. 5. Comply with the provisions of Section 91.1804.4 for expansive soil conditions. 6. In the event excavations reveal unfavorable conditions, the services of a soils engineer and/or geologist may be required. ☒ 7. Geological and Soils report(s) are required. Submit three copies (1 original and 2 copies), with appropriate fees, to the Grading Section for review and approval. ☒ 8. Incorporate all recommendations of the approved Geological and Soils report(s) and Department letters dated to come into the plans. Geologist and Soils Engineer to sign plans. 9. Site is subject to mudflow. Comply with provisions of Section 91.7014.3. ☒ 10. Buildings shall be located clear of the toe of all slopes which exceed a gradient of 3 horizontal to 1 vertical as per Section 91.1806.5.2. 11. Footings shall be set back from the descending slope surface exceeding 3 horizontal to 1 vertical as per Section 91.1806.5.3. 12. Swimming pools and spas shall be set back from descending and ascending slopes as per Section 91.1806.5.4. 13. Department approval is required for construction of on or over slopes steeper than 2 horizontal to 1 vertical. 14. Provide complete details of engineered temporary shoring or slot cutting procedures on plans. Call for inspection before excavation begins. ☒ 15. All concentrated drainage, including roof water, shall be conducted, via gravity, to the street or an approved location at a 2% minimum. Drainage to be shown on the plans. 16. A Registered Deputy Inspector is required for. 17. All fill or backfill shall be compacted by mechanical means to a minimum 90% relative compaction as determined by ASTM method D-1557. Subdrains shall be provided where required by Code. ☒ 18. Specify on the plans: "The soils engineer is to approve the key or bottom and leave a certificate on the site for the grading inspector. The grading inspector is to be notified before any grading begins and, for bottom inspection, before fill is placed. Fill may not be placed without approval of the grading inspector." 19. Existing non-conforming slopes shall be cut back at 2:1 (26 degrees) or retained. 20. All cut or fill slopes shall be no steeper the 2:1 (26 degrees). 21. Stake and flag the property lines in accordance with a licensed survey map. 22. Approval required by the Department of for.
ADDITIONAL REQUIREMENTS Note to plan check GAZEBO built without permits or Department approval and is in the required set back from the toe of the rear yard slope, Geological and Soils report addressing reduced set back is required.

Inspector Signature: 	Inspector, Office, Phone John Weight, Metro , 213-482-0396	Date 03/15/2006
--	--	---------------------------

1020531200631304