Given a simple system like the one in Figure 1 I wish to solve the power flow using the Flexible General Branch Model.




Figure 1: Simplified system with the AC/DC converter

Now, the consideration is that converter 1 (conv1) operates following control mode 5 whereas converter 2 (conv2) uses the control mode 2. Thus,  $|V_2|$  and the active power leaving bus 3 that goes through conv2 (we will call it  $P_f$ ) correspond to data I specify.

As I understand it, I encounter the next unknowns:  $\delta_2$ ,  $\delta_3$ ,  $\delta_4$ ,  $|V_3|$ ,  $|V_4|$ ,  $m_{a,1}$ ,  $B_{eq,2}$  and  $\theta_{sh,2}$ . My guess is that the control variable  $m_a$  has to be found only for conv1 because we control  $|V_2|$  while  $B_{eq}$  and  $\theta_{sh}$  are related to conv2 in this case due to the fact that it operates in control mode 2.

I then take into consideration equations 1 and 2 for buses 2, 3 and 4:

$$\sum P = 0,\tag{1}$$

$$\sum Q = 0. (2)$$

So there are two equations left to construct a system of 8 equations and 8 unknowns. Let's say  $i_{34}$  is the current leaving bus 3 in direction to bus 4. As a result of that we have:

$$V_3 i_{34}^* = P_f + j0. (3)$$

To my surprise, the jacobian involved in solving the nonlinear system of equations becomes singular.