

Lightning Protection System Submittal Package

Project Name:	concrete block buildings and conforming to Underwriters Laboratories,
Date:	December 11, 2025
Compliance Standard:	UL 96A
Total Bid Amount:	\$242,250.43

Submitted By:

Company: ABC Lightning Protection Co.
Address: 123 Main St, Your City, ST 12345
Phone: (555) 123-4567
Email: info@abclightning.com
License: LP-12345

This submittal package certifies that the proposed lightning protection system complies with **UL 96A** standards. All materials and installation methods meet or exceed the requirements of the applicable codes and standards.

UL 96A Compliance Certification

Air Terminals

Air terminals installed per UL 96A Section 4.1. Maximum 20 ft spacing on roof perimeter and edges. Minimum height 10 inches above protected surface.

Conductors

Main conductors and down conductors per UL 96A Section 4.2. Minimum two-way path to ground. 8-inch minimum bending radius maintained throughout.

Grounding

Ground electrodes per UL 96A Section 4.3. Minimum 10 ft depth. Ground resistance tested to verify <25 ohms.

Bonding

All metal bodies within 6 ft of system bonded per UL 96A Section 4.4.

Materials Certification

All materials used in this installation are listed and labeled per the applicable standard. Copper and aluminum components meet minimum conductivity requirements. All fasteners, connectors, and grounding electrodes are approved for lightning protection system use.

Bill of Materials

Air Terminals

Item	Quantity	Unit	Description
D/SMKIVSS	11.0	ea	Dynasphere Air Terminal, MKIV

Down Conductors & Main Cables

Item	Quantity	Unit	Description
A800A09F65	248.0	ea	Non-Insulated Stranded Conductor, 0.5" dia, 133 kcmil, 2/0 Stranded
A238GC2S24KIT	82.0	ea	CLAMP,FENCE,4/0X24 FLEX, 1-1/2 & 3-1/2,LH

Grounding System

Item	Quantity	Unit	Description
611300	2.0	ea	Copper-Bonded Ground Rod, Pointed, 1/2" dia, 10', 10 mil Plating, 6.9 lb