

Lightning Protection System Submittal Package

Project Name:	Sample Office Building - Lightning Protection
Date:	October 03, 2025
Compliance Standard:	UL 96A
Total Bid Amount:	\$8,206.74

Submitted By:

Company: ABC Lightning Protection Co.
Address: 123 Main St, Your City, ST 12345
Phone: (555) 123-4567
Email: info@abclightning.com
License: LP-12345

This submittal package certifies that the proposed lightning protection system complies with **UL 96A** standards. All materials and installation methods meet or exceed the requirements of the applicable codes and standards.

UL 96A Compliance Certification

Air Terminals

Air terminals installed per UL 96A Section 4.1. Maximum 20 ft spacing on roof perimeter and edges. Minimum height 10 inches above protected surface.

Conductors

Main conductors and down conductors per UL 96A Section 4.2. Minimum two-way path to ground. 8-inch minimum bending radius maintained throughout.

Grounding

Ground electrodes per UL 96A Section 4.3. Minimum 10 ft depth. Ground resistance tested to verify <25 ohms.

Bonding

All metal bodies within 6 ft of system bonded per UL 96A Section 4.4.

Materials Certification

All materials used in this installation are listed and labeled per the applicable standard. Copper and aluminum components meet minimum conductivity requirements. All fasteners, connectors, and grounding electrodes are approved for lightning protection system use.

Bill of Materials

Air Terminals

Item	Quantity	Unit	Description
AT-001	24.0	ea	Air Terminal - Copper

Down Conductors & Main Cables

Item	Quantity	Unit	Description
COND-100	426.0	ft	Conductor Cable - Copper 4/0 AWG
CLAMP-01	142.0	ea	Cable Clamp

Grounding System

Item	Quantity	Unit	Description
GR-10	2.0	ea	Ground Rod - 10ft Copper