

Field Activity Report

Project File: Oakland Exchange Medical Office MEP Set.pdf

Technician: admin

Role: admin

Date: 17/4/2026

Activity Description:

Plan Snapshot (Current View)

	D. REFRIGERATION SYSTEM SPECIALTIES:
	EXPANSION VALVE WITH REPLACEABLE THERMOSTATIC ELEMENT.
TESTED	4. REFRIGERANT DRYER.
	5. HIGH-PRESSURE SWITCH.
	6. LOW-PRESSURE SWITCH.
	7. THERMOSTAT FOR COIL FREEZE-UP PROTECTION DURING LOW AMBIENT TEMPERATURE OPERATION OR LOSS OF AIR.
AND	8. BRASS SERVICE VALVES INSTALLED IN DISCHARGE AND LIQUID LINES.
AL,	9. OPERATING CHARGE OF REFRIGERANT.
ON	E. REFRIGERANT COILS: EVAPORATOR AND CONDENSER COILS SHALL BE DESIGNED, TESTED, FABRICATED, AND RATED
OF	ACCORDING TO ARI 410 AND ASHRAE 33. COILS SHALL BE LEAK TESTED UNDER WATER WITH AIR AT 315 PSIG OR PER
N:	ASHRAE RECOMMENDATION.
	1. CAPACITY REDUCTION: CIRCUIT COILS FOR FACE CONTROL.
	2. TUBES: COPPER.
	FINS: ALUMINUM
	3. FIN AND TUBE JOINT: MECHANICAL BOND.
	4. SUCTION AND DISTRIBUTOR: SEAMLESS COPPER TUBE WITH BRAZED JOINTS.
	5. COATING: PHENOLIC EPOXY CORROSION-PROTECTION COATING ON BOTH COILS.
	6. SOURCE QUALITY CONTROL: TEST TO 450 PSIG, AND TO 300 PSIG UNDERWATER.
	F. CONDENSER FAN: PROPELLER TYPE, DIRECTLY DRIVEN BY MOTOR.
AD	G. SAFETY CONTROLS:
	1. COMPRESSOR MOTOR AND OUTSIDE-COIL FAN MOTOR LOW AMBIENT LOCKOUT.
	2. OVERCURRENT PROTECTION FOR COMPRESSOR MOTOR AND OUTSIDE-COIL FAN MOTOR.
	1.2 FILTERS
	COMPLY WITH NFPA 90A.
DURES,	H. CLEANABLE FILTERS: 2-INCH- (50-MM-) THICK, CLEANABLE METAL MESH.
S.	I. DISPOSABLE PANEL FILTERS: 2-INCH- (50-MM-) THICK, FACTORY-FABRICATED, FLAT-PANEL TYPE, DISPOSABLE AIR
S.	FILTERS WITH HOLDING FRAMES.
	MEDIA: INTERLACED GLASS FIBERS SPRAYED WITH NONFLAMMABLE ADHESIVE.
	3. FRAME: GALVANIZED STEEL.
	1.2 CONTROLS
D	A. FACTORY-WIRE CONNECTION FOR CONTROLS' POWER SUPPLY.
	B. CONTROL DEVICES, INCLUDING SENSORS, TRANSMITTERS, RELAYS, SWITCHES, THERMOSTATS, HUMIDISTATS,
SH	DETECTORS, OPERATORS, ACTUATORS, AND VALVES, SHALL BE MANUFACTURER'S STANDARD ITEMS TO
	ACCOMPLISH INDICATED CONTROL FUNCTIONS.
	C. UNIT CONTROLS: SOLID-STATE CONTROL BOARD AND COMPONENTS WITH FIELD-ADJUSTABLE CONTROL
	PARAMETERS.
	D. SUPPLY-FAN CONTROL: UNITS SHALL BE ELECTRICALLY INTERLOCKED WITH CORRESPONDING EXHAUST FANS, TO
	OPERATE CONTINUOUSLY WHEN EXHAUST FANS ARE RUNNING. TIME CLOCK SHALL SWITCH OPERATION FROM
	OCCUPIED TO UNOCCUPIED. NIGHT SETBACK THERMOSTAT SHALL CYCLE FAN DURING UNOCCUPIED PERIODS TO
KEEP	MAINTAIN SPACE TEMPERATURE.
	1. TIMER: SEVEN-DAY ELECTRONIC CLOCK.
	PIPING:
DD MUST	CONDENSATE DRAINS:
E	CONDENSATE PIPE TO BE TYPE L OR PVC. ROUTE TO DRYWELL OR AS INDICATED ON PLANS. UNITS 3 TONS AND
OTHER	SMALLER MAY DRAIN TO GRADE. ELSE COORDINATE WITH PLUMBER TO PROVIDE HUR DRAIN(S) IN MECHANICAL ROOM.

FLORIDA MECHANICAL CODE. INSULATION SHALL RESISTANCE (R) VALUE OF 6.0. ALL EXHAUST DUCT ACCORDANCE WITH LATEST SMACNA STANDARDS. WIDE GLASS FABRIC TAPE WITH FOSTER 30/35 MINIMUM 30 GAUGE GALVANIZED SHEET METAL UI

SEAL ALL JOINTS WITH GLASS FAB AND MASTIC.

ADJUSTABLE SPLITTERS AND DAMPERS SHALL BE PROVIDED WITH LOCKING QUADRANTS ON EXPOS ACCESS PANELS OR YOUNG REGULATORS SHALL CEILINGS OR IN SOFFITS.

ELBOWS OR CHANGES IN DUCT DIRECTION GREAT OF CURVED AIRFOIL BLADES OR VANES WHICH WILL TURBULENCE.

VIBRATION ISOLATION:

ALL BLOWER UNITS AND VIBRATING TYPE EQUIPMENT ISOLATION EQUIPMENT SIZED IN ACCORDANCE WITH

PROVIDE FLEXIBLE CONNECTORS AT ALL SUPPLY CONSISTING OF HEAVY CANVAS OR NEOPRENE FLEX

AIR FILTERS:

FILTERS SHALL BE 1" FIBERGLASS MEDIA THROW AWAY ENTERING AND LEAVING SURFACES. SUPPLY ONE FILTER 30/30 OR EQUAL.

HEAT PUMP UNIT INSTALLATION:

PROVIDE CONCRETE PADS FOR GRADE MOUNTED PUMP CONCRETE, AND SHALL BE 4" LARGER ON EACH DIMENSIONS WITH APPROVED SHOP DRAWINGS PER

