INSPECTION REPORT

AIR HANDLING UNIT SYSTEM - PREVENTIVE MAINTENANCE

ID Unit AHU	: 15101B	**Document No.**	: F-I-EM-04-061-01/02
Area Name	: Mezzanine 1 Pharma	**Effective Date**	: 30 AUG 2023
Room Location	: Row Material Warehouse I	**Period**	**: Monthly (1 Month)**
Manufacture	: Saiver	**Cleanliness Class**	: G
Date Executed	: 02 March 2026	**Revision**	: 02

SCAN TO VERIFY

NO	ACTIVITY ITEM	ACTUAL VALUE	RESULT
Section A: Pemeriksaan Kondisi Fisik Unit			
1	1. periksa kondisi Motor/Fan (Bersih dan Tidak ada Noise)	PASS	**PASS**
2	3. Periksa lampu penerangan Kabin AHU (Ganti jika lampu rusak)	PASS	**PASS**
3	2. periksa kondisi Body AHU pastikan tetap bersih	PASS	**PASS**
Section B: Pemeriksaan Coll			
4	9. Periksa Tekanan Out Heating Coil	2.6	**PASS**
5	5. Periksa Tekanan Out Cooling Coil	4.2	**PASS**
6	6. Periksa Suhu In nHeating Coil	55	**PASS**
7	7. Periksa Suhu Out Heating Coil	40	**PASS**
8	8. Periksa Tekanan In Heating Coil	2.4	**PASS**
9	1. Periksa Kondisi Cooling Coil dan Heating Coll (Bersih)	PASS	**PASS**
10	2. Periksa Suhu In Cooling Coil	7	**PASS**
11	3. Periksa Suhu Out Cooling Coil	12	**PASS**
12	4. Periksa Tekanan In Cooling Coil	4.4	**PASS**
Section C: Pemeriksaan Filter			
13	Delta P Hepa Filter (H13)	350	**PASS**
14	Delta P Medium Filter (F9)	280	**PASS**
15	Delta P Medium Filter (F6)	70	**PASS**
16	Delta P Pre Filter (G4)	75	**PASS**

Executed By (Inspector)

Kevin Julian

Date: 02 March 2026

Verified By (Supervisor)

Asep Suherman

Digitally Approved