INSPECTION REPORT

AIR HANDLING UNIT SYSTEM - PREVENTIVE MAINTENANCE

ID Unit AHU	: 15101C	**Document No.**	: F-I-EM-04-061-01/02
Area Name	: Mezzanine 1 Pharma	**Effective Date**	: 30 AUG 2023
Room Location	: Primary Packaging Warehouse Corridor	**Period**	:
Manufacture	: Saiver	**Cleanliness Class**	: G
Date Executed	: 27 February 2026	**Revision**	: 02

NO	ACTIVITY ITEM	ACTUAL VALUE	RESULT
Section A: Tightening, Lubricating, Cleaning (TLC)			
1	Bersihkahn Body Unit AHU Luar dan Dalam	PASS	**PASS**
2	Bersihkan cooling coil	PASS	**PASS**
3	Bersihkan Heating Coil	PASS	**PASS**
4	Bersihkan drain pan di dalam AHU dengan air bertekanan, pastikan drainage AHU tidak m	PASS	**PASS**
5	Periksa dan bersihkan Strainer Cooling Coil dan Heating Coil	PASS	**PASS**
6	Bersihkan Strainer Cooling Coil dan Heating Coil	PASS	**PASS**
7	Kencangkan Baut Sping Mounting	PASS	**PASS**
8	Periksa Valve dan Damper, pastikan masih berfungsi dengan Normal	PASS	**PASS**

Executed By (Inspector)

Kadita

Date: 27 February 2026

Verified By (Supervisor)

Asep Suherman

Digitally Approved