Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTER HEAD)

FIRE SAFETY CHECKLIST ON BUILDING PLANS

Date Received: _____

Building Plan Checklist #: _____ Date Released: _____

Name of Owner: _____

Project Title: _____

Location of Construction: _____

Classification of Occupancy: _____

No. of Floors: _____

INSTRUCTIONS: PLANS, SPECIFICATIONS, AND FIRE SAFETY COMPLIANCE REPORT SHALL BE IN ACCORDANCE WITH THE PROVISIONS OF RA 9514 & ITS RIRR. CHECK THE APPROPRIATE BOX [ ] FOR THE REQUIRED FIRE SAFETY MEASURES IN THE PROPOSED PLAN/S. IN CASES WHEN THE PLANS ARE NOT COMPLIANT WITH RA 9514 AND ITS RIRR, THE NOTICE OF DISAPPROVAL SHALL BE ISSUED AND NO ISSUANCE OF FSEC.

Notes:
* The data or measurements for the fill-in-the-blank sections are derived directly from the building plans.
** The Notice of Disapproval shall contain the deficiencies noted to be complied with in the submitted building plan/s.
Example: Exit width is not in accordance with Section 10.2.5.2 para F of the RIRR of RA 9514; Failure to provide a fire alarm system in accordance with Section 10.2.10.6 para B of the RIRR of RA 9514.

	I. MEANS OF EGRESS: (CIVIL/ARCHITECTURAL PLAN)	**COMPLIANT**		
		Yes	**No**	**N/A**
1	Permissible Exit Components: Capacity (No. of Persons)			
	[ ] Doors _____			
	[ ] Stairs _____			
	[ ] Smoke-proof enclosures _____			
	[ ] Horizontal Exits _____			
	[ ] Ramps _____			
	[ ] Exit Passageways _____			
	[ ] Escalator and moving walks _____			
	[ ] Fire escape stair _____			
	[ ] Fire escape ladder _____			
	[ ] Slide escape _____			
	[ ] Area of refuge _____			
	[ ] Outside stairs _____			
2	Capacity factor (Means of Egress):			
	Stairway: _____ mm / person			
	Level component & Ramp (Corridor, Door): ____ mm / person			
3	Occupant load factor: _____ m² / person			
4	Common path of travel: _____ m (with sprinkler) _____ m (w/o sprinkler)			
5	Dead end limit / Corridor: _____ m (with sprinkler) _____ m (w/o sprinkler)			
6	Travel distance: _____ m (with sprinkler) _____ m (w/o sprinkler)			
7	Remoteness of exits: _____ m (with sprinkler) _____ m (w/o sprinkler)			
8	Number of means of egress per floor: _____			
	/each room with occupant load ≥ 50 or with hazard content: _____			
9	Corridor width: _____ m			
10	Stair width : _____ m			
11	Ramp width : _____ m			

	I. MEANS OF EGRESS: (CIVIL/ARCHITECTURAL PLAN)	**COMPLIANT**		
		Yes	**No**	**N/A**
12	Any door leaf in a means of egress shall not project more than 180 mm into the required width of an aisle, a corridor, a passageway, or a landing, unless the door leaf is equipped with an approved self-closing device.			
13	Each guest door used as means of egress shall at least 20 minutes fire resistant.			
14	Doors as means of egress that open directly onto exit access corridors shall be self-closing and self-latching.			
15	There shall no openings in corridor partitions other than door openings.			
16	Handrails projections shall not more than 114 mm			
17	Exit stair landing shall not be less than the required width of exit door.			
18	There shall be no enclosed usable space under the stairs in an exit enclosure nor shall the open space under such stairs be used for any purpose.			
19	Exit stairway finishing shall not exceed class B.			
20	Exit stairs shall be provided with Guard and Handrails.			
21	Exit stairways terminate directly at a public way or at an exterior exit discharge.			
22	Exit stairs thread depth shall not be less than 280 mm.			
23	Exit stairs riser height shall not be less than 100 mm nor more than 180 mm.			
23	Exit stairs riser height shall not be less than 100 mm nor more than 180 mm.			
24	Exit stairs head room shall not be less than 2000 mm.			
25	Ramp as means of egress shall have a maximum slope shall be 1:12 (~ 8.3 %).			
26	Ramp as means of egress shall have a maximum cross slope shall be 1:48 (~ 7.14 %).			
27	Ramp as means of egress shall have a maximum rise for a single ramp run shall be 760mm.			

II. FEATURES OF FIRE PROTECTION		COMPLIANT		
A. CONSTRUCTION AND COMPARTMENTATION (CIVIL/ARCHITECTURAL PLAN)		Yes	No	N/A
28	Construction Type: [ ] Type I [ ] Type II [ ] Type III [ ] Type V [ ] Type II			
29	Walls & Ceiling finish: [ ] Class A [ ] Class B [ ] Class C			
30	Floor finish: [ ] Class I [ ] Class II			
31	Separation of Occupancy (Walls / Partition) shall at least 60 minutes fire resistant.			
32	Two (2) hours fire resistance firewall, 760mm above the roof surface. (See MC No. 2021-064 dated 28 June 2021 for Alternative).			
33	Provide fire stopping for all conceded spaces.			
B. FIRE DOORS: (ARCHITECTURAL PLAN)				
34	Fire door shall be installed in accordance with NFPA 80, Standard for Fire Doors and other Opening Protectives			
35	Door assemblies shall be installed in accordance with NFPA 105, Standard for the Installation of Smoke Door Assemblies and Other Opening Protectives			
36	Exit doors shall swing in direction of egress			
37	Exit doors shall be provided with re-entry mechanism at every four (4) storey.			
38	Exit doors assembly shall at least 60 minutes fire resistant for three (3) communicating level and below.			
39	Exit doors assembly shall at least 90 minutes fire resistant for four (4) communicating level and above.			
40	Exit doors shall be provided with panic hardware, vision panel, and self-closing mechanism.			
41	Door exit width : _____ m.			
C. PROTECTION OF VERTICAL OPENING: (MECHANICAL/ELECTRICAL PLAN) (Escalator Opening may be Protected by One of the Following Methods)				
42	Sprinkler Vent Method.			
43	Spray Nozzle Method.			
44	Partial Enclosure Method.			
III. WARNINGS: SIGNS, LIGHTING, & EXITS SIGNAGE (ARCHITECTURAL PLAN)				
45	Marking of [ ] Means of egress [ ] Directional Sign [ ] Exits Sign [ ] Emergency Evacuation Plan			
46	Illumination of [ ] Means of egress [ ] Corridors [ ] Passageway [ ] Stair landing [ ] Exit doors			

IV. FIRE PROTECTION: (*Mandatory Field Based on Hydraulic Calculation Submitted)				
A. AUTOMATIC FIRE SUPPRESSION SYSTEM: (MECHANICAL/DESIGN AND TECHNICAL SPECIFICATIONS/ FIRE PROTECTION DRAWING (IF ANY))		COMPLIANT		
		Yes	No	N/A
47	NFPA 13			
48	NFPA 13 R			
49	*Hazard : _____			
50	*Flowing density : _____ gpm (mm/m2)			
51	*Area of operation : _____ ft2 (m2)			
52	*Sprinkler type : _____			
53	*Sprinkler elevation / K - factor : _____ ft (m) / _____			
54	*Residual pressure at sprinkler head : _____ psi			
55	* Fire water reservoir : _____ gallons			
56	* Sprinkler discharge : _____ gpm			
57	* Demand flow rate : _____ gpm			
58	* Fire pump : _____hp			
59	* Service factor : _____ min			
60	* Fire pump capacity : _____ gpm			
61	* Fire pump cut-in pressure : _____ psig (pounds per in² gauge)			
62	* Jockey pump capacity : _____ gpm			
63	* Cut in / Cut out pressure : _____ / _____ psig			
64	* Inside hose stream allowance : _____ gpm			
B. WET STANDPIPE: (MECHANICAL/DESIGN AND TECHNICAL SPECIFICATIONS/ FIRE PROTECTION DRAWING (IF ANY))				
65	Class I (2 ½ " hose connection)			
66	Class II 1 ½ " hose connection)			
67	Class III (Combination of I & II)			
68	*Number of standpipe risers : _____			
69	*Design flow rate : _____ gpm			
70	*Residual pressure at outlet : _____ psig			
C. FIRE DETECTION AND ALARM SYSTEM: (ELECTRICAL/ELCTRONICS/FIRE PROTECTION (IF ANY))				
71	Manual call points			
72	Alarm Bell			
73	Smoke and Heat detector			
74	Siren Strobe			
75	Fire Alarm Annunciator			
76	Occupant Notification (Audible / Visible)			
77	Emergency Force Notification (If applicable)			
78	Fire Alarm Control Panel (FACP).			
D. PORTABLE FIRE EXTINGUISHER: (ARCHITECTURALFIRE PROTECTION PLAN(IF ANY)				
79	Class: _____ _____ _____			
80	Maximum travel distance to extinguisher: _____m			
81	Sizes / Number of fire extinguishers for the listed grades of hazards shall be sufficient to meet the requirement of table 7 & 8 of RIRR of RA 9514.			

V. BUILDING SERVICE EQUIPMENT: (ARCHITECTURAL/MECHANICAL/FIRE PROTECTION PLAN(IF ANY))		COMPLIANT		
		Yes	No	N/A
82	Automatic Kitchen hood Fire Suppression System.			
83	Stairwell pressurization.			
84	Zone Smoke Control.			
85	Elevator Pressurization.			
86	Vestibule Pressurization.			
87	Smoke refuge area pressurization.			
88	Mechanical smoke exhaust or Natural smoke ventilation for warehouse or Atrium.			

VI. OTHER FIRE SAFETY REQUIREMENTS (ARCHITECTURAL PLAN)		COMPLIANT		
		Yes	No	N/A
89	No fix grills or any obstruction shall be installed on window openings and/or fire exits			
90	Provide/post "NO SMOKING" sign/s where combustible materials are stored or handled. Such signs shall be conspicuously and suitable located.			

VII. RECOMMENDATION/S:

State below the identified fire safety requirements (Item, Number - i.e. Item B, No. 65) and additional requirement/s (if any).

_____

_____

_____

_____

_____

_____

_____

_____

Fire Safety Evaluation Clearance (FSEC) is being issued on the following conditions:

1. [ ] That all fire safety requirements and other requirements shall be complied/corrected prior to construction.
2. [ ] Provide safeguard during construction.
3. [ ] Provide fire department access road.
4. [ ] Subject to additional requirements upon recommendation of the fire safety inspector during Inspection and final inspection.
5. [ ] Submit revised documents (Plans, Specification, FSCR) before securing Fire Safety Inspection Certificate (FSIC) for Certificate of Occupancy.

ACKNOWLEDGED BY:

_____

Signature over Printed Name of Owner/Representative

Date/Time: _____

FIRE CODE FEES:

Amount Paid : Php : _____

O.R. Number: # : _____

Date Paid : : _____

PLANS CHECKED BY:

_____

Name of Building Plan Evaluator

_____

Name of Building Plan Evaluator

Date Checked: _____

RECOMMEND ISSUANCE OF [ ] FSEC / [ ] NOD:

_____

Chief, Fire Safety Enforcement Section/Unit

APPROVED / DISAPPROVED:

_____

City/Municipal Fire Marshal

DISTRIBUTION:
***Original* (Applicant/Owner's copy)**
***Duplicate* (BO/BPLO copy as the case maybe)**
***Triplicate* (BFP copy)**