Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)

FIRE SAFETY INSPECTION CHECKLIST

SMALL/GENERAL BUSINESS ESTABLISHMENT

Sari-Sari Store, Kiosk, Barber Shop, Beauty Parlor, Water Refilling, Convenience Store and alike

I. REFERENCE:

Inspection Order No. (IO):_____ Date Issued :_____ Date Inspected :_____

II. NATURE OF INSPECTION CONDUCTED (Check appropriate box)

[ ] Inspection during construction
[ ] FSIC for Certificate for Occupancy
[ ] FSIC for Business Permit (New)
[ ] FSIC for Business Permit (Renewal)
[ ] FSIC for Certificate of Annual Inspection (PEZA)
[ ] Verification Inspection for Compliance:
[ ] NTC / [ ] NTCV / [ ] Abatement / [ ] Closure
[ ] Notice of Disapproval, if Certificate of Occupancy
[ ] Others (Specify):_____

III. GENERAL INFORMATION

Name of Building : _____
Address : _____
Business Name : _____
Nature of Business : _____
Name of Owner/Representative : _____ Contact No. : _____
FSEC No. : _____ / Date Issued : _____
Building/Renovation Permit : _____ / Date Issued : _____
FSIC No. (Latest) : _____ / Date Issued : _____
Business Permit No. : _____ / Date Issued : _____
Fire Insurance Policy No. : _____ / Date Issued : _____

IV. OTHER INFORMATION

Type of Occupancy: [ ] Mercantile [ ] Business [ ] Others (Specify): _____
Construction Type: [ ] Timber Framed and Walls [ ] Reinforced Concrete Framed with Masonry Walls
[ ] Steel Framed and Walls [ ] Mixed Construction

Total Floor Area: _____m^2 Occupant Load: _____Person/s No. of Stories: _____ Portion Occupied: _____
Building Height: _____m With Mezzanine: [ ] Yes / [ ] No Handrails/Railings provided: [ ] Yes / [ ] No

V. MEANS OF EGRESS

A. EXIT ACCESS

Horizontal components	Actual Dim.	Passed	Failed	Remarks / Corrective Action
Doors	(m)	[ ]	[ ]	
Corridors / Hallways	(m)	[ ]	[ ]	

B. EXITS

Components	Clear Width	Passed	Failed	Remarks / Corrective Action
Exits Doors	(m)	[ ]	[ ]	
Horizontal Exits	(m)	[ ]	[ ]	
Stairs	(m)	[ ]	[ ]	

* Min. Width 0.60 m. between Rails of Fire Escape Stairs * Min. New Stair Width (0.915 m.) < 50 persons OL

At least two (2) means of egress for each floor [ ] Yes / [ ] No Exits doors open and close properly? [ ] Yes / [ ] No
Do doors swing in direction of egress? [ ] Yes / [ ] No

VI. SIGNS, LIGHTING, AND EXITS SIGNAGE

A. MARKING OF MEANS OF EGRESS (EXIT)

Components	Passed	Failed
Minimum letter height, 150 mm; Width of Stroke, 19 mm	[ ]	[ ]
EXIT signs are posted along Exit access, Exits and Exit discharge	[ ]	[ ]
EXIT signs are properly illuminated	[ ]	[ ]

VII. HAZARD

Hazard Classification: [ ] Low [Ordinary [ ] High Storage Clearance Required? [ ] Yes / [ ] No
Fire Safety Clearance for Storage [ ] Yes / [ ] No Date Issued:_____ Control No._____
Hazard Content: _____ Total Volume: _____
Location: _____

- Low-hazard contents shall be classified as those of such low combustibility that no self-propagating fire therein can occur.
- Ordinary hazard contents shall be classified as those that are likely to burn with moderate rapidity or to give off a considerable volume of smoke.
- High-hazard contents shall be classified as those that are likely to burn with extreme rapidity or from which explosions are likely.

A. OTHER FLAMMABLE LIQUIDS (I.E. ALCOHOL, ETHER, ETC…)

Components	Passed	Failed
Clearance of Stocks from the Ceiling	[ ]	[ ]
Gas Detector and Shut Off Device for LPG	[ ]	[ ]

LPG System provided with Approved Plans, (if 300 kgs./300 GWC) [ ] Yes / [ ] No
Installation Clearance [ ] Yes / [ ] No Date Issued:_____ Control No._____

Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(FIRE STATION LETTERHEAD)

Stored in sealed metal containers? [ ] Yes / [ ] No Provided with "NO SMOKING" sign? [ ] Yes / [ ] No

VIII. FIRE PROTECTION

A. First Aid Fire Protection (Fire Extinguishers)

Item to Inspect	Identification	Passed	Failed
Fire Extinguisher Size	Minimal sizes of fire extinguishers for the listed grades of hazards shall be provided on the basis of table 7 & 8 of RIRR of RA 9514.	[ ]	[ ]
Minimum number of Extinguisher	The minimum number of extinguishers shall be sufficient to meet the requirements of table 7 & 8 of RIRR of RA 9514.	[ ]	[ ]
Location	All extinguishers are in their proper location.	[ ]	[ ]
Seals & Tags	Extinguisher seals and tags are intact and extinguisher was serviced in the last 12 months.	[ ]	[ ]
Markings	Proper marking on extinguisher to indicate the type of fire the extinguisher can be used on.	[ ]	[ ]
Condition	No leaks, corrosion or other defects noticed.	[ ]	[ ]
Pressure	Pressure gauge arrow pointing in the "green" area	[ ]	[ ]

Type: _____ Quantity: _____ Capacity: _____

B. Emergency Lighting Systems Provided: [ ] Yes / [ ] No Functional: [ ] Yes / [ ] No

Locations: [ ] Hallways [ ] Exit Doors [ ] Stairway Landings Others Specify: _____

C. Fire Detection and Alarm Provided: [ ] Yes / [ ] No [ ] Smoke [ ] Heat [ ] Manual / [ ] Automatic

Functional: [ ] Yes / [ ] No Integrated: [ ] Yes / [ ] No Units per floor: _____ units Adequate: [ ] Yes / [ ] No

Location of Control Panel (if Applicable): _____

DEFECTS/DEFICIENCIES

ITEM IV: _____

_____

ITEM V: _____

_____

ITEM VI: _____

_____

ITEM VII: _____

_____

ITEM VIII: _____

_____

RECOMMENDATIONS

[ ] Comply the following DEFFECTS/DEFICIENCIES stated above and pay the corresponding Fire Code Fees including the Storage Clearance Fee , Conveyance Clearance Fee before the issuance of Fire Safety Inspection Certificate (FSIC).

Fire Code Fees to pay: _____

[ ] For issuance of

[ ] Notice to Comply
[ ] Notice to Correct Violation
[ ] Closure Order
[ ] Abatement Order with Administrative Fine
[ ] Closure Order for the non-payment of Administrative Fine
[ ] Notice of Disapproval, if Certificate of occupancy is applied

_____ _____

Fire Safety Inspector/s Team Leader

ACKNOWLEDGED BY:

_____

Signature Over Printed Name of Owner/ Representative

Date & Time: _____

RECOMMEND APPROVAL:

_____

CHIEF, FIRE SAFETY ENFORCEMENT SECTION/UNIT

APPROVAL:

_____

CITY/ MUNICIPAL FIRE MARSHAL

PAALALA: "MAHIGPIT NA IPINAGBABAWAL NG PAMUNUAN NG BUREAU OF FIRE PROTECTION SA MGA KAWANI NITO ANG MAGBENTA O MAGREKOMENDA NG ANUMANG BRAND NG FIRE EXTINGUISHER"

"FIRE SAFETY IS OUR MAIN CONCERN"

DISTRIBUTION:
Original **(Applicant/Owner's Copy)**
Duplicate **(BFP Copy)**