Republic of the Philippines
Department of the Interior and Local Government
Bureau of Fire Protection

FIRE SAFETY INSPECTION CHECKLIST
(For New FSIC and FSIC for Certificate of Occupancy)

Instructions: Fill out the form accurately and check the appropriate box.

A. GENERAL INFORMATION

1 REFERENCE

Inspection Order No. (IO) :_____ Date Issued: _____
Date Inspected :_____

2 NATURE OF INSPECTION CONDUCTED (Check appropriate box)

[ ] FSIC for Certificate for Occupancy
[ ] FSIC for Business Permit (New)
[ ] FSIC for Certificate of Annual Inspection (PEZA) (New)
[ ] Verification Inspection for Compliance:
[ ] NTC / [ ] NTCV / [ ] Abatement [ ] Closure
[ ] Others (Specify) : _____

3 REQUIREMENTS

[ ] FSIC for Occupancy:
• Fire Safety Compliance and Commissioning Report (FSCCR) [ ] Yes [ ] No [ ] N/A
[ ] FSIC for New Business Permit / Renewal / Certificate of Annual Inspection / Others:
• Fire Safety Maintenance Report (FSMR) [ ] Yes [ ] No [ ] N/A

4 GENERAL INFORMATION

Name of Building : _____
Address : _____
Business Name : _____
Nature of Business : _____
Name of Owner/ Representative : _____
Contact No. : _____
[ ] FSIC for Occupancy:
· FSEC No. : _____ Date Issued :_____
· Building Permit : _____ Date Issued :_____
[ ] FSIC for New Business Permit / Certificate of Annual Inspection / Others:
· FSIC No. (Latest) :_____ Date Issued :_____
· Certificate of Fire Drill :_____ Date Issued :_____
· Business Permit No. :_____ Date Issued :_____
· Fire Insurance Policy No. (If any) :_____ Date Issued :_____

5 GENERAL OCCUPANCY CLASSIFICATION

[ ] Assembly / [ ] Educational / [ ] Day Care / [ ] Health Care / [ ] Detention and Correctional
[ ] Residential: (Sub classification)_____ / [ ] Residential Board and Care
[ ] Mercantile / [ ] Business / [ ] Industrial / [ ] Storage / [ ] Special Structure: _____

6 OTHER INFORMATION

Maximum Occupant Load :_____P/Floor Number of Stories: _____ Storey
Building Height: _____m High Rise: [ ] Yes / [ ] No

B. FEATURES OF FIRE PROTECTION

I. CONSTRUCTION AND COMPARTMENTATION

A. CONSTRUCTION TYPE

[ ] Type I : Concrete & Steel (Fire Resistive)
[ ] Type II : Concrete & Exposed Steel (Noncombustible)
[ ] Type III : Concrete & Wood (Ordinary)
[ ] Type IV : Heavy Timber (Large mass wood)
[ ] Type V : Wood frame (Lightweight wood)

B. WALLS / CEILING INTERIOR FINISH

[ ] Class A : Flame spread index, 0–25;smoke developed index, 0–450
[ ] Class B : Flame spread index, 26–75; smoke developed index, 0–450
[ ] Class C : Flame spread index, 76–200; smoke developed index, 0–450
(Note: Flame Spread Index can be seen in the technical specification of the product)

C. FLOOR INTERIOR FINISH

[ ] Class I : Critical radiant flux, not less than 0.45 W/cm^2.
[ ] Class II : Critical radiant flux, not more than 0.22 W/cm^2, but less than 0.45W/cm^2
(Note: Flame Spread Index can be seen in the technical specification of the product)

SECTIONAL OCCUPANCY (INDICATE SPECIFIC USAGE OF EACH FLOOR, PART OR PORTION OF THE BUILDING/STRUCTURE/FACILITY/ BUSINESS ESTABLISHMENT)

Basement : _____

Ground floor:_____

Second floor:_____

Third floor:_____

Fourth floor:_____

Nth Floor : _____

(Use separate sheet if necessary)

II. MEANS OF EGRESS

A. EXIT ACCESS

[ ] Doors [ ] Hallways [ ] Anteroom
[ ] Corridors [ ] Passageways [ ] Ramps

Horizontal components	Capcity (No. of Persons)	Actual Dimensions	Passed	Failed	N/A	Remarks / Corrective Action
Doors		m	[ ]	[ ]	[ ]	
Corridors		m	[ ]	[ ]	[ ]	
Hallways		m	[ ]	[ ]	[ ]	
Passageways		m	[ ]	[ ]	[ ]	
Lobby		m	[ ]	[ ]	[ ]	
Anteroom		m	[ ]	[ ]	[ ]	
Ramps		m	[ ]	[ ]	[ ]	
Common Path of Travel		m	[ ]	[ ]	[ ]	
Dead End		m	[ ]	[ ]	[ ]	
Travel Distance		m	[ ]	[ ]	[ ]	

	Actual Dim.	Passed	Failed	N/A
Any door leaf in a means of egress shall leave not less than one-half of the required width of an aisle, a corridor, a passageway, or a landing unobstructed.	_____	[ ]	[ ]	[ ]
Any door leaf in a means of egress shall not project more than 180 mm into the required width of an aisle, a corridor, a passageway, or a landing, unless the door leaf is equipped with an approved self-closing device.	_____	[ ]	[ ]	[ ]

At least two (2) means of egress for each room with occupant load ≥ 50 or with hazard content.	_____	[ ]	[ ]	[ ]
Each guest door used as means of egress shall at least 20 minutes fire resistant.	_____	[ ]	[ ]	[ ]
Doors that open directly onto exit access corridors shall be self-closing and self-latching.		[ ]	[ ]	[ ]
There shall no openings in corridor partitions other than door openings.		[ ]	[ ]	[ ]
Free from any obstruction.		[ ]	[ ]	[ ]
No flammable material stored.		[ ]	[ ]	[ ]

B. EXITS

[ ] Normal Stairs [ ] Curved Stairs [ ] Spiral Stairs / [ ] [ ] Winding Stairs

[ ] Horizontal Exits [ ] Outside Stairs [ ] Exit Passageways [ ] Fire Escape Stairs

[ ] Fire Escape Ladder (for 1 & 2 family dwelling only)

[ ] Slide Escape (for Industrial Occupancy Only)

Horizontal components	Capcity (No. of Persons)	Clear Width	Passed	Failed	N/A	Remarks / Corrective Action
Exits Doors		m	[ ]	[ ]	[ ]	
Normal Stairs		m	[ ]	[ ]	[ ]	
Curve stairs		m	[ ]	[ ]	[ ]	
Winding Stairs		m	[ ]	[ ]	[ ]	
Horizontal Exits		m	[ ]	[ ]	[ ]	
Outside Stairs		m	[ ]	[ ]	[ ]	
Exit Passageways		m	[ ]		[ ]	
Fire Escape Stairs		m	[ ]	[ ]	[ ]	
Fire Escape Ladders		m	[ ]	[ ]	[ ]	
Slide Escape		m	[ ]	[ ]	[ ]	

	Actual Dimension	Passed	Failed	N/A
At least two (2) means of egress for each floor.	_____	[ ]	[ ]	[ ]
Doors assembly: 60 minutes fire resistant for three (3) communicating level and below.	_____	[ ]	[ ]	[ ]
Doors assembly: 90 minutes fire resistant for four (4) communicating level and above.	_____	[ ]	[ ]	[ ]
Exits Doors provided with Re-entry mechanism at every four (4) storey.	_____	[ ]	[ ]	[ ]
Stair thread: Minimum depth = 280 mm.	_____	[ ]	[ ]	[ ]
Stair riser: Minimum / Maximum height = 100 mm / 180 mm.	_____	[ ]	[ ]	[ ]
Minimum stair head room: 2000mm	_____	[ ]	[ ]	[ ]
Exits doors open and close properly		[ ]	[ ]	[ ]
Doors swing in direction of egress.		[ ]	[ ]	[ ]
Exit Doors provided with panic hardware, vision panel, and self-closing mechanism.		[ ]	[ ]	[ ]
There shall be no enclosed usable space under the stairs in an exit enclosure nor shall the open space under such stairs be used for any purpose.		[ ]	[ ]	[ ]
Interior finish: Class B		[ ]	[ ]	[ ]

C. EXITS DISCHARGE

	Actual Distance	Passed	Failed	N/A
Remoteness of exit discharge not less than ½ of length of the overall dimension of the building or area to be served.	_____	[ ]	[ ]	[ ]
Remoteness of exit discharge not less than 1/3 of length of the overall dimension of the building or area to be served is the bldg. is protected throughout by ASASS.	_____	[ ]	[ ]	[ ]
Exterior grounds are kept clear of objects that might impede evacuation or firefighting equipment		[ ]	[ ]	[ ]
Terminate directly at a public way or at an exterior exit discharge.		[ ]	[ ]	[ ]

III.	**SIGNS, LIGHTING, AND EXITS SIGNAGE**				
	A. MARKING OF MEANS OF EGRESS (EXIT)				
		Actual Distance	**Passed**	**Failed**	**N/A**
	Minimum letter height, 150 mm	_____	[ ]	[ ]	[ ]
	EXIT signs are posted along Exit access, Exits and Exit discharge		[ ]	[ ]	[ ]
	EXIT signs are properly illuminated		[ ]	[ ]	[ ]
	B. MARKING OF MEANS OF EGRESS (EMERGENCY EVACUATION PLAN)				
			Passed	**Failed**	**N/A**
	Posted on strategic and conspicuous location inside the building		[ ]	[ ]	[ ]
	Drawn with a photo-luminescent background to be readable in case of power failure.		[ ]	[ ]	[ ]
	Containing the following basic information below		[ ]	[ ]	[ ]
	1. “You Are Here/ room number/ building” Marking		[ ]	[ ]	[ ]
	2. Fire Exits		[ ]	[ ]	[ ]
	3. Primary Route to Exit (Nearest to the viewer)		[ ]	[ ]	[ ]
	4. Secondary Route to Exit (Second nearest to the viewer)		[ ]	[ ]	[ ]
	5. Fire alarm pull stations and annunciators		[ ]	[ ]	[ ]
	6. Fire extinguishers/ hose cabinets		[ ]	[ ]	[ ]
	7. Emergency Light		[ ]	[ ]	[ ]
	8. First Aid Kits locations (if applicable)		[ ]	[ ]	[ ]
	9. Emergency Call stations (if applicable		[ ]	[ ]	[ ]
	10. Areas of safe refuge (for high-rise building)		[ ]	[ ]	[ ]
	11. Assembly areas instructions		[ ]	[ ]	[ ]
	12. “In Case of Emergency” instructions		[ ]	[ ]	[ ]
	Design Format:	**Actual Distance**	**Passed**	**Failed**	**N/A**
	[ ] Size 330.2 mm wide * 215.9 mm height	_____	[ ]	[ ]	[ ]
	(Floor area < 50 m²)				
	·Room or spaces				
	[ ] Size 609.6 mm wide * 457.2 mm height	_____	[ ]	[ ]	[ ]
	(Floor area = 50 – 150 m²)				
	· Room or spaces				
	· Building lobbies upon entry.				
	· Elevator lobbies at every floor.				
	· Hallways and corridors.				
	·On every bend/corner Or every 15m interval in the case of long hallway.				
	[ ] Size 609.6 mm height * 914.4 mm wide	_____	[ ]	[ ]	[ ]
	(Floor area ≥ 151m²)				
	· Room or spaces				
	· Upon entry of the building				
	· Area of assembly or every 25m interval in the case auditorium & gymnasium.				
	Symbols/icons/logos to be used for the marking shall be in accordance with NFPA 170, Standard for Signs and Symbols.				
	C. ILLUMINATION OF MEANS OF EGRESS All data below shall be referred from the manufacturer's specifications.				
		Actual Lux/Time	**Passed**	**Failed**	**N/A**
	Floors and other walking surfaces: shall be at least 1 ft-candle (10.8 lux), measured at the floor.	_____	[ ]	[ ]	[ ]
	In assembly occupancies: walking surfaces of exit access shall be at least 0.2 ft-candle (2.2 lux)	_____	[ ]	[ ]	[ ]
	Stairs: shall be at least 10 ft-candle (108 lux), measured at the walking surfaces.	_____	[ ]	[ ]	[ ]

Emergency Lighting	Actual Lux/Time	Passed	Failed	N/A
[ ] Illumination not less than an average of 1 ft-candle (10.8 lux) and, at any point, not less than 0.1 ft-candle (1.1 lux), measured along the path of egress at floor level.	_____	[ ]	[ ]	[ ]
[ ] Emergency lighting system shall be arranged to provide the required illumination automatically in the event of any interruption of normal lighting (e.g. Failure of a public utility, ect.) for a period at least 1.5-hour.	_____	[ ]	[ ]	[ ]
[ ] Periodic Testing of Emergency Lighting Equipment (Written record)		[ ]	[ ]	[ ]

IV. HAZARD

Hazard Contents :_____ Quantity (Vol. / Weight) :_____

Hazard Identification Placard :_____ Within MAQ : [ ] Yes / [ ] No [ ] N/A

Hazard Identification No. :_____ Hazard Classification:

[ ] Low [ ] Ordinary [ ] High

Class :_____ Flash Point :_____

(Use additional sheets if necessary.)

Low hazard contents shall be classified as those of such low combustibility that no self-propagating fire therein can occur.

Ordinary hazard contents shall be classified as those that are likely to burn with moderate rapidity or to give off a considerable volume of smoke.

High hazard contents shall be classified as those that are likely to burn with extreme rapidity or from which explosions are likely.

A. OTHER FLAMMABLE LIQUIDS (I.E. ALCOHOL, ETHER, ETC…)	**Passed**	**Failed**	**N/A**
Stored in sealed metal containers	[ ]	[ ]	[ ]
Properly dispensed as per SOP	[ ]	[ ]	[ ]
Provided with “NO SMOKING” sign.	[ ]	[ ]	[ ]
B. MISCELLANEOUS HAZARDS (MECHANICAL EQUIPMENT ROOM, STORAGE, SUPPLY ROOM)	**Passed**	**Failed**	**N/A**
All no smoking areas has adequate signs.	[ ]	[ ]	[ ]
Gasoline/ Diesel is stored in the proper place and in a metal safety can.	[ ]	[ ]	[ ]
C. HOUSEKEEPING, MAINTENANCE, STORAGE & WASTE DISPOSAL	**Passed**	**Failed**	**N/A**
Brooms, mops, rags and other cleaning supplies stored in metal cabinets or approved cans	[ ]	[ ]	[ ]
Paints, solvents and other flammables stored in metal cabinet: oily rags in metal containers	[ ]	[ ]	[ ]
Dry leaves, shrubbery trimmings and other combustibles kept away from buildings	[ ]	[ ]	[ ]

V. FIRE PROTECTION

Item to Inspect	Procedure How to Inspect			
A. Automatic Fire Suppression System (Sprinkler)		**Passed**	**Failed**	**N/A**
Sprinkler Pumps	Check automatic start and pressure.	[ ]	[ ]	[ ]
Sprinkler Valves	Valves are locked in the open position, no leaks, corrosion, or other defects noted.	[ ]	[ ]	[ ]
Sprinkler water flow alarm	Open test valve and ensure manual alarm bell functions and sprinkler pumps start.	[ ]	[ ]	[ ]
B. Wet Standpipe/Fire Hose Cabinet		**Passed**	**Failed**	**N/A**
Cabinet Door Operative	Check that door is unobstructed and opens properly.	[ ]	[ ]	[ ]
Hose Condition	Check that hose is not rotted, wet, moldy, etc.	[ ]	[ ]	[ ]
Nozzle	Check that nozzle is in place and operates correctly.	[ ]	[ ]	[ ]
Hose hung properly	Check that hose is hung properly so that it can easily be un-rolled if needed.	[ ]	[ ]	[ ]
Valves and valve handles	Check that valve handles are in place and that valves operate properly and are in the open position	[ ]	[ ]	[ ]

C. Fire Pump		Passed	Failed	N/A
Pump System	Inspect accuracy of pressure gauges and sensors	[ ]	[ ]	[ ]
Pipings	Check pipings if there is leak	[ ]	[ ]	[ ]
Motor	Check unusual noise or vibrations	[ ]	[ ]	[ ]
Electrical System	Check if there is corrosion in PCBs, cracked cable/wire insulation, leak in plumbing parts, sign of water in electrical part	[ ]	[ ]	[ ]
D. Fire Detection System		**Passed**	**Failed**	**N/A**
Fire Detection System	Random Test of call points and smoke detectors.	[ ]	[ ]	[ ]
E. Fire Alarm Facilities		**Passed**	**Failed**	**N/A**
Location Signs	Check all signs are in place and legible.	[ ]	[ ]	[ ]
Alarm Panels	Check that all alarm panels are functioning correctly and are unobstructed.	[ ]	[ ]	[ ]
F. Lifts (Elevator)		**Passed**	**Failed**	**N/A**
Lifts	All lifts “home” to ground floor during fire test, doors open and lift stops.	[ ]	[ ]	[ ]
Fans	All lift fans operate correctly.	[ ]	[ ]	[ ]
Fireman’s lift	Fireman’s lift can be keyed to operate during fire alarm test.	[ ]	[ ]	[ ]
G. First Aid Fire Protection (Fire Extinguishers)		**Passed**	**Failed**	**N/A**
Fire Extinguisher Size	Minimal sizes of fire extinguishers for the listed grades of hazards shall be provided on the basis of table 7 & 8 of RIRR of RA 9514.	[ ]	[ ]	[ ]
Minimum number of Extinguisher.	The minimum number of extinguishers shall be sufficient to meet the requirements of table 7 & 8 of RIRR of RA 9514.	[ ]	[ ]	[ ]
Location	All extinguishers are in their proper location.	[ ]	[ ]	[ ]
Seals & Tags	Extinguisher seals and tags are intact and extinguisher was serviced in the last 12 months.	[ ]	[ ]	[ ]
Markings	Proper marking on extinguisher to indicate the type of fire the extinguisher can be used on.	[ ]	[ ]	[ ]
Condition	No leaks, corrosion or other defects noticed.	[ ]	[ ]	[ ]
Pressure	Pressure gauge reads in the “green” area.	[ ]	[ ]	[ ]
H. Emergency Lighting Systems		**Passed**	**Failed**	**N/A**
Battery Lights	All battery-poweredhting turns on when mains power is removed.	[ ]	[ ]	[ ]
I. Kitchen		**Passed**	**Failed**	**N/A**
Hoods & Vents	Hoods, vents, fans and ducts in good condition and free from grease	[ ]	[ ]	[ ]
J. Building Service Equipment				
1. Utilities:		**Passed**	**Failed**	**N/A**
Cooking equipment protected by AKHFSS (Restaurant and similar establishment with Occupant Load > 50p)		[ ]	[ ]	[ ]
Hoods, Filters, Ducts and Fans	Inspect the hood, duct and filters for grease build up.	[ ]	[ ]	[ ]
	Nozzles are with grease caps and clean.	[ ]	[ ]	[ ]
	All appliances are in the proper place, have not been moved and are fully covered by the hood.	[ ]	[ ]	[ ]
	There have been no alterations or changes to the hood, ducts or appliances. Only alterations permitted by NFPA 96 may be made to the exhaust system.	[ ]	[ ]	[ ]
	Hood and duct have not been damaged and that there are no breaches. Pipes or other penetrations of the hood or duct openings, which are part of the system design, are in good condition and remain tightly fitted.	[ ]	[ ]	[ ]

		All lights located in the hood to ensure that they are properly protected. Lights should be rated for hazardous locations and enclosed to prevent grease from entering or contacting hot parts or wiring.	[ ]	[ ]	[ ]
		Sufficient air is available to allow the ventilation system to operate properly.	[ ]	[ ]	[ ]
	Fire Detection and Suppression System	The indicator needle in the pressure gauge is green or “OK,” section of the dial.	[ ]	[ ]	[ ]
		No signs of damage, leaks or tampering in the fire suppression system tank.	[ ]	[ ]	[ ]
		Check fire suppression system cylinder for the last hydrostatic test – within the past 12 years. The most recent test date will be stamped into the metal of the cylinder - usually near the valve assembly. Cylinders older than 12 years or those without a date stamp must be replaced.	[ ]	[ ]	[ ]
		Manual pull station is easily accessible to all employees and it is not obstructed or blocked in any way.	[ ]	[ ]	[ ]
		operating instructions for the fire suppression system are posted, visible and easy to read.	[ ]	[ ]	[ ]
		The automatic gas and electrical shut-off devices are in place and properly connected.	[ ]	[ ]	[ ]
		All kitchen staff are familiar with the proper operation of the fire suppression system.	[ ]	[ ]	[ ]
		The required kitchen portable fire extinguisher is in place. Ensure the extinguisher is the proper type – K Class (alkali base), that the last monthly inspection is noted, and that the unit has been serviced within the previous 12 months.	[ ]	[ ]	[ ]
	2. Heating, Ventilating and Air-conditioning:		**Passed**	**Failed**	**N/A**
	Design & Installation in accordance with PMEC		[ ]	[ ]	[ ]
	3. Smoke Control Systems/Smoke Management shall be provided in the following:		**Passed**	**Failed**	**N/A**
	[ ] All high-rise buildings (stairwells, at least 1 elevator shaft, zoned smoke control, and vestibule).		[ ]	[ ]	[ ]
	[ ] Pressurization of smoke refuge area.		[ ]	[ ]	[ ]
	[ ] Every Atrium of covered mall of over 2- levels / Other type of Occupancy over 3 – levels.		[ ]	[ ]	[ ]
	[ ] Underground structure and windowless facilities.		[ ]	[ ]	[ ]
	[ ] All movie houses.		[ ]	[ ]	[ ]
	[ ] All other buildings or structures with at least 1,115m² single floor area.		[ ]	[ ]	[ ]
	4. Rubbish Chutes, Laundry Chutes, and Flue-Fed Incinerators: (Does not apply to detached single- or two-family dwelling)		**Passed**	**Failed**	**N/A**
	[ ] Chutes & Incinerators shall be enclosed.		[ ]	[ ]	[ ]
	[ ] Design and Maintained in accordance with the latest edition of PMEC.		[ ]	[ ]	[ ]
	K. FIRE WALL (FW) (if required)		**Passed**	**Failed**	**N/A**
	Provided with Fire Wall (minimum 2 hours fire resistance)		[ ]	[ ]	[ ]
	FW extension above the roof surface shall not be less than 760mm (See MC No. 2021-064 dated 28 June 2021 for Alternative)		[ ]	[ ]	[ ]
	Wall type: [ ] 125mm Solid Concrete / [ ] 150mm Solid Masonry / [ ] 200mm Hallow Unit Masonry				

VI. DEFECTS/DEFICIENCIES (Attached pictures, sketch and others) (Use separate sheet if necessary)

ITEM I: _____

_____

_____

ITEM II: _____

_____

_____

ITEM III: _____

_____

_____

ITEM IV: _____

_____

_____

ITEM V: _____

_____

_____

REMARKS: _____

_____

VII. RECOMMENDATIONS

[ ] Comply the following DEFFECTS/DEFICIENCIES stated above.

[ ] Secure the following Fire Safety Clearances: _____ _____

_____ _____

_____ _____

[ ] Pay the corresponding Fire Code Fees including the fees for Fire Safety Clearances.

[ ] For issuance of
- [ ] FSIC
- [ ] Notice to Comply
- [ ] Notice to Correct Violation
- [ ] Abatement Order
- [ ] Closure Order
- [ ] Closure Order for the Non-payment of Administrative Fine
- [ ] Notice of Disapproval (NOD)

ACKNOWLEDGED BY:

_____ _____ _____

Signature Over Printed Name of Owner/ Representative | Fire Safety Inspector/s | Fire Safety Inspector/s

_____

Team Leader

Date & Time: _____

RECOMMEND APPROVAL:

_____

CHIEF, FIRE SAFETY ENFORCEMENT SECTION/UNIT

APPROVAL:

_____

CITY/ MUNICIPAL FIRE MARSHAL