Republic of the Philippines
Department of the Interior and Local Government
BUREAU OF FIRE PROTECTION
(Region)
(District/Provincial Office)
(STATION)
(Station Address)

FIRE SAFETY INSPECTION CHECKLIST

for FIRE SAFETY CLEARANCE
CONVEYANCE OF LPG IN CYLINDERS
☐ **FOR TWO (2)-WHEELED VEHICLE**
☐ **FOR THREE (3)-WHEELED VEHICLE**

Date_____

Control No._____
Name of Operator_____
Address _____
Brand of Vehicle _____ Plate No._____
Motor(Engine)Number _____ Chassis No. _____
Validity of Registration_____

Instruction: (√) Check the appropriate box (Yes/No), if the following conditions are provided:

	CONDITIONS	Yes	No
1	LTO Certificate of Registration & Updated LTO Official Receipt (OR) of vehicle is available.		
2	Business Permit and Fire Safety Inspection Certificate Num._____ (for renewal) & date issued_____ for Business (Operator).		
3	A copy of the latest License to Operate (LTO) issued by the DOE.		
4	The cargo space must be Metal Cage, fully ventilated.		
5	Metal cage must be equipped with rubber saddle and belt or equivalent at both sides of the metal cage.		
6	All signal, brake and emergency/hazard lights must be working.		
7	The tire ply should be intact, with no visible separation, wide tear, holes, or bulges.		
8	Required signages are provided at the required locations (Back of the cage of the two- wheeled motorcycle; back and sides of the three-wheeled motorcycles).		
9	All filled and used empty LPG cylinders shall be loaded in an upright position.		
10	Two-wheeled vehicles shall have a maximum load of 2 cylinders-11 kg or 4 cylinders -2.7 kg.		
11	Three-wheeled vehicles shall have a maximum 2 stacks load of total of 12 cylinders -11 kg or its equivalent for smaller sizes of cylinders. (1 stack=6 cylinders)		
12	The driver of the vehicle shall have an unobstructed view.		
13	Provide 5R size photos of the motor vehicle (front, rear, side).		

DEFECTS / DEFICIENCIES NOTED DURING INSPECTION:

_____
_____
_____

RECOMMENDATIONS:
For issuance of ☐ Conveyance Clearance ☐ Notice of Disapproval

ACKNOWLEDGED BY:

_____ _____
Signature Over Printed Name of Owner/Representative Fire Safety Inspector/s
Date & Time _____

_____
Team Leader

RECOMMEND APPROVAL:

_____
CHIEF, FIRE SAFETY ENFORCEMENT SECTION

APPROVED / DISAPPROVED:

_____
CITY / MUNICIPAL FIRE MARSHAL