Republic of the Philippines
Department of the Interior and Local Government
Bureau of Fire Protection

(Region)
(District/Provincial Office)
(STATION)
(Station Address)

FIRE SAFETY INSPECTION CHECKLIST

CONVEYANCE CLEARANCE thru PIPELINES

Date_____

Control No._____

Name of the Firm (Company): _____
Address of the Firm (Company): _____
Location of the Pipeline System: _____
Name of the Pipeline: _____
Length of the Pipeline (m): _____Diameter of the Pipeline (m): _____
Thickness of the Pipeline (in): _____ Year of Manufacturing of the Pipeline: _____
Product Convey in the Pipeline: _____
Total Volume Convey in the Pipeline (m^3): _____
Inlet Gas Pressure in the Pipeline (bar): _____
Outlet Gas Pressure in the Pipeline (bar): _____

Instruction: (√) Check the appropriate box (Yes/No) if the following condition is provided:

	TEST RECORDS	Yes	No	Remarks
1	Radiography test			
2	Ultrasonic test			
3	Hydrostatic test			

Note: Attached hardcopy of all test records mentioned above, if conducted:

	FIELD IDENTIFICATION	Yes	No	Remarks
1	Is piping labeled/tagged with equipment ID number?			
2	Is the pipeline adequately identified?			
3	Are labels/tags readable?			
4	Do labels/tags need replacing?			
	CORROSION			
5	Any corrosion at support points or fixtures?			
6	Any coating or paint deterioration?			
7	Any areas with scale, pits, or rust?			
8	Any corrosion between flanges?			
9	Any significant corrosion of flange bolts?			
	PIPE SUPPORT			
10	Any shoes off their supports?			
11	Any hangers missing or damaged?			
12	Any springs hangers bottomed-out?			
13	Any problems with support braces?			
14	Any corrosion of supports?			
15	Any loose or broken brackets?			
	LEAKS			
16	Any leaks from the process?			
17	Any leaks from steam tracing?			
18	Are any valves leaking?			
19	Any leaks at leak repair clamps?			
20	Any evidence of past leaks?			
	VIBRATION			
21	Any significant vibration observed?			
22	Any evidence of excessive movement?			
23	Any pipe distortion observed?			
24	**INSULATION**			
25	Any physical damage or penetration?			
26	Any deterioration/damage of weather seals?			
27	Any bulging or wet insulation?			
28	Any discoloration indicating leakage?			
29	Any retaining bands missing/broken?			
30	Any missing jackets, plugs, or insulation?			

Prohibited Acts:

* Smoking is prohibited within 50ft in the vicinity of pipeline.
* Kaingin/Intentional grass fire at the vicinity of pipeline.

DEFECTS / DEFICIENCIES NOTED DURING INSPECTION:

_____
_____
_____
_____
_____
_____
_____
_____
_____
_____
_____
_____
_____
_____

RECOMMENDATIONS:
For issuance of ☐ Conveyance Clearance ☐ Notice of Disapproval

ACKNOWLEDGED BY:

_____ _____
Signature Over Printed Name of Owner/Representative Fire Safety Inspector/s

Date & Time _____

_____
Team Leader/ Fire Safety Inspector

RECOMMEND APPROVAL:

_____
CHIEF, FIRE SAFETY ENFORCEMENT SECTION

APPROVED / DISAPPROVED:

_____
CITY / MUNICIPAL FIRE MARSHAL

PAALALA: "MAHIGPIT NA IPINAGBABAWAL NG PAMUNUAN NG BUREAU OF FIRE PROTECTION SA MGA KAWANI NITO ANG MAGBENTA O MAGREKOMENDA NG ANUMANG BRAND NG FIRE EXTINGUISHER"

"FIRE SAFETY IS OUR MAIN CONCERN"