SENI-142: An Open-Access Resilient Insular Transmission Benchmark of the Dominican Republic with Diakoptic Territorial Decomposition under Spatial Planning Law 368-22

Junior Alexis Villanueva-Rosario, *Ms.C., Ph.D.(c)*

V-TECH | V-CORE TECH S.R.L. / Villa-Core Technologies, S.L.

Department of Electrical Grids and Renewable Energy (EERR) Research

Doctoral Chair in Power Systems and Artificial Intelligence

Santo Domingo, Dominican Republic | ingjavillanueva@gmail.com

***Abstract*—This paper introduces SENI-142, an open, fully georeferenced benchmark of the complete bulk transmission system of the Dominican Republic. The model comprises 142 nodal compute buses derived from 112 bulk transmission substations (115 bulk buses at 345, 230, and 138 kV plus 27 condensed boundary ports at 69 kV), 135 transmission lines, and 58 power transformers at the 345, 230, and 138 kV levels; the radial 69 kV subtransmission layer is condensed into multiport equivalents preserving complex boundary injections and short-circuit impedances. The network is partitioned into ten planning regions aligned with national Law 368-22 and aggregated into four electrical macro-domains. A hierarchical boundary-coordinate formulation (HBCF) is applied, wherein the linear systems arising at each Newton–Raphson iteration are condensed exactly via the Schur complement. On commodity 8-thread hardware, the partitioned solver achieves a full AC state solution in a measured wall-clock time of 2.65 ms (resident set: 473 MiB) — an experimental reference measurement obtained on the author's 8-thread Linux workstation with his C++/Sparse research engine, serving as a comparison baseline for future community solvers — with an algebraic domain-decomposition residual of $\delta = 2.788 \times 10^{-14}$ pu relative to a monolithic reference. The structural model is validated across exactly 520 complete consecutive weeks (87 360 hourly states over 3,640 Monday-to-Sunday days, drawn from the 2016–2025 operational archive) using a 24-hour block bootstrap and evaluated under an official $N-1$ catalogue of 215 contingencies under explicit post-contingency reserve redispatch and bounded slack injection. The 87,360-state multi-temporal campaign and the 215-contingency screening are results of the author's patent-pending C++/Sparse engine; the released bundle certifies the network model, the condensed-solve invariants and the eight canonical contingency balances. Multitemporal AC optimal power flow is formulated with power-to-gas, pumped-storage hydro, and biomethanation balances. The dataset, network parameters, and open validation harness are released through IEEE DataPort and a public repository.**

J. A. Villanueva-Rosario is with the Department of Electrical Grids and Renewable Energy (EERR) Research, V-TECH (V-CORE TECH S.R.L. / Villa-Core Technologies, S.L.), Santo Domingo, Dominican Republic (e-mail: ingjavillanueva@gmail.com).

***Index Terms*—Benchmark testing, diakoptics, digital twins, energy storage, hydrogen, insular power systems, optimal power flow, power system resilience, pumped-storage hydroelectricity, Schur complement, spatial planning, transmission networks.**

Resumen (Español)

Este artículo presenta SENI-142, un benchmark abierto y georreferenciado del sistema de transmisión troncal de la República Dominicana. El modelo comprende 142 barras de cómputo nodal derivadas de 112 subestaciones de transmisión troncal (115 barras troncales a 345, 230 y 138 kV más 27 puertos frontera condensados a 69 kV), 135 líneas de transmisión y 58 transformadores de potencia en los niveles de 345, 230 y 138 kV; la capa radial de subtransmisión de 69 kV se condensa en equivalentes multipuerto que preservan las inyecciones complejas de frontera y las impedancias de cortocircuito. La red se particiona en las diez regiones de planificación de la Ley 368-22, agregadas en cuatro macrodominios eléctricos. Se aplica una formulación jerárquica de coordenadas de frontera (HBCF), donde los sistemas lineales de cada iteración de Newton–Raphson se condensan algebraicamente de forma exacta mediante el complemento de Schur. En hardware estándar de 8 hilos, el solver particionado resuelve el estado AC completo en 2.65 ms (memoria residente: 473 MiB) — medición experimental de referencia obtenida en la estación de trabajo Linux de 8 hilos del autor mediante su motor de investigación C++/Sparse, como línea base de comparación para futuros solvers de la comunidad — con un residuo de partición de $\delta = 2.788 \times 10^{-14}$ pu frente a la solución monolítica. El modelo estructural se valida sobre exactamente 520 semanas completas consecutivas (87 360 estados horarios sobre 3,640 días de lunes a domingo, extraídos del archivo operativo 2016–2025) mediante bootstrap por bloques de 24 horas y se evalúa ante un catálogo oficial $N-1$ de 215 contingencias bajo redespacho explícito de reserva rodante y barra slack acotada. La campaña

multitemporal de 87,360 estados y el cribado de 215 contingencias constituyen resultados del motor patent-pending C++/Sparse del autor; el paquete público certifica el modelo de red, los invariantes de resolución condensada y los balances de las ocho contingencias canónicas. Se formula el flujo óptimo de potencia AC multitemporal con acoplamiento multivectorial (hidrógeno, bombeo hidráulico y biometanación). Los datos estructurales, parámetros de rama y el arnés de validación se liberan abiertamente en IEEE DataPort.

I. Introduction

Insular interconnected systems occupy an extreme point of the power engineering design space. An island cannot draw inertia, reactive support, or emergency transfer from neighbors: every megawatt of reserve, every volt-ampere of reactive compensation, and every megahertz of damping capability must be produced, dispatched, and defended inside the same synchronous footprint that consumes it. The Dominican Republic is a canonical instance: a single synchronous island of roughly eleven million people, with no submarine or overland interconnection, more than forty percent of national load concentrated in the metropolitan Ozama region, an inertia anchor dominated by the Punta Catalina coal plant, and a renewable build-out whose instantaneous solar share has reached 36.6% of demand in operational telemetry [1]. The national consequences of losing the generation–load equilibrium are not hypothetical: the nationwide service interruptions recorded in November 2025 and February 2026, documented in operator event logs [1] and in the national press archive [2], mobilized emergency response at the scale of a full territory and renewed the policy debate on frequency stability, black-start capability, and the observability of the transmission estate [3]. The physics of this fragility is by now classical [4] — declining system inertia degrades the rate of change of frequency and narrows the feasible control envelope of converter-dominated grids [5], [6], [7], [8] — but the empirical instruments available to study it remain surprisingly primitive.

The benchmarking infrastructure of the field is, in its majority, synthetic. The canonical test cases that still govern doctoral training and comparative studies — the WSCC 9-bus network, the IEEE 14-, 30-, 57-, and 118-bus systems — descend from drafting-table abstractions of the early 1960s: reactances are round academic numbers, loads are fixed triangles of power, geography is absent, climate is absent, and nothing in the dataset has ever tripped, been maintained, been paid for, or been hit by a hurricane. At the opposite pole, utility-grade network cases are held in proprietary formats of commercial simulation platforms, are encumbered by confidentiality, and are rarely released in forms that permit independent re-execution. The open-systems movement has answered with valuable infrastructure — the MATPOWER case collection [9], and the Power Grid Library of AC-OPF benchmark instances [10] among them — but its instances are, almost without exception, *synthetic or anonymized*: they are grids that exist to be hard, not grids that exist. Between the toy and the secret there is almost nothing: an open, complete, measured model of a real national transmission system, with provenance sufficient for independent verification, is a public good that the research community currently lacks for the insular Caribbean — and, with few exceptions, for the insular world at large.

This article closes that gap with **SENI-142**, an open-access benchmark constructed around three commitments. First, **fidelity to a measured reality**: the network model is a calibrated, georeferenced one-line CAD reconstruction derived from the national bulk transmission estate and single-line surveys, and validated against exactly 520 complete consecutive 168-hour weeks — 87,360 hourly states spanning 3,640 Monday-to-Sunday days, drawn without a single interpolated hour from the 2016–2025 operational archive of the system operator — dispatched unit by unit and hour by hour, so that every simulated state answers to an archived operational one. Second, **structural honesty about scale**: the full national system is solved — all bulk buses, all trunk lines, all transformers — not a reduced district of it, and the solution method is formulated so that its exactness and complexity are theorems rather than aspirations: a hierarchical border-coordinate formulation (HBCF) in the diakoptic tradition [11], [12], condensed by the Schur complement [13] and factorized on a partition that follows the ten territorial planning regions of the SNIT instituted by the national territorial statute Law 368-22, in strict technical compatibility with the General Electricity Law 125-01 [14]. Third, **deterministic reproducibility**: every artifact passes a four-phase digital-twin lifecycle with a fail-closed gate cascade, detached SHA-512 sealing, and atomic promotion, so that any figure reported in this article can be regenerated from a bit-identical, cryptographically attested software state.

The contributions are five, and each is falsifiable:

- **C1 — Benchmark.** An open, georeferenced, standards-consistent model of the complete bulk transmission network of the Dominican Republic: 142 nodal buses derived from 112 fenced physical substation estates — decomposed into 115 bulk transmission buses (6 at 345 kV, 3 at 230 kV, 106 at 138 kV) and 27 boundary ports condensed from the 69 kV layer — 135 transmission lines, 58 power transformers, strata of 345, 230, and 138 kV, with the 69 kV subtransmission layer reduced by injection-preserving equivalents; released with topology, parameters, provenance metadata, and validation harness through IEEE DataPort and GitHub.
- **C2 — Formulation.** The HBCF diakoptic partition of a full insular grid into ten sovereign territorial microgrids — the legal planning regions of Law 368-22 — aggregated into four electrical macro-subdomains with a minimal border set, and the proof that its Schur condensation is exact, with complexity $O(\sum_k N_k^3 + N_B^3)$ against the $O(N^3)$ of monolithic dense factorization.
- **C3 — Deterministic digital twin.** A four-phase lifecycle (hermetic POSIX-namespace enclave with

a fourteen-gate fail-closed cascade; research-testbed verification of static post-event $N-1$ feasibility against a 215-contingency catalog; SHA-512-detached Golden Master; atomic kernel promotion via `renameat2` with zero regression) that converts simulation telemetry into evidence with a chain of custody.

- **C4 — Multi-vector flexibility.** The coupling of power-to-gas hydrogen (electrolysis, 700 bar storage, fuel-cell re-injection), 764 MW of reversible pumped hydro storage, and ADM1-based biomethanation to a multi-temporal AC-OPF, stated with its full Karush–Kuhn–Tucker (KKT) system and validated by a zonal CAPEX/OPEX balancing proof.
- **C5 — Measured silicon performance.** Resolution of each hourly national AC state in 2.65 ms with 473 MiB of resident memory and fasorial border residual $\delta = 2.788 \times 10^{-14}$ pu on consumer-grade hardware (an experimental reference measurement of the author's C++/Sparse research engine on his 8-thread Linux workstation, kept as a comparison baseline for community solvers; the released open harness deterministically reproduces the 41 mathematical and structural controls rather than this wall-clock figure) — two to three orders of magnitude inside the 1–5 s state-estimation cycle of an energy management system (EMS), adequate for static contingency screening — under a 24-hour block-bootstrap validation protocol.

The 87,360-state multi-temporal campaign and the 215-contingency screening are results of the author's patent-pending C++/Sparse engine; the released bundle certifies the network model, the condensed-solve invariants and the eight canonical contingency balances.

The remainder of the article is organized as follows. Section II states the methodology: the invariant formulation (graph model, 69 kV reduction, HBCF partition, Schur condensation, data protocol, deterministic lifecycle, reactive-limit regularization, multi-temporal AC-OPF) and the modular clause that instantiates the Dominican case under Law 368-22. Section III documents the benchmark topology, from the 112-substation physical estate to the 142-bus nodal model and the ten territorial microgrids. Section IV develops the multi-vector flexibility constellation and its zonal economic validation. Section V reports silicon performance, accuracy, and contingency resilience. Section VI discusses policy implications and limitations, and Section VII concludes with the open-release plan and four research routes.

II. Methodology: Diakoptic HBCF Schur Formulation and Fail-Closed Digital-Twin Lifecycle

The methodology is deliberately organized in two coupled components. The **invariant formulation** — graph representation, equivalent reduction, spatial partition, exact condensation, data protocol, deterministic lifecycle, regularization, and optimization — is problem-independent and transfers without modification across the family of studies built on this platform. The **territorial instantiation clause** binds this formulation to one reference reality: the national grid of the Dominican Republic, partitioned according to the country's own spatial planning statute. This division makes the benchmark a reusable scientific instrument. The subsections below follow that formulation through the numerical pipeline: sealed intake, columnar persistence, nodal physics and reduction, the four-block Jacobian, multi-tier numerical verification, the contingency battery, diakoptic condensation, the three network states, and SHA-512 custody.

A. Steady-State AC Feasibility Scope

SENI-142 is strictly a steady-state AC feasibility benchmark. Each solved state is an algebraic equilibrium $F(\mathbf{x}) = \mathbf{0}$ on the transmission network. It is an operating point, and the formulation does not integrate a time trajectory. The formulation explicitly does not simulate fast electromagnetic transients (EMT), frequency dynamics, synthetic inertia, rate of change of frequency (RoCoF), frequency nadir, or the actuation of under-frequency load shedding (UFLS/EDAC). The outage of the largest generation block, Punta Catalina (752 MW, about 21.8% of the 3,450 MW reference national peak demand documented in Table III), is evaluated solely in terms of steady-state voltage margins and post-contingency thermal branch solvability under co-optimized spinning reserve; in the dynamic plane it is a frequency-stability event outside the static frontier of this article.

B. Sealed intake, physical census, and normative screen

The solver does not accept a loose file. Entry is a sealed input manifest whose digest is checked before any bus is instantiated, and the manifest selects the physical case. In the measured-estate mode, prospective technologies that are not in commercial operation remain outside the solved dispatch, so the base case is the Dominican system as operated. In the full doctoral-scenario mode those prospective assets may be instantiated; they stay labeled and are never mixed silently into the measured record.

The physical census is the single-line survey already consolidated in Table X: the benchmark comprises 142 nodal compute buses derived from 112 bulk transmission substations (115 bulk buses at 345, 230, and 138 kV plus 27 condensed boundary ports at 69 kV), coupled by 135 transmission lines and 58 power transformers. The unreduced drawing census of the source survey remains an internal artifact of the single-line database; the released compute model is the condensed 142-bus estate defined below.

Before any admittance is assembled, a normative screen rejects a record that violates IEEE C37 substation arity or the CIM exchange constraints of IEC 61970 [15]. Series reactances must satisfy $X > 0$, shunt susceptances $B \geq 0$, and two-winding and three-winding transformers must close their own balance. A record that fails the screen aborts the case. It is not repaired by a default.

The same screen is a homologation against current commercial catalogs, not a syntactic patch. Series reactance $X > 0$, shunt susceptance $B \geq 0$, and the thermal rating $I_{\max}$ are taken from the catalogs of ACSR and AAAC conductors, of power transformers, and of reactive compensation banks rated up to 250 MVAr. Bay arity and protection classes follow IEEE C37. The exchanged network object follows IEC 61970 (CIM) [15]. None of these values is a synthetic default: a catalog field that fails the screen aborts the case.

C. Columnar persistence and merit-order dispatch

Validated records are laid out as contiguous in-memory columns so that one instruction stream operates on many nodal quantities without copying each record into a relational frame. The layout is an architectural role. On those columns the thermal fleet is ordered by heat-rate merit, and each hour supplies the nodal demand pair (P_d, Q_d) that later enters the power balance.

D. Graph-theoretic representation of the bulk network

The transmission system is modeled as a connected undirected graph $\mathcal{G} = (\mathcal{V}, \mathcal{E})$ [16], where $\mathcal{V}$ is the set of transmission buses ($|\mathcal{V}| = 142$) and $\mathcal{E} = \mathcal{E}_{\text{line}} \cup \mathcal{E}_{\text{trafo}}$ is the union of line and transformer branches, with $|\mathcal{E}_{\text{line}}| = 135$ transmission lines and $|\mathcal{E}_{\text{trafo}}| = 58$ power transformers. Each branch carries a per-unit series admittance and half-charging susceptance on a common 100 MVA base; the nodal admittance matrix $\mathbf{Y}_{\text{bus}} \in \mathbb{C}^{142\times142}$ therefore encodes 20,164 complex entries of coupled electromagnetic state. Nodal power injections follow the standard rectangular balance

$$S_i = P_i + jQ_i = V_i \sum_{j\in\mathcal{V}} Y_{ij}^{*}\, V_j^{*}, \qquad i \in \mathcal{V}, \tag{1}$$

with buses classified as slack, PV, or PQ [17]. The angle reference is the 345 kV bus of the Julio Sauri substation (JSAURI), held at $V = 1.02$ pu. Its active power is the bounded variable of (9) and is not an unbounded mismatch reservoir. That bus receives directly the injection of the largest thermal plant in the country (Section III-B). Where a physical substation hosts more than one voltage level, each voltage level is a distinct bus and the intervening autotransformer is a branch. The reconciliation of Section II-T is what carries the 112 bulk transmission substations to the 142 nodal compute buses (115 bulk buses at 345, 230, and 138 kV plus 27 condensed boundary ports at 69 kV; Section III-A).

Figure 1 places the 142 solved nodes in the four electrical macrodomains of Law 368-22 (Ω_1 Norte, Ω_2 Sur, Ω_3 Este, Ω_4 Metropolitano). Bulk yards keep the color of their measured nominal voltage, 345 kV, 230 kV, or 138 kV. The 27 retained boundary terminals stay at the measured 69 kV and are drawn in green. The compute model counts 135 transmission lines. The figure draws a stroke for each pair the census closes: a yard record that names both terminals, or a colinear one-line trace that arrives at a second solved bus of the same voltage. A record whose far terminal is not a census bus is omitted.

E. Equivalent reduction of the 69 kV subtransmission layer

Sixty-three radial laterals of the 69 kV layer are condensed into static multiport equivalents of Thévenin/Norton type. For each retained boundary terminal, which stays at its measured 69 kV, the equivalent preserves (i) the aggregated complex injection of the condensed area at every modeled hour and (ii) the short-circuit impedance Z_{cc} seen from that terminal, obtained by Kron-type network reduction. Formally, for boundary port p with condensed interior Ω_r,

$$V_p = E_{\text{th}}^{(r)} - Z_{\text{th}}^{(r)} I_p, \qquad \sum_{i\in\Omega_r} S_i = V_p I_p^{*} + \Delta S_{\text{loss}}, \tag{2}$$

so that the boundary power balance explicitly accounts for the internal losses represented by ΔS_{loss} while the equivalent preserves the retained-port variables and eliminates dimensional inflation of $\mathbf{Y}_{\text{bus}}$. The reduction is recomputed from the archived configuration of the estate and is itself part of the sealed artifact, consistent with recommended practice for industrial system analysis [18] and with CIM-based interchange of network models [15].

Of the ninety 69 kV busbars, sixty-three are the radial laterals removed above. The other twenty-seven remain solved buses at the measured 69 kV. Each of those twenty-seven is a retained boundary terminal. The 115 bulk nodes of Table X are the census buses at 345, 230, and 138 kV. The model that is actually solved has 142 buses: those 115 bulk nodes plus these 27 terminals at 69 kV. Removing the sixty-three laterals is also why a fast-decoupled flow and Gauss–Seidel converge on this estate: the branches whose R/X ratio would otherwise singularize the Jacobian are no longer nodes of the solved system. Synchronous units keep their full P–Q capability. Static renewable plants are not synchronous machines; their reactive support is stated with the continuous map of Section II-G.

F. Breadth-first scaling of connectivity

Let $\mathcal{G}_Y = (\mathcal{V}, \mathcal{E}_Y)$ be the sparsity graph of $\mathbf{Y}_{\text{bus}}$: an undirected edge exists wherever a retained branch has nonzero admittance. Breadth-first search (BFS), the connectivity scaling denoted M09, starts at the Julio Sauri slack and visits every bus reachable on $\mathcal{G}_Y$. Algorithm 1 is the procedure. A bus that remains unvisited belongs to another connected component. That component is an electrical island: it has no finite power-flow state, and its voltage magnitude is recorded as $V_m = \text{NaN}$ rather than as a fabricated residual. After the traversal, every visited bus of degree one is a radial antenna and is a candidate for the 69 kV condensation of Section II-E. Discovery order then places interior buses before border buses. That order is the permutation applied to the connectivity before the Schur partition of Section II-K.

The reordering is a permutation matrix $\mathbf{P}$. Singular values are invariant under permutation similarity, so




Figure 1. Schematic of the 142-node trunk, grouped into the four electrical macrodomains of Law 368-22 (Ω_1 Norte, Ω_2 Sur, Ω_3 Este, Ω_4 Metropolitano). Color is the measured nominal voltage: 345 kV in red, 230 kV in gold, 138 kV in blue, and the 27 retained 69 kV boundary terminals in green. A stroke joins two solved buses only: same-estate autotransformer links; yard records that name both ends, including the Palamara 138 kV bays to Julio Sauri, San Cristobal Norte, Hainamosa, Itabo, Valdesia, Bonao 2, Villa Mella and Arroyo Hondo; the 345 kV corridors Punta Catalina–Julio Sauri and Manzanillo Power Land–El Naranjo; the 138 kV link km 15 de Azua–Cruce de Cabral 2; the 230 kV tie Quisqueya 1–Quisqueya 2; and every other same-voltage pair whose colinear one-line trace arrives at a second census label. Parallel circuits are one stroke. The dashed bent stroke is the published 230 kV Julio Sauri–San Cristobal Norte reinforcement between the two 138 kV estates, because the census declares no separate 230 kV bus there. A record whose far terminal is not a census bus is omitted. Panel positions are schematic. Raw drawing coordinates are not shown.

Algorithm 1 Breadth-first scaling on the admittance graph (M09)

Require: sparsity graph $\mathcal{G}_Y = (\mathcal{V}, \mathcal{E}_Y)$, slack s
$Q \leftarrow (s)$, seen $\leftarrow \{s\}$, $\pi \leftarrow (s)$
while $Q \neq \emptyset$ **do**
  $u \leftarrow \mathrm{pop}(Q)$
  for $v \in \mathcal{N}(u)$ **do**
    if $v \notin$ seen **then**
      seen $\leftarrow$ seen $\cup \{v\}$; append v to Q and to π
    end if
  end for
end while
$\mathcal{I} \leftarrow \mathcal{V} \setminus$ seen ▷ islands, $V_m = \mathrm{NaN}$
$\mathcal{A} \leftarrow \{u \in$ seen $: \deg(u) = 1\}$ ▷ radial antennas
return permutation π, islands $\mathcal{I}$, antennas $\mathcal{A}$

$\kappa_2(\mathbf{PJP}^T) = \kappa_2(\mathbf{J})$. The BFS itself does not move the condition number and does not enlarge the state dimension. On the SENI-RD base case the measured movement is a change of operating point between the real network and the ideal network:

$$\kappa_{\mathrm{real}} = 341.21, \qquad \kappa_{\mathrm{ideal}} = 365.91, \\ \frac{\kappa_{\mathrm{ideal}} - \kappa_{\mathrm{real}}}{\kappa_{\mathrm{real}}} = +7.24\%. \tag{3}$$

The ideal state tightens the voltage band and the losses. It does not optimize $\kappa(\mathbf{J})$. The pair $341.21 \rightarrow 365.91$ is the spectral condition $\kappa_2(\mathbf{J})$ of the base-case Jacobian at the real and the ideal operating points. The increment of $+7.24\%$ is an operating-point change of conditioning. It is not an increase of dimension. IEEE Std 399-1997 [18] is cited in Section II-E as industrial-practice context for system studies. It is not used here as a strict threshold on $\kappa(\mathbf{J})$ for transmission power flow.

G. Centered reactive regularization and inverter capability

Hard PV–PQ switching at a generator reactive limit induces limit cycles in Newton-type iterations when the operating point oscillates about that limit. The stated controller is a centered map of class C^1 with $Q(V_{\mathrm{ref}}) = 0$,

$$Q_g^{\mathrm{reg}}(V) = Q_g^{\max}\left(\frac{2}{1 + e^{-\gamma(V_{\mathrm{ref}} - V)}} - 1\right). \tag{4}$$

At $V = V_{\mathrm{ref}}$ the exponent vanishes and the regulator injects zero reactive power. Its derivative

$$\frac{\partial Q_g^{\mathrm{reg}}}{\partial V} = -2\gamma Q_g^{\max}\,\sigma(1-\sigma), \qquad \sigma = \frac{1}{1 + e^{-\gamma(V_{\mathrm{ref}} - V)}},$$

enters the Jacobian and keeps the Newton step differentiable. A C^1 smoothstep with a deadband inside the same voltage band is an admissible transition of the same class. The measured regularization error of this controller over the validation horizon is 5.32×10^{-12}. Static renewable plants use the same centered family,

$$Q_{\mathrm{sgen}}(V) = Q_{\max}\left(\frac{2}{1 + e^{-\gamma(V_{\mathrm{ref}} - V)}} - 1\right), \tag{5}$$

which is odd about the voltage reference. Every inverter-coupled injection also lies in the apparent-power disk

$$P_{g,t}^2 + Q_{g,t}^2 \leq \left(S_g^{\max}\right)^2, \tag{6}$$

as required by IEEE Std 2800-2022 [19] and IEEE Std 1547-2018 [20].

H. Four-block Jacobian and the solver cascade

The Newton step uses the full four-block Jacobian. No block is replaced by a forced decoupling approximation:

$$\mathbf{J} = \begin{bmatrix} \mathbf{J}_{P\theta} & \mathbf{J}_{PV} \\ \mathbf{J}_{Q\theta} & \mathbf{J}_{QV} \end{bmatrix} = \begin{bmatrix} \partial\mathbf{P}/\partial\boldsymbol{\theta} & \partial\mathbf{P}/\partial\mathbf{V} \\ \partial\mathbf{Q}/\partial\boldsymbol{\theta} & \partial\mathbf{Q}/\partial\mathbf{V} \end{bmatrix}. \tag{7}$$

The solve on the reduced network is a cascade of four methods. A flat start supplies a balanced initial state. A fast-decoupled step estimates the angles. A polar Newton–Raphson iteration then drives the mismatch below 10^{-8} pu. If the Jacobian approaches ill-conditioning, a damped Levenberg–Marquardt step replaces the undamped Newton update. The 10^{-8} pu figure is the stopping criterion of the methodological specification, not a second measured residual.

With one angle reference removed, the unreduced polar mismatch has order $2 \times 141 = 282$. The unreduced operator is therefore $\mathbf{J} \in \mathbb{R}^{282\times282}$, partitioned into the four quadrants $\mathbf{J}_{P\theta}$, $\mathbf{J}_{PV}$, $\mathbf{J}_{Q\theta}$, and $\mathbf{J}_{QV}$ of (7). PV buses delete the corresponding voltage rows and columns from the factored Newton step, so the cascade does not claim that every hourly factorization is the dense 282×282 square. The published object is the unreduced polar Jacobian, stored in full and without ellipsis. Together with $\mathbf{Y}_{\mathrm{bus}} \in \mathbb{C}^{142\times142}$ (20,164 complex entries), it is the matrix pair that the seals of Section II-O close.

I. Multi-tier numerical verification

Three independent calculations audit one state: the physical solve, the four-block Jacobian of Section II-H, and a dual spectral validator. The validator reports the orthogonal condition number $\kappa_2(\mathbf{J}) = \sigma_{\max}/\sigma_{\min}$ from the factorization $\mathbf{J} = \mathbf{U}\boldsymbol{\Sigma}\mathbf{V}^T$, and the smallest eigenvalue $\lambda_{\min}(\mathbf{J}_R)$ of the reduced reactive block by an Arnoldi subspace iteration. The algebraic domain-decomposition residual — the maximum mismatch between the condensation-recovered state and the monolithic reference — satisfies

$$\|\mathbf{v}_{\mathrm{rec}} - \mathbf{v}_{\mathrm{full}}\|_\infty = 2.788 \times 10^{-14}\ \mathrm{pu} \leq 10^{-11}\ \mathrm{pu} \tag{8}$$

over the validation horizon [21]. As an external-validity control, the same spectral methodology was first stress-checked on synthetic cases: the 22×22 Jacobian of the classical IEEE 14-bus system, for instance, classifies as MARGINAL in the project's spectral taxonomy with $\kappa_2 = 117.7823$, a classification cross-verified against independent tooling before any national deployment.

J. Bounded slack, spinning reserve, and the N-1 test

The angle reference remains the Julio Sauri 345 kV bus at $V = 1.02$ pu. Its active power is a bounded decision,

$$P^{\min}_{\text{slack}} \le P_{\text{slack},t} \le P^{\max}_{\text{slack}}, \tag{9}$$

and does not absorb an arbitrary mismatch. Spinning reserve is co-optimized on the generating fleet,

$$\begin{aligned}\sum_{g\in\mathcal{G}} r^{+}_{g,t} \;\ge\; R^{\text{req}}_t &= \max\Big(\underbrace{\max_g P^{\max}_g}_{N-1\text{ unitary layer}} \;,\; \underbrace{P^{\text{cmplx}}_{\text{PC}}}_{\text{common-mode layer}} \Big) \\ &= \max(376, 752) = 752 \text{ MW},\end{aligned} \tag{10}$$

where $P^{\text{cmplx}}_{\text{PC}} = 2 \times 376$ MW is the rating of the complete Punta Catalina complex. For each contingency $c \in \mathcal{C}$ the post-event dispatch deploys that reserve,

$$P^{(c)}_{g,t} = P^{0}_{g,t} + \Delta P^{(c)}_{g,t}, \qquad 0 \le \Delta P^{(c)}_{g,t} \le r^{+}_{g,t}, \tag{11}$$

and the record reports the slack deviation $\Delta P^{(c)}_{\text{slack},t}$ together with the unserved-load variable $P^{(c)}_{\text{shed},t}$.

The requirement (10) implements an explicit two-layer security doctrine. *Layer 1 — unitary $N-1$.* The 215-element catalog audits single outages — 104 trunk lines, 16 autotransformer banks, 32 synchronous thermal units and 63 static renewable plants — with each 376 MW unit of Punta Catalina audited individually, so the unitary layer of the requirement is the largest unit rating, 376 MW. *Layer 2 — common mode.* The most severe plant-level common-mode event of the island, the simultaneous trip of the complete complex ($2 \times 376 = 752$ MW), is additionally covered by sizing the requirement at the complex rating. Co-optimizing the reserve at $\sum r^{+}_{g} \ge 752$ MW is therefore not a tautology but a deliberately ultra-conservative preventive criterion: because the co-optimized fleet covers the largest common-mode deficit, every unitary outage of the catalog is covered *a fortiori* on the capacity axis, and the open feasibility question for each contingency reduces to network deliverability of the deployed reserve and post-event voltage sufficiency — exactly what the four-clause PASS below verifies by explicit AC solve rather than by assumption. Both layers remain inside the static frontier of Section II-A: (10) sizes the redispatch capability that the post-event AC solve deploys; it does not model the frequency excursion.

The contingency catalog is the transmission operator's own list: 104 trunk lines at 345, 230 and 138 kV, 16 substation autotransformer banks, 32 synchronous thermal units and 63 static renewable plants, 215 single outages in total. A contingency c is PASS only when all four clauses hold.

1) The AC power flow converges with $\|\Delta P^{(c)}, \Delta Q^{(c)}\|_\infty \le 10^{-8}$ pu.
2) Every retained bus satisfies $V^{(c)}_i \in [0.95, 1.05]$ pu.
3) Every surviving branch $\ell \in \mathcal{L} \setminus \{c\}$ satisfies $|S^{(c)}_\ell| \le S^{\max}_\ell$ and $|I^{(c)}_\ell| \le I^{\max}_\ell$.
4) The slack deviation stays inside its bound, $|\Delta P^{(c)}_{\text{slack}}| \le \varepsilon_{\text{slack}}$, and the active-power deficit is zero, $P^{(c)}_{\text{shed}} = 0$.

Every outage in that catalog met the four clauses, 215 of 215. When a severe outage drives voltages outside the band, an auxiliary bisection computes the shunt step ΔQ_{shunt} that restores every bus to $[0.95, 1.05]$ pu. That step is a documented corrective measure of voltage support. It is not unused thermal headroom.

K. Spatial diakoptic partition: the HBCF

The Hierarchical Border-Coordinate Formulation (HBCF) partitions $\mathcal{G}$ into K territorial subsystems $\mathcal{G}_k = (\mathcal{V}_k, \mathcal{E}_k)$, pairwise vertex-disjoint, interconnected exclusively through a minimal border set $\mathcal{V}_B = \bigcup_{k=1}^{K} \partial\mathcal{V}_k$ of cut boundary buses. The partition is *hierarchical in two registers*:

1) **Legal-territorial register.** Law 368-22 (Ley de Ordenamiento Territorial, Uso de Suelo y Asentamientos Humanos) [14], the territorial statute of the Dominican State, institutes the ten official planning regions of the SNIT. The benchmark SENI-142 adopts this sovereign spatial partition as the basis of its ten-microgrid diakoptics — so that electrical partition and territorial governance coincide — in strict technical compatibility with the technical governance of the General Electricity Law 125-01, a modeling decision with direct policy consequences (Section VI).
2) **Electrical register.** For numerical condensation, the ten microgrids bundle into $K = 4$ electrical macro-subdomains — North (Cibao), South, East, and Metropolitan — whose interconnections are exactly the trunk 230/138 kV ties of the estate. The border set $\mathcal{V}_B$ is the set of buses incident to those ties; Kron cutting of the trunk branches [11], [12] isolates the subdomains and defines the condensation boundary Γ.

After reordering buses as (interior | border), the nodal Jacobian or admittance system at any operating point takes the block form

$$\begin{bmatrix} \mathbf{A} & \mathbf{B} \\ \mathbf{C} & \mathbf{D} \end{bmatrix} \begin{bmatrix} \mathbf{x}_I \\ \mathbf{x}_B \end{bmatrix} = \begin{bmatrix} \mathbf{u}_I \\ \mathbf{u}_B \end{bmatrix}, \tag{12}$$

where $\mathbf{x}_I$ collects the internal variables of all subdomains and $\mathbf{x}_B$ the border state. By construction $\mathbf{A} = \text{diag}(\mathbf{A}_1, \ldots, \mathbf{A}_K)$ is block-diagonal, with $\mathbf{A}_k$ the internal Jacobian block of macro-subdomain k.

L. Exact condensation by the Schur complement

The condensation rests on three algebraic results. They are stated in full because they carry the exactness claim of the block domain decomposition.

Lemma 1 (block-diagonal inverse)**.** *If* $\mathbf{A} = \text{diag}(\mathbf{A}_1, \ldots, \mathbf{A}_K)$ *with each* $\mathbf{A}_k \in \mathbb{R}^{N_k \times N_k}$ *nonsingular, then* $\mathbf{A}^{-1} = \text{diag}(\mathbf{A}_1^{-1}, \ldots, \mathbf{A}_K^{-1})$.

Proof. Immediate: for each block position (k, l), $\mathbf{A}_k \mathbf{A}_k^{-1} = \mathbf{I}_{N_k}$ if $l = k$ and $\mathbf{A}_k \cdot \mathbf{0} = \mathbf{0}$ otherwise; the product equals the identity on the direct sum of the interior spaces. □

Theorem 1 (exactness of Schur condensation)**.** *If the full system matrix* $\left(\begin{smallmatrix}\mathbf{A} & \mathbf{B}\\ \mathbf{C} & \mathbf{D}\end{smallmatrix}\right)$ *is nonsingular and* $\mathbf{A}$ *is nonsingular, then* $\mathbf{x}_B$ *is the unique solution of the reduced border system*

$$\mathbf{S}\,\mathbf{x}_B = \mathbf{u}_B - \mathbf{C}\,\mathbf{A}^{-1}\mathbf{u}_I, \qquad \mathbf{S} = \mathbf{D} - \mathbf{C}\,\mathbf{A}^{-1}\mathbf{B}, \tag{13}$$

and $\mathbf{x}_I = \mathbf{A}^{-1}(\mathbf{u}_I - \mathbf{B}\,\mathbf{x}_B)$ *restores the interior state. The pair* $(\mathbf{x}_I, \mathbf{x}_B)$ *coincides with the unique solution of the unreduced block system.*

Proof. Block Gaussian elimination on the full system premultiplies the first row by $\mathbf{C}\mathbf{A}^{-1}$ and subtracts it from the second, eliminating $\mathbf{x}_I$ and yielding the border system above; these operations are nonsingular row operations, hence the reduced system is equivalent to the original and uniqueness transfers from the nonsingularity hypothesis. Back-substitution is the second row of the elimination. The Schur complement $\mathbf{S}$ is nonsingular precisely when the full matrix is [13]. □

Proposition 1 (complexity)**.** *Dense factorization of the* N*-bus system costs* $O(N^3)$*; the partitioned solution costs one block-diagonal factorization* $\sum_k O(N_k^3)$ *plus one border factorization* $O(N_B^3)$ *plus the elimination products, i.e.* $O\big(\sum_k N_k^3 + N_B^3\big)$ *with* $\sum_k N_k + N_B = N$ *and* $N_B \ll N$*. For sparse* $\mathbf{A}_k$ *factorized with fill-reducing orderings, the local cost approaches linearity in* N_k *[22], [23].*

The algebraic domain-decomposition residual of the condensation is (8). One hourly AC state on this partition is resolved in 2.65 ms. That wall-clock time is the static screening throughput of the partitioned solver: the rate at which an energy-management system can screen contingencies and at which an intraday dispatch can refresh a state. The value $\delta = 2.788 \times 10^{-14}$ pu certifies that the block Schur condensation introduces no truncation relative to the monolithic solve in double precision. Algorithm 2 states the complete solver.

M. The triad of network states

Three networks are distinguished and only one is released here. The real network $\mathcal{G}_{\text{real}}$ is the homologated SENI-142 benchmark of this article. The ideal network $\mathcal{G}_{\text{ideal}}$ is the physical frontier of the estate that already exists: corridors and conductor sizes are uprated to the admissible limit, and no new right-of-way is introduced. The optimal network $\mathcal{G}_{\text{opt}}$ begins only when that frontier is exhausted; it adds high-temperature low-sag reconductoring under CIGRE Technical Brochure 244, assisted by the reactive bisection of Section II-J. Pareto fronts and the comparison with the classical IEEE library are left to the companion optimization paper.

N. The deterministic validation lifecycle of the digital twin

Every reported figure in this article is downstream of a software state whose provenance is cryptographically attested. The lifecycle has four phases, and Figure 2 diagrams it in full:

Algorithm 2 Schur-border AC power flow on the SENI-142 HBCF partition

Require: partition $\{\mathcal{G}_k\}_{k=1}^{4}$, border set $\mathcal{V}_B$, hourly injections $(\mathbf{u}_I, \mathbf{u}_B)$, tolerance ε
Ensure: converged state $(\mathbf{x}_I, \mathbf{x}_B)$, residual ρ

initialize the flat start $(\mathbf{x}_I^{(0)}, \mathbf{x}_B^{(0)})$
assemble $\mathbf{J}^{(0)} = \left(\begin{smallmatrix}\mathbf{A} & \mathbf{B}\\ \mathbf{C} & \mathbf{D}\end{smallmatrix}\right)$
for $t \leftarrow 0, 1, 2, \ldots$ until $\rho \le \varepsilon$ **do**
  for $k \leftarrow 1, \ldots, K$ **do** ▷ parallel, disjoint memory
    $\mathbf{A}_k^{(t)} \leftarrow \partial(\Delta\mathbf{u}_k)/\partial\mathbf{x}_k$
    factor $\mathbf{A}_k^{(t)} = \mathbf{L}_k\mathbf{U}_k$ ▷ fill-reducing ordering
  end for
  $\mathbf{W}^{(t)} \leftarrow \big(\mathbf{A}^{(t)}\big)^{-1}\mathbf{B}^{(t)}$ ▷ K local back-substitutions
  $\mathbf{S}^{(t)} \leftarrow \mathbf{D}^{(t)} - \mathbf{C}^{(t)}\mathbf{W}^{(t)}$
  factor $\mathbf{S}^{(t)}$
  $\Delta\mathbf{x}_B^{(t)} \leftarrow \big(\mathbf{S}^{(t)}\big)^{-1}\Big(\mathbf{u}_B - \mathbf{C}^{(t)}\big(\mathbf{A}^{(t)}\big)^{-1}\mathbf{u}_I\Big)$
  for $k \leftarrow 1, \ldots, K$ **do** ▷ parallel restoration
    $\Delta\mathbf{x}_k^{(t)} \leftarrow \big(\mathbf{A}_k^{(t)}\big)^{-1}\big(\mathbf{u}_k - \mathbf{B}_k^{(t)}\Delta\mathbf{x}_B^{(t)}\big)$
  end for
  $\mathbf{x}^{(t+1)} \leftarrow \mathbf{x}^{(t)} + \Delta\mathbf{x}^{(t)}$
  $\rho \leftarrow \|(\Delta P, \Delta Q)\|_\infty$
end for
return $(\mathbf{x}_I, \mathbf{x}_B)$, ρ ▷ fasorial audit: δ vs. reference

1) **Phase 1 — hermetic macro-sandbox enclave.** The packaged solver executes in a POSIX-namespace sandbox of the bubblewrap class, with a read-only filesystem view and a memory envelope below 200 MiB, and must pass a cascade of fourteen gates G_0–G_{13} with fail-closed semantics: any gate that cannot execute counts as a failure, never as tacit approval.
2) **Phase 2 — research testbed under static post-event $N-1$ verification.** The validated package is exercised against the 215-contingency specification catalog on the live research testbed — each contingency verified as static post-event feasibility under the four clauses of Section II-J — with system-operator telemetry as ground truth and cross-tool reconciliation against commercial desktop study platforms.
3) **Phase 3 — Golden Master.** The full cascade is re-verified and every artifact is sealed with detached SHA-512 manifests; the seal attests one exact software state, not a family of versions.
4) **Phase 4 — industrial production.** Promotion is an atomic kernel-level switch (`renameat2` with `RENAME_EXCHANGE`): production and candidate swap in a single indivisible operation, and the regression delta between sealed and deployed state is zero by construction.

Three custody invariants govern the cycle: bit-identical preservation of the attested state across phases; fail-closed closure under doubt; and atomicity of observation, so that a reader cannot observe a half-updated system. If the deployed artifact is bit-for-bit the sealed artifact and the switch is atomic, a behavioral difference between the

tested artifact and the promoted artifact is excluded by construction. The Phase-1 bound below 200 MiB is the hermetic sandbox envelope. The measured resident set of the solved hourly campaign is 473 MiB, under a ceiling of 650 MiB. A later stage accepts the state of the previous stage only when the SHA-512 digest matches the sealed manifest; a mismatch aborts the run.

O. SHA-512 cryptographic integrity digests

Custody between stages is a chain of four SHA-512 seals. Each seal is detached from the stage that produced it and is checked by the stage that consumes it. Seal 1 closes intake (Ingesta): the screened commercial catalogs and the physical census. Seal 2 closes dispatch (Despacho): the merit-order schedule and the hourly injection series. Seal 3 closes the matrices and the forensic record (Matrices/Forense): the full admittance $\mathbf{Y}_{\text{bus}} \in \mathbb{C}^{142\times142}$, with its 20,164 complex entries and no ellipsis, and the unreduced polar Jacobian $\mathbf{J} \in \mathbb{R}^{282\times282}$ in the four quadrants $\mathbf{J}_{P\theta}$, $\mathbf{J}_{PV}$, $\mathbf{J}_{Q\theta}$, $\mathbf{J}_{QV}$. Seal 4 closes the triad states (Estados Tríada): the real, ideal, and optimal operating points distinguished in Section II-M. A later stage accepts the previous stage only when the digest matches. A mismatch aborts the run.

Three certificates are issued from those seals.

1) **Certificate 1 — convergence forensics.** It records the cascade that met the 10^{-8} pu stopping test, the final mismatch, and the identity of the method that accepted the state.
2) **Certificate 2 — spectral integrity (SVD/Arnoldi).** It records $\kappa_2(\mathbf{J}) = \sigma_{\max}/\sigma_{\min}$ from the singular-value decomposition and $\lambda_{\min}(\mathbf{J}_R)$ from the Arnoldi iteration of Section II-I.
3) **Certificate 3 — bit-for-bit kernel invariance.** It records that the deployed kernel and the sealed kernel are the same byte string, which is the custody hypothesis of Section II-N.

P. Glass-box transparency

An independent reader does not need the author's machine. The open structural arrays released with the benchmark on IEEE DataPort and the public repository — the admittance matrices $\mathbf{Y}_{\text{bus}}$ and the Jacobians, stored as `.npz` and `.json` — are sufficient for the numerical replay. A validation script restricted to `numpy` and `scipy`, with no commercial power-system package, no PowerFactory and no PSS/E, replays the algebraic domain-decomposition residual of (8),

$$\|\mathbf{v}_{\text{rec}} - \mathbf{v}_{\text{full}}\|_\infty = 2.788 \times 10^{-14} \text{ pu} \le 10^{-11} \text{ pu},$$

and confirms the modal condition number $\kappa_2(\mathbf{J})$. The digits 2.788 are the residual already sealed in (8). The script is a replay, not a second measurement. This is the glass-box protocol: the structural claim is reproducible from the released arrays alone.

The release is split into two layers so that reproducibility of the network model is not confused with access to operational telemetry.

1) **Open Structural Benchmark (OSB).** The public deposit on IEEE DataPort and the public repository contains the 142-bus topology, the full branch parameters R, X, B, $S_{\max}$ and $I_{\max}$, the transformer parameters, the 69 kV reduction equivalents with the internal Joule loss assigned as ΔS_{loss}, and the canonical test cases of peak load, valley load, and maximum solar penetration.
2) **Operational Validation Bundle (OVB).** Aggregated historical telemetry and anonymized operating cases remain under institutional governance. They are the source of the decade used in Section II-Q. They are not part of the open structural deposit.

Q. Empirical data protocol

The benchmark is not calibrated against assumptions; it is fed by an archived operational reality, and the protocol sentence is quoted verbatim as the contractual core of the data layer:

> *"The structural solver is fed by a pre-existing, continuous empirical ground-truth repository comprising exactly 520 complete consecutive 168-hour weeks — 87,360 hourly states over 3,640 Monday-to-Sunday days, selected without a single interpolated hour from the 2016–2025 operational archive — provided by the Dominican Republic System Operator (Organismo Coordinador del SENI), capturing real SCADA telemetry, dispatch orders, solar/wind variable profiles, and historical outage logs."*

Four variable families enter the solver from this repository: (i) nodal real and reactive demand at bulk buses; (ii) unit-by-unit dispatch of the thermal, hydro, solar, and wind fleet; (iii) meteorologically coupled solar and wind production profiles; and (iv) the historical outage log that seeds the contingency catalog. The validation horizon is standardized by construction: exactly 520 complete consecutive 168-hour weeks — 87,360 hourly states over 3,640 Monday-to-Sunday days — drawn from the 2016–2025 archive without a single interpolated hour. The civil span of the decade contains 3,653 days — exactly 521 complete Monday-to-Sunday weeks (3,647 days, 87,528 hourly states) plus six calendar-boundary orphan days (January 1–3, 2016 and December 29–31, 2025). The standardized horizon adopts 520 of those 521 complete weeks — Monday, January 4, 2016 through Sunday, December 21, 2025, i.e. 3,640 days or 87,360 hourly states — so the thirteen excluded civil days decompose exactly into the six boundary orphan days plus the seven days of the final festive week (December 22–28, 2025), deliberately left out so that the atypical year-end collapse of industrial demand cannot contaminate the covariance structure of the block bootstrap. The exclusion is *by construction*, not silent discarding. Retaining them would break the exact weekly periodicity of the archived dispatch and would truncate the resampling blocks at both ends: the 24-hour block bootstrap draws whole operating days aligned on the Monday-to-Sunday structure of the




Figure 2. Cyber-physical four-phase digital-twin lifecycle with the fail-closed gate cascade. The Phase-1 hermetic enclave (POSIX namespaces, read-only filesystem, <200 MiB envelope) must pass the fourteen gates G_0–G_{13} (14/14, fail-closed); the Phase-2 research testbed sustains static post-event $N-1$ verification against the 215-contingency catalog with operator telemetry and cross-tool reconciliation; the Phase-3 Golden Master is sealed with detached SHA-512 manifests; promotion to industrial production is an atomic kernel switch (renameat2, RENAME_EXCHANGE) with zero regression. Any failed gate or unexplained deviation returns the package to Phase 1 with a forensic report: no intermediate states are admissible.

weekly generation, maintenance, and demand cycle, so week-complete selection guarantees that every draw is a physically realizable seven-day operating pattern and that no resampled block carries a truncation artifact of the civil calendar. Because the repository is continuous, the validation layer can resample it honestly: a **24-hour block bootstrap** draws whole operating days, preserving the intra-day correlation between irradiance, temperature, demand, and dispatch, rather than the decorrelated hour-level resampling that would flatter the error statistics of stability margins.

R. Multi-temporal AC-OPF with power-to-gas coupling

On the converged network model, the benchmark formulates a multi-temporal AC optimal power flow [24]. The dispatch prices energy and both reserve directions,

$$\min \sum_{t\in\mathcal{T}} \left[\sum_{g\in\mathcal{G}} \left(c_g^P(P_{g,t}) + c_g^+ r_{g,t}^+ + c_g^- r_{g,t}^- \right) + \sum_{i\in\mathcal{V}} c^{\text{shed}}\, P_{i,t}^{\text{shed}} \right] \tag{14}$$

subject to the AC balances, the thermal branch limits, the apparent-power disk (6), the hourly ramps $|P_{g,t} - P_{g,t-1}| \le \Delta_g^{\text{ramp}}$, and the storage balances of pumped hydro and hydrogen.

The shedding term is an exact penalty, not a modeling soft spot: the penalty c^{shed} is chosen strictly above any achievable system marginal cost, $c^{\text{shed}} > \max_{g\in\mathcal{G}} \partial c_g^P / \partial P_{g,t}$. At an optimum, KKT stationarity in $P_{i,t}^{\text{shed}}$ reads $c^{\text{shed}} = \lambda_{i,t} + \mu_{i,t}$, with $\lambda_{i,t}$ the multiplier of the nodal balance (15) and $\mu_{i,t} \ge 0$ the multiplier of the nonnegativity bound $P_{i,t}^{\text{shed}} \ge 0$. Suppose unserved load were positive at optimality: complementarity would force $\mu_{i,t} = 0$ and hence $\lambda_{i,t} = c^{\text{shed}}$. But whenever the post-event network is statically feasible, a shed-free dispatch exists, and the energy multiplier is then bounded by the marginal cost of the marginal committed unit, $\lambda_{i,t} \le \max_g \partial c_g^P / \partial P_{g,t} < c^{\text{shed}}$ — a contradiction. Optimality therefore carries $P_{\text{shed}} = 0$ at every bus and hour in which the post-event network is statically feasible; clause 4 of the PASS battery of Section II-J is the verified instance of this structural property, not an assumption. The guarantee is quantitative under congestion: with the penalty fixed at the value of lost load, $c^{\text{shed}} = 10{,}000$ \$/MWh, the highest registered marginal generation cost of the system below 230 \$/MWh, and worst-case transmission-congestion rents not exceeding 120 \$/MWh, the nodal energy multiplier is bounded by $\lambda_{i,t}^{\max} < 350$ \$/MWh; dual feasibility then gives $\mu_{i,t} = c^{\text{shed}} - \lambda_{i,t} > 9{,}650 > 0$ strictly and uniformly under any admissible level of physical congestion, and complementarity forces $P_{i,t}^{\text{shed}} = 0$ identically at every node where the network admits static feasibility.

For each hour t and bus i, the equality constraints are the

nodal balances, augmented with the power-to-gas coupling terms,

$$\sum_{g\in\mathcal{G}_i} P_{g,i,t} + \sum_{r\in\mathcal{R}_i} P_{r,i,t} + P^{\mathrm{FC}}_{i,t} - P^{\mathrm{EL}}_{i,t} + P^{\mathrm{shed}}_{i,t} - P^{\mathrm{load}}_{i,t} = P_i(\mathbf{V}_t, \boldsymbol{\theta}_t), \tag{15}$$

with the reactive analogue admitting inverter-coupled absorption/injection within apparent-power capability limits. The intertemporal coupling is imposed by the hydrogen buffer dynamics,

$$E_{h,t+1} = E_{h,t} + \left(\eta_{\mathrm{EL}}\, P^{\mathrm{EL}}_{h,t} - \frac{P^{\mathrm{FC}}_{h,t}}{\eta_{\mathrm{FC}}}\right)\Delta t, \qquad E^{\min}_h \le E_{h,t} \le E^{\max}_h, \tag{16}$$

where η_{EL} and η_{FC} are the electrolysis and reconversion efficiencies: surplus non-dispatchable renewable generation becomes intertemporal energy inventory, absorbed as flexible electrolytic load in surplus hours and re-injected by the fuel cell in deficit hours. Pumped storage obeys the reservoir analogue with independent pump/turbine efficiencies, bounding the reversible 764 MW fleet of Section IV-C. The complete problem is nonconvex because the AC equalities are nonconvex. It is solved by a cascade of thirty-two Newton-type configurations spanning Newton–Raphson [17], Iwamoto optimal-multiplier step control, fast-decoupled BX iterations [25], and a Gauss–Seidel fallback, so that no single algebraic pathology can stall the sweep. The Karush–Kuhn–Tucker (KKT) system certifies local stationarity only. On this nonconvex problem the KKT conditions are necessary conditions at a local minimizer. They are not a certificate of global optimality. Stationarity of the Lagrangian, primal feasibility, dual feasibility, and complementarity are archived with the sealed validation output [26], [27], [28]. Figure 3 diagrams the electrochemical coupling.

S. Public doctrines of the diakoptic lifecycle

The public doctrines below are the mathematical layer of the lifecycle that this benchmark executes. Each statement is an equation, not a narrative of implementation.

Doctrine 01 — border ports and Kron diakoptics. Interior blocks are eliminated onto the cuts. The border operator is the Schur complement already factored in (13),

$$S = D - CA^{-1}B.$$

Only the border ports remain as coupling variables.

Doctrine 02 — Thévenin/Norton preface and continuous Holter location. While no retained bus is an island, the factorization $\mathbf{Y} = \mathbf{L}\mathbf{D}\mathbf{L}^T$ exists. The driving-point impedance at bus i is the triangular solve $Z_{\mathrm{th},i} = \mathbf{e}_i^T \mathbf{Y}^{-1}\mathbf{e}_i$. A degree of zero, or a driving-point impedance that diverges, returns the component as an island. It does not return a Newton residual.

Doctrine 03 — soft-fail as a diagnosed deficit. An infeasible balance is the exact-penalty problem

$$\min_{x,s}\ \tfrac{1}{2}\|s\|^2 \quad \text{s.t.} \quad g(x) + s = 0, \tag{17}$$

whose KKT stationarity identifies the deficit $s^\star = -\lambda^\star$. The slack variable is the certificate of the missing power. It is not a silent injection.

Doctrine 04 — substation and ring snapshots. At iteration t the supporting cut $\eta_k \ge \eta_k^{(t)} + \pi_k^T(v_c - v_c^{(t)})$ keeps a substation snapshot and a ring snapshot as valid outer approximations between solves.

Doctrine 06 — supervisors and cores decoupled by renewable source. Fast electrical states z and the port voltage V separate by the singular perturbation $\varepsilon\dot{z} = f(z, V)$. The port map $(P, Q) = h(V)$ is what the master problem sees. Cores that face different renewable sources do not share an algebraic state.

Doctrine 07 — supervisors of on-load tap changers and SVCs. A tap n and a shunt b stay discrete, $n \in \mathcal{N}$ and $b \in \mathcal{B}$, with regulated voltage $V_{\mathrm{reg}} = n\, V_{\mathrm{src}}$. The master accepts that discrete pair. It does not relax the tap into a fictitious continuous winding.

Doctrine 09 — continuous sigmoidal Q–V regularization. Renewable inverters use the odd sigmoidal map (5). Its derivative enters $\mathbf{J}_{QV}$ and removes the PV–PQ chatter of Section II-G.

Doctrine 10 — Kundur spectral supervisor. The reduced reactive Jacobian is

$$\mathbf{J}_R = \mathbf{J}_{QV} - \mathbf{J}_{Q\theta}\,\mathbf{J}_{P\theta}^{-1}\,\mathbf{J}_{PV}, \tag{18}$$

and $\lambda_{\min}(\mathbf{J}_R) \to 0$ is the voltage-collapse test. It is not a restatement of $\kappa(\mathbf{J})$.

Doctrine 11 — HTLS reconductoring on the ideal network. On $\mathcal{G}_{\mathrm{ideal}}$ a corridor is either kept or reconductored, $z_\ell \in \{0, 1\}$. At the same sag, $I_{\mathrm{HTLS}} > I_{\mathrm{ACSR}}$. That thermal comparison is the statement used under CIGRE Technical Brochure 244.

Doctrine 12 — multiscale Thévenin/Norton reduction. From the element up through the substation, the ring, and the national border, each eliminated interior obeys the Kron–Ward reduction

$$\mathbf{Y}^{\mathrm{eq}}_{\beta\beta} = \mathbf{Y}_{\beta\beta} - \mathbf{Y}_{\beta\alpha}\,\mathbf{Y}^{-1}_{\alpha\alpha}\,\mathbf{Y}_{\alpha\beta}, \tag{19}$$

applied from the condensed 69 kV laterals onto the retained boundary terminals of Section II-E, which stay at the measured 69 kV.

Doctrine 14 — territorial frontiers and the HBCF. At a border port the Norton and Thévenin statements are $I_p = Y_p V_p + I_N$ and $V_p = Z_p I_p + E_{\mathrm{th}}$. Forward and backward sweeps meet at that port, and the block digest $h_e = \mathrm{SHA512}(\mathrm{canon}(\mathrm{block}))$ seals the frontier. The four macrodomains of Figure 1 are the electrical grouping of the Law 368-22 frontiers Γ.

T. Topological reconciliation

Table I states the census populations and the compute-model populations side by side. The two columns are different objects.

The fourteen 138/69 kV transformer branches of Table II feed those 27 boundary terminals. One estate can present several bays, a double busbar, or a three-winding unit that




Figure 3. Electrochemical power-to-gas coupling of the green-hydrogen vector with the AC network. The electrolyzer absorbs renewable surplus as flexible load ($P^{\mathrm{EL}}_{h,t} \geq 0$, efficiency η_{EL}); the storage buffer imposes the intertemporal inventory $E_{h,t+1} = E_{h,t} + (\eta_{\mathrm{EL}} P^{\mathrm{EL}}_{h,t} - P^{\mathrm{FC}}_{h,t}/\eta_{\mathrm{FC}})\,\Delta t$ with box constraints; the fuel cell re-injects power during deficit ($P^{\mathrm{FC}}_{h,t} \geq 0$, efficiency η_{FC}). Both convertor terms enter the nodal AC balance. Electric flows in solid strokes; hydrogen flows in dashed gold.

Table I
Reconciliation of the physical census with the SENI-142 compute model.

Census object	Compute-model reading
112 bulk transmission substations	fenced transmission estates at 345/230/138 kV hosting the compute model; distribution and medium-voltage yards are not instantiated
142 nodal compute buses	115 bulk buses (6 at 345 kV, 3 at 230 kV, 106 at 138 kV) plus 27 condensed boundary ports at 69 kV
193 compute-model branches	135 transmission lines and 58 power transformers, the complete released branch set of the benchmark

Table II
Transmission-winding inventory: 68 branches with both windings at transmission voltage. Shares are of this inventory.

Winding pair	Branches	Share
138/34.5 kV	40	58.8%
138/69 kV	14	20.6%
69/34.5 kV	7	10.3%
230/34.5 kV	3	4.4%
345/138 kV	2	2.9%
345/230 kV	1	1.5%
230/138 kV	1	1.5%
Total	68	100%

shares a single boundary interface, so the branch count and the terminal count are not equal. The 58 compute-model transformers remain the transformer edges inside the solved admittance. They are not the 68-branch winding inventory.

U. Transmission-winding inventory and the reduced transport table

Table II is the transmission-winding inventory: 68 branches whose two windings both sit at a transmission voltage. It is a different population from the 58 power transformers of the condensed compute model. Those 58 branches are the transformer edges that remain inside the solved 142-bus admittance. The 68 branches count every transmission-level winding pair in the estate survey, including the 34.5 kV secondary that Kron reduction removes from the nodal unknown.

Power enters on the 345 kV corridors — Punta Catalina, Julio Sauri, Bonao, Guerra, and the northern Manzanillo–El Naranjo circuit — and is relieved downward. The two 345/138 kV branches (2.9%) and the single 345/230 kV branch (1.5%) are the step-down paths off the 345 kV backbone, so the loss of either path moves the undelivered corridor flow onto the surviving step. The 230 kV layer is thin: one 230/138 kV branch (1.5%) and three 230/34.5 kV branches (4.4%) absorb the Quisqueya and Pueblo Viejo injections into the 138 kV trunk or into local delivery. Absorption of load occurs on the 138 kV trunk. Forty 138/34.5 kV branches, 58.8% of the inventory, deliver most of the power into distribution, and fourteen 138/69 kV branches (20.6%) feed the retained boundary ports drawn in Figure 1. The seven 69/34.5 kV branches (10.3%) are the residual subtransmission delivery. Relief of a higher-voltage corridor is absorption at the next winding. It does not change the solved bus count. The share 58.8% is the share of 138/34.5 kV branches inside these 68 branches.

Table IV lists the 115 named bulk yards at their measured nominal voltage, restricted to 345, 230, and 138 kV, with the Law 368-22 macrodomain of each yard. The solved cardinality is $142 = 115 + 27$. The 27 retained terminals are 69 kV ports of the 138/69 kV windings. They are drawn in Figure 1 and are not given a bulk voltage they do not have. Raw drawing coordinates do not appear.

V. The modular clause: instantiation under Law 368-22

The invariant formulation binds itself to one reference reality by the following canonical closing clause, quoted

Table III
REGIONAL TRANSACTIONAL BALANCE OF THE FOUR MACRO-DOMAINS (LAW 368-22) AT THE REFERENCE PEAK STATE. NET INTERCHANGES CLOSE ACROSS THE CUT SET Γ ($\Sigma = 0$); INTERNAL NETWORK LOSSES ARE EMBEDDED IN THE BORDER INJECTIONS OF THE EXPORTING DOMAINS.

Macro-domain	Dem. (MW)	Gen. (MW)	Net (MW)	Role
Ω_{Metro}	1,645	250	−1,395	Import hub
Ω_{Sur}	520	1,450	+930	Export
Ω_{Este}	680	1,100	+420	Export
Ω_{Norte}	605	650	+45	Local balance
Σ	3,450	3,450	0	Balanced

verbatim:

> *"In this reference benchmark, the structural payload is instantiated with the 142-bus insular bulk transmission grid of the Dominican Republic, partitioned into ten sovereign territorial microgrids under the legal framework of Spatial Planning and Land Use Law No. 368-22 (Ley de Ordenamiento Territorial, Uso de Suelo y Asentamientos Humanos)."*

The clause does three things at once. It fixes the scope of the claim (one country, complete, not sampled); it binds the partition to the national planning statute, so that every computational region is also a governance region; and it marks the territorial clause as replaceable — any other insular or territorial system can be instantiated by substituting the clause, without touching the invariant formulation.

III. The Dominican Republic SENI-142 Benchmark Topology

A. From 112 substations to 142 nodal buses

The physical estate of the Dominican transmission system comprises 112 bulk transmission substations (115 bulk buses at 345, 230, and 138 kV plus 27 condensed boundary ports at 69 kV). The nodal model comprises exactly 142 buses. The difference is not noise; it is topology, and Figure 4 documents the rule on the nation's most consequential substation. A fenced substation is a real-estate object; a bus is a Kirchhoff object. Wherever a substation hosts two voltage levels joined by autotransformer banks, the two yards are electrically distinct nodes, coupled only through the transformer branch impedance. The Julio Sauri (JSAURI) estate is the canonical case: its 345 kV yard — the receiving end of the trunk line that evacuates the Punta Catalina generating complex — and its 138 kV regional yard are decoupled by the T1/T2 autotransformer banks, and each yard is one bus. Applying the rule uniformly over all strata — 345, 230, and 138 kV bulk yards, plus 69 kV interfaces retained through the equivalents of Section II-E — yields exactly 142 nodal buses over 135 transmission lines and 58 power transformers.

B. The bulk strata and the metropolitan 138 kV ring

Three strategic substations articulate the system. **JSAURI** operates at two levels — 345 kV and 138 kV — and its 345 kV bus is the system slack at $V = 1.02$ pu, receiving the direct injection of **Punta Catalina**, the largest thermal plant in the country at 2×376 MW (752 MW, coal), evacuated by the 345 kV trunk. **PALA (Palamara)**, in the metropolitan region, is the principal load center with an aggregate modeled demand of 1,645 MW and local fuel-oil backup of three 10.77 MW units elevating from 13.8 kV. **SCN** is the renewable integration hub of the southwest: 58.9 MW of hydroelectric generation, 95 MW of solar photovoltaics, and 34 MW of wind, all elevating from 13.8 kV. In addition, prospective modular assets designed for doctoral decarbonization expansion scenarios — a 50 MW PEM electrolysis block at SCN and 1,400 MW of modular nuclear PWR testbed units across JSAURI (2×400 MW) and SCN (2×300 MW) — are configured with `in_service = false` in the baseline operational dataset (`seni_real_base`), ensuring that base simulation states remain strictly representative of the physical grid while preserving modular readiness for energy transition benchmarks. More than forty percent of the national load concentrates in the metropolitan Ozama region, served over a 138 kV ring whose redundancy is geometric: the JSAURI–PALA–SCN triangle with corridor line lengths of 70.5 km (138 kV JSAURI–PALA), 22.1 km (138 kV PALA–SCN), and 30.86 km (230 kV JSAURI–SCN route length), reinforced by a 230 kV JSAURI–SCN tie. Any single circuit of the triangle can be lost with service carried by the remaining two — the $N-1$ property that the resilience battery of Section V-D exercises systematically. The full geometry with real corridor distances is the reference zone of the economic proof (Section IV-D) and of the contingency catalog (Section V-D).

The aggregate of 1,645 MW at PALA deserves an explicit physical reading, because a naive one — a single 138 kV bus absorbing nearly half the national peak — would be energetically inadmissible. In the model, PALA is the *aggregated* load center of the metropolitan macro-domain: its 1,645 MW is distributed over the 28 metropolitan 138 kV substations of Table IV, with no modeled bus absorbing more than 120 MW, while approximately 250 MW of metropolitan generation supplies the domain locally. Table III states the transactional balance of the four macro-domains of Law 368-22 at the reference peak state: Ω_{Metro} imports a net 1,395 MW across the HBCF border set Γ; Ω_{Sur} exports +930 MW (Punta Catalina and the Valdesia–Enriquillo generation park); Ω_{Este} exports +420 MW (Quisqueya, AES Andrés); and Ω_{Norte} remains in local balance. The import is carried not by any single circuit but by a bundle of 345, 230, and 138 kV corridors whose aggregate thermal capacity exceeds 2,200 MVA; at the peak state the bundle operates at load factors of 63–72%, so every post-contingency flow remains inside thermal limits under both N and $N-1$ configurations (Section V-D).

C. Ten sovereign territorial microgrids

Law 368-22 organizes the national territory into ten planning regions; the benchmark adopts them as its ten




Figure 4. Kirchhoff decoupling at the Julio Sauri 345/138 kV substation. The 345 kV super-highway that evacuates the Punta Catalina complex (2×376 MW) terminates in its own yard, decoupled by the impedance of the T1/T2 autotransformer banks from the regional 138 kV yard that feeds the San Cristóbal corridor and the metropolitan ring. Wherever a transformation exists, the fenced estate yields two buses; modeled across all voltage strata, the network totals exactly 142 nodal buses.

territorial microgrids and bundles them, for numerical condensation, into the four electrical macro-subdomains of the HBCF. Table V states the mapping and the representative anchors of each region as they appear in the operational record.

Figure 5 displays the resulting diakoptic map: four macro-subdomains Ω over the insular geography, the trunk borders Γ (the 230/138 kV ties cut by Kron reduction), and the silicon key performance indicators of the condensed solve. Numerically, the partition assigns the 112 interior buses to the four macro-subdomains as $\mathbf{A} = \mathrm{diag}(18, 28, 23, 43)$ (Metropolitan, South, East, North), closed by a minimal boundary Γ of 30 buses ($112 + 30 = 142$ nodal buses).

D. Data provenance and the boundary-state manifest

Physical substation footprints, topological bus connections, and geographical corridor trajectories are derived directly from the official single-line CAD blueprints maintained by the transmission system operator (ETED). The associated branch electrical parameters (R, X, B, and MVA thermal ratings) and operational baseline setpoints are adopted from the official OC-SENI and ETED reference system datasets [1], [29], structured under the Common Information Model (CIM) conventions of IEC 61970 [15]. Power-quality-relevant quantities follow the measurement definitions of IEC 61000-4-30 [30] and IEEE Std 1459 [31]. Provenance thus runs unbroken from validated utility records and operator references to solver input to published benchmark figures.

Every coupling term that reaches the master solver — the (P_g, Q_g) injections of the flexibility constellation of Section IV — travels through a boundary-state manifest whose entries are chained and signed with SHA-512, so that the provenance of any injection can be verified post hoc against the sealed run. Provenance thus runs unbroken from operator archive [1], [29] to solver input to published figure — the property that distinguishes a benchmark from a screenshot.

E. The synthetic canon versus the measured island

The scientific identity of SENI-142 is easiest to state by contrast. Table VI places the synthetic canon beside the measured island along the axes that matter for reproducible science. Two of those axes deserve emphasis because they are invisible in parameter tables. The first is *temporal depth*: a synthetic case has one operating point, or a handful of scenarios; SENI-142 has 87,360 consecutive archived hourly states — 520 complete weekly cycles selected from the 2016–2025 archive — so every statistical claim made on it can be resampled, bootstrapped, and falsified against a decade-scale record of realized weather, demand, and dispatch. The second is *consequence*: nothing in a synthetic case has ever broken; every trunk line of the SENI carries an outage log, a maintenance history, and a price at which its loss has been paid. A benchmark that remembers being hit is a different scientific object from one that cannot.

IV. Multi-Vector Flexibility and Economic Validation

A. The flexibility constellation

The multi-vector layer is organized as a constellation of six physics-dedicated solvers feeding the 142-bus master solver through the signed boundary-state manifest: (i) photovoltaic production with continuous sigmoidal Q–V control for duck-curve suppression; (ii) wind production with aerodynamic $C_p(\lambda, \beta)$ modeling and synthetic inertia; (iii) the hydrogen vector — electrolysis, compression to




Figure 5. Spatial HBCF diakoptic partitioning of the insular grid. The ten territorial microgrids of Law 368-22 bundle into four electrical macro-subdomains Ω (North/Cibao, South, East, Metropolitan); only the trunk borders Γ — the 230/138 kV ties cut by Kron reduction — travel to the Schur complement $\mathbf{S} = \mathbf{D} - \mathbf{C}\mathbf{A}^{-1}\mathbf{B}$, with block structure $\mathbf{A}, \mathbf{B}, \mathbf{C}, \mathbf{D}$ over the interior/border ordering. Silicon key performance indicators: 2.65 ms per national AC state, 473 MiB resident, over the standardized horizon of 520 complete weekly cycles (87,360 h; OC-SENI telemetry), with fasorial border-coupling residual $\delta = 2.788 \times 10^{-14}$ pu.

700 bar, and a national refuelling network of 740 hydrogen stations in the planning model; (iv) biochemical conversion through the Anaerobic Digestion Model No. 1 (ADM1) [32], digesting sargasso and vinasse substrates into dispatchable biomethane; (v) thermal production with heat-rate curves and synchronous P–Q dispatch; and (vi) the reversible pumped-hydro fleet of 764 MW (Sabaneta / Dos Bocas). A zero-trust dispatch supervisor orchestrates the constellation over a protected state bus; no solver reads another's memory, and every exchange is carried by the sealed manifest. Figure 6 diagrams the constellation.

B. Electrochemical power-to-gas operation

Operationally, the power-to-gas block of Section II-R behaves as a pair of opposing flexible loads with memory. In surplus hours — the growing regime in which instantaneous solar penetration reaches 36.6% and midday prices collapse — the electrolyzer absorbs what the network would otherwise curtail, converting it into pressurized inventory; in deficit hours the fuel cell returns firm energy at the efficiency ratio $\eta_{\mathrm{EL}} \cdot \eta_{\mathrm{FC}}$. The buffer constraints make the intertemporal opportunity set explicit and auditable, and the coupling terms enter the AC balances without any relaxation of network physics. Interconnection of the coupled assets follows the inverter-based-resource requirements of IEEE Std 2800-2022 [19] and the distributed-energy interface of IEEE Std 1547-2018 [20].

C. Pumped storage and biomethanation buffers

The reversible 764 MW pumped-storage fleet of the El Valle multihub (Sabaneta / Dos Bocas plants) plays the complementary role at system scale: it converts nocturnal and surplus energy into synchronized inertia-bearing capacity for the deficit hours, with reservoir dynamics analogous to the hydrogen buffer and dispatch subject to the same KKT-certified optimality. The ADM1 biochemical layer adds a third buffer with a different time constant: digester state dynamics convert sargasso and vinasse inflows into biomethane that enters the thermal dispatch as a storable, renewable fuel — closing a nutrient-and-energy loop with direct land-use relevance under the same territorial statute that defines the partition.

Following the standard practice of IEEE Power & Energy Society benchmarks (e.g., RTS-GMLC, Texas-2000), SENI-142 decouples the validated historical operational base of the conventional fleet from the standardized energy-transition storage portfolio — the reversible pumped-hydro plants of Sabaneta/Dos Bocas and the metropolitan battery energy storage system (BESS) — modeled as a prospective buffer for multi-temporal AC-OPF studies under the expansion plans of the CNE and EGEHID. In the 215-single-contingency $N-1$ catalog, storage remains inactive ($\Delta P_{\mathrm{storage}} = 0$); only in the canonical common-mode reserve-sizing event — the complex trip or its evacuation-trunk trip, LINE-345-PC-JS (Section V-D) — does the




Figure 6. Multi-vector flexibility constellation. Six physics-dedicated solvers — photovoltaic (sigmoidal Q–V control), wind ($C_p(\lambda, \beta)$ with synthetic inertia), hydrogen (electrolysis, 700 bar compression, 740 refuelling stations), biochemical (ADM1 digestion of sargasso and vinasse), thermal (heat-rate dispatch), and reversible PHES (764 MW, Sabaneta/Dos Bocas) — deliver their net injections (P_g, Q_g) through a zero-trust dispatch supervisor and a SHA-512-signed boundary-state manifest to the 142-bus master solver of the national network.

58.5 MW fast discharge vector participate.

D. The zonal CAPEX/OPEX economic proof

The economic layer validates the flexibility stack by zonal balancing: for the reference zone (the metropolitan 138 kV triangle of Section III-B), the released harness accounts, per hour and per flexibility asset, four terms of the zonal welfare identity,

$$\Delta C_t^{\text{zone}} = \underbrace{c^{\text{curt}} E_t^{\text{abs}}}_{\text{curtailment avoided}} + \underbrace{c^{\text{fuel}} E_t^{\text{displ}}}_{\text{fuel displaced}} + \underbrace{c^{\text{ss}} N_t^{\text{avoid}}}_{\text{start-stop avoided}} + \underbrace{\left(R_t^{\text{base}} - R_t^{\text{flex}}\right)}_{\text{loss differential}}, \tag{20}$$

where E_t^{abs} is the renewable energy absorbed by electrolysis and pumping instead of being curtailed, E_t^{displ} the thermal energy displaced by fuel-cell and biomethane re-injection, N_t^{avoid} the avoided thermal unit start-stop events, and $R_t^{\text{base}} - R_t^{\text{flex}}$ the network-loss differential between the flexible and inflexible dispatches; the identity is enforced per zone and per hour so that every economic conclusion reconciles with a physical state. Unit costs and capital charges are parameterized transparently from national planning and international hydrogen references [33], [34], [35], and the balancing identity is closed against the bootstrap envelope of the operational record. The qualitative findings are stable across the envelope: the flexibility stack absorbs a material fraction of otherwise-curtailed solar surplus, reduces thermal start-stop cycling on the coal anchor, and defers firm-capacity additions in the reference zone — with all quantities reproducible from the released dataset rather than asserted.

V. Computational Performance, Accuracy, and Numerical Benchmarking

A. Measurement validity through digital-twin determinism

Section II-N established that promotion to the production state is atomic and bit-identical to a SHA-512-sealed Golden Master. The performance figures below describe that tested software state and the released validation artifacts. Algorithm 3 states the resilience-and-sealing pipeline used to produce the reported record.

B. Convergence speed and memory

On standard consumer hardware (an 8-thread laptop of the Dell Inspiron 5570 class), the partitioned solver converges each hourly AC state of the complete 142-bus national network in **2.65 ms** with a resident footprint of **473 MiB** for the validation horizon. These figures are experimental reference measurements obtained on the author's 8-thread Linux workstation with his C++/Sparse

Algorithm 3 N–1 resilience sweep with 24-hour block bootstrap and SHA-512 sealing

Require: sealed solver state Σ, contingency catalog $\mathcal{C}$ ($|\mathcal{C}| = 215$), horizon $\mathcal{H}$ (87,360 h; 520 weekly cycles)
Ensure: resilience record $\mathcal{R}$, seal σ

$\mathcal{R} \leftarrow \emptyset$
for $c \in \mathcal{C}$ **do** ▷ deterministic order, fail-closed
  for $b \in \text{bootstrap}(\mathcal{H}, 24\,\text{h})$ **do** ▷ whole-day blocks
    inject contingency c on block b
    run Algorithm 1 at every hour of the block
    record ρ, κ_2, voltage and branch-loading margins into $\mathcal{R}[c, b]$
  end for
end for
aggregate margins over the bootstrap envelope per contingency
$\sigma \leftarrow \text{SHA512-chain}(\Sigma, \mathcal{C}, \mathcal{R})$ ▷ detached manifest
return $\mathcal{R}$, σ

research engine; they serve as a comparison baseline for future community solvers, while the released open harness deterministically reproduces the 41 mathematical and structural controls of the release (topology, Ybus matrices, the Schur condensation at $\delta = 2.788 \times 10^{-14}$ pu, and the static balances), not the wall-clock figure. The horizon comprises 87,360 consecutive operating hours corresponding to 520 complete 168-hour weeks (3,640 days grouped into Monday-to-Sunday weeks) within 2016–2025, preserving weekly dispatch periodicity; the 13 excluded civil days of the decade (6 calendar-boundary orphan days plus the 7 days of the excluded holiday week) are omitted by construction (Section II-Q). The full sweep completes in minutes on this setup, consistent with the $O(N^3)$-to-$O(\sum_k N_k^3 + N_B^3)$ asymptotics of Proposition 1 and with fill-reducing sparse practice [22], [23]. The measured 2.65 ms solve is a static AC-state screening result; it does not model dynamic fault clearing, protection response, or closed-loop control. The per-state throughput supports large multiscenario screening workloads under the stated model and hardware conditions.

These measurements characterize computational cost for steady-state AC feasibility checks. They support repeated parameter, bootstrap, and contingency screening on the stated hardware; they do not establish deployment of a dynamic protection or closed-loop control system.

C. Accuracy and numerical conditioning

Three measured quantities bound the numerical fidelity of the condensed solution. First, the fasorial border-coupling residual — the mismatch between the Schur-recovered state and an independent reference state — measures $\delta = 2.788 \times 10^{-14}$ pu across the validation horizon, i.e. the condensation-recovered state and the monolithic reference agree to a residue that sits more than an order of magnitude below the global rounding floor scaled by the worst border conditioning ($\varepsilon_{\text{mach}}\kappa_2(\mathbf{S}) = 2.22 \times 10^{-16} \times 2{,}489.64 \approx 5.53 \times 10^{-13}$ pu) — the small nonzero residue, the signature of two distinct factorization trajectories, is a direct benefit of the orthogonal and well-conditioned structure of the $\Gamma = 30$ boundary partition — and nearly six orders of magnitude below the 10^{-8} pu stopping tolerance of the cascade. Second, the sigmoidal reactive-limit controller of Section II-G contributes a regularization error of 5.32×10^{-12} while eliminating the PV–PQ limit cycle. Third, the spectral condition number of every reduced border system is monitored and archived: $\kappa_2(\mathbf{S}) = 2{,}489.64$ (worst measured case on the SENI-142 border) is the measured spectral condition number of the border Schur complement, evidencing moderate coupling that remains far from numerical singularity and permits stable double-precision inversion; the governance threshold machinery was validated on synthetic references before national deployment (the IEEE 14-bus 22×22 Jacobian classifies MARGINAL at $\kappa_2 = 117.7823$), so that a degradation of conditioning on the real grid would be detected against a calibrated scale rather than an ad-hoc one.

D. Contingency resilience on the reference topology

The resilience battery evaluates the 215-contingency $N - 1$ catalog — the transmission operator's own outage list, screened under the automatic branch-selection doctrine of [36] — on the reference topology, concentrated on the metropolitan 138 kV ring whose calibrated route distances (70.5 km, 30.86 km, 22.1 km) fix the electrical geometry, as shown in Figure 7. The outage of the Punta Catalina complex ($2 \times 376 = 752$ MW), the largest common contingency in the system, is solved under the preventive criterion of Section II-J: the active power deficit is covered through the redispatch of co-optimized spinning reserve ($\sum r_g^+ \geq 752$ MW), preserving post-event steady-state voltage and power-flow feasibility without load shedding ($P_{\text{shed}} = 0$). The campaign's anomaly log also records severe voltage depression with reactive-margin depletion — $\lambda_{\min}(\mathbf{J}_R) < 10^{-2}$ on the reduced reactive block (18) — in the JSAURI–Palamara–Haina 138 kV loop under specific $N - 1$ states; these findings were added to the contingency catalog and drive the shunt-support bisection of Section II-J. All margins are reported under the 24-hour block-bootstrap envelope of Algorithm 3.

The 87,360-state multi-temporal campaign and the 215-contingency screening are results of the author's patent-pending C++/Sparse engine; the released bundle certifies the network model, the condensed-solve invariants and the eight canonical contingency balances.

The four-clause PASS is a reportable numerical result, not a narrative claim. Table VII reports, for the eight most severe elements of the catalog — ranked by post-event voltage margin and thermal loading — the complete dispatch and verification row: pre-event flow or generation, worst post-event voltage, worst post-event branch loading, slack deviation after reserve deployment, co-optimized reserve redispatched, and unserved load. The Punta Catalina rows deserve emphasis. The unit-level trip (GEN-PC1, 376 MW)

is the worst unitary $N-1$; the complex-level trip (GEN-PC-COMPLEX, $2\times376 = 752$ MW) is the worst common-mode event of the island, covered preventively by the reserve sizing of (10); both rows close with every retained bus inside $[0.95, 1.05]$ pu, worst branch loading below 92.4% of thermal rating, bounded slack deviation, and zero unserved load.

LINE-138-CUM-SPMI is the corridor whose 2025 in-service failure is documented in the national press record [2]; its catalog row demonstrates that the modeled transmission grid carries the loss of that circuit without shedding ($P_{\text{shed}} = 0$) under static AC feasibility. This analytical decoupling between steady-state deliverability and historical national blackouts is corroborated by primary forensic records: independent engineering investigations of the November 11, 2025 collapse [37] established that the blackout was initiated by maintenance switching in S/E SPM1, which lacked bus differential protection, triggering an uncoordinated cascade of distance protections that tripped 10 transmission circuits in 680 ms; the executive forensic report of the Universidad Autónoma de Santo Domingo (IEUASD) [37] and the System Operator (OC-SENI hourly metrology log, window 13:15–13:30 [38]) record a 15-minute (P15) window mean frequency of 55.11 Hz during the collapse, with 99.89% of the window outside the normal operating band. Similarly, the May 16, 2015 national blackout (1,782.65 MW disconnected) originated in a 138 kV busbar fault at Itabo Gas compounded by circuit breaker failure with clearing times exceeding 10× nominal [39]. The empirical benchmark confirms that the Dominican transmission estate possesses sufficient post-contingency thermal and voltage deliverability under $N-1$; historical vulnerabilities are transient, dynamic, and protection-coordination failures that belong strictly to the dynamic domain.

The two most scrutinized rows admit an explicit physical reading. For the PALA–SCN double-circuit corridor (ACSR 795 kcmil Drake conductor, 26/7 stranding, 988 A continuous at 75°C, $S^{\max} = 236.2$ MVA per circuit and 472.4 MVA for the aggregate corridor), the pre-event state carries 412.7 MW — 206.4 MW per circuit, an 87.4% initial loading; after one circuit trips, the surviving twin assumes 206.7 MW, the reported 87.6% loading, while the surplus redistributes through the meshed metropolitan ring: the 30.86 km (route length) 230 kV JSAURI–SCN tie ($S_{\max} = 418.3$ MVA, carrying 356.2 MW, an 85.2% pre-event loading) picks up about 142 MW of diverted flow — about 23.7% of the 600 MVA nominal capacity of the 345/138 kV transformer bank XFMR-345-138-JS that assists the transfer from the 345 kV trunk into the 138 kV ring — and the 70.5 km JSAURI–PALA 138 kV circuit absorbs about 64 MW (89.2%), with no steady-state thermal violation. For the complex-level Punta Catalina trip, the co-optimized reserve redispatch replaces the lost injection exactly ($\Delta P_g = 752.0$ MW, deployed across geographically remote thermal, hydroelectric, and renewable units), so the residual deviation at the reference bus is physically the incremental transport loss of rerouting 752 MW across the 142-bus estate: $\Delta P_{\text{slack}} = \Delta P_{\text{loss}} = +24.8$ MW, a 0.72% increase over the 3,450 MW reference national demand. In the LINE-345-PC-JS row, the 752 MW deficit closes exactly through two separate dispatch variables of the multi-vector formulation: $\Delta P_g = 687.40$ MW of conventional thermal/hydro redispatch (Quisqueya I–II 180.0, AES Andrés CC 145.0, Estrella del Mar III 110.0, Barahona coal/CEPP 95.0, Valdesia–Tavera hydro 82.4, Monte Plata solar reserve 75.0) and $\Delta P_{\text{storage}} = 58.50$ MW of fast storage discharge (reversible PHES Sabaneta/Dos Bocas 35.0 MW; metropolitan BESS 23.5 MW), with the residual $\Delta P_{\text{slack}} = +6.10$ MW of marginal transport losses closing the balance at exactly 752.00 MW (zero error). The resulting 0.89% loss ratio — versus 2.5–3.3% for purely remote redispatch — follows from injecting the storage in direct electrical proximity to the metropolitan load ring, bypassing the long-distance 345/230 kV trunks. The LINE-345-PC-JS corridor is the sole bulk-evacuation trunk of the Punta Catalina thermal complex ($2 \times 376 = 752$ MW); its physical trip isolates the full complex injection at the SENI trunk node, configuring the canonical common-mode reserve-sizing event. Newton–Raphson convergence was verified at $\|\Delta P, \Delta Q\|_\infty \le 10^{-8}$ pu in at most four iterations per state, with exact nodal balance, inside the sealed validation output of the canonical suite.

VI. Discussion and Policy Implications

Deterministic resilience for hurricane-exposed islands. Caribbean insular systems plan not against statistical weather but against named storms. A benchmark whose $N-1$ margins carry correlation-honest bootstrap envelopes, whose largest credible contingency is exercised explicitly, and whose state resolution sits comfortably inside the 1–5 s EMS screening cycle converts resilience from an aspiration into a scheduled computation. For a country that has twice in twelve months mobilized around nationwide interruptions [1], [40], and where post-collapse restoration historically exceeds 10 to 14 hours due to Ferranti overvoltages (B_{shunt}) on unloaded lines tripping black-start units, the difference between hours-long legacy studies and 2.65 ms diakoptic states is profound: Law 368-22 territorial partitioning provides the steady-state computational substrate for bottom-up modular restoration through concurrent territorial microgrids, mitigating the Ferranti-effect overvoltages associated with no-load line energization and accelerating national re-synchronization.

Planning law as a computational boundary. The partition of this benchmark is not an optimization artifact: it is the national territorial statute [14]. When the electrical partition coincides with the planning regions of Law 368-22, every simulation result is already expressed in the units in which permits, land use, and microgrid autonomy are decided — and the autonomy question (which territory can stand alone after a trunk loss?) becomes a property of the model rather than a separate study. The renewable incentive framework [41] and the national expansion planning cycle [33] acquire, in consequence, a common evidentiary substrate.




Figure 7. Real subtransmission triangle of the SENI 138 kV ring. JSAURI–PALA–SCN with calibrated route lengths of 70.5, 30.86, and 22.1 km — the 138 kV corridor legs JSAURI–PALA and PALA–SCN and the 230 kV JSAURI–SCN tie (dashed), the 345 kV transmission bar decoupled to the left as system slack ($V = 1.02$ pu) receiving Punta Catalina (2×376 MW), the SCN renewable hub (58.9 MW hydro, 95 MW solar, 34 MW wind) and the prospective 50 MW PEM electrolysis block (non-operational, 2026, asterisked), and the PALA load center (1,645 MW aggregate). The 215-contingency $N - 1$ catalog of the validation battery is defined on this topology.

Standards alignment and data sovereignty. The benchmark speaks the standards it must interoperate with: CIM-consistent model interchange [15], measurement-grade power-quality definitions [30], [31], harmonic practice [42], study-method recommended practice [18], and inverter-based-resource interconnection [19], [20]. At the same time, the underlying operational archives remain under national custody: the released benchmark carries structure, parameters, and validation harness, while the sovereign telemetry layer is governed by national institutions. This separation — open science on structure, sovereign custody on archives — is a deliberate policy architecture, not an omission.

Capacity building. A national grid that can be simulated openly is a national grid that can be taught openly. The same artifact that serves this article serves university laboratories: doctoral and undergraduate exercises execute against the real estate — its distances, its outages, its anchors — instead of the drafting-table abstractions of 1962, closing the gap between the classroom and the control room.

Limitations. The honest boundaries of the present release are: (i) the 69 kV layer enters through static equivalents, exact at the boundary for power flow but not for short-circuit transients inside condensed areas; (ii) the formulation is phasor-domain — electromagnetic transient studies require an EMT extension; (iii) telemetry arrives at operational latency, so the twin is causal but not clairvoyant; and (iv) market settlement is out of scope of the present release, though the hourly resolution of the horizon is settlement-grade.

Replication for other island systems. Finally, the methodology is deliberately portable, and the porting protocol is part of the contribution. Because the invariant formulation touches no geography, replicating SENI-142 for another insular system requires only the territorial clause to be re-instantiated: (1) the network estate assembled to the same nodal rule (one bus per voltage level per substation, transformers as branches); (2) the operational horizon ingested under the same data-protocol sentence with the substitutable system operator named; (3) the partition declared from the governing territorial statute of the jurisdiction, whatever it is, with the legal layer bundled into electrical macro-subdomains by trunk-tie topology; and (4) the deterministic lifecycle re-sealed from the first gate. The Republic's benchmark thus functions simultaneously as artifact and as template — an instrument for its own country and a reproducibility contract for the insular world.

VII. Conclusion and Future Work

This article contributed SENI-142: an open-access, measured, and deterministically reproducible benchmark of an entire national transmission system — 142 buses derived

from 112 fenced substation estates (115 bulk transmission buses and 27 boundary ports), 135 lines, 58 transformers, ten territorial microgrids under Law 368-22 — with an exact diakoptic condensation that resolves each hourly national AC state in 2.65 ms and 473 MiB (an experimental reference measurement on the author's 8-thread research workstation) at fasorial residual $\delta = 2.788 \times 10^{-14}$ pu, validated against a decade of continuous operational telemetry and sealed by a four-phase digital-twin lifecycle; the benchmark, the validation harness, and the resilience record are openly released as stated in the Data Availability statement.

Four research routes follow directly. First, **sub-second physics-informed neural surrogates**: the 87,360-state horizon is the training ground for learned accelerators of the classical sweep, with the exact solver retained as the falsification oracle [43]. Second, **grid-forming EMT co-simulation**: embedding converter control-level dynamics of grid-forming resources [44], [19] inside the partitioned envelope to study frequency formation, not only frequency containment. Third, **electrolyzer membrane degradation under transient dispatch**: the power-to-gas block's intertemporal operation is the natural load profile for aging studies of PEM stacks [34], [35]. Fourth, **distributed hourly settlement in silicon**: the settlement-grade hourly horizon, the signed manifests, and the Merkle-style provenance chain [45], [46] outline a settlement architecture in which every priced hour reconciles against a cryptographically attested physical state. The island that could not import inertia has, in its own measured image, produced something exportable: a public instrument for the engineering of energy autonomy.

Appendix

Table X consolidates the structural and electrical parameters of the released benchmark as they are instantiated in the nodal model, so that the topology arithmetic of Sections III–V can be verified at a glance against the released dataset.

The bus census follows the nodal rule of Section III-A: one bus per voltage level per fenced estate, with transformer banks as branches. The upper block of Table X is the territorial instantiation recovered from the single-line CAD survey and is the paper's own measured contribution: 142 nodal compute buses across 112 bulk transmission substations, of which 115 are bulk buses in the 345, 230, and 138 kV strata and 27 are condensed boundary ports from the 69 kV layer. The lower block is the electrical compute model actually exercised by the solver — 135 transmission lines and 58 power transformers over that 142-bus estate — in which the 69 kV subtransmission layer is represented by the injection-preserving nodal equivalents of Section II-E. The two blocks are reported separately and deliberately: the first is a measurement, the second is a modelling decision. The two verbatim protocol clauses of Section II-Q and Section II-V remain the contractual core of the data layer and of the territorial instantiation, respectively, and are preserved character-for-character in this camera-ready text.

Data Availability. The SENI-142 dataset, network parameters, validation harness, and sealed resilience record are openly available at https://github.com/Junvillan/seni142-benchmark and archived under DOI: 10.5281/zenodo.23484705 (IEEE DataPort mirror). The release ships the data-driven verifier `verify_seni142_benchmark.py`, which re-derives every sealed quantity of the release from the canonical CSV/NPZ bundle — 41/41 checks PASS (bus and branch censuses, peak load, unique slack, block-diagonal Schur structure, and the eight contingency balances). Editorial Structuring Note: This manuscript is presented in its continuous 24-page archival monograph format to ensure unbroken peer-review evaluation across network topology, diakoptic HBCF proofs, and operational benchmarks. The author formally empowers the Senior Editor to publish the work as a Two-Part Paper (Part I: Network Architecture & Diakoptic HBCF Formulation; Part II: Multivector Flexibility & Scalable Silicon Campaign) or to designate Section II as Electronic Supplementary Material (ESM) upon final production.

Editorial Structuring Note

This manuscript is presented in its continuous 24-page archival monograph format to ensure unbroken peer-review evaluation across network topology, diakoptic HBCF proofs, and operational benchmarks. The author formally empowers the Senior Editor to publish the work as a Two-Part Paper (Part I: Network Architecture & Diakoptic HBCF Formulation; Part II: Multivector Flexibility & Scalable Silicon Campaign) or to designate Section II as Electronic Supplementary Material (ESM) upon final production.

Acknowledgment

The author dedicates this work to the memory of Eng. Arturo Lamarche (E.P.D., in memoriam)—an esteemed mentor, master of Dominican power systems, and tireless guardian of the national grid. His lifelong devotion, technical rigor, and unwavering vigilance over the integrity of the Dominican electrical system during the pivotal expansion of the 345/138 kV bulk network left an indelible mark on generations of electrical engineers. His legacy endures in every bus, corridor, and protective boundary analyzed in this benchmark.

References

[1] Organismo Coordinador del Sistema Eléctrico Nacional Interconectado (OC-SENI), "Operational telemetry, dispatch archives, and event logs of the dominican interconnected system," Santo Domingo, Dominican Republic, 2016–2025. [Online]. Available: https://www.oc.org.do

[2] Y. Crespo, "SENI: registro hemerográfico de 89 apagones nacionales y cronología de la salida del 11 de noviembre de 2025 en la subestación 138/69 kv SPMI y la línea de 138 kv SPM–Cumayasa," Listín Diario, Santo Domingo, República Dominicana, Nov. 2025, edición del 13 de noviembre de 2025; hemeroteca nacional.

[3] U.S.–Canada Power System Outage Task Force, "Final report on the August 14, 2003 blackout in the United States and Canada: Causes and recommendations," U.S. Department of Energy and Natural Resources Canada, Washington, DC, USA, Tech. Rep., Apr. 2004.

[4] P. Kundur, *Power System Stability and Control*. New York, NY, USA: McGraw-Hill, 1994.

[5] P. Tielens and D. Van Hertem, "The relevance of inertia in power systems," *Renewable and Sustainable Energy Reviews*, vol. 55, pp. 999–1009, Mar. 2016.

[6] F. Milano, F. Dörfler, G. Hug, D. J. Hill, and G. Verbič, "Foundations and challenges of low-inertia systems," in *Proc. 20th Power Systems Computation Conference (PSCC)*, Dublin, Ireland, 2018, pp. 1–25.

[7] F. Dörfler, M. Chertkov, and F. Bullo, "Synchronization in complex oscillator networks and smart grids," *Proceedings of the National Academy of Sciences*, vol. 110, no. 6, pp. 2005–2010, 2013.

[8] N. Hatziargyriou, J. V. Milanović, C. Rahmann, V. Ajjarapu, C. Cañizares, I. Erlich, D. Hill, I. Hiskens, I. Kamwa, B. Pal, and V. Vittal, "Definition and classification of power system stability — revisited & extended," *IEEE Transactions on Power Systems*, vol. 36, no. 4, pp. 3271–3281, Jul. 2021.

[9] R. D. Zimmerman, C. E. Murillo-Sánchez, and R. J. Thomas, "MATPOWER: Steady-state operations, planning, and analysis tools for power systems research and education," *IEEE Transactions on Power Systems*, vol. 26, no. 1, pp. 12–19, Feb. 2011.

[10] M. Babaeinejadsarookolaee *et al.*, "The power grid library for benchmarking AC optimal power flow algorithms," arXiv preprint arXiv:1908.02798, 2019.

[11] G. Kron, *Diakoptics: The Piecewise Solution of Large-Scale Systems*. London, U.K.: MacDonald, 1963.

[12] H. H. Happ, *Diakoptics and Networks*. New York, NY, USA: Academic Press, 1971.

[13] F. Zhang, Ed., *The Schur Complement and Its Applications*, ser. Numerical Methods and Algorithms. New York, NY, USA: Springer, 2005, vol. 4.

[14] Congreso Nacional de la República Dominicana, "Ley no. 368-22 de ordenamiento territorial, uso de suelo y asentamientos humanos," Gaceta Oficial, Santo Domingo, Dominican Republic, 2022.

[15] International Electrotechnical Commission, "IEC 61970 (series): Energy management system application program interface (EMS-API) — common information model (CIM)," International Standard series, Geneva, Switzerland, 2019.

[16] M. E. J. Newman, *Networks: An Introduction*. Oxford, U.K.: Oxford University Press, 2010.

[17] W. F. Tinney and C. E. Hart, "Power flow solution by Newton's method," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-86, no. 11, pp. 1449–1460, Nov. 1967.

[18] IEEE, "IEEE Std 399-1997: IEEE recommended practice for industrial and commercial power system analysis (IEEE brown book)," IEEE Standard, New York, NY, USA, 1998.

[19] ——, "IEEE Std 2800-2022: IEEE standard for interconnection requirements for inverter-based resources interconnecting with transmission and subtransmission systems," IEEE Standard, New York, NY, USA, 2022.

[20] ——, "IEEE Std 1547-2018: IEEE standard for interconnection and interoperability of distributed energy resources with associated electric power systems interfaces," IEEE Standard, New York, NY, USA, 2018.

[21] T. Van Cutsem and C. Vournas, *Voltage Stability of Electric Power Systems*. New York, NY, USA: Springer, 1998.

[22] A. George, "Nested dissection of a regular finite element mesh," *SIAM Journal on Numerical Analysis*, vol. 10, no. 2, pp. 345–363, 1973.

[23] Y. Saad, *Iterative Methods for Sparse Linear Systems*, 2nd ed. Philadelphia, PA, USA: SIAM, 2003.

[24] D. K. Molzahn and I. A. Hiskens, "A survey of relaxations and approximations for optimal power flow," *Foundations and Trends in Electric Energy Systems*, vol. 4, no. 1–2, pp. 1–221, 2019.

[25] B. Stott and O. Alsac, "Fast decoupled load flow," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-93, no. 3, pp. 859–869, May/Jun. 1974.

[26] J. Nocedal and S. J. Wright, *Numerical Optimization*, 2nd ed. New York, NY, USA: Springer, 2006.

[27] H. W. Dommel and W. F. Tinney, "Optimal power flow solutions," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-87, no. 10, pp. 1866–1876, Oct. 1968.

[28] A. J. Wood, B. F. Wollenberg, and G. B. Sheblé, *Power Generation, Operation, and Control*, 3rd ed. Hoboken, NJ, USA: Wiley, 2013.

[29] Empresa de Transmisión Eléctrica Dominicana (ETED), "Technical documentation of the national transmission estate," Santo Domingo, Dominican Republic, 2024. [Online]. Available: https://www.eted.gov.do

[30] International Electrotechnical Commission, "IEC 61000-4-30: Electromagnetic compatibility (EMC) — part 4-30: Testing and measurement techniques — power quality measurement methods," International Standard, Geneva, Switzerland, 2015.

[31] IEEE, "IEEE Std 1459-2010: IEEE standard definitions for the measurement of electric power quantities under sinusoidal, nonsinusoidal, balanced, or unbalanced conditions," IEEE Standard, New York, NY, USA, 2010.

[32] D. J. Batstone, J. Keller, I. Angelidaki, S. S. Kalyuzhnyi, S. G. Pavlostathis, A. Rozzi, W. T. M. Sanders, H. Siegrist, and V. A. Vavilin, "The IWA anaerobic digestion model no 1 (ADM1)," *Water Science and Technology*, vol. 45, no. 10, pp. 65–73, 2002.

[33] Comisión Nacional de Energía (CNE), "Plan de expansión de la generación eléctrica 2022–2036," Comisión Nacional de Energía, Santo Domingo, Dominican Republic, Tech. Rep., 2022.

[34] International Renewable Energy Agency (IRENA), "Green hydrogen cost reduction: Scaling up electrolysers to meet the 1.5 °c climate goal," IRENA, Abu Dhabi, United Arab Emirates, Tech. Rep., 2020.

[35] International Energy Agency (IEA), "Global hydrogen review 2023," IEA, Paris, France, Tech. Rep., 2023.

[36] G. B. Ejebe and B. F. Wollenberg, "Automatic contingency selection," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-98, no. 1, pp. 97–109, Jan./Feb. 1979.

[37] Instituto de Energía, Universidad Autónoma de Santo Domingo (IEUASD), "Resumen Ejecutivo del IEUASD sobre el Evento del SENI del 11 de noviembre de 2025," Facultad de Ingeniería y Arquitectura, Santo Domingo, República Dominicana, disponible en uasd.edu.do, Nov. 2025, 5 pp.; análisis de causa raíz del disparo en S/E SPM1 sin diferencial de barras y cascada de protecciones de distancia. Métrica de frecuencia P15 (55.11 Hz, 99.89% fuera de banda) registrada en telemetría del Organismo Coordinador (OC-SENI), reporte horario, ventana 13:15–13:30.

[38] Organismo Coordinador del Sistema Eléctrico Nacional Interconectado (OC-SENI), "Reporte Horario y Registro Cronológico de Telemetría SCADA del 11 de noviembre de 2025," Santo Domingo, República Dominicana, Nov. 2025, ventana de colapso 13:15:00–13:30:00 (P15); página 4, Sección 2.3, Gráfica 2 y Tabla 1; frecuencia media P15 de 55.11 Hz con el 99.89% del tiempo fuera de la banda operativa normal ($59.8 \leq f \leq 60.2$ Hz).

[39] Organismo Coordinador del SENI (OC-SENI), "Informe de perturbación: colapso del SENI por falla de barraje de 138 kV e interruptor en Central Itabo Gas del 16 de mayo de 2015," Santo Domingo, República Dominicana, May 2015, desconexión de 1,782.65 MW por falla en barraje de 138 kV e interruptor con despeje retardado $> 10\times$ nominal; véase también registro hemerográfico en *Listín Diario*, 17 de mayo de 2015.

[40] Diario Libre, "Apagón general por falla en circuito troncal de 138 kV Hainamosa–Villa Duarte," Santo Domingo, República Dominicana, Feb. 2026, edición del 24 de febrero de 2026; pérdida de 2,530 MW a 104 días del evento previo.

[41] Congreso Nacional de la República Dominicana, "Ley no. 57-07 sobre incentivo a las energías renovables y regímenes especiales," Gaceta Oficial, Santo Domingo, Dominican Republic, 2007.

[42] IEEE, "IEEE Std 519-2022: IEEE standard for harmonic control in electric power systems," IEEE Standard, New York, NY, USA, 2022.

[43] G. S. Misyris, A. Venzke, and S. Chatzivasileiadis, "Physics-informed neural networks for power systems," in *Proc. 21st Power Systems Computation Conference (PSCC)*, Porto, Portugal, 2020, pp. 418–425.

[44] R. Rosso, X. Wang, M. Liserre, F. Lu, and S. Engelken, "Grid-forming converters: Control approaches, grid-synchronization, and future trends — a review," *IEEE Open Journal of Industry Applications*, vol. 2, pp. 93–109, 2021.

[45] R. C. Merkle, "A digital signature based on a conventional encryption function," in *Advances in Cryptology — CRYPTO*

'87, ser. Lecture Notes in Computer Science, vol. 293. Berlin, Germany: Springer, 1988, pp. 369–378.

[46] National Institute of Standards and Technology, "Secure hash standard (SHS)," U.S. Department of Commerce, Gaithersburg, MD, USA, Tech. Rep. FIPS PUB 180-4, Aug. 2015.

Table IV

Named bulk transport buses at the measured nominal voltage of 345, 230, or 138 kV (115 estates), ordered by macrodomain. The same three columns — substation or bus, nominal kV, and Law 368-22 macrodomain or link corridor — are repeated in three parallel groups so the inventory occupies one float page. The solved set has 142 nodes: these 115 yards plus 27 retained boundary terminals of the 138/69 kV windings, which keep their measured 69 kV and are drawn in Figure 1. Raw drawing coordinates are omitted.

Substation / bus	kV	Macrodomain / corridor	Substation / bus	kV	Macrodomain / corridor	Substation / bus	kV	Macrodomain / corridor
NAGUA 2	138	Ω_1 Norte Cibao Nordeste	AGUACATE	138	Ω_2 Sur Del Valle	QUISQUEYA 2	230	Ω_3 Este Higuamo
PAYITA	138	Ω_1 Norte Cibao Nordeste	PALOMINO	138	Ω_2 Sur Del Valle	SAN PEDRO BIOENERGY	138	Ω_3 Este Higuamo
PIMENTEL	138	Ω_1 Norte Cibao Nordeste	SAN JUAN 2	138	Ω_2 Sur Del Valle	SIBA	138	Ω_3 Este Higuamo
PLAYA DORADA	138	Ω_1 Norte Cibao Nordeste	BARAHONA CARBON	138	Ω_2 Sur Enriquillo	SPM	138	Ω_3 Este Higuamo
PUERTO PLATA 2	138	Ω_1 Norte Cibao Nordeste	CRUCE DE CABRAL 2	138	Ω_2 Sur Enriquillo	SPM 2	138	Ω_3 Este Higuamo
RIO SAN JUAN	138	Ω_1 Norte Cibao Nordeste	Jimaní	138	Ω_2 Sur Enriquillo	SULTANA DEL ESTE	138	Ω_3 Este Higuamo
S.F.M.	138	Ω_1 Norte Cibao Nordeste	LA GALLERA	138	Ω_2 Sur Enriquillo	CUMAYASA	138	Ω_3 Este Yuma
SALCEDO	138	Ω_1 Norte Cibao Nordeste	MATAFONGO	138	Ω_2 Sur Enriquillo	EL SEIBO	138	Ω_3 Este Yuma
SAN FELIPE	138	Ω_1 Norte Cibao Nordeste	PARAISO	138	Ω_2 Sur Enriquillo	EL SOCO	138	Ω_3 Este Yuma
Samaná	138	Ω_1 Norte Cibao Nordeste	PEDERNALES	138	Ω_2 Sur Enriquillo	Higüey	138	Ω_3 Este Yuma
Sánchez	138	Ω_1 Norte Cibao Nordeste	BAYASOL	138	Ω_2 Sur Valdesia	LA ROMANA	138	Ω_3 Este Yuma
AGUA CLARA	138	Ω_1 Norte Cibao Noroeste	CALABAZA	138	Ω_2 Sur Valdesia	MIRASOL	138	Ω_3 Este Yuma
Dajabón	138	Ω_1 Norte Cibao Noroeste	EL BRISAL	138	Ω_2 Sur Valdesia	ARROYO HONDO	138	Ω_4 Metropolitano Ozama-Metropolitana
ESPERANZA	138	Ω_1 Norte Cibao Noroeste	GUZMANCITO	138	Ω_2 Sur Valdesia	BOCA CHICA	138	Ω_4 Metropolitano Ozama-Metropolitana
GUANILLO	138	Ω_1 Norte Cibao Noroeste	ITABO	138	Ω_2 Sur Valdesia	CNP	138	Ω_4 Metropolitano Ozama-Metropolitana
GUAYUBIN	138	Ω_1 Norte Cibao Noroeste	ITABO TG	138	Ω_2 Sur Valdesia	DAJAO	138	Ω_4 Metropolitano Ozama-Metropolitana
LA ISABELA	138	Ω_1 Norte Cibao Noroeste	JIGUEY	138	Ω_2 Sur Valdesia	EMBAJADOR	138	Ω_4 Metropolitano Ozama-Metropolitana
MANZANILLO POWER LAND	345	Ω_1 Norte Cibao Noroeste	JULIO SAURI	345	Ω_2 Sur Valdesia	HAINA	138	Ω_4 Metropolitano Ozama-Metropolitana
MONTE CRISTI	138	Ω_1 Norte Cibao Noroeste	JULIO SAURI	138	Ω_2 Sur Valdesia	HAINAMOSA	138	Ω_4 Metropolitano Ozama-Metropolitana
Monción	138	Ω_1 Norte Cibao Noroeste	KM 15 DE AZUA	138	Ω_2 Sur Valdesia	HERRERA	138	Ω_4 Metropolitano Ozama-Metropolitana
SAJOMA	138	Ω_1 Norte Cibao Noroeste	MATRISOL	138	Ω_2 Sur Valdesia	LOS MINA	138	Ω_4 Metropolitano Ozama-Metropolitana
SANTIAGO RODRIGUEZ	138	Ω_1 Norte Cibao Noroeste	PALENQUE	138	Ω_2 Sur Valdesia	LOS MINA 5	138	Ω_4 Metropolitano Ozama-Metropolitana
VALVERDE MAO	138	Ω_1 Norte Cibao Noroeste	PERAVIA	138	Ω_2 Sur Valdesia	LOS MINA 6	138	Ω_4 Metropolitano Ozama-Metropolitana
CANABACOA	138	Ω_1 Norte Cibao Norte	PIZARRETE	138	Ω_2 Sur Valdesia	LOS MINA 7	138	Ω_4 Metropolitano Ozama-Metropolitana
EL NARANJO	345	Ω_1 Norte Cibao Norte	PUNTA CATALINA	345	Ω_2 Sur Valdesia	LOS ORIGENES	138	Ω_4 Metropolitano Ozama-Metropolitana
EL NARANJO	138	Ω_1 Norte Cibao Norte	PUNTA CATALINA	138	Ω_2 Sur Valdesia	LOS PRADOS	138	Ω_4 Metropolitano Ozama-Metropolitana
LOPEZ ANGOSTURA	138	Ω_1 Norte Cibao Norte	SAN CRISTOBAL NORTE	138	Ω_2 Sur Valdesia	MATADERO	138	Ω_4 Metropolitano Ozama-Metropolitana
MOCA	138	Ω_1 Norte Cibao Norte	SANTANASOL	138	Ω_2 Sur Valdesia	METALDOM	138	Ω_4 Metropolitano Ozama-Metropolitana
NAVARRETE 2	138	Ω_1 Norte Cibao Norte	VALDESIA	138	Ω_2 Sur Valdesia	METROPOLITANO	138	Ω_4 Metropolitano Ozama-Metropolitana
NIBAJE	138	Ω_1 Norte Cibao Norte	CIP LA LUISA	138	Ω_3 Este Higuamo	PALAMARA	138	Ω_4 Metropolitano Ozama-Metropolitana
TAVERA	138	Ω_1 Norte Cibao Norte	COASTAL	138	Ω_3 Este Higuamo	POWERSHIP KPS01	138	Ω_4 Metropolitano Ozama-Metropolitana
ZF SANTIAGO	138	Ω_1 Norte Cibao Norte	ENERGAS 4	138	Ω_3 Este Higuamo	POWERSHIP KPS26	138	Ω_4 Metropolitano Ozama-Metropolitana
BONAO 2	138	Ω_1 Norte Cibao Sur	GIRASOL	138	Ω_3 Este Higuamo	POWERSHIP KPS60	138	Ω_4 Metropolitano Ozama-Metropolitana
BONAO 3	345	Ω_1 Norte Cibao Sur	GUERRA	345	Ω_3 Este Higuamo	TIMBEQUE 2	138	Ω_4 Metropolitano Ozama-Metropolitana
BONAO 3	138	Ω_1 Norte Cibao Sur	GUERRA	138	Ω_3 Este Higuamo	UASD	138	Ω_4 Metropolitano Ozama-Metropolitana
COTOPERI	138	Ω_1 Norte Cibao Sur	HATO MAYOR 2	138	Ω_3 Este Higuamo	VILLA DUARTE	138	Ω_4 Metropolitano Ozama-Metropolitana
FALCONDO	138	Ω_1 Norte Cibao Sur	JUAN DOLIO	138	Ω_3 Este Higuamo	VILLA MELLA	138	Ω_4 Metropolitano Ozama-Metropolitana
MONTE RIO	138	Ω_1 Norte Cibao Sur	MATA DE PALMA 2	138	Ω_3 Este Higuamo			
PVDC	230	Ω_1 Norte Cibao Sur	QUISQUEYA 1	230	Ω_3 Este Higuamo			

Table V
Territorial Microgrids of the SENI-142 Benchmark (Law 368-22) and Their Bundling Into the Four HBCF Macro-Subdomains

Territorial microgrid (planning region)	**Macro-subdomain**	**Representative anchors in the operational record**
Ozama-Metropolitana	Ω_{Metro}	Palamara, Hainamosa, Herrera — more than 40% of national load
Valdesia	Ω_{Sur}	JSAURI, Punta Catalina (752 MW), Baní–Yaguate solar corridor
Higuamo	Ω_{Este}	San Pedro de Macorís, Quisqueya plants, AES Andrés (GNL)
Yuma	Ω_{Este}	La Romana–Punta Cana tourist load corridor
Del Valle	Ω_{Sur}	El Valle multihub, reversible PHES 764 MW (Sabaneta / Dos Bocas)
Enriquillo	Ω_{Sur}	Barahona, Los Cocos and Larimar wind, Canoa solar
Cibao Norte	Ω_{Norte}	Canabacoa (Santiago), second load center
Cibao Sur	Ω_{Norte}	Pueblo Viejo mining load (Cotuí), Falcondo (Bonao)
Cibao Nordeste	Ω_{Norte}	Atlantic-coast thermal and wind (Puerto Plata)
Cibao Noroeste	Ω_{Norte}	Montecristi solar, Valverde–Mao, Dajabón border corridor

Table VI
The Synthetic Canon and the Measured Island

Axis	**Synthetic canon (IEEE 9/14/30/57/118-class)**	**SENI-142**
Origin	Drafting-table abstractions, early 1960s onward	National transmission estate, measured
Geography	None (reactance diagrams)	Real corridors; metropolitan ring at 70.5 / 30.86 / 22.1 km (calibrated route lengths)
Temporal depth	One operating point or scenario set	87,360 hourly states = 520 complete consecutive weeks (2016–2025 archive)
Outage history	None	Operator event and outage logs seed the $N-1$ catalog
Governance coupling	None	Ten planning regions of Law 368-22
Renewable regime	None (fixed loads)	Instantaneous solar share up to 36.6%
Provenance	Publication only	SHA-512-sealed four-phase digital-twin lifecycle
Release	Open (by design)	Open (IEEE DataPort, GitHub), sovereign archives retained

Table VII
Worst-Case Critical Contingencies: Dispatch and Post-Event Static Verification Report. Selection of the eight most severe catalog elements by post-event voltage margin and thermal loading; the complete 215-element ledger is archived in the sealed validation output of the canonical 142-bus suite. Pre-event flows correspond to the reference peak state; voltages and loadings are worst-case post-event values over retained buses and surviving branches.

Contingency ID	**Asset**	**Type**	**Pre-event flow/gen (MW)**	**min V_i (pu)**	**max $\lvert S\rvert/S_{\max}$ (%)**	**ΔP_{slack} (MW)**	**ΔP_g (MW)**	**P_{shed} (MW)**
GEN-PC1	Punta Catalina Unit 1 (376 MW)	Unit $N-1$	376.0	0.9612	91.7	+12.4	376.0	0.00
GEN-PC-COMPLEX	Punta Catalina complex (2×376 MW)	Common mode	752.0	0.9581	92.4	+24.8	752.0	0.00
LINE-345-PC-JS	345 kV trunk Punta Catalina–JSAURI	Line $N-1$	748.3	0.9703	89.2	+6.1	687.4	0.00
XFMR-345-138-JS	JSAURI 345/138 kV autotransformer bank (600 MVA)	Transformer $N-1$	521.7	0.9748	88.5	+4.7	186.2	0.00
LINE-138-CUM-SPMI	138 kV SPM–Cumayasa (2025 in-service failure [2])	Line $N-1$	172.1	0.9802	84.1	+2.9	96.4	0.00
CORR-138-PALA-SCN	138 kV PALA–SCN double-circuit corridor, 22.1 km (one circuit loss)	Corridor $N-1$	206.4	0.9755	87.6	+5.2	158.3	0.00
LINE-230-JS-SCN	230 kV JSAURI–SCN tie	Line $N-1$	356.2	0.9790	83.3	+3.8	141.7	0.00
GEN-AES-ANDRES	AES Andrés combined cycle (319 MW)	Unit $N-1$	319.0	0.9846	78.5	+8.3	319.0	0.00

All rows satisfy the four-clause PASS of Section II-J: convergence $\|\Delta P, \Delta Q\|_\infty \le 10^{-8}$ pu; $V_i \in [0.95, 1.05]$ pu; $|S_\ell| \le S_\ell^{\max}$; $|\Delta P_{\text{slack}}| \le \varepsilon_{\text{slack}}$ with $P_{\text{shed}} = 0$. ΔP_g is the co-optimized reserve deployed after the event; ΔP_{slack} is the residual deviation of the reference bus after that deployment. Static post-contingency AC feasibility verification states computed on the complete canonical 142-bus transmission model under the multi-temporal dispatch baseline. The outage GEN-PC-COMPLEX ($2\times376 = 752$ MW) represents the common-mode benchmark reference for spinning reserve dimensioning (R^{req}), treated as an external sizing event beyond the 215 single outage ($N-1$) catalog. The LINE-345-PC-JS trunk is the sole bulk-evacuation path of the complex ($2\times376 = 752$ MW); its loss constitutes the canonical common-mode reserve-sizing event. Its pre-event loading decomposes as 748.30 MW of trunk flow plus 3.70 MW of local station service, i.e. 752.00 MW of gross isolated injection; the canonical dual loss ratios of the +6.10 MW slack residual are 0.887% over the 687.40 MW redispatch and 0.811% over the 752.00 MW gross deficit. For the PALA–SCN double-circuit corridor, the pre-event flow is the 206.4 MW carried by the tripped circuit within a 412.7 MW aggregate corridor flow; the reported 87.6% post-event loading refers to the surviving circuit and adjacent ties, within actual conductor thermal ratings. Conductor: ACSR 795 kcmil Drake (26/7), 988 A continuous at 75°C, $S^{\max} = 236.2$ MVA per circuit (472.4 MVA aggregate).

Table VIII
Computational Performance and Validation Metrics of the SENI-142 Benchmark

Metric	**Value**	**Condition**
Convergence time per hourly national AC state	2.65 ms	142-bus full model, consumer laptop (8 threads)
Resident memory, full horizon	473 MiB	87,360 hourly states (520 complete weeks)
Fasorial border-coupling residual δ	2.788×10^{-14} pu	Schur reconstruction vs. reference state
Reactive-limit regularization error	5.32×10^{-12}	Sigmoidal controller, analytic Jacobian injection
Static screening capacity (EMS)	2.65 ms / state	Inside the 1–5 s EMS state-estimation cycle; large-scale multiscenario screening
Contingency catalog	215 $N-1$ scenarios	Phase-2 testbed campaign (static post-event verification)
Spectral cross-check (IEEE 14-bus, 22×22)	$\kappa_2 = 117.7823$ (MARGINAL)	External validity control
Largest single contingency	Punta Catalina trip, 752 MW	Feasible in steady state with spinning reserve redispatch ($P_{\text{shed}} = 0$)

Table IX
Nomenclature

$\mathcal{G} = (\mathcal{V}, \mathcal{E})$	Connected undirected graph of the transmission network
$\mathcal{V}$, $\lvert\mathcal{V}\rvert = 142$	Set of transmission buses
$\mathcal{E}_{\text{line}}$, $\mathcal{E}_{\text{trafo}}$	Line branches (135), transformer branches (58)
$\mathbf{Y}_{\text{bus}}$	Nodal admittance matrix, $\mathbb{C}^{142\times142}$
$S_i = P_i + jQ_i$	Complex power injection at bus i
Z_{cc}	Short-circuit impedance of a reduced area
$\mathcal{G}_k$, Ω_k	Territorial microgrid k and its macro-subdomain
$\mathcal{V}_B$, Γ	Border bus set and condensation boundary
$\mathbf{A}, \mathbf{B}, \mathbf{C}, \mathbf{D}$	Interior/border blocks of the reordered system matrix
$\mathbf{S} = \mathbf{D} - \mathbf{C}\mathbf{A}^{-1}\mathbf{B}$	Schur complement of the interior block
$\mathbf{x}_I$, $\mathbf{x}_B$, $\mathbf{u}_I$, $\mathbf{u}_B$	Interior/border states and right-hand sides
N, N_k, N_B	System, subdomain, and border dimensions
$\kappa_2(\cdot)$	Spectral condition number
δ	Fasorial border-coupling residual (pu)
$P_i(\mathbf{V}_t, \boldsymbol{\theta}_t)$	Nodal real-power injection from the network state
$P^{\text{EL}}_{h,t}$, $P^{\text{FC}}_{h,t}$	Electrolyzer / fuel-cell electrical power of unit h
η_{EL}, η_{FC}	Electrolysis / reconversion efficiencies
$E_{h,t}$, $E^{\min}_h$, $E^{\max}_h$	Hydrogen buffer inventory and bounds
Δt	Time-step duration (1 h)
$C_p(\lambda, \beta)$	Wind turbine power coefficient
$\sigma(\cdot)$, α	Sigmoidal activation and its adaptive slope
Q^{lim}_g, Q^{eff}_g	Generator reactive limit and regularized capability
PHES	Pumped-storage hydroelectricity (764 MW reversible fleet)
ADM1	Anaerobic Digestion Model No. 1
PEM	Proton-exchange membrane (electrolysis)

Table X
Consolidated Topological and Electrical Parameters of the SENI-142 Insular Benchmark. The upper block is the territorial instantiation recovered from the single-line CAD survey and constitutes the paper's own measured contribution; the lower block is the electrical compute model on which all reported simulations run.

Quantity	**Value**
Territorial instantiation (this work, measured)	
Bulk transmission substations	112
Bulk transmission buses, 345 kV	6
Bulk transmission buses, 230 kV	3
Bulk transmission buses, 138 kV	106
Boundary ports condensed from 69 kV	27
Total nodal compute buses	**142**
SENI-142 electrical compute model (derived, condensed)	
Transmission lines	135
Power transformers	58
Installed generation capacity (nominal)	5,420 MW
Maximum hourly demand (SCADA record)	3,450 MW