Roof Health & Condition Report

Property: Job Site, San Diego
Inspection Date: October 24, 2026

ROOF HEALTH INDEX
35 / 100

COMPONENT CHECKED	OBSERVED CONDITION	STATUS EVALUATION
Shingle Covering (20 Yrs Old)	Missing / Wind Damaged	**Critical Replacement Required**
Roof Decking & Substrate	Spongy Areas Around Valleys / Eaves	**Structurally Sound**
Chimney & Valley Flashings	Rusted, Corroded, or Lifting Metal	**Acceptable**
Plumbing Vent Pipe Boots	Cracked / Dry-Rotted Rubber Seals	**Seal Failure Imminent**
Attic Airflow & Ventilation	Adequate Intake/Exhaust	**Meets Code**

Inspector Field Notes:
"South slope tabs fractured. Water intrusion near master bath."