

MAINTENANCE REPORT

Generated on: 04/06/2026, 11:24:58

Report Summary

Total Maintenance Activities: 4

Activities in Last 30 Days: 4

Recent Maintenance History:

- [03/06/2026] Extinguisher Serial: SN-ACT03
Action Taken: REPLACED THE FIRE EXTINGUISHER
Issues: THE FIRE EXTINGUISHER WAS EMPTY
- [03/06/2026] Extinguisher Serial: SN-EXP01
Action Taken: dasfdadsf
Issues: adsfadsf
- [02/06/2026] Extinguisher Serial: SN-002
Action Taken: Replaced the new fire extinguisher
Issues: was empty
- [25/05/2026] Extinguisher Serial: SN-ACT01
Action Taken: Replaced discharge hose and recharged CO2 canister.
Issues: Cracked hose, low pressure