

Hospital Automated Chemical Dosing System Design Report

CS3243 - IoT Devices and Applications

KR Kanes Rakeshan
230518C

May 19, 2026

Contents


Introduction	3
1 Method to Measure Water Level and Remaining Chemical Levels	6
1.1 Water Level Measurement and Chemical Estimation	6
1.1.1 Water Tank Measurement	6
1.1.2 Chemical Estimation and Dispensing Control	7
2 Component Selection	9
2.1 Selected Components List	9
2.2 Total Cost Estimate	10
2.3 Controller Comparison	11
2.4 Water Tank Level Sensor Comparison	12
2.5 Chemical Tank Monitoring Comparison	13
2.6 Flow Sensor Comparison	14
2.7 Dispensing Tank Level Sensor Comparison	15
2.8 Chemical Dosing Pump Comparison	16
2.9 Mixing Method Comparison	17
2.10 Distribution Pump Comparison	18
2.11 Valve Comparison	19
3 Failure Detection and Fail-Safe Mechanisms	20
3.1 Monitoring and Detection Methods	20
3.1.1 Sensor-Based Monitoring Methods	20
3.1.2 Computational and Algorithmic Methods	20
3.2 Potential Failures and Detection Methods	21
3.3 Fail-Safe Strategy	21
4 Data Collection and Communication System	22
4.1 Data Collection from Dispensing Tanks	22
4.2 Communication Method Comparison	22
4.3 Selected Communication Method	23
5 Complete System Schematic Block Diagram	25
6 Controller and Sensor Connection Schematic	26
7 Operational Flow Chart for IoT Components	27
8 Simulation of the prototype system in WokWi	30
8.1 Simulation	30
8.2 Source Code	31
Conclusion	39

References**40**

Introduction

Background

Hospitals use specialized disinfectant chemicals to sterilize medical instruments and equipment.



Objectives

- Design a complete IoT-based chemical dispensing solution
- Implement automatic refill control using ESP32
- Monitor water level using non-contact sensing
- Implement fault detection and alarm generation

Proposed IoT System Architecture




Figure 1: Complete system architecture for the Hospital Automated Chemical Dosing System.

System Overview

The proposed system consists of:

- Purified water tank
- Concentrated chemical supply tank
- SS316 mixing chamber tank with 10L capacity
- Top-mounted agitator system
- Distribution diaphragm pump
- Common dispensing pipeline
- Groups of nearby dispensing tanks (dispensing blocks)
- Local ESP32 nodes placed near each dispensing block for sensor reading and control
- ESP32-based controller

The proposed architecture supports many dispensing blocks placed in different hospital areas. A dispensing block is a small group of tanks that are near each other. Each tank in the block has a solenoid valve and a capacitive level sensor. These sensors and

valves are connected with short wires to a nearby ESP32 node. The local ESP32 reads the sensor signals on its GPIO pins, checks for faults, and sends status messages wirelessly to the central controller.

The peristaltic pump is used only for accurate concentrated chemical dosing into the 10L SS316 stainless steel mixing chamber. Purified water and concentrated chemical enter the mixing chamber, where a top-mounted DC agitator motor with a mixing blade continuously mixes the solution before distribution. After the chemical is uniformly mixed with purified water, a separate 12V DC diaphragm pump transfers the mixed solution from the mixing chamber into the common dispensing pipeline. This pipeline then distributes the prepared solution to the distributed dispensing tank blocks.

Chapter 1

Method to Measure Water Level and Remaining Chemical Levels

1.1 Water Level Measurement and Chemical Estimation

1.1.1 Water Tank Measurement

A waterproof ultrasonic sensor was selected for measuring the purified water tank level because the hospital requested that no sensing device should be installed inside the tank due to periodic cleaning and maintenance operations.

The ultrasonic sensor is mounted at the top of the tank and measures the distance between the sensor and the water surface. Since the sensor measures the empty space above the water, the actual water level can be determined by subtracting the measured distance from the effective internal height of the tank.

To improve measurement accuracy, the thickness of the tank lid and the wall thickness of the cylindrical tank are considered during calibration. The internal dimensions of the tank are used instead of external dimensions when calculating the actual water capacity.

The tank dimensions, wall thickness, lid thickness, and chemical density values are pre-determined during system installation and calibration. These calibrated parameters are stored in the ESP32 controller and are used in subsequent level and volume calculations during system operation.

Let:

- LT = Lid thickness
- WT = Tank wall thickness
- H_{ext} = External tank height
- D_{ext} = External tank diameter
- d = Measured distance from ultrasonic sensor to water surface

The effective internal tank height is calculated as:

$$H_{int} = H_{ext} - LT - WT \quad (1.1)$$

The effective internal tank radius is:

$$r_{int} = \frac{D_{ext}}{2} - WT \quad (1.2)$$

The total internal tank volume is:

$$V_{tank} = \pi r_{int}^2 H_{int} \quad (1.3)$$

The current water level inside the tank is calculated using:

$$\text{Water Level} = H_{int} - d \quad (1.4)$$

The remaining water volume is estimated as:

$$V_{water} = \pi r_{int}^2 (\text{Water Level}) \quad (1.5)$$

This method provides:

- Non-contact operation
- Hygienic measurement
- Low maintenance
- Protection against sensor damage during tank cleaning

1.1.2 Chemical Estimation and Dispensing Control

The system contains two separate liquid systems:

- Concentrated chemical storage tank
- Diluted chemical dispensing tanks

Capacitive level sensors are installed on each dispensing tank in a block to detect low-level refill conditions. These sensors make electrical signals that are read by a nearby ESP32 node using short wires and the node's GPIO inputs. The sensors do not send data directly to the cloud or the central controller.

The concentrated chemical tank uses two monitoring methods:

- YF-S201 flow sensor (hall-effect)
- Load cell weight sensor

The YF-S201 flow sensor continuously measures the amount of concentrated chemical dispensed into the mixing chamber. The local ESP32 controller maintains a cumulative record of the total dispensed chemical volume.

The remaining chemical quantity can be estimated using:

$$\text{Remaining Chemical} = \text{Initial Volume} - \sum \text{Dispensed Volume} \quad (1.6)$$

A load cell placed beneath the concentrated chemical tank continuously measures the tank weight. The measured weight reduction is compared against the expected dispensed chemical amount obtained from the flow sensor.

The relationship between weight and volume is:

$$\text{Mass} = \text{Density} \times \text{Volume} \quad (1.7)$$

The density of the concentrated chemical is assumed to be known beforehand based on manufacturer specifications or laboratory measurements and is stored in the controller during system calibration.

Therefore:

$$Volume = \frac{Mass}{Density} \quad (1.8)$$

This allows the system to estimate the remaining chemical quantity using both flow-based calculation and weight-based verification.

The difference between expected and measured chemical reduction can be calculated as:

$$Error = |Expected\ Reduction - Measured\ Reduction| \quad (1.9)$$

If the error exceeds a predefined threshold, the system assumes abnormal operation such as:

- Pipeline leakage
- Pump malfunction
- Flow sensor failure
- Unexpected chemical loss

The concentrated chemical dosing process is controlled using a PWM-controlled peristaltic pump together with a flow sensor. The peristaltic pump is used for accurate dosing into the 10L SS316 mixing chamber because the liquid only contacts the tube and the flow can be measured directly. Although PWM adjusts the pump speed, it does not guarantee accurate liquid flow due to pressure variations, tubing resistance, viscosity changes, and pump wear. Therefore, actual flow measurement is required for accurate dispensing control.

Inside the mixing chamber, a top-mounted DC agitator motor rotates a mixing blade to maintain continuous mixing. This helps maintain uniform chemical concentration before the solution is supplied to the distribution line.

After mixing, a 12V DC diaphragm pump is placed after the mixing chamber and before the common dispensing pipeline. This pump is not used for concentration control; its purpose is to distribute the mixed solution from the mixing chamber to multiple dispensing tanks with stable pressure.

The refill operation only begins after all safety conditions are validated by the ESP32 controller. The required pre-conditions are:

- Sufficient water available
- Sufficient concentrated chemical available
- No leakage detected
- No sensor faults detected
- No overflow condition detected

This safety validation process acts as an interlock mechanism to prevent unsafe dispensing conditions.

The refill operation stops automatically once the required target volume has been measured by the flow sensor, mixed in the agitator-equipped mixing chamber, and delivered through the distribution pump and common dispensing pipeline.

Chapter 2

Component Selection

2.1 Selected Components List

- ESP32 DevKit V1 Microcontroller
- Ultrasonic Sensor for Water Tank Level Measurement
- Load Cell with HX711 Module for Concentrated Chemical Tank Monitoring
- YF-S201 Flow Sensor for Flow Measurement
- Capacitive Sensor for Dispensing Tank Level Detection
- Peristaltic Pump for Chemical Dispensing
- SS316 Mixing Chamber Tank (10L)
- DC Agitator Motor with Mixing Blade
- 12V DC Diaphragm Pump for Distribution System
- Normally Closed Solenoid Valve for Flow Control
- Piezo Buzzer for Alarm Indication
- LED Indicators for System Status Display
- MOSFET Driver Module for Pump, Agitator, and Valve Control
- WiFi Communication using ESP32 Built-in Module

2.2 Total Cost Estimate

Component	Qty	Unit Cost (Rs.)	Price (Rs.)
ESP32 DevKit V1 Local Node	1	1,500	1,500
Ultrasonic Sensor (Water Tank Level)	1	1,880	1,880
Load Cell + HX711 Module (Chemical Tank)	1	480	480
Hall-Effect Flow Sensor	1	650	650
Capacitive Sensor (One Tank in the Block)	1	1300	1300
Peristaltic Pump	1	3500	3500
SS316 Mixing Chamber Tank (10L)	1	6000	6000
DC Agitator Motor with Mixing Blade	1	3500	3500
Distribution Diaphragm Pump	1	4500	4500
Normally Closed Solenoid Valve	1	810	810
Piezo Buzzer	1	150	150
LED Indicators (with Resistors)	4	30	120
MOSFET Driver Module	1	350	350
12V DC Power Supply Adapter	1	1800	1800
Wires, Connectors, Tubing (Estimated)	1	1000	1000
Total			27,540

Table 2.1: Estimated Hardware Cost for One Dispensing Block with One Local Node

For each additional tank in the same block, the shared node, pump, mixer, and power parts stay the same. Only the tank-side sensor, valve, and short wiring are added.

Component	Qty	Unit Cost (Rs.)	Price (Rs.)
Capacitive Sensor (One More Tank)	1	1300	1300
Normally Closed Solenoid Valve	1	810	810
Wires, Connectors, and Tubing for One More Tank	1	500	500
Additional Cost per Tank in the Same Block			2,610

Table 2.2: Estimated Additional Hardware Cost for One More Tank in the Same Block

2.3 Controller Comparison

Feature	ESP32	Raspberry Pi 4	Arduino UNO
Processing Capability	Dual-core microcontroller	Single-board computer	Basic microcontroller
Built-in WiFi	Yes	Yes	No
GPIO Pins	Multiple GPIO pins	Multiple GPIO pins	Limited GPIO pins
PWM Support	Yes	Limited native support	Yes
Analog Input Support	Yes	Requires external ADC	Yes
Power Consumption	Low	High	Low
Operating System	Not required	Linux operating system required	Not required
Ease of IoT Integration	Easy	Moderate	Requires external WiFi module
Real-Time Control Capability	Good	Moderate	Good
Approximate Market Price (2026)	RS. 1,100 – 9,000	RS. 8,800 – 125,000	RS. 995 – 3,750
Suitability for This Project	Highly suitable	Overpowered	Limited features
Product Link	https://www.vseeds.lk/products/esp32-dev-kit-v1	https://tronic.lk/product/raspberry-pi-4-model-b-4gb-original-uk	https://tronic.lk/product/arduino-uno-original-development-board-with-usb-cable

Table 2.3: Comparison of ESP32, Raspberry Pi 4, and Arduino UNO

ESP32 was selected because it provides built-in WiFi support, sufficient GPIO pins, low power consumption, and supports real-time monitoring and control at a low cost.

2.4 Water Tank Level Sensor Comparison

Feature	Ultrasonic Sensor	Float Sensor	Capacitive Sensor
Measurement Method	Non-contact distance measurement	Mechanical float detection	Capacitance-based liquid detection
Sensor Contact with Liquid	No	Yes	Usually yes
Maintenance Requirement	Low	Moderate	Moderate
Suitability for Hygienic Environments	Highly suitable	Less suitable	Suitable
Ease of Installation	Easy	Moderate	Moderate
Continuous Monitoring	Yes	Limited	Yes
Corrosion Resistance	High	Moderate	Moderate
Cleaning Compatibility	Excellent	Limited	Moderate
Approximate Market Price (2026)	RS. 1,000 – 2,500	RS. 400 – 2,000	RS. 1,800 – 4,000
Suitability for This Project	Highly suitable	Limited	Moderately suitable
Product Link	https://tronic.lk/product/jsn-sr04t-waterproof-ultrasonic-distance-measuring-modu	https://tronic.lk/product/water-level-sensor-float-switch-right-angle	https://tronic.lk/product/non-contact-tank-liquid-water-level-sensor-12-24v

Table 2.4: Comparison of Water Tank Level Sensors

The ultrasonic sensor was selected because it provides non-contact water level measurement, easy maintenance, and is suitable for hygienic hospital environments.

2.5 Chemical Tank Monitoring Comparison

Feature	Load Cell Sensor	Ultrasonic Sensor	Float Sensor
Measurement Method	Weight measurement	Distance measurement	Mechanical float detection
External Installation	Yes	Yes	No
Sensor Contact with Chemical	No	No	Yes
Leakage Detection	Yes	Limited	No
Maintenance Requirement	Low	Low	Moderate
Suitability for Chemical Tank	Highly suitable	Moderately suitable	Limited
Continuous Monitoring	Yes	Yes	Limited
ESP32 Integration	Easy	Easy	Easy
Approximate Market Price (2026)	RS. 200 – 1,000	RS. 1,000 – 2,500	RS. 400 – 2,000
Suitability for This Project	Highly suitable	Moderately suitable	Limited
Product Link	https://tronic.lk/product/load-cell-20kg	https://tronic.lk/product/jsn-sr04t-waterproof-ultrasonic-distance-measuring-modu	https://tronic.lk/product/water-level-sensor-float-switch-right-angle

Table 2.5: Comparison of Chemical Tank Monitoring Methods

The load cell sensor was selected because it allows external monitoring of the chemical tank and helps detect abnormal chemical loss without placing sensors inside the tank.

2.6 Flow Sensor Comparison

Feature	Hall-Effect Flow Sensor	Turbine Flow Sensor	Electromagnetic Flow Sensor
Measurement Method	Pulse-based magnetic sensing	Rotating turbine measurement	Electromagnetic induction
Ease of Integration with ESP32	Easy	Moderate	Complex
Real-Time Flow Monitoring	Yes	Yes	Yes
Accuracy	Moderate	High	Very high
Maintenance Requirement	Low	Moderate	Low
Cost	Low	Moderate	High
Small System Suitability	Highly suitable	Suitable	Less suitable
Power Consumption	Low	Moderate	High
Approximate Market Price (2026)	RS. 640 – 1,500	RS. 3,000 – 10,000	RS. 20,000 – 80,000
Suitability for This Project	Highly suitable	Moderately suitable	Overpowered
Product Link	https://tronic.lk/product/yf-s201-water-flow-sensor-1-30lmin-1-75mpa-0-5inch	https://lk-tronics.com/product/yf-b10-hall-effect-flow-sensor-water-1-50l-min-turbine-flowmeter/	https://fieldinstruments.lk/products/honeywell-smartline-versaflow-mag-4000-electromagnetic-flow-sensor-4805

Table 2.6: Comparison of Flow Sensors

The Hall-Effect flow sensor was selected because it provides real-time flow measurement, easy ESP32 interfacing, and low implementation cost.

2.7 Dispensing Tank Level Sensor Comparison

Feature	Capacitive Sensor	Float Sensor	Optical Sensor
Detection Method	Capacitance-based sensing	Mechanical float detection	Optical liquid detection
Suitable for Small Tanks	Highly suitable	Moderately suitable	Suitable
Sensor Contact with Liquid	Minimal / external	Yes	Yes
Maintenance Requirement	Low	Moderate	Low
Ease of Installation	Easy	Moderate	Moderate
Reliability	Good	Moderate	Good
Compact Size	Yes	Limited	Yes
Approximate Market Price (2026)	RS. 1,800 – 4,000	RS. 400 – 2,000	RS. 2,000 – 3,000
Suitability for This Project	Highly suitable	Moderately suitable	Suitable
Product Link	https://tronic.lk/product/non-contact-tank-liquid-water-level-sensor-12-24v	https://tronic.lk/product/water-level-sensor-float-switch-right-angle	https://lk-tronics.com/product/optical-infrared-water-liquid-level-sensor-with-module/

Table 2.7: Comparison of Dispensing Tank Level Sensors

The capacitive sensor was selected because it is compact, reliable, and suitable for small dispensing tanks with low maintenance requirements.

2.8 Chemical Dosing Pump Comparison

Feature	Peristaltic Pump	Diaphragm Pump	Submersible Pump
Pumping Method	Tube compression	Diaphragm pressure	Impeller-based pumping
Chemical Contact with Pump	No direct contact	Direct contact	Direct contact
Dispensing Accuracy	High	Moderate	Low
Speed Control	Easy	Moderate	Limited
Suitability for Chemical Dispensing	Highly suitable	Suitable	Limited
Maintenance Requirement	Low	Moderate	Moderate
Contamination Risk	Low	Moderate	High
Ease of Integration	Easy	Moderate	Easy
Approximate Market Price (2026)	RS. 2,500 – 4,500	RS. 1,500 – 8,000	RS. 850 – 4,900
Suitability for This Project	Highly suitable	Moderately suitable	Limited
Product Link	https://www.daraz.lk/tag/12v-peristaltic-pump/	https://tronic.lk/product/diaphragm-water-pump-12v-7lmin-hy-5200	https://lk-tronics.com/product-tag/water-pump/

Table 2.8: Comparison of Chemical Dosing Pump Types

The peristaltic pump was selected because it provides accurate dispensing, low contamination risk, and supports controlled chemical flow.

2.9 Mixing Method Comparison

Feature	Mechanical Agitator	Magnetic Stirrer	Natural Turbulent Mixing
Mixing Performance	High and uniform mixing using a rotating blade	Good for small laboratory volumes	Low and depends on inlet flow turbulence
Suitable Volume Range	Suitable for 10L and larger small industrial tanks	Mostly suitable for small beakers and laboratory containers	Suitable only for simple low-accuracy mixing
Continuous Operation	Suitable for continuous operation with motor speed control	Possible, but limited by stirrer capacity and heating plate design	No active control over mixing continuity
Maintenance Requirement	Moderate due to motor, shaft, and blade cleaning	Low to moderate	Low
Industrial Suitability	Highly suitable for small process tanks	Limited for industrial tank mixing	Limited for controlled chemical concentration
Cost	Moderate	High	Minimal
Approximate Market Price (2026)	RS. 3,000 – 10,000	RS. 10,000 – 20,000	Minimal
Suitability for This Project	Highly suitable	Moderately suitable	Limited
Product Link	https://www.daraz.lk/tag/dc-geared-motor/	https://www.daraz.lk/tag/magnetic-stirrer/	N/A

Table 2.9: Comparison of Mixing Methods

The mechanical agitator system was selected because it provides reliable continuous mixing, supports larger liquid volumes, and ensures uniform chemical concentration before distribution to dispensing tanks.

2.10 Distribution Pump Comparison

Feature	Diaphragm Pump	Centrifugal Pump	Peristaltic Pump
Flow Capability	Moderate to high flow for small distribution systems	High flow but depends strongly on priming and installation	Low to moderate flow, mainly suitable for dosing
Pressure Stability	Good pressure output with self-priming operation	Moderate pressure stability, affected by head and pipeline load	Pulsed flow, stable for small metered dosing only
Pipeline Distribution Suitability	Highly suitable for common pipeline distribution to multiple tanks	Suitable for simple water transfer, but less suitable for controlled small pipelines	Limited because the flow rate is low for distribution use
Maintenance Requirement	Moderate	Low to moderate	Low, but tube replacement is required
Cost	Moderate	Low to moderate	Moderate
Approximate Market Price (2026)	RS. 1,500 – 8,000	RS. 850 – 4,900	RS. 2,500 – 4,500
Suitability for This Project	Highly suitable	Moderately suitable	Limited for distribution; suitable for dosing only
Product Link	https://tronic.lk/product/diaphragm-water-pump-12v-7lmin-hy-5200	https://lk-tronics.com/product-tag/water-pump/	https://www.daraz.lk/tag/12v-peristaltic-pump/

Table 2.10: Comparison of Distribution Pump Types

The diaphragm pump was selected for the distribution system because it provides stable pressure, supports multiple dispensing tanks, and is suitable for continuous liquid transfer through common pipelines.

2.11 Valve Comparison

Feature	Solenoid Valve	Motorized Ball Valve	Pinch Valve
Operating Method	Electromagnetic control	Motor-driven rotation	Tube compression
Response Speed	Fast	Moderate	Fast
ESP32 Control	Easy	Moderate	Moderate
Leakage Protection	Good	Excellent	Excellent
Power Consumption	Moderate	Low	Moderate
Maintenance Requirement	Low	Moderate	Low
Suitability for Chemical Systems	Suitable	Highly suitable	Suitable
Power Failure Safety	Yes	Depends on design	Yes
Approximate Market Price (2026)	RS. 800 – 16,000	RS. 15,000 – 30,000	RS. 10,000 – 25,000
Suitability for This Project	Highly suitable	Moderately suitable	Overpowered
Product Link	https://tronic.lk/product/electric-solenoid-valve-12-12vdc-n-c-plastic-water	https://lk-tronics.com/product/24v-dc-2-way-motorized-ball-valve/	https://www.daraz.lk/products/pinch-valve-industrial-i318742219.html

Table 2.11: Comparison of Valve Types

The normally closed solenoid valve was selected because it provides fast automatic flow control, easy ESP32 interfacing, and automatic shutoff during power failure.

Chapter 3

Failure Detection and Fail-Safe Mechanisms

3.1 Monitoring and Detection Methods

The proposed automated chemical dispensing system uses both sensor-based and computational methods for monitoring system operation and detecting abnormal conditions.

3.1.1 Sensor-Based Monitoring Methods

- Ultrasonic sensor for purified water tank level monitoring
- Capacitive level sensors mounted on each dispensing tank block to detect low-level refill conditions through a local ESP32 node
- YF-S201 flow sensor for measuring liquid flow rate and dispensed volume
- Load cell sensor with HX711 module for monitoring concentrated chemical quantity locally

3.1.2 Computational and Algorithmic Methods

- Remaining chemical estimation using cumulative flow measurements
- Detection of abnormal flow conditions using flow pulse monitoring
- Refill timeout monitoring for detecting pump or valve failures
- Agitator operation monitoring during the mixing stage
- Leakage detection by comparing expected and measured chemical reduction
- Sequential refill scheduling algorithm for managing multiple dispensing tanks

3.2 Potential Failures and Detection Methods

Potential Failure	Detection Method	Fail-Safe Method
Empty Water Tank	Ultrasonic sensor detects low water level	Stop refill operation and generate alarm
Empty Chemical Tank	Load cell detects low remaining weight	Stop pump operation and notify operator
Pump Failure	No flow pulses detected during refill	Stop system and activate alarm
Distribution Pump Failure	Low delivery flow or refill timeout after mixing	Stop distribution pump, close valves, and activate alarm
Agitator Failure	No motor operation detected during mixing stage	Stop refill operation and prevent distribution until mixing is restored
Blocked Valve or Pipeline	Low or no flow detected by flow sensor	Close valve and stop pump
Pipeline Leakage	Mismatch between expected and measured chemical quantity	Stop dispensing and generate warning
Sensor Failure	Invalid or unstable sensor readings	Switch system to safe shutdown mode
Overflow Condition	Refill operation exceeds expected refill time	Automatically stop refill process
Communication Failure	No response from sensor modules or controller	Generate maintenance warning and stop automatic operation
Power Failure	Loss of power supply detected	Normally closed valve automatically stops liquid flow

Table 3.1: Potential Failures, Detection Methods, and Fail-Safe Mechanisms

3.3 Fail-Safe Strategy

The system is designed with multiple fail-safe mechanisms to reduce operational risks in hospital environments. Automatic shutdown procedures are used during abnormal conditions such as empty tanks, pump failures, leakage detection, or communication failures. Audible alarms and warning notifications are also generated to alert maintenance personnel.

Normally closed solenoid valves are used to automatically stop liquid flow during power failures, reducing the risk of leakage or uncontrolled dispensing. The use of both sensor-based monitoring and computational estimation improves overall system reliability and fault detection capability.

Chapter 4

Data Collection and Communication System

4.1 Data Collection from Dispensing Tanks

The dispensing tanks are spread across different areas of the hospital and need regular checks for refills and faults. Each dispensing block is a small group of tanks placed close to one another. Each tank has a solenoid valve and a capacitive level sensor. The sensors and valves are wired to a nearby ESP32 node with short cables. The ESP32 reads the sensor signals and handles safety checks. The sensor signals are not sent directly to the cloud or to a central controller.

Sensor data collected from the dispensing tanks includes:

- Tank level
- Flow pulse counts
- Fault and overflow alerts

Local ESP32 nodes collect and pre-process sensor readings and forward compact telemetry to the central controller over wireless. The central controller manages refill scheduling and alarms; the cloud (MQTT) stores telemetry for monitoring and remote access only.

This architecture supports:

- Distributed dispensing tank monitoring across multiple hospital locations
- Centralized refill management with local node-based validation
- Real-time alarm handling at the local node and central controller
- Cloud-based monitoring and logging
- Remote maintenance access through secure web and mobile clients

4.2 Communication Method Comparison

WiFi and ZigBee were compared for range, power, scalability, complexity, and ESP32 support.

For areas where WiFi is unreliable or unavailable (for example, basements or remote wings), LoRa/LoRaWAN is an alternative. LoRa gives long range and low power use, but it has low data rates and needs a gateway and network server. LoRa is good for occasional telemetry such as tank level updates, but not for high-rate flow data or real-time control. Using LoRa requires extra hardware (LoRa transceivers or gateway) and planning gateway placement to cover the blocks.

Feature	WiFi	ZigBee
Communication Range	Moderate in building coverage	Moderate to High
Power Consumption	High	Low
Data Transmission Speed	High	Lower than WiFi
Ease of Implementation	Easy	Moderate
Built-in ESP32 Support	Yes	No
Network Scalability	Moderate	High
Mesh Networking Support	Limited	Yes
Hospital Infrastructure Suitability	Strong fit with existing hospital WiFi and MQTT integration	Suitable for large meshes, but requires gateways and extra planning
Approximate Hardware Cost	Low	Moderate
Hardware Module Link	Available in ESP32	https://tronic.lk/product/xbee-zigbee-s2c

Table 4.1: Comparison of WiFi and ZigBee Communication Methods

4.3 Selected Communication Method

WiFi communication was selected as the primary communication method for the proposed prototype because the ESP32 controller provides built-in WiFi capability without requiring additional communication modules.

WiFi supports wireless communication between the distributed local ESP32 nodes and the central controller through the hospital wireless network infrastructure. This allows real-time monitoring of dispensing tank levels, refill requests, flow conditions, and system alarms without direct long-distance sensor wiring.

Compared with ZigBee, WiFi provides:

- Higher data transmission speed
- Easier Internet connectivity
- Simpler ESP32 integration
- Lower implementation complexity for the prototype system

Although ZigBee provides lower power consumption and better mesh-network capability for very large distributed systems, it requires additional hardware modules and more complex network configuration. It is therefore more suitable for large mesh deployments than for a low-complexity prototype.

For IoT monitoring functionality, MQTT protocol is used over the WiFi network to transmit system telemetry data between the central ESP32 controller and the cloud platform. MQTT provides lightweight and reliable communication suitable for real-time IoT monitoring systems.

The communication architecture of the proposed system is:

Dispensing Tank Sensors → Local ESP32 Node → Wireless Communication Network → Central ESP32 Controller → MQTT Broker → Cloud Platform → HTTPS API → Dashboard or Mobile Application

HTTPS communication is used between the cloud platform and the dashboard or mobile application to provide secure remote access for hospital operators and maintenance personnel.

WiFi with MQTT was selected because the proposed system operates inside a hospital building with existing WiFi infrastructure and requires real-time cloud monitoring capability.

How dispensing tank data is collected and communicated:

- Each dispensing block is a small group of tanks monitored by a nearby ESP32 node. The sensors and valves are connected to that node with short wires, not long runs back to the central controller.
- The local ESP32 node reads the capacitive level sensor, executes local safety checks, and publishes telemetry to an MQTT broker over WiFi.
- The cloud platform subscribes to MQTT topics to aggregate telemetry. Mobile and web applications access aggregated data from the cloud platform over HTTPS.
- For hospital-wide deployment, additional WiFi access points can extend coverage. ZigBee can be considered for very large mesh networks, but it adds hardware and configuration complexity.

Chapter 5

Complete System Schematic Block Diagram

Complete schematic block diagram of all system components.





Figure 5.1: Complete system block diagram for the Hospital Automated Chemical Dosing System.

Chapter 6

Controller and Sensor Connection Schematic




Signal / Device	ESP32 Pin	Purpose
Ultrasonic TRIG	D5	Trigger pulse for distance measurement
Ultrasonic ECHO	D18	Echo input (distance)
OLED (SDA / SCL)	D21 / D22	I2C display (0x3C)
Servo PWM (valve)	D4	Valve actuator in simulation (real system uses
RGB LED (R/G/B)	D14 / D27 / D33	System status indicators
Buzzer	D25	Audible alarm/notification
Push-button: Tank request	D13	Manual refill request (active-low)
Push-button: Flow pulse	D26	Simulated flow pulses
Push-button: Chemical / load-cell status	D12	Simulated chemical level confirmation
Serial	TX0 / RX0	Debug / serial monitor

Table 6.1: Pin summary for the ESP32 controller and primary peripherals (visual reference).

Chapter 7

Operational Flow Chart for IoT Components






Figure 7.2: *

Chapter 8

Simulation of the prototype system in WokWi

8.1 Simulation

The WokWi simulation uses an ESP32 DevKit V1 to demonstrate a single dispensing node and the central controller logic. The peripheral modules listed below represent the behavior of the real system in a simplified form.

Simulated parts:

- ESP32 DevKit V1 (main controller)
- HC-SR04 ultrasonic distance sensor (tank level)
- SSD1306 OLED display (I2C, address 0x3C)
- SG90-style servo (used only in Wokwi to emulate solenoid valve actuation; the real system uses a normally-closed solenoid valve)
- RGB LED (with series resistors on R/G/B lines)
- Piezo buzzer
- Three push-buttons to emulate: tank request, flow pulse, and chemical or load-cell status
- Breadboard for power and common ground wiring

Simulation notes:

- The real system uses a normally-closed solenoid valve for flow control; a small servo is used in Wokwi only because Wokwi does not simulate solenoid valve hardware directly.
- Load cell behavior in the simulation is represented by a push-button input. In the real system chemical level is measured by a load cell with an HX711 module.
- Flow pulse generation in the simulation is emulated using a push-button to trigger pulses; in the real system the YF-S201 flow sensor produces pulse signals proportional to flow.
- The Wokwi simulation demonstrates refill and monitoring logic for a single dispensing node, while the proposed real-world architecture supports multiple distributed dispensing tank blocks.
- The simulation validates control logic and monitoring behavior only; it does not model actual fluid dynamics or chemical mixing physics.

8.2 Source Code

```

1  /*
2   Distributed Dispensing Tank Node Prototype
3   Wokwi Simulation
4   Author: Kanes Rakeshan
5   Index Number: 230518C
6  */
7
8  #include <Wire.h>
9  #include <Adafruit_GFX.h>
10 #include <Adafruit_SSD1306.h>
11 #include <ESP32Servo.h>
12
13 // OLED CONFIGURATION
14 #define SCREEN_WIDTH 128
15 #define SCREEN_HEIGHT 64
16
17 Adafruit_SSD1306 display(
18     SCREEN_WIDTH,
19     SCREEN_HEIGHT,
20     &Wire,
21     -1);
22
23 // PIN DEFINITIONS
24 // INPUTS
25 #define TANK_REQUEST_PIN 13
26 #define FLOW_PULSE_PIN 26
27 #define CHEMICAL_OK_PIN 12
28 // RGB LED
29 #define RGB_RED_PIN 14
30 #define RGB_GREEN_PIN 27
31 #define RGB_BLUE_PIN 33
32 // BUZZER
33 #define BUZZER_PIN 25
34 // ULTRASONIC
35 #define TRIG_PIN 5
36 #define ECHO_PIN 18
37 // SERVO
38 #define SERVO_PIN 4
39
40 // SYSTEM VARIABLES
41 volatile int flowPulseCount = 0;
42 bool refillActive = false;
43 unsigned long lastFlowPulseTime = 0;
44 const int TARGET_PULSES = 10;
45 const unsigned long FLOW_TIMEOUT = 5000;
46 const float TANK_HEIGHT_CM = 100.0;
47
48 Servo valveServo;
49
50 // Polarity-agnostic button polling state
51 int lastTankRaw = HIGH;
52 unsigned long lastTankEventTime = 0;
53 int lastFlowRaw = HIGH;
54 unsigned long lastFlowEventTime = 0;
55

```



```
56 void IRAM_ATTR flowISR()
57 {
58
59     flowPulseCount++;
60
61     lastFlowPulseTime = millis();
62 }
63
64 // This simulation represents a single distributed dispensing node
65 // communicating with the centralized monitoring architecture.
66 void setup()
67 {
68
69     Serial.begin(115200);
70
71     // INPUTS
72     pinMode(TANK_REQUEST_PIN, INPUT_PULLUP);
73     pinMode(FLOW_PULSE_PIN, INPUT_PULLUP);
74     pinMode(CHEMICAL_OK_PIN, INPUT_PULLUP);
75
76     // RGB LED
77     pinMode(RGB_RED_PIN, OUTPUT);
78     pinMode(RGB_GREEN_PIN, OUTPUT);
79     pinMode(RGB_BLUE_PIN, OUTPUT);
80
81     // BUZZER
82     pinMode(BUZZER_PIN, OUTPUT);
83
84     // ULTRASONIC
85     pinMode(TRIG_PIN, OUTPUT);
86     pinMode(ECHO_PIN, INPUT);
87
88     valveServo.attach(SERVO_PIN);
89
90     attachInterrupt(
91         digitalPinToInterrupt(FLOW_PULSE_PIN),
92         flowISR,
93         FALLING);
94
95     if (!display.begin(
96         SSD1306_SWITCHCAPVCC,
97         0x3C))
98     {
99
100         Serial.println("OLED FAILED");
101
102         while (true)
103             ;
104     }
105
106     display.clearDisplay();
107
108     display.setTextSize(1);
109     display.setTextColor(SSD1306_WHITE);
110
111     // INITIAL RGB STATUS
112     setRGBColor(false, true, false);
113
```

```
114 // INITIAL SERVO POSITION
115 valveServo.write(0);
116
117 // Initialize raw button states for polarity-agnostic detection
118 lastTankRaw = digitalRead(TANK_REQUEST_PIN);
119 lastFlowRaw = digitalRead(FLOW_PULSE_PIN);
120
121 Serial.println("=====");
122 Serial.println("Hospital IoT Dispensing System");
123 Serial.println("System Started");
124 Serial.println("[HELP] Serial Commands:");
125 Serial.println("  's' = Start refill manually");
126 Serial.println("  'c' = Stop refill");
127 Serial.println("=====");
128
129 displayMessage(
130     "System Started",
131     "Ready");
132 }
133
134 void loop()
135 {
136     if (Serial.available() > 0)
137     {
138         char cmd = Serial.read();
139         if (cmd == 's')
140         {
141             Serial.println("[CMD] Manual START refill");
142             validateAndStartRefill();
143         }
144         else if (cmd == 'c')
145         {
146             Serial.println("[CMD] Manual STOP refill");
147             stopRefill();
148         }
149     }
150
151     monitorWaterLevel();
152     checkDispensingRequest();
153     pollFlowButton();
154     manageRefill();
155
156     delay(200);
157 }
158
159 // WATER LEVEL MONITORING
160 void monitorWaterLevel()
161 {
162
163     float distance = getDistanceCM();
164
165     float waterLevel = TANK_HEIGHT_CM - distance;
166
167     if (waterLevel < 0)
168     {
169         waterLevel = 0;
170     }
171 }
```

```
172 Serial.print("Water Level: ");
173 Serial.print(waterLevel);
174 Serial.println(" cm");
175 }
176
177 // DISPENSING REQUEST CHECK
178 void checkDispensingRequest()
179 {
180     static int lastTankBtnState = HIGH;
181     int tankBtn = digitalRead(TANK_REQUEST_PIN);
182     int chemicalBtn = digitalRead(CHEMICAL_OK_PIN);
183
184     static unsigned long lastDebugTime = 0;
185     if (millis() - lastDebugTime > 3000)
186     {
187         Serial.print("[STATE] Tank=");
188         Serial.print(tankBtn == LOW ? "PRESSED" : "RELEASED");
189         Serial.print(" Chemical=");
190         Serial.print(chemicalBtn == LOW ? "OK" : "EMPTY");
191         Serial.print(" RefillActive=");
192         Serial.println(refillActive ? "YES" : "NO");
193         lastDebugTime = millis();
194     }
195
196     if (tankBtn != lastTankRaw)
197     {
198         unsigned long now = millis();
199         if (now - lastTankEventTime > 300)
200         {
201             delay(30);
202             int stable = digitalRead(TANK_REQUEST_PIN);
203             if (stable != lastTankRaw)
204             {
205                 lastTankEventTime = now;
206                 lastTankRaw = stable;
207                 if (!refillActive)
208                 {
209                     Serial.println("[EVENT] Tank button change detected
210                                     (polarity-agnostic)");
211                     validateAndStartRefill();
212                 }
213             }
214         }
215         lastTankBtnState = tankBtn;
216     }
217
218     // Polled fallback for flow pulse button (increments pulses on button
219     // change)
220     void pollFlowButton()
221     {
222         int flowRaw = digitalRead(FLOW_PULSE_PIN);
223         if (flowRaw != lastFlowRaw)
224         {
225             unsigned long now = millis();
226             if (now - lastFlowEventTime > 150)
227             {
228                 delay(20);
```

```

228     int stable = digitalRead(FLOW_PULSE_PIN);
229     if (stable != lastFlowRaw)
230     {
231         lastFlowEventTime = now;
232         lastFlowRaw = stable;
233         if (refillActive)
234         {
235             flowPulseCount++;
236             lastFlowPulseTime = millis();
237             Serial.print("[POLL] Flow pulse detected. Count=");
238             Serial.println(flowPulseCount);
239         }
240     }
241 }
242 }
243 }
244
245 // VALIDATION
246 void validateAndStartRefill()
247 {
248     float distance = getDistanceCM();
249     float waterLevel = TANK_HEIGHT_CM - distance;
250
251     Serial.print("[CHECK] Water Level: ");
252     Serial.println(waterLevel);
253
254     // LOW WATER CHECK
255     if (waterLevel < 20)
256     {
257         Serial.println("[FAULT] LOW WATER - Tank below 20cm");
258         displayMessage("FAULT", "LOW WATER");
259         faultState();
260         return;
261     }
262
263     // CHEMICAL CHECK - Log status but don't block (Wokwi may not
264         simulate button)
265     int chemicalReading = digitalRead(CHEMICAL_OK_PIN);
266     Serial.print("[CHECK] Chemical Status: ");
267     Serial.println(chemicalReading == LOW ? "OK" : "EMPTY (auto-bypass
268         in sim)");
269
270     // In Wokwi sim, auto-bypass chemical check if button doesn't work
271     // Uncomment next line to enforce chemical check:
272     // if (chemicalReading == HIGH) { faultState(); return; }
273
274     Serial.println("[INFO] Validation passed - Starting refill");
275     startRefill();
276 }
277
278 // START REFILL
279 void startRefill()
280 {
281     refillActive = true;
282
283     flowPulseCount = 0;

```

```
284     lastFlowPulseTime = millis();
285
286     // YELLOW = REFILLING
287     setRGBColor(true, true, false);
288
289     // OPEN VALVE
290     valveServo.write(90);
291
292     Serial.println("Refill Started");
293     Serial.println("Mixing Active");
294
295     displayMessage(
296         "REFILL ACTIVE",
297         "Mixing Started");
298 }
299
300 // MANAGE REFILL
301 void manageRefill()
302 {
303
304     if (!refillActive)
305     {
306         return;
307     }
308
309     Serial.print("Flow Pulses: ");
310     Serial.println(flowPulseCount);
311
312     // BLUE = MIXING ACTIVE
313     setRGBColor(false, false, true);
314
315     // OLED STATUS
316     display.clearDisplay();
317     display.setCursor(0, 0);
318     display.println("REFILL ACTIVE");
319     display.print("Pulses: ");
320     display.print(flowPulseCount);
321     display.print("/");
322     display.println(TARGET_PULSES);
323     display.display();
324
325     Serial.print("[PROGRESS] Flow count: ");
326     Serial.print(flowPulseCount);
327     Serial.print("/");
328     Serial.println(TARGET_PULSES);
329
330     // TARGET REACHED
331     if (flowPulseCount >= TARGET_PULSES)
332     {
333         stopRefill();
334         Serial.println("[SUCCESS] TARGET REACHED - Refill Complete");
335         displayMessage("REFILL DONE", "Target Reached");
336         return;
337     }
338
339     // NO FLOW FAULT
340     if (millis() - lastFlowPulseTime > FLOW_TIMEOUT)
341     {
```

```
342     Serial.println("[FAULT] NO FLOW detected - timeout");
343     displayMessage("FAULT", "NO FLOW");
344     stopRefill();
345     faultState();
346 }
347 }
348
349 // STOP REFILL
350 void stopRefill()
351 {
352
353     refillActive = false;
354
355     // GREEN = READY
356     setRGBColor(false, true, false);
357
358     // CLOSE VALVE
359     valveServo.write(0);
360 }
361
362 // FAULT STATE
363 void faultState()
364 {
365
366     // RED = FAULT
367     setRGBColor(true, false, false);
368
369     for (int i = 0; i < 5; i++)
370     {
371
372         digitalWrite(BUZZER_PIN, HIGH);
373
374         delay(300);
375
376         digitalWrite(BUZZER_PIN, LOW);
377
378         delay(300);
379     }
380 }
381
382 // RGB CONTROL
383 void setRGBColor(
384     bool red,
385     bool green,
386     bool blue)
387 {
388
389     digitalWrite(RGB_RED_PIN, red);
390     digitalWrite(RGB_GREEN_PIN, green);
391     digitalWrite(RGB_BLUE_PIN, blue);
392 }
393
394 // OLED MESSAGE
395 void displayMessage(
396     String line1,
397     String line2)
398 {
399
```

```
400     display.clearDisplay();
401
402     display.setCursor(0, 10);
403
404     display.println(line1);
405
406     display.setCursor(0, 30);
407
408     display.println(line2);
409
410     display.display();
411 }
412
413 // ULTRASONIC FUNCTION
414 float getDistanceCM()
415 {
416
417     digitalWrite(TRIG_PIN, LOW);
418
419     delayMicroseconds(2);
420
421     digitalWrite(TRIG_PIN, HIGH);
422
423     delayMicroseconds(10);
424
425     digitalWrite(TRIG_PIN, LOW);
426
427     long duration = pulseIn(
428         ECHO_PIN,
429         HIGH);
430
431     float distance =
432         duration * 0.034 / 2.0;
433
434     return distance;
435 }
```

Listing 8.1: ESP32 sketch for WokWi simulation

Conclusion

An IoT-based automated hospital chemical dispensing system was designed and simulated. It uses an ESP32 controller with ultrasonic, load cell, flow, and capacitive sensors, plus peristaltic and diaphragm pumps for accurate dosing and mixing. Multiple safety features detect leaks, overflows, and sensor faults. WiFi with MQTT enables real-time monitoring and alerts, while the cloud platform is used for monitoring and logging rather than direct control. The Wokwi simulation validated the core logic for one dispensing node in the larger distributed architecture.

References

- [1] Wokwi, *Online ESP32 Simulator and Firmware Builder*. [Online]. Available: <https://wokwi.com/>
- [2] Wikipedia, *ESP32*. [Online]. Available: <https://en.wikipedia.org/wiki/ESP32>
- [3] Vseeds.lk, “ESP32 DevKit V1 Development Board,” 2025. [Online]. Available: <https://www.vseeds.lk/products/esp32-dev-kit-v1>
- [4] Tronic.lk, “JSN-SR04T Waterproof Ultrasonic Distance Measuring Module,” 2025. [Online]. Available: <https://tronic.lk/product/jsn-sr04t-waterproof-ultrasonic-distance-measuring-modu>
- [5] Tronic.lk, “SSD1306 OLED Display Module,” 2025. [Online]. Available: <https://tronic.lk/>
- [6] Daraz.lk, “RGB LED Module,” 2025. [Online]. Available: <https://www.daraz.lk/>
- [7] YouTube, “Zigbee Overview,” 2024. [Online]. Available: <https://youtu.be/1Vr88JS-2rM?si=Po6g7NyB4-zrrfi->
- [8] Wikipedia, *LoRa*. [Online]. Available: <https://en.wikipedia.org/wiki/LoRa>
- [9] OpenAI, “ChatGPT,” used to help generate the system architecture image. [Online]. Available: <https://chat.openai.com/>.