

Project:

Exam\_16.01

Licensed user:

Hochschule Flensburg, University of Applied Sciences  
Darf nur für Zwecke der Lehre verwendet werden

student / weti-lab-vt10@hs-flensburg.de

Calculated:

1/16/2025 3:27 PM/4.0.547

## PARK - Main Result

Calculation: AEP\_Enercon\_Normal

### Setup

AEP scaled to a full year based on number of samples  
Scaling factor from 31.0 years to 1 year: 0.032

Calculation performed in UTM (north)-WGS84 Zone: 32

At the site centre the difference between grid north and true north is: 0.61°

### Wake

Wake Model: N.O. Jensen (RIS<sub>1/2</sub>/EMD) Park 2 2018

Wake decay constant

Wake decay constant: 0.085 Mixed farmland Hub height dependent

Reference WTG: 01\_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (12)

### Scaler/wind data

Name EMD Default Measurement Mast Scaler  
Terrain scaling Measured Data Scaling (WASP Stability / A-Parameter)  
Micro terrain flow model WASP IBZ from Site Data  
Used period 1/1/1994 1:00:00 AM - 1/1/2025  
Meteo object(s) MCP LT - MCP session (1) - [Neural Network] (3), 125.00m - MCP LT - MCP session (1) - [Neural Network]  
Displacement height Omnidirectional from objects  
WASP version WASP 11 Version 11.04.0026

### Power correction

Power curve correction (adjusted IEC method, improved to match turbine control)

	Min	Max	Avg	Corr. [%]	Neg. corr. [%]	Pos. corr. [%]
Air density						
From air density settings	[1/2 °C]	7.6	7.6	7.6		
From air density settings	[hPa]	990.6	990.6	990.6		
Resulting air density	[kg/m <sup>3</sup> ]	1.229	1.229	1.229		
Relative to 151/2 °C at sea level	100.4	100.4	100.4	0.2	0.0	0.2



## Calculated Annual Energy for Wind Farm

WTG combination	Result PARK [MWh/y]	Result-10.0% [MWh/y]	GROSS (no loss) Free WTGs [MWh/y]	Wake loss [%]	Specific results <sub>1/2</sub>		Full load hours [Hours/year]	Wind speed	
					Capacity factor [%]	Mean WTG result [MWh/y]		free [m/s]	wake reduced [m/s]
Wind farm	92,757.7	83,481.9	97,246.7	4.6	31.7	13,913.7	2,783	7.0	6.9

<sub>1/2</sub>) Based on Result-10.0%

## Calculated Annual Energy for each of 6 new WTGs with total 30.0 MW rated power

WTG type								Power curve		Annual Energy			Wind speed	
Valid	Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Creator	Name	Result	Result-10.0%	Wake loss [%]	free	reduced		
								[MWh/y]	[MWh/y]		[m/s]	[m/s]		
1	No	ENERCON E-147 EP5 E2-5,000	5,000	147.0	126.0	USER	Mode 00 - OM 0 s - 5000 kW	15,755.5	14,180	3.1	7.03	6.93		
2	No	ENERCON E-147 EP5 E2-5,000	5,000	147.0	126.0	USER	Mode 00 - OM 0 s - 5000 kW	15,887.8	14,299	2.3	7.03	6.95		
3	No	ENERCON E-147 EP5 E2-5,000	5,000	147.0	126.0	USER	Mode 00 - OM 0 s - 5000 kW	15,388.1	13,849	4.7	7.00	6.84		
4	No	ENERCON E-147 EP5 E2-5,000	5,000	147.0	126.0	USER	Mode 00 - OM 0 s - 5000 kW	15,304.4	13,774	5.0	7.00	6.82		
5	No	ENERCON E-147 EP5 E2-5,000	5,000	147.0	126.0	USER	Mode 00 - OM 0 s - 5000 kW	15,226.7	13,704	5.6	7.00	6.81		
6	No	ENERCON E-147 EP5 E2-5,000	5,000	147.0	126.0	USER	Mode 00 - OM 0 s - 5000 kW	15,195.2	13,676	7.1	7.05	6.80		

## WTG siting

UTM (north)-ETRS89 Zone: 32

	Eastings	Northing	Z	Row data/Description	Calculation period
					Start End
1 New	547,702	6,061,711	60.0	01_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (12)	1/1/1994 1/1/2025
2 New	547,819	6,060,747	60.0	02_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (13)	1/1/1994 1/1/2025
3 New	548,537	6,060,868	60.0	03_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (14)	1/1/1994 1/1/2025
4 New	549,253	6,061,072	60.0	04_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (15)	1/1/1994 1/1/2025
5 New	548,497	6,061,973	60.0	05_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (16)	1/1/1994 1/1/2025
6 New	549,164	6,061,683	60.0	06_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (17)	1/1/1994 1/1/2025

## PARK - Production Analysis

Calculation: AEP\_Enercon\_Normal WTG: All new WTGs, Air density 1.229 kg/m<sup>3</sup>

### Directional Analysis

Sector		0 N	1 NNE	2 ENE	3 E	4 ESE	5 SSE	6 S	7 SSW	8 WSW	9 W	10 WNW	11 NNW	Total
Model based energy	[MWh]	2,564.3	2,612.0	2,964.6	6,653.4	7,140.4	5,246.6	6,948.5	13,415.0	15,712.9	15,802.3	14,034.3	4,152.3	97,246.7
-Decrease due to wake losses	[MWh]	195.3	95.8	221.7	434.2	374.2	189.1	407.4	339.1	660.7	830.3	592.7	148.4	4,489.0
Resulting energy	[MWh]	2,369.0	2,516.2	2,743.0	6,219.2	6,766.2	5,057.5	6,541.1	13,075.8	15,052.2	14,972.1	13,441.5	4,004.0	92,757.7
Specific energy	[kWh/mi <sup>2</sup> ]													911
Specific energy	[kWh/kW]													3,092
Decrease due to wake losses	[%]	7.6	3.7	7.5	6.5	5.2	3.6	5.9	2.5	4.2	5.3	4.2	3.6	4.62
Full Load Equivalent	[Hours/year]	79	84	91	207	226	169	218	436	502	499	448	133	3,092

Project:

Exam\_16.01

Licensed user:

Hochschule Flensburg, University of Applied Sciences  
Darf nur für Zwecke der Lehre verwendet werden

student / weti-lab-vt10@hs-flensburg.de

Calculated:

1/16/2025 3:27 PM/4.0.547

## PARK - Power Curve Analysis

Calculation: AEP\_Enercon\_Normal WTG: 1 - ENERCON E-147 EP5 E2 5000 147.0 !O!, Hub height: 126.0 m

Name: Mode 00 - OM 0 s - 5000 kW

Source: ENERCON GmbH

Source/Date	Created by	Created	Edited	Stop wind speed [m/s]	Power control	CT curve type	Generator type	Specific power kW/m <sup>1/2</sup>
8/1/2019	USER	2/10/2020	2/25/2020	25.0	Pitch	User defined	Variable	0.29

D0802432-3\_#\_de\_#\_Datenblatt\_Betriebsmodus\_E-147\_EP5\_E2\_5000\_kW\_mit\_TES.pdf  
Enercon reserves the right to change the above specifications without prior notice.

HP curve comparison - Note: For standard air density

Vmean	[m/s]	5	6	7	8	9	10
HP value Pitch, variable speed (2013)	[MWh]	8,581	13,010	17,262	21,030	24,193	26,713
ENERCON E-147 EP5 E2 5000 147.0 !O! Mode 00 - OM 0 s - 5000 kW	[MWh]	8,091	12,179	16,183	19,811	22,914	25,414
Check value	[%]	6	7	7	6	6	5

The table shows comparison between annual energy production calculated on basis of simplified "HP-curves" which assume that all WTGs performs quite similar - only specific power loading (kW/m<sup>1/2</sup>) and single/dual speed or stall/pitch decides the calculated values. Productions are without wake losses.

For further details, ask at the Danish Energy Agency for project report J.nr. 51171/00-0016 or see the windPRO manual.

The method is refined in EMD report "20 Detailed Case Studies comparing Project Design Calculations and actual Energy Productions for Wind Energy Projects worldwide", jan 2003.

Use the table to evaluate if the given power curve is reasonable - if the check value are lower than -5%, the power curve probably is too optimistic due to uncertainty in power curve measurement.

## Power curve

Original data, Air density: 1.225 kg/m<sup>3</sup>

Wind speed [m/s]	Power [kW]	Cp	Wind speed [m/s]	Ct curve
3.0	68.0	0.24	3.0	0.88
3.5	143.0	0.32	3.5	0.84
4.0	248.0	0.37	4.0	0.83
4.5	382.0	0.40	4.5	0.83
5.0	548.0	0.42	5.0	0.82
5.5	748.0	0.43	5.5	0.82
6.0	986.0	0.44	6.0	0.82
6.5	1263.0	0.44	6.5	0.81
7.0	1578.0	0.44	7.0	0.79
7.5	1926.0	0.44	7.5	0.77
8.0	2297.0	0.43	8.0	0.74
8.5	2676.0	0.42	8.5	0.70
9.0	3050.0	0.40	9.0	0.65
9.5	3406.0	0.38	9.5	0.60
10.0	3736.0	0.36	10.0	0.55
10.5	4036.0	0.34	10.5	0.50
11.0	4297.0	0.31	11.0	0.46
11.5	4514.0	0.29	11.5	0.41
12.0	4682.0	0.26	12.0	0.37
12.5	4804.0	0.24	12.5	0.34
13.0	4886.0	0.21	13.0	0.30
13.5	4937.0	0.19	13.5	0.27
14.0	4967.0	0.17	14.0	0.24
14.5	4984.0	0.16	14.5	0.22
15.0	4993.0	0.14	15.0	0.20
15.5	4997.0	0.13	15.5	0.18
16.0	4999.0	0.12	16.0	0.16
16.5	5000.0	0.11	16.5	0.15
17.0	5000.0	0.10	17.0	0.14
17.5	5000.0	0.09	17.5	0.12
18.0	5000.0	0.08	18.0	0.11
18.5	5000.0	0.08	18.5	0.11
19.0	5000.0	0.07	19.0	0.10
19.5	5000.0	0.06	19.5	0.09
20.0	5000.0	0.06	20.0	0.09
20.5	5000.0	0.06	20.5	0.08
21.0	5000.0	0.05	21.0	0.07
21.5	5000.0	0.05	21.5	0.07
22.0	5000.0	0.05	22.0	0.07
22.5	5000.0	0.04	22.5	0.06
23.0	5000.0	0.04	23.0	0.06
23.5	5000.0	0.04	23.5	0.06
24.0	5000.0	0.03	24.0	0.05
24.5	5000.0	0.03	24.5	0.05
25.0	5000.0	0.03	25.0	0.05

## Power and efficiency vs. wind speed

Data used in calculation, Mean air density: 1.229 kg/m<sup>3</sup>

Wind speed [m/s]	Power [kW]	Cp
1.0	0.0	0.00
2.0	0.0	0.00
3.0	68.5	0.24
4.0	249.2	0.37
5.0	550.3	0.42
6.0	989.8	0.44
7.0	1,583.5	0.44
8.0	2,303.9	0.43
9.0	3,057.7	0.40
10.0	3,744.1	0.36
11.0	4,304.2	0.31
12.0	4,686.8	0.26
13.0	4,888.1	0.21
14.0	4,967.7	0.17
15.0	4,993.2	0.14
16.0	4,999.0	0.12
17.0	5,000.0	0.10
18.0	5,000.0	0.08
19.0	5,000.0	0.07
20.0	5,000.0	0.06
21.0	5,000.0	0.05
22.0	5,000.0	0.05
23.0	5,000.0	0.04
24.0	5,000.0	0.03
25.0	5,000.0	0.03

## PARK - Wind Data Analysis

Calculation: AEP\_Enercon\_Normal Wind data: 1 - 01\_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (12); Hub height: 126.0

Site coordinates

UTM (north)-ETRS89 Zone: 32

East: 547,702 North: 6,061,711

01\_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (12)

Masts used

Take nearest

### Winddata for site

Sector	Free mean wind speed [m/s]	Wake reduced mean wind speed [m/s]	Frequency [%]	
0 N	5.9		5.9	3.6
1 NNE	6.0		6.0	3.6
2 ENE	6.0		5.6	4.5
3 E	6.7		6.3	7.6
4 ESE	6.6		6.3	8.3
5 SSE	6.5		6.3	6.2
6 S	7.0		6.7	7.0
7 SSW	7.6		7.6	12.0
8 WSW	7.7		7.7	13.7
9 W	7.5		7.5	14.7
10 WNW	7.3		7.3	13.4
11 NNW	6.1		6.1	5.4
All	7.0		6.9	100.0

PARK - Wind Data Analysis

Calculation: AEP\_Enercon\_Normal Wind data: 2 - 02\_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m) (13); Hub height: 126.0  
Site coordinates  
UTM (north)-ETRS89 Zone: 32  
East: 547,819 North: 6,060,747  
02\_ENERCON E-147 EP5 E2 5000 147.0 !O! hub: 126.0 m (TOT: 199.5 m)  
(13)  
Masts used  
Take nearest

Winddata for site				
Sector	Free mean wind speed	Wake reduced mean wind speed	Frequency	
	[m/s]	[m/s]	[%]	
0 N	5.9		5.6	3.6
1 NNE	6.0		5.8	3.6
2 ENE	5.9		5.5	4.5
3 E	6.7		6.1	7.6
4 ESE	6.7		6.7	8.3
5 SSE	6.5		6.5	6.2
6 S	7.0		7.0	7.0
7 SSW	7.5		7.5	12.0
8 WSW	7.7		7.7	13.7
9 W	7.5		7.5	14.7
10 WNW	7.4		7.4	13.4
11 NNW	6.2		6.2	5.4
All	7.0		6.9	100.0

PARK - WTG distances

Calculation: AEP\_Enercon\_Normal  
WTG distances

	Z	Nearest WTG	Z	Horizontal distance	Distance in rotor diameters
	[m]		[m]	[m]	
1	60.0	5	60.0	838	5.7
2	60.0	3	60.0	728	4.9
3	60.0	2	60.0	728	4.9
4	60.0	6	60.0	617	4.2
5	60.0	6	60.0	727	4.9
6	60.0	4	60.0	617	4.2
Min	60.0		60.0	617	4.2
Max	60.0		60.0	838	5.7



New WTG

Scale 1:25,000

## PARK - Time varying AEP

Calculation: AEP\_Enercon\_Normal

Windfarm: 30.0 MW based on 6 turbines of type ENERCON E-147 EP5 E2 5000 147.0 !OI.

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses.

Values are scaled to a full year, see correction factors at main result page.

Hour/Month [MWh]	1	2	3	4	5	6	7	8	9	10	11	12	Grand Total
0	452	404	389	314	303	277	266	266	310	389	390	427	4,187
1	445	402	389	310	292	267	254	270	299	368	393	421	4,110
2	443	396	385	311	286	264	258	264	299	365	388	433	4,094
3	439	396	372	300	291	254	260	260	294	371	390	417	4,045
4	449	396	378	306	286	258	257	259	300	368	383	423	4,061
5	441	401	375	295	286	257	252	251	297	364	371	426	4,015
6	440	391	369	286	270	240	235	249	290	373	366	418	3,928
7	430	387	367	273	241	233	222	220	271	359	363	410	3,777
8	427	381	341	235	234	222	216	206	259	347	349	398	3,616
9	413	368	330	236	216	222	221	202	239	324	334	391	3,495
10	413	353	331	240	220	226	222	214	264	323	337	383	3,525
11	402	347	331	242	223	222	217	210	252	317	312	373	3,447
12	395	360	339	257	246	246	238	230	273	332	338	379	3,633
13	408	373	361	278	260	262	249	244	294	351	338	382	3,799
14	409	372	372	289	274	277	265	260	285	352	350	382	3,886
15	411	381	375	290	278	277	262	251	294	355	337	383	3,893
16	407	367	362	288	270	265	249	249	283	344	345	382	3,810
17	410	358	351	277	265	258	242	240	278	334	348	391	3,752
18	409	364	357	272	252	241	233	226	271	339	351	394	3,709
19	430	376	364	280	262	238	230	229	274	363	362	391	3,799
20	432	386	381	295	281	232	234	232	283	367	368	404	3,894
21	439	399	395	302	279	255	240	244	301	381	381	405	4,021
22	440	403	398	315	296	259	248	256	300	396	389	418	4,117
23	439	398	387	316	294	264	257	269	322	396	382	418	4,143
Grand Total	10,224	9,155	8,797	6,807	6,405	6,015	5,829	5,802	6,833	8,577	8,665	9,648	92,758

Hour/Month [MW]	1	2	3	4	5	6	7	8	9	10	11	12	Grand Total
0	14.6	14.4	12.5	10.5	9.8	9.2	8.6	8.6	10.3	12.6	13.0	13.8	11.5
1	14.4	14.3	12.5	10.3	9.4	8.9	8.2	8.7	10.0	11.9	13.1	13.6	11.3
2	14.3	14.1	12.4	10.4	9.2	8.8	8.3	8.5	10.0	11.8	12.9	14.0	11.2
3	14.2	14.1	12.0	10.0	9.4	8.5	8.4	8.4	9.8	12.0	13.0	13.5	11.1
4	14.5	14.1	12.2	10.2	9.2	8.6	8.3	8.3	10.0	11.9	12.8	13.6	11.1
5	14.2	14.3	12.1	9.8	9.2	8.6	8.1	8.1	9.9	11.7	12.4	13.7	11.0
6	14.2	14.0	11.9	9.5	8.7	8.0	7.6	8.0	9.7	12.0	12.2	13.5	10.8
7	13.9	13.8	11.8	9.1	7.8	7.8	7.2	7.1	9.0	11.6	12.1	13.2	10.3
8	13.8	13.6	11.0	7.8	7.6	7.4	7.0	6.6	8.6	11.2	11.6	12.9	9.9
9	13.3	13.1	10.6	7.9	7.0	7.4	7.1	6.5	8.0	10.5	11.1	12.6	9.6
10	13.3	12.6	10.7	8.0	7.1	7.5	7.2	6.9	8.8	10.4	11.2	12.3	9.7
11	13.0	12.4	10.7	8.1	7.2	7.4	7.0	6.8	8.4	10.2	10.4	12.0	9.4
12	12.7	12.9	10.9	8.6	7.9	8.2	7.7	7.4	9.1	10.7	11.3	12.2	10.0
13	13.2	13.3	11.6	9.3	8.4	8.7	8.0	7.9	9.8	11.3	11.3	12.3	10.4
14	13.2	13.3	12.0	9.6	8.8	9.2	8.5	8.4	9.5	11.4	11.7	12.3	10.6
15	13.2	13.6	12.1	9.7	9.0	9.2	8.5	8.1	9.8	11.4	11.2	12.3	10.7
16	13.1	13.1	11.7	9.6	8.7	8.8	8.0	8.0	9.4	11.1	11.5	12.3	10.4
17	13.2	12.8	11.3	9.2	8.5	8.6	7.8	7.8	9.3	10.8	11.6	12.6	10.3
18	13.2	13.0	11.5	9.1	8.1	8.0	7.5	7.3	9.0	10.9	11.7	12.7	10.2
19	13.9	13.4	11.7	9.3	8.5	7.9	7.4	7.4	9.1	11.7	12.1	12.6	10.4
20	13.9	13.8	12.3	9.8	9.1	7.7	7.6	7.5	9.4	11.9	12.3	13.0	10.7
21	14.2	14.2	12.8	10.1	9.0	8.5	7.7	7.9	10.0	12.3	12.7	13.1	11.0
22	14.2	14.4	12.8	10.5	9.5	8.6	8.0	8.3	10.0	12.8	13.0	13.5	11.3
23	14.2	14.2	12.5	10.5	9.5	8.8	8.3	8.7	10.7	12.8	12.7	13.5	11.4
Grand Total	13.7	13.6	11.8	9.5	8.6	8.4	7.8	7.8	9.5	11.5	12.0	13.0	10.6

Project:

Exam\_16.01

Licensed user:

Hochschule Flensburg, University of Applied Sciences  
Darf nur für Zwecke der Lehre verwendet werden

--

student / weti-lab-vt10@hs-flensburg.de

Calculated:

1/16/2025 3:27 PM/4.0.547

## PARK - Time varying AEP

Calculation: AEP\_Enercon\_Normal

Windfarm: 30.0 MW based on 6 turbines of type ENERCON E-147 EP5 E2 5000 147.0 !O!.

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses.

Values are scaled to a full year, see correction factors at main result page.



## PARK - Time varying AEP

Calculation: AEP\_Enercon\_Normal

Windfarm: 30.0 MW based on 6 turbines of type ENERCON E-147 EP5 E2 5000 147.0 !O!.

Selection: All new WTGs

Calculated mean yield per month and hour [MWh]. The result includes wake losses and any curtailment losses.

Hours	Hours [%]	Hours accumulated	Power [MW]	Power (MW/WTG)
42	0.5	42	30.0	5.0
330	3.8	372	28.7 - 30.0	4.8 - 5.0
169	1.9	541	27.4 - 28.7	4.6 - 4.8
157	1.8	697	26.1 - 27.4	4.3 - 4.6
169	1.9	867	24.8 - 26.1	4.1 - 4.3
179	2.0	1045	23.5 - 24.8	3.9 - 4.1
192	2.2	1237	22.2 - 23.5	3.7 - 3.9
203	2.3	1441	20.9 - 22.2	3.5 - 3.7
226	2.6	1667	19.6 - 20.9	3.3 - 3.5
235	2.7	1901	18.3 - 19.6	3.0 - 3.3
255	2.9	2156	17.0 - 18.3	2.8 - 3.0
272	3.1	2429	15.7 - 17.0	2.6 - 2.8
297	3.4	2726	14.3 - 15.7	2.4 - 2.6
316	3.6	3042	13.0 - 14.3	2.2 - 2.4
341	3.9	3384	11.7 - 13.0	2.0 - 2.2
363	4.1	3746	10.4 - 11.7	1.7 - 2.0
400	4.6	4146	9.1 - 10.4	1.5 - 1.7
436	5.0	4582	7.8 - 9.1	1.3 - 1.5
483	5.5	5065	6.5 - 7.8	1.1 - 1.3
517	5.9	5582	5.2 - 6.5	0.9 - 1.1
570	6.5	6152	3.9 - 5.2	0.7 - 0.9
626	7.1	6777	2.6 - 3.9	0.4 - 0.7
663	7.6	7440	1.3 - 2.6	0.2 - 0.4
767	8.8	8207	0.0 - 1.3	0.0 - 0.2
559	6.4	8766	0.0	0.0

Project:

Exam\_16.01

Licensed user:

Hochschule Flensburg, University of Applied Sciences  
Darf nur für Zwecke der Lehre verwendet werden

--

student / weti-lab-vt10@hs-flensburg.de

Calculated:

1/16/2025 3:27 PM/4.0.547

## PARK - Scaling info

Calculation: AEP\_Enercon\_Normal

### Scaler settings

Name	EMD Default Measurement Mast Scaler
Terrain scaling	Measured Data Scaling (WASP Stability / A-Parameter)
RIX correction	No RIX correction
Displacement height	from objects
Micro terrain flow model	Site data: RESGEN (5)

Site Data: Site data: RESGEN (5)

Obstacles:

All obstacles used

Roughness:

Terrain data files used in calculation:

C:\Users\student\Desktop\Exam\_16\_01\_2025\Windpro\_exam\_16.01\ROUGHNESSLINE\_ONLINEDATA\_0.wpo

Min X: 518,359, Max X: 578,403, Min Y: 6,030,681, Max Y: 6,091,978, Width: 60,044 m, Height: 61,297 m

Orography:

Terrain data files used in calculation:

C:\Users\student\Desktop\Exam\_16\_01\_2025\Windpro\_exam\_16.01\CONTOURLINE\_ONLINEDATA\_0.wpo



Min X: 538,612, Max X: 558,177, Min Y: 6,051,218, Max Y: 6,071,644, Width: 19,565 m, Height: 20,426 m

### Post calibration

Overall factor	1.0000
Overall offset	0.0000
By sector	No
By month	No
By hour	No
By wind speed	No

## PARK - Map

Calculation: AEP\_Enercon\_Normal



Map: EMD OpenStreetMap , Print scale 1:12,500, Map center UTM (north)-ETRS89 Zone: 32 East: 548,534 North: 6,061,313  
New WTG WTG area