

IF IN DOUBT ASK

DO NOT SCALE THE DRAWING

THIS DRAWING IS PROPERTY OF KALA GENSET PVT. LTD. AND
MUST BE RETURNED ON REQUEST. IT IS SUBMITTED AS CONFIDENTIAL
INFORMATION WITH OUR ENQUIRY, TENDER, ORDER OR CONTRACT NO.
IT IS NOT TO BE ISSUED FOR ANY OTHER PURPOSE OR ORDER NOR
MAY BE COPIED OR LENT WITHOUT OUR AUTHORITY IN WRITING.



'D' = DEPTH IS DEPEND UP ON SOIL GRADE AS MENTIONED ABOVE.

BRICK WORK AS ILLUSTRATED
TO BE PROVIDED AROUND
RCC FOUNDATION.

ITEMS--(1) FOUNDATION TO BE MADE ON A GOOD PREPARED SURFACE WITH SOIL STRATA BEARING CAPACITY ADEQUATE TO SUPPORT THE WEIGHT OF GENSET & FOUNDATION.

REFER CHART FOR SOIL STRENGTH.

MATERIAL OR LAYER	SAFE BEARING CAPACITY REGION
BEARING MATERIAL	97,600 - 976,400
HARD ROCK GRANITE	27,400 - 976,400
MEDIUM ROCK SHELL	97,600 - 126,400
HARD PAH	17,800 - 97,600
SOFT ROCK	16,200 - 95,600
HARD CLAY	59,000 - 46,800
GROVEL AND GRAVEL SAND	59,000 - 46,800
SAND, SILT AND CLAY	59,000 - 29,000
COMPACTED FINE SAND	19,500 - 39,000
MEDIUM CLAY	19,500 - 39,000
LOOSE FINE SAND	9,750 - 39,500
SOFT CLAY	9,750

(2) THE LENGTH & WIDTH OF FOUNDATION SHOULD BE AT LEAST 300 mm MORE ON EACH SIDE THAN GENSET LENGTH & WIDTH RESPECTIVELY.

(3) CHECK THE FOUNDATION LEVEL DIAGONALLY AS WELL AS ACROSS THE LENGTH & WIDTH FOR EVEN FLATNESS AND SAME SHOULD BE WITHIN ±50mm IN HORIZONTAL PLANE IN ANY ONE DIRECTION ONLY.

(4) ENSURE THAT THE CONCRETE IS COMPLETELY CURED BEFORE POSITIONING THE GENSET.

(5) ENSURE THAT THE FOUNDATION TO SUPPORT 1.5 TIMES (DYNAMIC LOAD) OF THE TOTAL NET WEIGHT OF THE SINGLE GENERATING SET INSTALLATION & 2 TIMES OF THE TOTAL NET WEIGHT FOR THE MULTIPLE GENERATING SET INSTALLATION.

(6) FOR ROOFTOP INSTALLATION IT IS NECESSARY TO HAVE PLANNING AND STRUCTURAL DESIGN APPROVAL.

(7) DO NOT INSTALL GENSET ON LOOSE SAND OR CLAY.
AVOID HARD/SHARP PROJECTIONS SUCH AS STONE OR STEEL PARTS ON FOUNDATION SURFACE WHICH MAY DAMAGE FUEL TANK AT BOTTOM.

(8) AVOID UNEVEN FOUNDATION WHICH MAY LEAD TO IMPROPER RESTING OF GENSET ON FOUNDATION, THERE BY LEADING TO LEAKAGE OF SOUND AND VIBRATION OF GENSET.

(9) IF GENSET IS TO BE MOUNTED ON FOUNDATION HAVING UNEVEN SURFACE RUBBER UNWIDABLE CIRCUMSTANCES, USE APPROPRIATE THICKNESS OF RUBBER PLACING ABOVE FOUNDATION FOR POSITIVE SEALING OF GENSET AGAINST WEATHER.

(10) FOR CABLE TRAYING OPENING OPTION, AN FOUNDATION, PROVIDE GENSET GENERAL ARRANGEMENT DRAWING.

	SPACIFIC REGION
BEARING MATERIAL	2,640.00 - 3,75.00
WOOD ROCK GRANITE	172.000 - 1,66.000
MEDIUM ROCK SHELL	975.000 - 971.600
WOOD PINE	750.000 - 885.600
SOFT ROCK	46.800 - 46.800
WOOD CLAY	39.000 - 46.800
GRAVEL AND COARSE SAND	39.000 - 46.800
EXPOSED JETTIMAN COARSE AND COMPACTED FINE SAND	59.300 - 39.000
MEDIUM CLAY	19.500 - 39.000
LOOSE FINE SAND	9.750 - 39.500
SOFT CLAY	9.750



KALA GENSET PVT LTD
PUNE 410501 (INDIA)

THE:- **FIRST ANGLE PROJECTION**

FOUNDATION PLAN DRAWING
FOR 3R1040T G1_30 KVA