


NOTES:-1) FOUNDATION TO BE MADE ON A GOOD PREPARED SURFACE WITH SOIL STRATA BEARING CAPACITY ADEQUATE TO SUPPORT THE WEIGHT OF GENSET & FOUNDATION. REFER CHART FOR SOIL STRENGTH.

NATURE OF LOAD BEARING MATERIAL	SAFE BEARING CAPACITY KG/SQ.M
HARD ROCK GRANITE	2,44,100 - 9,76,400
MEDIUM ROCK SHELL	97,600 - 1,46,400
HARD PAN	78,100 - 97,600
SOFT ROCK	48,800 - 58,800
HARD CLAY	39,000 - 46,800
GRAVEL AND COARSE SAND	28,300 - 39,000
LOOSE MEDIUM COARSE AND COMPACTED FINE SAND	19,500 - 39,000
MEDIUM CLAY	19,500 - 39,000
LOOSE FINE SAND	9,750 - 39,500
SOFT CLAY	9,750

- 2) THE LENGTH & WIDTH OF FOUNDATION SHOULD BE AT LEAST 300 mm MORE ON EACH SIDE THAN GENSET LENGTH & WIDTH RESPECTIVELY.
- 3) CHECK THE FOUNDATION LEVEL DIAGONALLY AS WELL AS ACROSS THE LENGTH & WIDTH FOR EVEN FLATNESS AND SAME SHOULD BE WITHIN ± 50 mm IN HORIZONTAL PLANE IN ANY ONE DIRECTION ONLY.
- 4) ENSURE THAT THE CONCRETE IS COMPLETELY CURED BEFORE POSITIONING THE GENSET.
- 5) ENSURE THAT THE FOUNDATION TO SUPPORT 1.5 TIMES (DYNAMIC LOAD) OF THE TOTAL WET WEIGHT OF THE SINGLE GENERATING SET INSTALLATION & 2 TIMES OF THE TOTAL WET WEIGHT FOR THE MULTIPLE GENERATING SET INSTALLATION.
- 6) FOR ROOFTOP INSTALLATION, IT IS NECESSARY TO HAVE PLANNING AND STRUCTURAL DESIGN APPROVAL.
- 7) DO NOT INSTALL GENSET ON LOOSE SAND OR CLAY. AVOID HARD/SHARP PROJECTIONS SUCH AS STONE OR STEEL PARTS ON FOUNDATION SURFACE, WHICH MAY DAMAGE FUEL TANK AT BOTTOM.
- 8) AVOID UNEVEN FOUNDATION WHICH MAY LEAD TO IMPROPER RESTING OF GENSET ON FOUNDATION, THERE BY LEADING TO LEAKAGE OF SOUND AND VIBRATION ON GENSET.
- 9) IF GENSET IS TO BE MOUNTED ON FOUNDATION HAVING UNEVEN SURFACE UNDER UNAVOIDABLE CIRCUMSTANCES, USE APPROPRIATE THICKNESS OF RUBBER MATTING ABOVE FOUNDATION FOR POSITIVE SEALING OF GENSET WITH BASE.
- 10) FOR CABLE TRENCH OPENING OPTION ON FOUNDATION, REFER TO GENSET GENERAL ARRANGEMENT DRAWING.



THIS DRAWING IS PROPERTY OF KALA GENSET PVT. LTD. AND MAY BE COPIED OR LENT WITHOUT OUR AUTHORITY IN WRITING. IT IS NOT TO BE ISSUED FOR ANY OTHER PURPOSE OR ORDER NOR INFORMATION WITH OUR ENQUIRY, TENDER, ORDER OR CONTRACT NO. MUST BE RETURNED ON REQUEST. IT IS SUBMITTED AS CONFIDENTIAL.

DO NOT SCALE THE DRAWING

IF IN DOUBT ASK

FROM UP TO	DEVIATION ON MACHINED DIMENSIONS	DEVIATION CLASS	DEVIATION
0 - 3	0.5 - 3	±0.1	±0.1
3 - 6	0.5 - 3	±0.1	±0.1
6 - 30	0.5 - 3	±0.2	±0.2
30 - 120	0.5 - 3	±0.3	±0.3
120 - 400	0.5 - 3	±0.5	±0.5
400 - 1000	0.5 - 3	±0.8	±0.8
1000 - 2000	0.5 - 3	±1.2	±1.2
2000 - 4000	0.5 - 3	±2	±2

PRODUCT IMPROVEMENT IS A CONTINUOUS PROCESS. DIMENSION SPECIFICATION MAY CHANGE WITH IMPROVEMENT. KINDLY CONTACT KOEL FOR LATEST INFORMATION.

PRINTS OF PREVIOUS REVISION NO. SHOULD BE SCRAPPED

Rev. No.

REVISION

APPROVED BY

MODIFIED BY

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE



KALA GENSET PVT LTD.
PUNE 410501 (INDIA)

DRAWING NO. 3R110501A/40WS1/01

SHEET- 1 OF 1

SCALE - 1:1

FOUNDATION PLAN DRAWING

FOR 3R110501A 40WS1

TITLE

FIRST ANGLE PROJECTION