


0	30 - 120	±0.3	±0.5	±0.8	±1.2	±2
DO NOT SCALE THE DRAWING						
THIS DRAWING IS PROPERTY OF KALA GENSET PVT. LTD. AND MUST BE RETURNED ON REQUEST. IT IS SUBMITTED AS CONFIDENTIAL INFORMATION WITH OUR ENQUIRY, TENDER, ORDER OR CONTRACT NO. IT IS NOT TO BE ISSUED FOR ANY OTHER PURPOSE OR ORDER NOR MAY BE COPIED OR LENT WITHOUT OUR AUTHORITY IN WRITING.						

NATURE OF LOAD BEARING MATERIAL	SAFE BEARING CAPACITY (KPa)	SAFE BEARING CAPACITY (KIP/FOOT)
HARD ROCK	2,440 - 9,760	550 - 2,200
HARD ROCK GRANITE	87,600 - 1,146,000	19,500 - 258,000
MEDIUM ROCK SHEL	78,100 - 872,600	17,500 - 19,500
HARD PAN	48,800 - 58,800	10,900 - 13,200
SOFT ROCK	30,000 - 46,000	6,700 - 10,300
HARD CLAY	30,000 - 46,000	6,700 - 10,300
GRAVEL AND COARSE SAND	28,500 - 38,000	6,300 - 8,500
LOOSE/MEDIUM COARSE AND LOOSE/MEDIUM FINE SANDS	18,500 - 28,000	4,100 - 6,300
MEDIUM CLAY	18,500 - 28,000	4,100 - 6,300
LOOSE FINE SAND	9,750 - 38,000	2,200 - 8,500
SOFT CLAY	9,750	2,200

-
- Diagram illustrating the cross-section of a foundation structure, showing layers and dimensions:
- Top Layer:** 100mm FINISHED BRICK WORK
 - Second Layer:** FLOOR OF CEMENT CONCRETE BLOCK MUST BE IN WATER LEVEL
 - Third Layer:** EPOXY COAT (BETWEEN BASE PLATE & FOUNDATION TOP)
 - Fourth Layer:** RCC 1:2:4 (Reinforced Cement Concrete)
 - Fifth Layer:** PCC 1:4:8 (Plain Cement Concrete)
 - Sixth Layer:** HARD SOIL
- Dimensions and Notes:
- Vertical dimensions (from top to bottom): 500, 500, 100, 500, 100, 500.
 - Note: $d' = \text{DEPTH IS DEPEND UP ON SOIL GRADE AS MENTIONED ABOVE.}$
 - Note: IT IS RECOMMENDED TO HAVE FOUNDATION HEIGHT OF 200 mm ABOVE GROUND LEVEL



KALA GENSET PVT LTD.
PUNE 410501 (INDIA)



DRAWING No: 6SL90/320KVA/GA/001 REV. No.: 00 SHEET : 1 OF 1	TITLE FOUNDATION PLAN DRAWING FOR 6SL90ETA_320KVA CPCB4+	 FIRST ANGLE PROJECTION
---	--	---

PRINTS OF PREVIOUS
REVISION NO SHOULD
BE SCRAPPED

Rev. No.

REVISION

REF. NO. _____
DATE _____

MODIFIED
BY

APPROVED BY:

CHAMP

1

APPO	
------	--

LET

SHEET : 13HS

OF 1

1

FOR

90ETA

UKVA CP

2 ±
